The State of New Hampshire
Department of Environmental Services

Michael P. Nolin
Commissioner

April 6, 2005

LETTER OF DEFICIENCY #WSEB 05-036
Certified Mail #7099 3400 0003 0692 1054

Janet and William Myers
Montessori House of Children
784 New Hampton Road
Sanbornton, NH 03269

Subject: Sanbornton – Public Water System: Montessori House of Children (EPA #2075050)

Dear Owners:

The records of the Department of Environmental Services (DES) show that Montessori House of Children water system is classified as a public water system (PWS), as defined by RSA 485:1-a. A PWS is defined as any water system serving 15 or more services, or 25 or more people for 60 or more days per year. As such, the water system owner is required to submit samples to the State laboratory or a State-certified laboratory for coliform bacteria analysis in compliance with NH Administrative Rule Env-Ws 325.

DES records show that Standard Maximum Contaminant Level (MCL) violations for total coliform bacteria, as defined in NH Admin. Rule Env-Ws 315.01 have occurred and that letters of violation were issued for the following months:

February 2005 and March 2005

DES believes the MCL violations can be corrected and future violations prevented by taking the following actions:

1. **By April 20, 2005**, retain the services of a qualified water system consultant to address the system's water quality problems relative to the recent bacteriological occurrences; and

2. **By May 4, 2005**, submit to DES for review a copy of the consultant's report which shall include recommendations to correct the bacteria contamination; and

3. **By May 18, 2005**, submit to DES for review and approval an implementation schedule which identifies specific dates by which steps to correct the bacteria contamination will be accomplished.

P.O. Box 95, 29 Hazen Drive, Concord, New Hampshire 03302-0095
Telephone: (603) 271-3139 • Fax: (603) 271-5171 • TDD Access: Relay NH 1-800-735-2964
DES Web site: **www.des.nh.gov**

In the event compliance is not achieved within this period, DES may initiate formal action against you, including issuing an order requiring the deficiencies to be corrected, initiating an administrative fine proceeding, and/or referring the matter to the NH Department of Justice for imposition of appropriate penalties.

The copy of the consultant's written report **and the implementation schedule** as requested above should be addressed as follows:

Anne S. Bailey
Department of Environmental Services
Water Supply Engineering Bureau
29 Hazen Drive, P.O. Box 95
Concord, NH 03302-0095

Please be reminded to carry out the public notice requirements and provide proof of public notice to DES for the March 2005 MCL violation.

To avoid future violations, please submit water samples according to the water system's Master Sampling Schedule, along with Barbara Davis' letters dated April 1, 2005, copies of which are enclosed.

Please contact Anne Bailey by phone at (603) 271-0672, or by e-mail at *abailey@des.state.nh.us* if you have any questions regarding this letter.

Sincerely,

COPY

Sarah Pillsbury, P.G., Administrator
Water Supply Engineering Bureau

Enclosures: MCL public notice form
Letters Dated April 1, 2005
Master Sampling Schedule

h:\wseb\enfmon\enforce\lods\bacteria\2005\2075050 mcl 05-036.doc

cc: Gretchen R. Hamel, DES Legal Unit Administrator
Town of Sanbornton Health Officer
Alex White, Pump Systems, Inc., Primary Operator (w/encl.)
EPA Region I