The State of New Hampshire
Department of Environmental Services

Michael P. Nolin
Commissioner

April 27, 2006

Randall Heglin
Director of Public Works
Town of Jaffrey
23 Knight Street
Jaffrey, NH 03452

LETTER OF COMPLIANCE
For
LETTER OF DEFICIENCY
No. WD WWEB/C 06-04

Dear Mr. Heglin:

The Department of Environmental Services, Water Division, Wastewater Engineering Bureau (DES) reviewed the actions taken by the Town of Jaffrey in their April 25, 2006 response to Letter of Deficiency No. WD WWEB/C 06-04. DES determined that the issues addressed in the Letter of Deficiency have been resolved in a manner consistent with the Water Division regulations and NPDES permit requirements. The Town of Jaffrey should continue with the actions listed in the April 25, 2006 correspondence from the Town of Jaffrey. At this time, no further response from the Town is necessary. Therefore, DES hereby issues this Letter of Compliance.

Please be advised that the holding time information for *E. coli* provided by Chemserve, contract laboratory, is incorrect. That is, the holding time specified for *E. coli* in the April 11, 2006 Chemserve letter is for drinking water samples and not for non-potable water samples. The correct holding time is 6 hrs (maximum of 8 hrs) in accordance with 20th SM 9060B.1.c. (copy enclosed).

Please be further advised that DES will continue to monitor the compliance status of the Jaffrey Wastewater Plant, and that this letter does not provide relief against any existing or future violations.

If you have any questions regarding this matter, please contact Thomas J. Croteau at 271-2985, respectively. Thank you for your cooperation.

Sincerely,

COPY

John R. Bush, P.E.
Administrator
Wastewater Engineering Bureau

cc: Joy Hilton, USEPA Water Technical Unit
Gretchen Hamel, DES, Enforcement Coordinator
Thomas J. Croteau, Environmental Inspector, WWEB
Margaret Bastien, P.E., WWEB
DES WD WWEB/File

Attachment: 20th SM 9060B

Certified Mail RRR: 7099 3400 0018 1294 3790

P.O. Box 95, 29 Hazen Drive, Concord, New Hampshire 03302-0095
Telephone: (603) 271-3503 • Fax: (603) 271-2982 • TDD Access: Relay NH 1-800-735-2964
DES Web site: **www.des.nh.gov**