The State of New Hampshire

Department of Environmental Services

Michael P. Nolin
Commissioner

December 10, 2004

Munces Superior Inc.
Attn: Rob Munce
620 Main Street
Gorham, New Hampshire 03581

NOTICE OF PERMIT REVOCATION - PR # 04-017

RE: PLYMOUTH, TENNEY MOUNTAIN COUNTRY STORE, EXISTING UNDERGROUND STORAGE TANK FACILITY (UST # A-0114178) (DES # 199203071)

Dear Mr. Munce:

On September 12, 2003 representatives of the New Hampshire Department of Environmental Services, Waste Management Division ("DES") visited the above-referenced petroleum underground storage tank ("UST") facility and conducted an inspection to determine the facility's operational compliance with the requirements of NH Admin. Rules Part Env-Wm 1401 Underground Storage Facilities. A written description of the deficiencies noted during the inspection was provided and you were given 45 days to correct the deficiencies and notify DES, in writing, that the facility is in compliance.

On January 13, 2004, due to failure on your part to correct the noted deficiencies and submit the required notification, DES issued a **Notice of Non-Compliance Permit Revocation (NCPR # 04-006)** ("the Notice") to you. The Notice required that you attain compliance by April 12, 2004 or forfeit your Permit-to-Operate the subject UST facility. The Notice also provides you with an opportunity to appeal the permit revocation to the Waste Management Council.

As of this date, DES has not received notification that the facility has been returned to a compliance status nor has the Waste Management Council received a request to appeal the Notice. **Therefore, we regretfully must inform you that as of April 12, 2004 your Permit-to-Operate the subject UST facility has been revoked. No product may be delivered to the facility, nor shall any product be sold or used from this facility. Further, all product must be removed from the USTs at this facility within 30 days of the receipt of this letter.**

In addition, NH Administrative Rules Part Env-Wm 1401.10(a) requires owners of underground storage facilities for oil to maintain financial responsibility for costs associated with cleanup of releases from systems, the implementation of corrective measures, and compensation for third party damages in the amount equal to or greater that $1,000,000 per occurrence. Env-Wm 1401.10(c) provides that the financial responsibility requirement may be satisfied if the owner is eligible for reimbursement of costs associated with cleanup of releases from the Oil Discharge and Disposal Cleanup Fund ("the Fund"). Eligibility for the Fund is contingent upon achieving and maintaining compliance with statutory (RSA 146-C) and regulatory (Env-Wm 1401)

P.O. Box 95, 29 Hazen Drive, Concord, New Hampshire 03302-0095
Telephone: (603) 271-3644 • Fax: (603) 271-2181 • TDD Access: Relay NH 1-800-735-2964
DES Web site: **www.des.nh.gov**

requirements. Because this facility no longer has a valid Permit-to-Operate, due to non-compliance with the regulatory requirements, the Fund is no longer available to you for any releases that were discovered after April 12, 2004.

Once the facility has been returned to compliance, you may petition the Oil Fund Disbursement Board for reinstatement to the Fund as your financial responsibility mechanism. If denied, it will be necessary to obtain an alternate financial responsibility mechanism (for example, a private insurance policy) in the amount of $1,000,000 before DES can reissue a Permit-to-Operate for this facility.

Failure to comply with the requirements noted above will result in administrative fines and/or civil penalties, and referral to the New Hampshire Department of Justice for injunctive relief.

If there are any questions concerning the above, please contact Lynn A. Woodard, P.E. at the Waste Management Division at (603) 271-1165 or at lwoodard@des.state.nh.us.

Sincerely,

COPY

Anthony P. Giunta, P.G.
Director
Waste Management Division

CERTIFIED MAIL # 7000 1670 0000 0584 4394

CC: Michael P. Nolin, Commissioner
Gretchen R. Hamel, Legal Unit Administrator ✓
Fred McGarry, P.E., Chief Engineer, WMD
George Lombardo, P.E., WMD
Lynn Woodard, P.E, WMD
Tom Beaulieu, WMD
Mark Antonia, WMD
Health Officer, Town of Plymouth