PFOA Contamination Southern New Hampshire PFC Sampling Results

Updated June 24, 2016

PFOA/PFOS Sampling Results for Merrimack Village District Water Works

****MVD 7&8 TP –is a blend of MVD wells 7 and 8 after green sand treatment***

Well Name:	MVD-2	MVD-3	MVD-4 (offline)	MVD-5 (offline)	MVD-7	MVD-8	MVD-7&8 TP*
5/26/16	12/ND	13/ND	34/ND	35/ND	13/ND	8/ND	10/ND
5/12/16	18/4.4	29/4.5	75/5.5	79/4.8	25/4.6	13/4.5	17/4.4
5/5/16	33/4.9	45/16.7	130/11	66/4.7	27/4.7	9.6/ND	16/ND
4/28/16	24/ND	25/ND	85/5.9	57/ND	21/ND	9.2/ND	14/ND
4/21/16	26/5.5	26/ND	93/7.0	56/5.4	25/5.4	9.9/9.1	16/ND
4/14/16	31/15	32/6.1	94/8.8	67/5.5	30/7.0	10/ND	18/4.9
4/7/16	28/ND	Not Available – Scheduled Maintenance	94/6.8	52/ND	28/5.5	8.6/ND	Not Sampled
3/31/16	27/ND	Not Available – Scheduled Maintenance	90/5.6	56/ND	26/ND	8.5 & 9.7/ ND & ND	Not Sampled
3/9/16	17/ND	Not Available – Scheduled Maintenance	90/6	54 & 52/ND &ND	Not Available – Scheduled Maintenance	Not Available – Scheduled Maintenance	Not Sampled

PFOA/PFOS Sampling Results for Pennichuck Water Works Water Systems – Samples Collected by Pennichuck Water Works

	Cabot Preserve	Souhegan Woods	Pennichuck Litchfield Water System	Pennichuck Water Treat-ment Plant
Town:	Bedford	Amherst	Litchfield	Nashua
Source Water Desc.:	Water from MVD	Wells	Wells	Surface Water
Pop. Served:	940	290	3600	87500
6/15/16	9/ND	2/ND	4 & 6/ND & ND	2/ND
6/2/16	12/ND	2/ND	Not Sampled	4/ND
5/16/16	11/ND	2/ND	8 & 8/ ND & ND	Not Sampled
5/11/16	11/ND	2/ND	Not Sampled	Not Sampled
5/3/16	14/ND	2/ND	Not Sampled	Not Sampled
4/26/16	38/ND	2/ND	Not Sampled	Not Sampled
4/20/16	52/6.2	4.8/ND	Not Sampled	Not Sampled
4/13/16	52/8.1	5.7/5.9	12/ND	5.8/8.4
4/6/16	52/ND	4.9/ND	Not Sampled	Not Sampled
3/16/16	36/ND	3/ND	7 & 9/ND & ND	3/ND

"ND" = Not Detected. Laboratory reporting limits vary by sample.
All units are in nanograms-per-liter (parts-per-trillion)