

Stage I

Yearly



Maintenance Inspections of Vapor Recovery System for AST/UST Gasoline Dispensing Facilities

The owner or operator of a gasoline storage tank at a gasoline dispensing facility or a bulk gasoline plant subject to Env-Or 504.01 shall perform a yearly maintenance inspection:

1. No later than September 30 of each calendar year, and
2. At least 10 months between each inspection.

Facility Name: _____ Insp. Date: _____					
AST/UST Facility ID Number: _____					
Name of person conducting inspection: _____					
	Check when completed				
	Tk1	Tk2	Tk3	Tk4	Tk5
(1) Perform all items specified in Stage I Monthly Maintenance Inspection.					
(2) Replace or permanently plug each drain valve located in each spill bucket.					
(3) Verify that adaptor caps and dust covers are not in contact with overlying access covers.					
(4) Measure the distance between the tank bottom and the submerged fill tube end to insure a clearance of no more than 6 inches. If necessary, modify the submerged fill tube.					

The owner or operator must document each monthly maintenance inspection, including all findings and repairs made. Please keep this form with your records.

Please contact the New Hampshire Department of Environmental Services at (603) 271-3899 with any questions.