

# ENVIRONMENTAL PUBLIC RECORD



29 Hazen Drive, Concord, New Hampshire 03301 • (603) 271-3503 • www.des.nh.gov

## Federally Regulated<sup>1</sup> Underground Storage Tanks in New Hampshire

Posted 1/29/2016

### General Information

Total Number of Federally Regulated UST Facilities in NH: 1,093 (1,544 NH Regulated)

Total Number of Federally Regulated USTs in NH: 2,819 (3,519 NH Regulated)

### Summary Information for On-Site Inspections - Inspection Period 10/1/2014 to 9/30/2015

Number of Federally Regulated UST Facilities Inspected: 352

Percentage of Federally Regulated UST Facilities Found in Compliance<sup>2</sup>: 57

### Summary Information for Releases – Discovery Period 10/1/2014 to 9/30/2015

Number of Confirmed Federally Regulated UST Releases: 23

#### Summary Information for Federally Regulated UST Release Sources and Causes

SOURCE	CAUSE															
	Spill		Overfill		Phys/Mech Damage		Corrosion		Installation Problem		Other		Unknown			
	#	%	#	%	#	%	#	%	#	%	#	%	#	%		
Tank	0	0%														
Piping	0	0%														
Dispenser	14	61%			5	36%	2	14%				3	21%	4	29%	
STP Sump	1	4%												1	100%	
Delivery Problem	1	4%	1	100%												
Other	0	0%														
Unknown	7	30%	1	14%										6	86%	
Totals	23	100%	2	9%	5	22%	2	9%	0	0%	0	0%	3	13%	11	48%

Public site specific information about underground storage tank facility compliance and/or releases may be found on the State of New Hampshire OneStop data retrieval site at <http://www2.des.state.nh.us/DESOnestop/BasicSearch.aspx>

<sup>1</sup>A Federally regulated underground storage tank includes those tanks containing motor fuel such as gasoline and diesel for dispensing, motor fuel for use in electrical generators, and hazardous substances as defined in RSA 146-C:1, VII-a.

<sup>2</sup>The percentage of Federally regulated UST facilities found to be in significant operational compliance with both the spill, overfill, and corrosion protection requirements and the leak detection requirements of the New Hampshire Code of Administrative Rules, Env-Or 400, Underground Storage Tank Facilities <http://des.nh.gov/organization/commissioner/legal/rules/documents/env-or400.pdf> at the time of the state inspection

Information contained in this Public Record is current as of January 29, 2016. If there are any questions concerning the status of this information, please contact DES at (603) 271-3899.