

## New Hampshire Stormwater Manual - Errata Sheet

The following is a list of errors found in the New Hampshire Stormwater Manual. Format errors will not be listed on the errata sheet, but will be revised to the best of NHDES's knowledge in the upcoming revision. Until the document is revised, please refer to the below corrections. Please email Amy Clark at [amy.clark@des.nh.gov](mailto:amy.clark@des.nh.gov) if you find any other errors. Please note the page number and a description of the error.

### Volume 1: Stormwater and Antidegradation

DATE POSTED	PAGE	DESCRIPTION OF ERROR
3/2011	105 – Appendix E	<p>BMP Pollutant Removal Efficiencies and literature references update.</p> <p><a href="http://des.nh.gov/organization/divisions/water/stormwater/documents/wd-08-20a_apxe.pdf">http://des.nh.gov/organization/divisions/water/stormwater/documents/wd-08-20a_apxe.pdf</a></p>
4/2009	Page 105 – Appendix E	<p>Information on the literature references was inadvertently omitted. They are as follows:</p> <p><b>Sources A-F are as reported in the EPA Region 5 Model:</b></p> <ul style="list-style-type: none"> <li>A. Appendix D Model Best Management Practice Selection Methodology &amp; Lake County Decision-Making Framework, NIPC. July 1994.</li> <li>B. <a href="http://www.epa.gov/owow/wtrl/NPS/MMGI/Capter4/table407.gif">www.epa.gov/owow/wtrl/NPS/MMGI/Capter4/table407.gif</a>.</li> <li>C. <a href="http://ohioline.ag.ohio-state.edu/aex-fact/0467.html">http://ohioline.ag.ohio-state.edu/aex-fact/0467.html</a>.</li> <li>D. Athayde 1983</li> <li>E. Schueler. 1987.</li> <li>F. Model Stormwater Regulations. Duxbury, Marshfield, and Plymouth, MA. Horsley Witten Group. December 31, 2004. (Suggested Average assumes no practice is greater than 90% efficient. Median values are shown in parentheses.)</li> <li>G. 2005 Data Report. University of New Hampshire Stormwater Center. University of New Hampshire. <a href="http://www.unh.edu/erg/cstev">www.unh.edu/erg/cstev</a> and personal communication with Dr. Robert Roseen.</li> <li>H. Unpublished 2007 Draft Report. Seasonal Variations for Stormwater Management Systems in Cold Climate Condition. Robert M. Roseen, Thomas P. Ballestero, James Houle, Pedro Avelleneda, Joshua Briggs, George Fowler, Robert Wildey. University of New Hampshire.</li> <li>I. <a href="http://cfpub.epa.gov/npdes/stormwater/menuofbmps/index.cfm">http://cfpub.epa.gov/npdes/stormwater/menuofbmps/index.cfm</a></li> </ul> <p><b>Sources J - M are as reported in the Stormwater Center website <a href="http://www.stormwatercenter.net/Pollution_Prevention/Factsheets/Catchbasins.htm">www.stormwatercenter.net/Pollution_Prevention/Factsheets/Catchbasins.htm</a>:</b></p> <ul style="list-style-type: none"> <li>J. Pitt, R., M. Libum, S.Nix, S. Durrans, and S. Burian. 1997. Guidance Manual for Integrated Wet Weather Flow Collection and Treatment Systems for New Urbanized Areas. USEPA. Office of Research and Development. Cincinnati, OH.</li> <li>K. Aronson, G., D. Watson, and W. Pisaro. 1983. Evaluation of Catch Basin Performance for Urban Stormwater Control. EPA-600/2-83-043.</li> <li>L. Pitt and Shawley, 1982 (no other information given in Stormwater Center</li> </ul>

		<p>website)</p> <p><b>M.</b> Mineart, P. and S. Singh. 1994. Storm Inlet Pilot Study. Woodward-Clyde Consultants. Alameda County Urban Runoff Clean Water Program. Oakland, CA.</p> <p><b>Source N is as reported in the Low Impact Development Center website <a href="http://www.lid-stormwater.net/bioretention/bio_benefits.htm">www.lid-stormwater.net/bioretention/bio_benefits.htm</a>:</b></p> <p><b>N.</b> Yu, S.L., X. Zhang, A. Earles and M. Sievers, 1999: Field testing of ultra-urban BMPs. Proceedings of the 26th Annual Water Resources Planning and Management Conference ASCE, 609 June, Tempe, Arizona.</p> <p><b>Source O is as reported in the EPA's National Management Measures to Control Nonpoint Source Pollution from Urban Areas (Nov 2005) pg 3-17.</b></p> <p><b>O.</b> Herson-Jones, L.M., M. Hearty, and B. Jordan. 1995. Riparian Buffer Strategies for Urban Watersheds. Metropolitan Washington Council of Governments, Washington, DC.</p> <p><b>Source P is as reported in the Stormwater Center Library website at: <a href="http://www.stormwatercenter.net/Library/STP-Pollutant-Removal-Database.pdf">http://www.stormwatercenter.net/Library/STP-Pollutant-Removal-Database.pdf</a></b></p> <p><b>P.</b> Winer, Rebecca. 2000. National Pollutant Removal Performance Database for Stormwater Treatment Practices. 2nd Edition. Center for Watershed Protection. Elliot City, MD</p>
--	--	----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

## **Volume 2: Post-Construction Best Management Practices Selection & Design**

<b>DATE POSTED</b>	<b>PAGE</b>	<b>DESCRIPTION OF ERROR</b>
3/2011	Page 197 – Appendix B	BMP Pollutant Removal Efficiencies and literature references update.  <a href="http://des.nh.gov/organization/divisions/water/stormwater/documents/wd-08-20b_apxb.pdf">http://des.nh.gov/organization/divisions/water/stormwater/documents/wd-08-20b_apxb.pdf</a>
4/2009	Page 16-17	Format error – the example on page 16 continues below the first full paragraph on page 17. Items numbered 1 and 2 should be included in the shaded example box on page 16.
4/2009	Page 19	Item 7. on the bottom of the page should read as follows: “7. Within areas where the <del>design</del> infiltration rate is less than 0.5 inches per hour...”
9/2009	Page 33	In Table 3-4 titled “Summary of BMP Restrictions Associated with High-Load and Protected Resources”, the Water Supply Wells box under Stormwater From Non High-Load Areas should read as follows: “For private wells there is an exemption to the 75’ setback for stormwater management systems receiving runoff from areas less than 0.5 acre.”
4/2009	Page 124	In the design criteria, Bottom Width should read as follows: <del>4 to 8 feet</del> <b>0 to 8 feet</b> (widths up to 16 feet are allowable with dividing

		berm/structure such that neither channel width exceeds 8 feet).																																										
4/2009	Page 125	<p>The Example Design section should be labeled as follows:  <b>“FREEBOARD (0.3M (1 FOOT) <del>MINIMUM</del> RECOMMENDED)”</b>.</p> <p><b>“<del>0.3M (1 FOOT) MAX. 4” MAXIMUM WATER QUALITY TREATMENT DEPTH”</del>”</b></p>																																										
4/2009	Page 127	The vegetated buffer types that are bulleted out should include “Ditch turn-out buffers”, which was inadvertently listed below in the general requirements section.																																										
4/2009	Page 137	<p>The allowable contributing area in the design criteria should read as follows:</p> <ul style="list-style-type: none"> <li>● No area other than road surface, shoulder, and road ditch</li> <li>● <del>≤500 feet of 1 travel lane + ditch</del></li> <li>● <del>≤250 feet of 2 travel lanes + ditch</del></li> <li>● ≤ 6,000 sq. ft. of pavement, <del>it &gt; 2 lanes and ditch are directed to the buffer</del></li> </ul>																																										
4/2009	Page 138	<p>Replace table 4-10 and 4-11 with the following tables:</p> <p style="text-align: center;"><u>Table 4-10 Required Buffer Flow Path Length per Area Directed to the Buffer with 0% to 8% Buffer Slope</u></p> <table border="1" style="margin-left: auto; margin-right: auto;"> <thead> <tr> <th>Hydrologic Soil Group of Soil in Buffer</th> <th>Maximum Area Directed to the Buffer (square feet)</th> <th>Length of Flow Path for Forested Buffer (feet)</th> <th>Length of Flow Path for Meadow Buffer (feet)</th> </tr> </thead> <tbody> <tr> <td rowspan="3" style="text-align: center;">A or B</td> <td style="text-align: center;">3,000</td> <td style="text-align: center;">50</td> <td style="text-align: center;">70</td> </tr> <tr> <td style="text-align: center;">4,500</td> <td style="text-align: center;">50</td> <td style="text-align: center;">85</td> </tr> <tr> <td style="text-align: center;">6,000</td> <td style="text-align: center;">60</td> <td style="text-align: center;">100</td> </tr> <tr> <td rowspan="3" style="text-align: center;">C</td> <td style="text-align: center;">3,000</td> <td style="text-align: center;">60</td> <td style="text-align: center;">100</td> </tr> <tr> <td style="text-align: center;">4,500</td> <td style="text-align: center;">75</td> <td style="text-align: center;">120</td> </tr> <tr> <td style="text-align: center;">6,000</td> <td style="text-align: center;">100</td> <td style="text-align: center;">150</td> </tr> <tr> <td rowspan="3" style="text-align: center;">D</td> <td style="text-align: center;">3,000</td> <td style="text-align: center;">100</td> <td style="text-align: center;">150</td> </tr> <tr> <td style="text-align: center;">4,500</td> <td style="text-align: center;">150</td> <td style="text-align: center;">180</td> </tr> <tr> <td style="text-align: center;">6,000</td> <td style="text-align: center;">200</td> <td style="text-align: center;">230</td> </tr> </tbody> </table> <p style="text-align: center;"><u>Table 4-11: Required Buffer Flow Path Length per Area Directed to the Buffer with &gt;8% to 15% Buffer Slope</u></p> <table border="1" style="margin-left: auto; margin-right: auto;"> <thead> <tr> <th>Hydrologic Soil Group of Soil in Buffer</th> <th>Maximum Area Directed to the Buffer (square feet)</th> <th>Length of Flow Path for a Forested Buffer (feet)</th> <th>Length of Flow Path for Meadow Buffer (feet)</th> </tr> </thead> <tbody> <tr> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>	Hydrologic Soil Group of Soil in Buffer	Maximum Area Directed to the Buffer (square feet)	Length of Flow Path for Forested Buffer (feet)	Length of Flow Path for Meadow Buffer (feet)	A or B	3,000	50	70	4,500	50	85	6,000	60	100	C	3,000	60	100	4,500	75	120	6,000	100	150	D	3,000	100	150	4,500	150	180	6,000	200	230	Hydrologic Soil Group of Soil in Buffer	Maximum Area Directed to the Buffer (square feet)	Length of Flow Path for a Forested Buffer (feet)	Length of Flow Path for Meadow Buffer (feet)				
Hydrologic Soil Group of Soil in Buffer	Maximum Area Directed to the Buffer (square feet)	Length of Flow Path for Forested Buffer (feet)	Length of Flow Path for Meadow Buffer (feet)																																									
A or B	3,000	50	70																																									
	4,500	50	85																																									
	6,000	60	100																																									
C	3,000	60	100																																									
	4,500	75	120																																									
	6,000	100	150																																									
D	3,000	100	150																																									
	4,500	150	180																																									
	6,000	200	230																																									
Hydrologic Soil Group of Soil in Buffer	Maximum Area Directed to the Buffer (square feet)	Length of Flow Path for a Forested Buffer (feet)	Length of Flow Path for Meadow Buffer (feet)																																									

		<table border="1"> <tr> <td rowspan="3">A or B</td> <td>3,000</td> <td>60</td> <td>85</td> </tr> <tr> <td>4,500</td> <td>60</td> <td>100</td> </tr> <tr> <td>6,000</td> <td>70</td> <td>120</td> </tr> <tr> <td rowspan="3">C</td> <td>3,000</td> <td>70</td> <td>120</td> </tr> <tr> <td>4,500</td> <td>90</td> <td>145</td> </tr> <tr> <td>6,000</td> <td>120</td> <td>180</td> </tr> <tr> <td rowspan="3">D</td> <td>3,000</td> <td>120</td> <td>180</td> </tr> <tr> <td>4,500</td> <td>170</td> <td>220</td> </tr> <tr> <td>6,000</td> <td>230</td> <td>270</td> </tr> </table>	A or B	3,000	60	85	4,500	60	100	6,000	70	120	C	3,000	70	120	4,500	90	145	6,000	120	180	D	3,000	120	180	4,500	170	220	6,000	230	270
A or B	3,000	60		85																												
	4,500	60		100																												
	6,000	70	120																													
C	3,000	70	120																													
	4,500	90	145																													
	6,000	120	180																													
D	3,000	120	180																													
	4,500	170	220																													
	6,000	230	270																													
4/2009	Page 145	<p>The Example Design section should be labeled as follows:  <b>“FREEBOARD (0.3M (1 FOOT) <del>MINIMUM</del> RECOMMENDED)”</b>.   <b>“<del>0.3M (1 FOOT) MAX. 4” MAXIMUM WATER QUALITY TREATMENT DEPTH</del>”</b></p>																														
4/2009	Page 158	<p>In the design criteria, the Design Discharge should read as follows:  50-year, 24-hour storm without overtopping embankment crest, 1’ freeboard <del>required</del> <b>recommended</b>.</p>																														
4/2009	Page 174	<p>In the design criteria, the <math>D_o</math> in the apron length equation should be raised to the power of 1.5 not multiplied by 1.5. The equation should be corrected to read as follows:</p> $La = 1.8Q/(D_o)^{1.5} + 7D_o \text{ (when } TW < D_o/2)$ $La = 3.0Q/(D_o)^{1.5} + 7D_o \text{ (when } TW \geq D_o/2)$																														
4/2009	Page 174	<p>All descriptions of the variable “TW” should read as follows:</p> <p>TW = tailwater <del>elevation</del> <b>depth</b> (feet)</p>																														
4/2009	Page 197 – Appendix B	<p>Information on the literature references was inadvertently omitted. They are as follows:  <b>Sources A-F are as reported in the EPA Region 5 Model:</b></p> <ul style="list-style-type: none"> <li>A. Appendix D Model Best Management Practice Selection Methodology &amp; Lake County Decision-Making Framework, NIPC. July 1994.</li> <li>B. <a href="http://www.epa.gov/owow/wtrl/NPS/MMGI/Capter4/table407.gif">www.epa.gov/owow/wtrl/NPS/MMGI/Capter4/table407.gif</a>.</li> <li>C. <a href="http://.ohioline.ag.ohio-state.edu/aex-fact/0467.html">http://.ohioline.ag.ohio-state.edu/aex-fact/0467.html</a>.</li> <li>D. Athayde 1983</li> <li>E. Schueler. 1987.</li> <li>F. Model Stormwater Regulations. Duxbury, Marshfield, and Plymouth, MA. Horsley Witten Group. December 31. 2004. (Suggested Average assumes no practice is greater than 90% efficient. Median values are shown in parentheses.)</li> <li>G. 2005 Data Report. University of New Hampshire Stormwater Center.</li> </ul>																														

University of New Hampshire. [www.unh.edu/erg/cstev](http://www.unh.edu/erg/cstev) and personal communication with Dr. Robert Roseen.

**H.** Unpublished 2007 Draft Report. Seasonal Variations for Stormwater Management Systems in Cold Climate Condition. Robert M. Roseen, Thomas P. Ballestero, James Houle, Pedro Avelleneda, Joshua Briggs, George Fowler, Robert Wildey. University of New Hampshire.

**I.** <http://cfpub.epa.gov/npdes/stormwater/menuofbmeps/index.cfm>

**Sources J - M are as reported in the Stormwater Center website [www.stormwatercenter.net/Pollution\\_Prevention/Factsheets/Catchbasins.htm](http://www.stormwatercenter.net/Pollution_Prevention/Factsheets/Catchbasins.htm):**

**J.** Pitt, R., M. Libum, S. Nix, S. Durrans, and S. Burian. 1997. Guidance Manual for Integrated Wet Weather Flow Collection and Treatment Systems for New Urbanized Areas. USEPA. Office of Research and Development. Cincinnati, OH.

**K.** Aronson, G., D. Watson, and W. Pisaro. 1983. Evaluation of Catch Basin Performance for Urban Stormwater Control. EPA-600/2-83-043.

**L.** Pitt and Shawley, 1982 (no other information given in Stormwater Center website)

**M.** Mineart, P. and S. Singh. 1994. Storm Inlet Pilot Study. Woodward-Clyde Consultants. Alameda County Urban Runoff Clean Water Program. Oakland, CA.

**Source N is as reported in the Low Impact Development Center website [www.lid-stormwater.net/bioretenion/bio\\_benefits.htm](http://www.lid-stormwater.net/bioretenion/bio_benefits.htm):**

**N.** Yu, S.L., X. Zhang, A. Earles and M. Sievers, 1999: Field testing of ultra-urban BMPs. Proceedings of the 26th Annual Water Resources Planning and Management Conference ASCE, 609 June, Tempe, Arizona.

**Source O is as reported in the EPA's National Management Measures to Control Nonpoint Source Pollution from Urban Areas (Nov 2005) pg 3-17.**

**O.** Herson-Jones, L.M., M. Hearty, and B. Jordan. 1995. Riparian Buffer Strategies for Urban Watersheds. Metropolitan Washington Council of Governments, Washington, DC.

**Source P is as reported in the Stormwater Center Library website at: <http://www.stormwatercenter.net/Library/STP-Pollutant-Removal-Database.pdf>**

**P.** Winer, Rebecca. 2000. National Pollutant Removal Performance Database for Stormwater Treatment Practices. 2nd Edition. Center for Watershed Protection. Elliot City, MD