



**PERMIT APPLICATION FOR TITLE V OPERATING PERMIT
AIR RESOURCES DIVISION**

29 Hazen Drive, PO Box 95, Concord, NH 03302-0095
Phone: 603-271-1370 Fax: 603-271-7053

PROJECT NAME: Public Service of New Hampshire, Merrimack Station, Bow, NH Title V Operating Permit SIC Code: 4333 Electric Utility Application #: FY96-TV048	ENGINEER: DCL & ERN
	DATE: 03/15/10

APPLICATION RECEIVED:

Application # FY96-TV048 received on July 1, 1996 with additional information received on August 29, 1996, April 28, 1998, January 16, 2003, June 13, 2003, May 15, 2009, and July 28, 2009.

FACILITY DESCRIPTION:

Merrimack Station is a fossil fuel-fired electricity generating facility, owned and operated by Public Service of New Hampshire (PSNH), a subsidiary of Northeast Utilities. The facility is composed of two utility boilers, two combustion turbines operating as load shaving units, an emergency generator, an emergency boiler, and coal handling systems including primary and secondary coal crushers, coal piles, coal conveyor systems, and coal unloading from railcars. The facility operations also include various activities that are classified as insignificant or exempt activities.

The two utility boilers (MK1 and MK2) primarily burn bituminous coal and use No. 2 fuel oil in the cyclone burners on startups of the boilers; the two combustion turbines primarily burn No. 1 fuel oil or JP-4 aviation fuel; the emergency generator burns No. 2 fuel oil or diesel fuel, and the emergency boiler burns No. 2 fuel oil or on road low sulfur diesel fuel. Merrimack Station emits nitrogen oxide (NOx), sulfur dioxide (SO2), carbon monoxide (CO), volatile organic compounds (VOCs), particulate matter (PM), carbon dioxide (CO2), state regulated toxic air pollutants (RTAPs), and federal hazardous air pollutants (HAPs).

Each utility boiler is equipped with selective catalytic reduction (SCR) systems to control NOx emissions. Each utility boiler is also equipped with two electrostatic precipitators (ESP) to control PM emissions. Each utility boiler stack is equipped with continuous emissions monitoring systems (CEMS) for NOx, SO2, CO, and O2 or CO2, and a continuous opacity monitoring system (COMS).

Merrimack Station receives bituminous coal by railcar and by trucks. The coal conveyor systems are enclosed, where practical, and coal crushing occurs inside a building.

Merrimack Station operates a flyash reinjection system on each utility boiler.

FACILITY LOCATION:

Merrimack County is an attainment area for ozone, NO2, PM10, CO, and lead. Merrimack County is located in the Ozone Transport Region.

PURPOSE OF PERMIT:

- To streamline existing separate permits for permitted sources into one Title V Operating Permit.

SIGNIFICANT ACTIVITIES:

See Table 1 below.



PERMIT APPLICATION FOR TITLE V OPERATING PERMIT AIR RESOURCES DIVISION

29 Hazen Drive, PO Box 95, Concord, NH 03302-0095
 Phone: 603-271-1370 Fax: 603-271-7053

PROJECT NAME: Public Service of New Hampshire, Merrimack Station, Bow, NH Title V Operating Permit SIC Code: 4333 Electric Utility Application #: FY96-TV048	ENGINEER: DCL & ERN DATE: 03/15/10
Page 2 of 14	

Table 1 – Significant Activity Identification

Emission Unit Number	Description of Emission Unit	Maximum Gross Heat Input or Maximum Power Output	Maximum Operating Conditions
MK1	Utility Boiler (Installed in 1960) Cyclone Burner, Front wall firing	Bituminous Coal: 1,238 MMBtu/hr; 113 MW	A) Maximum fuel consumption rate of bituminous coal shall be limited to 48.5 tons/hr, not to exceed 425,289 tons during any consecutive 12-month period. ¹ B) No. 2 fuel oil consumption shall not exceed 14.5 million gallons during any consecutive 12 month period. ²
MK2	Utility Boiler (Installed in 1968) Cyclone Burner, Opposed wall firing	Bituminous Coal: 3,473 MMBtu/hr; 320 MW	A) Maximum fuel consumption rate of bituminous coal shall be limited to 136.2 tons/hr, not to exceed 1,193,078 tons during any consecutive 12-month period. ³ B) No. 2 fuel oil consumption shall not exceed 14.5 million gallons during any consecutive 12 month period. ⁴
MKCT1	Combustion Turbine #1 (Installed in 1968) One-end only firing	No. 1 fuel oil or JP-4 aviation fuel: 319 MMBtu/hr	Maximum fuel consumption rate shall not exceed 2,279 gal/hr. ⁵
MKCT2	Combustion Turbine #2 (Installed in 1969) One-end only firing	No. 1 fuel oil or JP-4 aviation fuel: 319 MMBtu/hr	Maximum fuel consumption rate shall not exceed 2,279 gal/hr. ⁶
PCC	Primary Coal Crusher System consisting of two crushers that operate in parallel (Installed in 1960)	NA	Maximum operating rate of MKPCC shall be limited to 885 ton/hr coal.
SCC	Secondary Coal Crusher System consisting of	NA	Maximum operating rate of MKSCC shall be limited to 690 ton/hr coal.

¹ The heating value of bituminous coal is assumed to be 12,750 Btu/lb. The fuel consumption rates may vary based on the actual heat content of the fuel burned.

² No. 2 fuel oil is only used to initially ignite the coal in the 3 cyclone burners in MK1 during startup of the Boiler.

³ The heating value of bituminous coal is assumed to be 12,750 Btu/lb. The fuel consumption rates may vary based on the actual heat content of the fuel burned.

⁴ No. 2 fuel oil is only used to initially ignite the coal in the 7 cyclone burners in MK2 during startup of the Boiler.

⁵ The heating value of JP-4 and No. 1 fuel oil is assumed to be 140,000 Btu/gal. The fuel consumption rates may vary based on the actual heat content of the fuel burned.

⁶ The heating value of JP-4 and No. 1 fuel oil is assumed to be 140,000 Btu/gal. The fuel consumption rates may vary based on the actual heat content of the fuel burned.



PERMIT APPLICATION FOR TITLE V OPERATING PERMIT AIR RESOURCES DIVISION

29 Hazen Drive, PO Box 95, Concord, NH 03302-0095
Phone: 603-271-1370 Fax: 603-271-7053

PROJECT NAME: Public Service of New Hampshire, Merrimack Station, Bow, NH Title V Operating Permit SIC Code: 4333 Electric Utility Application #: FY96-TV048	ENGINEER: DCL & ERN DATE: 03/15/10
Page 3 of 14	

Table 1 – Significant Activity Identification

Emission Unit Number	Description of Emission Unit	Maximum Gross Heat Input or Maximum Power Output	Maximum Operating Conditions
	two crushing systems employing two crushers (for a total of four crushers) operating in parallel (Installed in 1960)		
MKEG	Emergency Generator (Installed in 1988)	Diesel fuel (with a maximum sulfur content of 0.4% by weight): 3.932 MMBtu/hr	Maximum fuel consumption rate of diesel fuel shall not exceed 28.7 gal/hr. ⁷
MKEB	Emergency Boiler (Temporary – Each installation ⁸)	No. 2 fuel oil (with a maximum sulfur content of 0.4% by weight or on-road low sulfur diesel oil (with a maximum sulfur content of 0.05% by weight): 96 MMBtu/hr	A) Maximum fuel consumption rate of No. 2 fuel oil shall not exceed 520 gal/hr and 11,760 gal/day ⁹ ; or B) Maximum fuel consumption rate of on-road low sulfur diesel oil shall not exceed 701 gal/hr.

POLLUTION CONTROL EQUIPMENT:

Table 2 – Pollution Control Equipment/Method Identification

Pollution Control Equipment Number	Description of Equipment/Method	Emission Unit Number
MK1-PC1	Electrostatic Precipitator (ESP) #1 on MK1 (Included with original boiler installation in 1960)	MK1
MK1-PC2	ESP #2 on MK1 installed in 1989	MK1
MK1-PC3	Selective Catalytic Reduction (SCR) System (Operational in 1999, replacing the SNCR installed in 1995)	MK1
MK2-PC4	ESP #1 on MK2 (Included with the original boiler installation in 1968)	MK2
MK2-PC5	ESP #2 on MK2 installed in 1999	MK2

⁷ The heating value of diesel fuel is assumed to be 137,000 Btu/gal. The fuel consumption rates may vary based on the actual heat content of the fuel burned.

⁸ The facility has a Temporary Permit TP-B-0490 issued on March 6, 2003, which allows for seasonal installation of a temporary boiler for providing back-up heat and steam for the startup of MK1 and MK2 during winter months after an unplanned outage.

⁹ The heating value of No. 2 fuel oil is assumed to be 140,000 Btu/gal. The fuel consumption rates may vary based on the actual heat content of the fuel burned.



PERMIT APPLICATION FOR TITLE V OPERATING PERMIT AIR RESOURCES DIVISION

29 Hazen Drive, PO Box 95, Concord, NH 03302-0095
 Phone: 603-271-1370 Fax: 603-271-7053

PROJECT NAME: Public Service of New Hampshire, Merrimack Station, Bow, NH Title V Operating Permit SIC Code: 4333 Electric Utility Application #: FY96-TV048	ENGINEER: DCL & ERN DATE: 03/15/10
Page 4 of 14	

Table 2 – Pollution Control Equipment/Method Identification		
Pollution Control Equipment Number	Description of Equipment/Method	Emission Unit Number
MK2-PC6	SCR System installed in 1995	MK2

STACK INFORMATION:

Table 3 – Stack Information				
Emission Unit Number	Emission Unit Description	Minimum Stack Height (Feet) Above Ground Level	Maximum Inside Stack Diameter @ Exit (Feet)	Minimum Exhaust Air Flow (acfm)
MK1	Utility Boiler #1	225	8.6	480,000 at 300 deg F full load ¹⁰
MK2	Utility Boiler #2	317	14.5	1,200,000 at 335 deg F at full load ¹¹
MKCT1	Combustion Turbine #1	20	10.5" X 14"	821,000 at 840 deg F at full load ¹²
MKCT2	Combustion Turbine #2	20	10.5" x 14"	821,000 at 840 deg F at full load ¹³
MKEG	Emergency Generator	12	0.5	NA
MKEB	Emergency Boiler	22.33	4.0	NA

INSIGNIFICANT ACTIVITIES:

Table 4 – Insignificant Activities	
Activity	Basis
Solvent Cold Cleaning Station 1	Env-A 609.04(d)(2)
Solvent Cold Cleaning Station 2	Env-A 609.04(d)(2)
Solvent Cold Cleaning Station 3	Env-A 609.04(d)(2)

¹⁰ When operating MK1 below full load, operate the boiler and maintain volumetric air flows in a manner not to cause an exceedance of any emission limitation or operational limitation contained in this permit.

¹¹ When operating MK2 below full load, operate the boiler and maintain volumetric air flows in a manner not to cause an exceedance of any emission limitation or operational limitation contained in this permit.

¹² When operating MKCT1 below full load, operate the combustion turbine and maintain volumetric air flows in a manner not to cause an exceedance of any emission limitation or operational limitation contained in this permit.

¹³ When operating MKCT2 below full load, operate the combustion turbine and maintain volumetric air flows in a manner not to cause an exceedance of any emission limitation or operational limitation contained in this permit.



PERMIT APPLICATION FOR TITLE V OPERATING PERMIT AIR RESOURCES DIVISION

29 Hazen Drive, PO Box 95, Concord, NH 03302-0095
Phone: 603-271-1370 Fax: 603-271-7053

PROJECT NAME: Public Service of New Hampshire, Merrimack Station, Bow, NH Title V Operating Permit SIC Code: 4333 Electric Utility Application #: FY96-TV048	ENGINEER: DCL & ERN DATE: 03/15/10
--	---

Table 4 – Insignificant Activities

Activity	Basis
Solvent Cold Cleaning Station 4	Env-A 609.04(d)(2)
Solvent Cold Cleaning Temporary Units (3 Units < 60 days each unit)	Env-A 609.04(d)(2)
Slag Tank Warm-up Lines MK1 and MK2	Bypass of boiler exhaust to warm the Slag Tanks. Emissions accounted for in Boiler Emissions.
600 Gallon Gasoline Tank – Vehicle Fueling	Env-A 609.04(d)(2)
Shot Hoppers Ash Dumping	Env-A 609.04(d)(2)
SCR Economizer Hoppers Ash Dumping	Env-A 609.04(d)(2)
SCR Reactor Hoppers Ash Dumping	Env-A 609.04(d)(2)
Chemical Lab Hood Vents	Env-A 609.04(d)(2)
House Vacuum System with Baghouse	Env-A 609.04(d)(2)
Crusher House Propane Heating System	Env-A 609.04(d)(2)
Warehouse A Fuel Oil Heating Furnace System (2 propane unit)	Env-A 609.04(d)(2)
Yard Services Building #2 Fuel Oil Heating System	Env-A 609.04(d)(2)
Diesel/#2 Fuel Oil Storage Tanks (2 Tanks at 8,000 gallons each)	Env-A 609.04(d)(2)
Jet Fuel Storage Tanks (4 Tanks at 40,000 gallons each tank)	Env-A 609.04(d)(2)
Fly Ash Disposal Tank	Env-A 609.04(d)(2)
Fly Ash Silo Dust Collectors (2 Silos)	Env-A 609.04(d)(2)
Limestone Silo Dust Collector	Env-A 609.04(d)(2)
Vermiculite Silo Dust Collector	Env-A 609.04(d)(2)
PAC Silo Dust Collector	Env-A 609.04(d)(2)
Ammonia Storage and Distribution Systems	Env-A 609.04(d)(2)
Fly Ash Tank Unloading (Two unloading stations)	Env-A 609.04(d)(2)
Coal Handling and Unloading Systems	Env-A 609.04(d)(2)

EMISSIONS INFORMATION

Table 5 – Summary of Potential Emissions and Major Source Status

Pollutant	Potential Emissions (tpy)	Title V Major Source Thresholds	Title V Major Source?
SO ₂	113,222	100 tpy	yes
NO _x	13,171	50 tpy	yes
CO	515	100 tpy	yes
VOC	116	50 tpy	yes
TSP	4981	100 tpy	yes
HAPs	1,260 (mostly HCL & HF)	10 tpy of individual HAPs; 25 tpy for all HAPs combined	yes

- Notes:
- See calculation sheet for detailed calculations of the criteria pollutant emissions.
 - Potential emissions are based on maximum operational and emission limitations contained in the proposed Title V operating permit and/or AP-42 emission factors, except SO₂ emissions for MK1 and MK2 are based on the ton/hr coal consumption limit on an annual basis.



PERMIT APPLICATION FOR TITLE V OPERATING PERMIT AIR RESOURCES DIVISION

29 Hazen Drive, PO Box 95, Concord, NH 03302-0095
 Phone: 603-271-1370 Fax: 603-271-7053

PROJECT NAME: Public Service of New Hampshire, Merrimack Station, Bow, NH
 Title V Operating Permit
 SIC Code: 4333 Electric Utility
 Application #: FY96-TV048

ENGINEER: DCL & ERN

DATE: 03/15/10

Page 6 of 14

Table 6A – Emission Limitations for the Boilers (MK1 and MK2)

Pollutant	Emission Limit	Averaging Time	Authority
NOx	1.22 lb/MMBtu for MK1	7 consecutive 24-hour averages summed and divided by 7	NOx RACT Order ARD-97-001
	15.4 tons/day for MK2	24-hr calendar day average	Env-A 1211.03(d)(1)
	0.86 lb/MMBtu for MK2	Annual average	40 CFR 76.6(a)(2)
	29.1 tons/day combined from MK1 & MK2	24-hr calendar day average	NOx RACT Order ARD-97-001
	18.1 tons/day for MK1 when MK2 is not in full operation	24-hr calendar day average	NOx RACT Order ARD-97-001
	NOx Allowance Allocation for the Ozone Season in Table 9 below	Ozone Season (tons for May 1st through August 31st)	Env-A 3200
SO ₂	See State and Federal Acid Rain Program Limits below in Tables 7 and 8		Env-A 400, Env-A 2900, 40 CFR 72, 73, 76, 77
Sulfur Content for Coal	2.0 lb/MMBtu	3-month rolling average	Env-A 1606.01(b)
	2.8 lb/MMBtu	At any time	Env-A 1606.01(a)
Sulfur Content for No. 2 Fuel Oil	0.40 percent by weight	Each delivery	Env-A 1604.01(a)
TSP	0.27 lb/MMBtu for MK1 including periods of flyash injection, use formula in Env-A 2003.06 when below 1,238 MMBtu/hr		Env-A 2003.06 & Temporary Permit FP-T-0054
	1,463.1 tons for MK1	Consecutive 12 month period	Temporary Permit FP-T-0054
	0.227 lb/MMBtu for MK2 including periods of flyash injection, use formula in Env-A 2003.06 when below 3,473 MMBtu/hr		Env-A 2003.06 & Temporary Permit TP-B-0462
	3,458.6 tons for MK2	Consecutive 12 month period	Temporary Permit TP-B-0462
Opacity	30% - Normal Operations, except during periods of startup or shutdown	Hourly average	Temporary Permits FP-T-0054 & TP-B-0462



PERMIT APPLICATION FOR TITLE V OPERATING PERMIT AIR RESOURCES DIVISION

29 Hazen Drive, PO Box 95, Concord, NH 03302-0095
 Phone: 603-271-1370 Fax: 603-271-7053

PROJECT NAME: Public Service of New Hampshire, Merrimack Station, Bow, NH Title V Operating Permit SIC Code: 4333 Electric Utility Application #: FY96-TV048	ENGINEER: DCL & ERN DATE: 03/15/10
--	---

Table 6A – Emission Limitations for the Boilers (MK1 and MK2)

Pollutant	Emission Limit	Averaging Time	Authority
	During periods of startup, shutdown, malfunction, soot blowing, grate cleaning, and cleaning of fires, the 6-minute average opacity may exceed 40% opacity for a non-overlapping set or sets of time up to 60 minutes in any 8-hour period.	6-minute block average in any calendar hour	Temporary Permits FP-T-0054 & TP-B-0462
Ammonia slip	10 ppmvd @ 3% O ₂	Average of three one-hour test runs	Env-A 1405.02

Table 6B – Emissions Limitations for Other Combustion Devices

Emission Unit	Pollutant	Emission Limit	Authority
MKCT1 & MKCT2	NOx	0.90 lb/MMBtu for each unit on an hourly average	NOx RACT Order ARD-97-001
	TSP	0.30 lb/MMBtu for each unit	Env-A 2002.08
	Opacity	40% for any continuous 6 minute period	Env-A 2002.01
MKEG	Opacity	20% for any continuous 6 minute period	Env-A 2002.02
MKEB	SO ₂	38.96 lb/hr and 40.0 tons per consecutive 12 month period	Temporary Permit TP-B-0490
	CO	3.43 lb/hr and 100.0 tons per consecutive 12 month period	
	PM ₁₀	2.26 lb/hr and 15.0 tons per consecutive 12 month period	
	VOC	0.14 lb/hr and 25.0 tons per consecutive 12 month period	
	NOx	0.20 lb/MMBtu based on a 24-hour calendar day average, 13.72 lb/hr and 25.0 tons per consecutive 12 month period	Temporary Permit TP-B-0490 and Env-A 1211.12
	TSP	0.30 lb/MMBtu	Env-A 2002.08
	Opacity	20%, except during startup, shutdown, and malfunctions	40 CFR 60 Subpart Dc Section 60.43c(c) and Env-A 2002.02



PERMIT APPLICATION FOR TITLE V OPERATING PERMIT AIR RESOURCES DIVISION

29 Hazen Drive, PO Box 95, Concord, NH 03302-0095
 Phone: 603-271-1370 Fax: 603-271-7053

PROJECT NAME: Public Service of New Hampshire, Merrimack Station, Bow, NH Title V Operating Permit SIC Code: 4333 Electric Utility Application #: FY96-TV048	ENGINEER: DCL & ERN DATE: 03/15/10
Page 8 of 14	

EMISSIONS TRADING PROVISIONS:

Table 7 – State Acid Rain Program and Multiple Pollutant Budget Trading Program (Env-400 and Env-A 2900)	
Annual Emissions/ Allowances	Schiller Station (SR4, SR5, SR6), Merrimack Station (MK1 & MK2) and Newington Station (NT1) Combined
SO ₂ Emissions Cap	55,150 tons per calendar year
SO ₂ Initial Allowance Allocation (2007 and after)	7,289 allowances (tons)
NO _x Allowance Allocation (2007 and after)	3644 allowances (tons)

Table 8 – Federal Annual SO ₂ Allowance Allocation (tons)		
	2000 - 2009	2010 and Beyond
MK1	4288	4296
MK2	9242	9257

Table 9 – State NO _x Allowance Allocation for the Ozone Season (tons) Env – A 3200 (Note: Seasons beyond 2010 to be determined in accordance with Env-A 3207.04)		
Emission Unit	2009	2010
MK1	203	184
MK2	531	458
MKCT1	0	0
MKCT2	0	0



PERMIT APPLICATION FOR TITLE V OPERATING PERMIT AIR RESOURCES DIVISION

29 Hazen Drive, PO Box 95, Concord, NH 03302-0095
 Phone: 603-271-1370 Fax: 603-271-7053

PROJECT NAME: Public Service of New Hampshire, Merrimack Station, Bow, NH Title V Operating Permit SIC Code: 4333 Electric Utility Application #: FY96-TV048	ENGINEER: DCL & ERN DATE: 03/15/10
--	---

Table 10 - CO ₂ Allowance Allocation for 3-Year Compliance Periods (Env- A 4600) 2009 and Beyond*	
MK1	0
MK2	0

*All CO₂ allowances must be acquired.

STACK TESTING ACTIVITIES:

Table 11 – NO _x RACT Testing on MKCT1 & MKCT2						
	May 17, 1995	May 22, 1998	May 17 & 18, 2001	June 8, 2004	April 12 & 16, 2007	NO _x RACT Limit
MKCT1 NO _x (lb/MMBtu)	0.68 @ 18.1 MW	0.74 @ 18.3 MW	0.62 @ 19.7 MW	0.72 @ 19.5 MW	0.84 @ 20.2 MW	0.90
MKCT2 NO _x (lb/MMBtu)	0.73 @ 19.5 MW	0.78 @ 19.1 MW	0.62 @ 18.9 MW	0.63 @ 16.1 MW	0.74 @ 20.2 MW	0.90

Table 12 – TSP Testing on MK1 & MK2					
	MK1 3/7/90	MK1 2/27&28/90 No flyash re injected	MK2 11/09/99	MK2 11/10/99	MK2 3/14&15/2000
TSP (lb/MMBtu)	0.111 ¹⁴	0.031 ¹⁵	0.043 ¹⁶	0.041 ¹⁷	0.021 ¹⁸
TSP Allowed (lb/MMBtu)	0.27	0.27	0.227	0.227	0.227

Table 13 – Ammonia Slip Testing on MK1 & MK2			
	MK1 6/14/2000	MK2 6/13/2000	Limit
Ammonia ppm _{dv} @ 3% O ₂	0.06	0.18	10

¹⁴ Unable to determine the number of fields in service in the original or supplemental ESPs.

¹⁵ Unable to determine the number of fields in service in the original or supplemental ESPs.

¹⁶ Testing on 11/09/99 was with 7 of the 12 fields in service in the original ESP and 22 of 24 fields in service in the supplemental ESP.

¹⁷ Testing on 11/10/99 was with 11 of the 12 fields in service in the original ESP and 21 of 24 fields in service in the supplemental ESP.

¹⁸ Testing on 3/14&15/2000 was with 7 of the 12 fields in service in the original ESP and all 24 of 24 fields in service in the supplemental ESP.



PERMIT APPLICATION FOR TITLE V OPERATING PERMIT AIR RESOURCES DIVISION

29 Hazen Drive, PO Box 95, Concord, NH 03302-0095
Phone: 603-271-1370 Fax: 603-271-7053

PROJECT NAME: Public Service of New Hampshire, Merrimack Station, Bow, NH Title V Operating Permit SIC Code: 4333 Electric Utility Application #: FY96-TV048	ENGINEER: DCL & ERN DATE: 03/15/10
Page 10 of 14	

Tables 14 and 15 show the results of stack testing that PSNH conducted to comply with RSA 125-O:14. Note that DES has not yet completed review and approval of this data.

Table 14 – Baseline Mercury Emissions Testing on MK1 as submitted by PSNH¹⁹			
Date	Ave. Hg lb/TBtu	Ave. Hg lb/hr	Ave. Hg lb/yr
20-Jan-07	14.90	1.46E-02	127.91
6-Feb-07	8.42	9.82E-03	86.05
22-Feb-07	10.38	1.17E-02	102.66
11-Apr-07	5.33	6.38E-03	55.87
31-May-07	5.16	6.39E-03	55.96
Average	8.84	9.78E-03	85.69

Table 15 – Baseline Mercury Emissions Testing on MK2 as submitted by PSNH²⁰			
Date	Ave. Hg lb/TBtu	Ave. Hg lb/hr	Ave. Hg lb/yr
31-Jan-07	11.24	3.46E-02	303.01
21-Feb-07	9.81	3.11E-02	272.28
10-Apr-07	8.76	2.92E-02	255.71
4-Jun-07	7.51	2.56E-02	224.50
5-June-07	7.78	2.71E-02	237.44
Average	9.02	2.95E-02	258.59

Table 16 below shows baseline mercury emissions information that PSNH submitted in a letter dated September 7, 2007 as required by RSA 125-O:14. Note that DES has not yet completed review and approval of this data.

Table 16 – Baseline Mercury Emissions as submitted by PSNH²¹			
Unit ID	Average Hg Emission Rate (lb Hg/ton of coal fired)	Average Annual Coal Throughput (2003 through 2005) in tons/yr	Average Annual Hg Emissions in lb/yr
MK1	0.000207	352,320	73
MK2	0.000259	826,927	214
SR4	0.000081	154,766	13
SR5	0.000081	159,815	13
SR6	0.000081	159,693	13
Baseline Total Hg Emissions in lb/yr			326

NEW SOURCE REVIEW APPLICABILITY DETERMINATION

On February 4, 2008, PSNH Merrimack submitted a letter providing information regarding the applicability of New Source Review (NSR) to modifications at PSNH Merrimack. The submittal included PSNH's estimate of future actual emissions to support PSNH's assessment that NSR is not applicable to modifications to the steam turbine and generator for MK2.

On March 31, 2008, DES issued a conditional New Source Review applicability determination concerning modifications at PSNH Merrimack. DES concurs with PSNH's determination that the 24-month period from January 2006 through December 2007 is the representative emissions baseline period.

¹⁹ Note that DES has not yet completed review and approval for this information.

²⁰ Note that DES has not yet completed review and approval for this information.

²¹ Note that DES has not yet completed review and approval for this information.



PERMIT APPLICATION FOR TITLE V OPERATING PERMIT AIR RESOURCES DIVISION

29 Hazen Drive, PO Box 95, Concord, NH 03302-0095
Phone: 603-271-1370 Fax: 603-271-7053

PROJECT NAME: Public Service of New Hampshire, Merrimack Station, Bow, NH Title V Operating Permit SIC Code: 4333 Electric Utility Application #: FY96-TV048	ENGINEER: DCL & ERN	
	DATE: 03/15/10	Page 11 of 14

To verify that future actual emissions do not exceed the baseline emission levels as a result of these modifications, PSNH is required to submit actual emissions data for five years (up to 10 years, at DES' option). The Title V operating permit includes monitoring, recordkeeping, and reporting of the actual emissions for the five-year period commencing in 2008.

MODELING:

PSNH initially submitted an air quality modeling analysis to EPA in 1992 to determine the potential impacts of sulfur dioxide from the burning of coal. To obtain more accurate data for the analysis, PSNH constructed a meteorological tower in 1993 and used on-site meteorological data from 1994-1995 to refine the modeling. Further evaluations were performed in 1996 and a detailed analysis was proposed to address the effects of buildings on plume dispersion. Additional modeling was done in 1999, and in 2003 PSNH worked with DES and EPA to develop a modeling strategy to address outstanding modeling issues.

On December 11, 2008, DES concluded review of an ambient air quality impact analysis for the PSNH – Merrimack Station in support of a permit application for a proposed wet flue gas desulphurization system, which would result in decreases in sulfur dioxide and mercury emissions from the MK1 and MK2 boilers. The air dispersion modeling demonstrated compliance with the NAAQS for NOx, CO, SO2, and PM10. In addition, the modeling showed compliance with the ambient air limits for ammonia. Please see the attached modeling memo dated December 11, 2008 for further details.

On July 28, 2009, PSNH submitted a revised RTAP analysis to demonstrate compliance with the ambient air limits for coal dust. (See below for further discussion)

RTAP COMPLIANCE:

- Env-A 1400 is not applicable to combustion devices (MK1, MK2, MKCT1, MKCT2, MKEG, MKEB) because they burn virgin fossil fuels, exempted by Env-A 1402.01(b)(4). However, Env-A 1400 does apply to the SCR systems on MK1 and MK2, since there are ammonia slip emissions from these add-on pollution control devices for NOx emissions. Demonstration of compliance with the ambient air limit for ammonia was based on adjusted in stack concentrations for each of the two boilers.
- Env-A 1400 is not applicable to coal piles because no supportable method for conducting air dispersion modeling exists. EPA's AP-42 document provides emission factors for calculating PM emissions from storage piles, but it states however, that "calculated emissions represent intermittent events and should not be input directly into dispersion models that assume steady state emission rates." DES's air quality dispersion models assume steady state emission rates; therefore, no method for modeling the coal pile emissions exists. Thus, Env-A 1400 is not applicable to the piles, because practical methods of modeling emissions to assess compliance is not available.
- Env-A 1400 is applicable to the coal handling operations²², specifically the railcar unloading, truck unloading, and coal load-out to the piles. PSNH conducted air dispersion modeling to demonstrate compliance with the ambient air limit for coal dust.

SUPPLEMENTAL INFORMATION ON MONITORING

- DES streamlined the monitoring requirements for the Federal Acid Rain Program (40 CFR 75), the NOx Budget Program (Env-A 3200), the Multi-pollutant Budget Program (Env-A 2900), and State Monitoring Requirements (Env-A 800). See below for a comparison of the duplicative provisions.
- PSNH does not monitor for moisture; therefore, no moisture monitoring requirements were included.
- PSNH monitors SO2 for compliance with the state acid rain program by using the CEM data (not coal analysis data)

²² Note that New England Wood Pellet (NEWP) did not regulate the wood dust storage piles on the grounds that DES does not have the authority to regulate the "unloading, handling and storage of raw materials" and no supportable emission estimation methods exist. The Findings of Fact for the temporary permit for NEWP argues that DES only has the authority to regulate the RTAPs from devices and processes. The unloading, handling and storage of raw materials at NEWP and PSNH do not include similar operations. PSNH's coal handling activity is a process because it combines the operation of equipment (e.g., conveyors), devices (e.g., crusher) and raw materials (e.g., coal). In contrast, NEWP wood dust unloading, handling, and storage is not a process or device because no devices or equipment are involved.



PERMIT APPLICATION FOR TITLE V OPERATING PERMIT AIR RESOURCES DIVISION

29 Hazen Drive, PO Box 95, Concord, NH 03302-0095
Phone: 603-271-1370 Fax: 603-271-7053

PROJECT NAME: Public Service of New Hampshire, Merrimack Station, Bow, NH Title V Operating Permit SIC Code: 4333 Electric Utility Application #: FY96-TV048	ENGINEER: DCL & ERN
	DATE: 03/15/10 Page 12 of 14

PSNH also uses CEM data to determine compliance with the Federal Acid Rain Program.

- The combustion turbines (MKCT1 & MKCT2) applied for and received approval for an alternative monitoring plan for compliance with the NOx Budget Program (Env-A 3200). PSNH uses the stack testing data obtained during NOx RACT testing conducted every 3 years and the actual operating hours and fuel consumption data or default values to determine compliance.
- Env-A 808.03(d) is applicable to MK1 & MK2 because the stack volumetric flow measuring devices installed after January 1, 1992. PSNH installed and completed certification of the stack volumetric flow measuring devices in 1998.
- PSNH meets the NOx mass emission monitoring requirements (NOx Budget Program) on annual basis for MK1 and MK2 and on an ozone season basis for MKCT1 & MKCT2.
- The definition of excess emissions of opacity in the Temporary Permits for MK1 and MK2 are less stringent than Env-A 2002.01. Env-A 2002.01 requires opacity to not exceed 40% for any continuous 6 minute period. In this Title V Operating Permit and the Temporary Permits, the average opacity may exceed 40% for a non-overlapping set or sets of time up to 60 minutes in any 8-hour period during startup, shutdown, malfunction, soot blowing, grate cleaning, and cleaning of fires. The operating permits defined excess emission of opacity as “any air pollutant, which for a period or periods aggregating more than 60 minutes in any 8-hour period, exhibits 40% opacity or greater.”

COMPARISON OF MONITORING REQUIREMENTS (ENV-800 VS 40 CFR 75)

- Out of control period: Concerning calibration drift, 40 CFR 75.24(a)(1) is more stringent than Env-A 808.01(g)(1)(a) and (b). 40 CFR 75.24(a)(1) says that the out of control period begins when the calibration drift exceeds the specification, and the out of control period according to Env-A 808.01 begins when the calibration check exceeds twice the allowable limit for 5 consecutive days. For relative accuracy test audits (RATAs), cylinder gas audit (CGAs), relative accuracy audits (RAAs), both 40 CFR 75.24, which refers to 40 CFR 75 Appendix A, and Env-A 808(g)(1)(c), which refers to 40 CFR 60 Appendix F, say that the out of control period begins when the sampling is completed.
- Valid hour of data: According to Env-A 808.01(i), a valid hour is a minimum of 42 minutes of CEM readings taken in any calendar hour. According to 40 CFR 75.10(d), a valid hour is one data point in each fifteen-minute quadrant of an hour, where the unit combusted fuel during that quadrant of an hour. An hourly average may be computed from at least two data points separated by a minimum of 15 minutes (where the unit operates for more than one quadrant of an hour) if data are unavailable because of calibration, quality assurance, or preventative maintenance performed on the CEM.
- One cycle of operation for gaseous emissions: 5 minutes (Env-A 808.03(c)(2)) vs 15 minutes (40 CFR 75.10(d))
- One cycle of operation for opacity: 10 second for measuring analyzing and recording (Env-A 808.03(c)(2)) and 10 second for measuring and analyzing and 6-minute for recording (40 CFR 75.10(d))
- Percent data availability requirements: 40 CFR 75.32 is more stringent than Env-A 808.10 because Env-A 808.10 takes out any operating hours during daily calibrations and quarterly audits. Env-A 808.02(c)(2) requires that facilities in the NOx budget program meet the percentage data availability requirements of Env-A 808.10 (a)-(d) in addition to 40 CFR 75. 40 CFR 75.30 through 75.37 and 75.50(f) contain provisions for missing data substitution procedures whereas Env-A 808.10 requires submittal of a plan to DES of how to deal with non-compliance with percentage data availability requirements.
- Relative Accuracy: For RATAs, 40 CFR 75.24 and 40 CFR 75 Appendix A appear to be more stringent than 40 CFR 60 (except for lb NOx/hr, which is not calculated by Part 75) at 10% relative accuracy versus calculated relative accuracy. For RATAs, 40 CFR 75 Appendix B also provides for an incentive for an annual RATA if the relative accuracy is less than or equal to 7.5%. For the lb NOx/hr, PSNH must use the relative accuracy of 40 CFR 60.

APPLICABLE REGULATIONS:

Federal Regulations

- 40 CFR 60 Subpart D – NSPS for Fossil-Fuel-Fired Steam Generators for Which Construction, Modification, or Reconstruction is Commenced After August 17, 1971 – NA – PSNH is an electric utility steam generating facility.
- 40 CFR 60 Subpart Da – NSPS for Electric Utility Steam Generating Units for Which Construction, Modification, or Reconstruction is Commenced After September 18, 1978 – NA – The MK1 and MK2 Boilers were installed in 1960 and 1968 respectively and the MKCT1 and MKCT2 Combustion Turbines were installed in 1968 and 1969 respectively, and none of these units have undergone any physical or operational modifications after September 18,



PERMIT APPLICATION FOR TITLE V OPERATING PERMIT AIR RESOURCES DIVISION

29 Hazen Drive, PO Box 95, Concord, NH 03302-0095
Phone: 603-271-1370 Fax: 603-271-7053

PROJECT NAME: Public Service of New Hampshire, Merrimack Station, Bow, NH Title V Operating Permit SIC Code: 4333 Electric Utility Application #: FY96-TV048	ENGINEER: DCL & ERN
	DATE: 03/15/10 Page 13 of 14

1978.

- 40 CFR 60 Subpart Db – NSPS for Industrial-Commercial-Institutional Steam Generating Units for Which Construction, Modification, or Reconstruction is Commenced After June 19, 1984 – NA – PSNH does not have any boilers which are in the 100 to 250 mmBtu/hr gross heat input range.
- 40 CFR 60 Subpart Dc – NSPS for Small Industrial-Commercial-Institutional Steam Generating Units for Which Construction, Modification, or Reconstruction is Commenced After June 9, 1989– Applicable to the MKEB – Each temporary package boiler installation at the Merrimack Station will be subject to Subpart Dc as the facility can bring in boilers with gross heat input rates of up to 96.0 MMBtu/hr.
- 40 CFR 60 Subpart K – NSPS for Storage Vessels for Petroleum Liquids for Which Construction, Reconstruction, or Modification Commenced After June 11, 1973, and Prior to May 19, 1978 – NA
- 40 CFR 60 Subpart Ka – NSPS for Storage Vessels for Petroleum Liquids for Which Construction, Reconstruction, or Modification Commenced After May 18, 1978, and Prior to July 23, 1984 – NA
- 40 CFR 60 Subpart Kb – NSPS for Volatile Organic Liquid Storage Vessels (Including Petroleum Liquid Storage Vessels) for Which Construction, Reconstruction, or Modification Commenced After July 23, 1984 – NA
- 40 CFR 60 Subpart Y – NSPS for Coal Preparation Plants – NA – Installed prior to October 24, 1974.
- 40 CFR 60 Subpart GG -- NSPS for Stationary Gas Turbines (applicable to turbines greater than 10 MMBtu/hr and that commenced construction, modification, or reconstruction after October 3, 1977)– NA, combustion turbines installed in 1968 and 1969.
- 40 CFR 61 Subpart M – NESHAP for Asbestos – Applicable when removing asbestos materials.
- 40 CFR 63 Subpart Q – MACT for Industrial Cooling Towers -- NA
- 40 CFR 63 Subpart EEEE – MACT for Organic Liquid Distribution (non-gasoline) – NA, No. 1 and No. 2 Fuel Oil and On-road low sulfur diesel fuel is below the vapor pressure threshold for existing tanks for controls, .
- 40 CFR 63 Subpart YYYY – MACT for Stationary Combustion Turbines -- Merrimack Station's 2 Combustion Turbines, MKCT1 and MKCT2, are existing sources, i.e., constructed and operated prior to January 14, 2003, therefore the MACT is applicable; however, there are no requirements for existing sources, including the requirements of Subpart A of 40 CFR 63 or the initial notification requirements as stated in 40 CFR 63 Subpart YYYY Section 63.6090(b)(4).
- 40 CFR 63 Subpart DDDDD- MACT for Industrial, Commercial and Institutional Boilers and Process Heaters – fossil-fuel fired electric utility steam generating units – This rule was vacated by the D.C. Circuit Court and will not be applicable to MK1 or MK2 or MKEB.
- 40 CFR 60 and 63 – NSPS and MACT for New and Existing Stationary Sources: Electric Utility Steam Generating Units and Clean Air Mercury Rule (CAMR). – This regulation addresses mercury emissions from coal-fired utility boilers. In March 2005, EPA de-listed electric utilities as a MACT source category, and issued the Clean Air Mercury Rule instead, which was applicable to PSNH Merrimack Station (40 CFR 60 Subparts B, HHHH, and Da); however this rule was vacated. Therefore, any applicable provisions will be incorporated into the Title V permit at a later date.
- 40 CFR Part 68 – Chemical Accident Prevention – Applicable – Ammonia stored for use in the SCR systems is above the threshold quantities.
- 40 CFR 72 – Permits Regulation (Acid Rain permits) – Applies to MK1 and MK2.
- 40 CFR 73 – Sulfur Dioxide Allowance System - Applicable to MK1 and MK2, but not MKCT1 and MKCT2.
- 40 CFR 74 – Sulfur Dioxide Opt-Ins – NA
- 40 CFR 75 – Continuous Emission Monitoring – Applicable to MK1 and MK2.
- 40 CFR 76 – Acid Rain Nitrogen Oxides Emission Reduction Program - Applicable to MK1 and MK2, but not MKCT1 and MKCT2. Note that MK1 falls below the 1,060,000 lb/hr steam at full load applicability threshold for Phase I Group 2 Boilers and so is not subject to 40 CFR §76.6(a)(2), which is a NOx limit of 0.86 lb/mmBtu
- 40 CFR 77 – Excess Emissions – Applicable to MK1 and MK2.
- 40 CFR 96 – NOx Budget Trading Program for SIPs – NA (New Hampshire is not part of the program.)

State Regulations

- Env-A 400 Acid Deposition Control Program – This is only applicable to MK1 and MK2.
- Env-A 504.01(d) – NESHAP for Asbestos
- Env-A 600 Statewide Permit System
- Env-A 700 Permit Fee System



PERMIT APPLICATION FOR TITLE V OPERATING PERMIT AIR RESOURCES DIVISION

29 Hazen Drive, PO Box 95, Concord, NH 03302-0095
Phone: 603-271-1370 Fax: 603-271-7053

PROJECT NAME: Public Service of New Hampshire, Merrimack Station, Bow, NH Title V Operating Permit SIC Code: 4333 Electric Utility Application #: FY96-TV048	ENGINEER: DCL & ERN
	DATE: 03/15/10 Page 14 of 14

- Env-A 800 Testing and Monitoring Procedures
- Env-A 901 Owner or Operator Recordkeeping and Reporting Obligations
- Env-A 1002 Fugitive Dust – This is applicable facility wide. For coal dust emissions, PSNH must implement Best Management Practices. See Standard Operating Procedures submitted by PSNH.
- Env-A 1211.01 (j) – NOx RACT Exemption for Emergency Generators – Applicable to MKCT1 and MKCT2.
- Env-A 1211.03 NOx RACT for Utility Boilers – Applicable to MK1 and MK2.
- Env-A 1211.04 NOx RACT for Steam Electric Boilers – NA – PSNH Merrimack Station is not a small power production facility, they are capable of operating at a capacity greater than 30 MW
- Env-A 1211.06 NOx RACT for Combustion Turbines – Applicable to MKCT1 and MKCT2
- Env-A 1211.13 NOx RACT for Load Shaving Units – Not Applicable to MKCT1 and MKCT2
- Env-A 1211.11 – NOx RACT for Emergency Generators – NA unless the hours of operation exceed 500 hours per consecutive 12-month period
- Env-A 1211.16 Multiple Sources Under Common Ownership (Bubble)
- Env-A 1211.17 Emissions Averaging Equation
- Env-A 1211.19 Seasonal Control of NOx Emissions
- Env-A 1211.20 NOx Testing
- Env-A 1211.21 NOx monitoring
- Env-A 1400 Regulated Toxic Air Pollutants
- Env-A 1604.01(a) and (d) Fuel Sulfur Content Specifications for No. 1 fuel oil, No. 2 Fuel Oil, JP-4 aviation fuel, and on-road low sulfur diesel oil.
- Env-A 1606.01 Fuel Sulfur Content Specifications for Coal
- Env-A 1800 – Asbestos Management and Control
- Env-A 2002.01, 2002.02, and 2002.04 Visible Emission Standards for Fuel Burning Devices
- Env-A 2002.06 and 2002.07 Particulate Emission Standards
- Env-A 2107 - Visible Emission Standards for Non-Fuel Burning Devices – NA - The requirements of Env-A 2100 are not applicable to PSNH Merrimack Station because it is not a process, manufacturing, and service-based industry, and it is regulated by other provisions. The fugitive emissions are regulated under Env-A 1002, *Fugitive Dust*.
- Env-A 2103 – Emission Standards for Particulate Matter – NA - The requirements of Env-A 2100 are not applicable to PSNH Merrimack Station because it is not a process, manufacturing, and service-based industry, and it is regulated by other provisions. The fugitive dust requirements of Env-A 1002 require controls for the particulate matter, and Env-A 1400 regulates the toxic particulate matter, such as coal dust.
- Env-A 2900 Multi-pollutant Annual Budget and Trading Program
- Env-A 3000 Emission Reduction Credits Trading Program
- Env-A 3100 Discrete Emission Reduction Trading Program
- Env-A 3200 NOx Budget Trading Program
- Env-A 3700 NOx Emission Reduction Fund - NA
- Env-A 3800 – Voluntary Greenhouse Emission Reduction Registry – NA
- Env-A 4000 – Portable Fuel Container Spillage Control – NA
- Env-A 4100 – Consumer Products – NA
- Env-A 4200 – Architectural and Industrial Maintenance Coatings – NA
- Env-A 4300 – Other Solid Waste Incineration – NA
- Env-A 4600 – Carbon Dioxide (CO₂) Budget Trading Program – Applicable to MK1 and MK2
- RSA 125-O:11 - 18 – Mercury Emissions – Applicable to MK1 and MK2

NA = Not Applicable

SUMMARY AND CONCLUSIONS:

PSNH Merrimack Station is in compliance with all air quality requirements. After taking into consideration public comments, DES issues the Proposed Title V Operating Permit for PSNH Merrimack Station.

STATE OF NEW HAMPSHIRE
Department of Environmental Services
Air Resources Division

Intraoffice Memorandum

TO: Doug Laughton, Program Manager
Permitting and Environmental Health Bureau

DATE: October 20, 2009

FROM: Lisa Landry, Modeling Supervisor
Permitting and Environmental Health Bureau

AFS #: 3301300026

Application #:

SUBJ: PSNH Merrimack Station – Bow
Revised Coal Dust Modeling

UTM E: 299011

UTM N: 4779703

Modeling Project Summary

- **Purpose:** Env-A 1400 evaluation of respirable coal dust particles
- **Initial assumptions (modeling input):** see Tables 1 and 2; continuous operations
- **Pass/Fail (if failed for what):** passed for respirable coal dust
- **Restrictions resulting from modeling:** no additional restrictions

DES has reviewed an ambient air quality impact analysis for PSNH's Merrimack Station in Bow. The purpose was to assess the impacts of coal dust from various operations at the Merrimack facility. This analysis, as performed by TRC, is the same as the August 2009 modeling with the exception of the emission rates used. The previous analysis used PM10 emission factors; however the Ambient Air Limit in Env-A1400 is based on the respirable portion of PM which is 4µm or smaller. Since emission factors for 4µm or smaller are not readily available, more conservative factors were used in this analysis which are based on 5µm or smaller.

PSNH initially looked at the potential impacts from coal dust in 2001 in a modeling analysis performed by Northeast Utilities, and later revised their analysis in 2003. The recent TRC modeling was initially submitted in July, 2009, later updated in August based on comments made by DES, and this analysis was submitted in October of 2009.

TRC evaluated three distinct operations which could produce airborne coal dust: railcar unloading, truck unloading and conveyor load-out. For the railcar and truck unloading operations, coal is dumped either into a partially-covered shed (in the case of the railcars) or directly on the coal pile by the trucks. In the conveyor load-out operation, coal from the railcar shed is transported to the piles by a conveyor system where it is dropped from a boom. Each operation was modeled as a volume source, and all were assumed to occur simultaneously for 8760 hrs/yr.

The modeling inputs used in the TRC analysis are shown in Table 1, while the assumptions used to develop the emission rates and to set-up the modeling are given in Table 2. The emission rates were calculated using a formula taken from AP-42 and take into account wind speed to estimate how much of the coal dust (modeled as PM5) from the various coal handling operations becomes airborne. TRC originally used the average annual wind speed to calculate emissions on both a daily and annual basis but DES requested they look at hourly emission rates when modeling against the 24-hour AAL since coal dust emissions vary over time.

Table 1
Modeled Input Data

Parameter	Units	Railcar Unloading	Trucks	Coal Load-Out
Source ID	---	Rail	Truck	Loadout
Source Type	---	Volume	Volume	Volume
Location	---	railcar shed center	boom center	boom center
UTM E1	m	299039.3	299010.7	299010.7
UTM N1	m	4779786.6	4779703.0	4779703.0
Base Elevation	m MSL	62.8	62.8	62.8
Obstacle Height	m	10.06	15.24	15.24
Length	m	19.96	49.4	49.4
Width	m	11.89	49.4	49.4
Volume Source Height	m	5.03	0.91	4.57
Sigma-z0	m	4.68	7.09	7.09
Sigma-y0	m	4.04	12.97	12.97
Hours unloading per day	---	12	12	12
Coal handled	TPD	9000	2000	9000
Coal handled	TPH	750	167	750
Coal handled	TPY	900,000	300,000	900,000
PM ₅ * (24-hour)	g/s	calculated hourly	calculated hourly	calculated hourly
PM ₅ * (annual)	g/s	0.00018	0.00052	0.00180
Coal				
Moisture	%	6.42	7.08	6.42
Particle size mult. (k)		0.2	0.2	0.2
Mean wind speed	mph	5.42	5.42	5.42
Emission factor (E)	lb/Ton	0.000139	0.000121	0.000139
Control Efficiency	%	90	0	0
Emission factor (model)	lb/Ton	0.000014	0.000121	0.000139

* refers to respirable portion of PM

Table 2
Assumptions Used in the TRC Modeling Analysis

- One train with 90 railcars will unload in 12 hours
- Each railcar unloads 100 tons of coal
- 100 trains per year will deliver coal
- 10,000 trucks per year will deliver coal
- Each truck will unload 30 tons of coal
- Up to 2000 tons of coal will be delivered in a day during a 12 hour period by truck
- The coal will drop 6 feet during truck delivery
- The coal load-out by conveyor will drop 30 feet
- The boom radius for coal load-out is 91.5 feet
- The coal pile height is 50 feet
- The moisture content of the different coals are:
 - Pile A 7.08%
 - Pile B 6.6%
 - Pile C 6.36%
 - Pile D 5.88%
- The emissions for each volume source will occur 12 hours or less per day, but since they can occur during any hour of the day, they were modeled to occur 24 hours per day. The total daily emissions for each source were equally distributed over each hour of the day.

The most recent version of AERMOD was used to predict maximum off-property impacts from the three coal handling operations. The meteorological data used in the analysis were obtained from an on-site tower and SODAR system and covered 23 months from 1994 and 1995. This is the same meteorological data set approved in 2008 by DES for the scrubber modeling project.

Table 3 presents the results of the TRC modeling analysis submitted in October, 2009. The analysis predicts all coal dust impacts to be below the AALs based on the assumptions contained in Tables 1 and 2 and assuming only the respirable portion of PM. The maximum impacts were predicted to be on the facility property line, just to the east of the active coal pile.

For conservatism, DES modified some assumptions by way of increasing the number of tons of coal each truck can hold and the number of trucks per day. A lower coal moisture content was also examined to see what affect these changes would have on emissions and therefore on the impacts. Though the predicted coal dust impacts would increase, they are still expected to be below the AALs.

Table 3
Maximum Coal Dust Impacts (ug/m³) from TRC Modeling
(all operations modeled at 8760 hrs/yr)

Pollutant	24-Hour Impact	24-Hour AAL	Annual Impact	Annual AAL	Pass/Fail
Coal Dust (bituminous) (respirable portion)	1.2	4.5	0.2	3.0	PASS

Project Tracking and Details

- **Modeler(s):** L. Landry **Reviewer:** J. Black
- **Site visit made on:** 10-6-2005 by J. Black
- **Hardcopy files returned to:**
- **Model:** AERMOD v. 07026, AERMET v. 06341
- **Met data:** on-site data from 1994-1995 **Met site:** Bow
- **Analysis details:** an hourly emissions file was developed by TRC to account for wind speed dependent emission rates; all operations were modeled as volume sources; a minimum of one year of met data is needed according to EPA guidance but 23 months of data were collected so this entire period was used.

MK1 Boiler - 1,238 MMBtu/hr, Maximum of 48.5 tons/hr coal feed rate and 425,289 tons per consecutive 12 month period
 Max Sulfur content = 3.645% by weight, AP42 emission factor for SO₂ = 38 X (% sulfur by weight) = 38 X 3.645 = 138.51 lb/ton
 7.8% ash by weight, PM10 emission factor = 0.26 X 7.8 = 2.028 lb/ton
 TSP = Max Permit Limit = 0.227 lb/MMBtu X Max Heat Input Rate 1,238 MMBtu/hr = 281.03 lb/hr
 NOx RACT Limit = 13.7 tons/day X 365 days/yr = 5,000.5 tons/yr

Pollutant	Emission Max. Op.		PTE	
	Factor (lb/ton)	Rate (tons/hr)	lb/hr	tons/yr
SO ₂	138.51	48.5	6717.74	29423.7
NO _x				5005.5
CO	0.5	48.5	24.25	106.2
PM10(F)	2.028	48.5	98.36	430.8
TSP			281.03	1230.9 (Permit Limit Max = 1463 tons/yr)
NM VOC	0.11	48.5	5.34	23.4

Emission factors for SO₂, CO, PM10, & VOC are from USEPA AP-42 5th Edition, Chapter 1.1 - Bituminous and Subbituminous Coal Combustion, Tables 1.1.3 and 1.1.4, with the exception of NO_x, which came from the NO_x RACT limit, and TSP from the TSP emission limit in the Permit.

MK2 Boiler - 3,473 MMBtu/hr, Maximum of 136.2 tons/hr coal feed rate
 Max Sulfur content = 3.645% by weight, AP42 emission factor for SO₂ = 38 X (% sulfur by weight) = 38 X 3.645 = 138.51 lb/ton
 7.8% ash by weight, PM10 emission factor = 0.26 X 7.8 = 2.028 lb/ton
 TSP = Max Permit Limit = 0.27 lb/MMBtu X Max Heat Input Rate 3,473 MMBtu/hr = 937.71 lb/hr
 NOx RACT Limit = 15.4 tons/day X 365 days/yr = 5,621 tons/yr

Pollutant	Emission Max. Op.		PTE	
	Factor (lb/ton)	Rate (tons/hr)	lb/hr	tons/yr
SO ₂	138.51	136.2	18865.06	82629.0
NO _x				5621.0
CO	0.5	136.2	68.10	298.3
PM10(F)	2.028	136.2	276.21	1209.8
TSP			937.71	4107.2 (Permit Limit Max = 3459 tons/yr)
NM VOC	0.11	136.2	14.98	65.6

Emission factors for SO₂, CO, PM10, & VOC are from USEPA AP-42 5th Edition, Chapter 1.1 - Bituminous and Subbituminous Coal Combustion, Tables 1.1.3 and 1.1.4, with the exception of NO_x, which came from the NO_x RACT limit, and TSP from the TSP emission limit in the Permit.

MKCT1 and MKCT2

319 MMBtu/hr max firing rate, 2,279 gal/hr No. 1 fuel oil max feed rate

Pollutant	Emission Max. Op.		PTE		2 Units
	Factor lb/MMBtu	Rate MMBtu/hr	lb/hr	tons/yr	PTE tons/yr
SO ₂	0.4040	319	128.88	564.5	1129.0
NO _x	0.9000	319	287.10	1257.5	2515.0
CO	0.0033	319	1.05	4.6	9.2
PM10(F)	0.0043	319	1.37	6.0	12.0
TSP	0.0120	319	3.83	16.8	33.5
NM VOC	0.0004	319	0.13	0.6	1.1

NO_x emission factors from NO_x RACT Order. All other emission factors are from USEPA AP-42 5th Edition, Chapter 3.1 Stationary Gas Turbines, Distillate Oil Fired Turbines, Tables 3.1-1 and 3.1-2a.

MKEG Emissions

3.932 MMBtu/hr from diesel fuel, maximum firing rate of 28.7 gal/hr
 500 hours operating restriction

Pollutant	Emission Max. Op.		PTE lb/hr	PTE tons/yr
	Factor lb/MMBtu	Rate MMBtu/hr		
SO2	0.29	3.93	1.14	0.3
NOx	4.41	3.93	17.33	4.3
CO	0.95	3.93	3.73	0.9
PM10(F)	0.31	3.93	1.22	0.3
TSP	0.31	3.93	1.22	0.3
NMVOG	0.35	3.93	1.38	0.3

Emission factors from USEPA AP-42 5th Edition, Chapter 3.3 - Gasoline and Diesel Industrial Engines
 < 600 Hp, Table 3.3.1.

MKEB Emissions

Temporary Permit TP-B-0490 established federally enforceable operational & emissions limitations shown below:
 520 gal/hr and 11,760 gal/day maximum No. 2 fuel oil at 0.4% sulfur, by weight
 OR 701 gal/hr On-Road Low Sulfur Diesel Fuel (Less than 0.05% sulfur, by weight)

Pollutant	PTE	PTE
	lb/hr	tons/yr
SO2	38.96	40.0
NOx	13.72	25.0
CO	3.43	100.0
PM10(F)	2.26	15.0
TSP	5.71	25.0
NMVOG	0.14	25.0

Facility Wide Potential to Emit Criteria Pollutants Emissions Summary (tons/yr)

Pollutant	MK1 tons/yr	MK2 tons/yr	MKCT1 tons/yr	MKCT2 tons/yr	MKEG tons/yr	MKEB tons/yr	Facility	Title V Major	Title V Major
							Wide Total	Source Thresholds	
SO2	29423.7	82629.0	564.5	564.5	0.3	40.0	113222.0	100 tpy	yes
NOx	5005.5	5621.0	1257.5	1257.5	4.3	25.0	13170.8	50 tpy	yes
CO	106.2	298.3	4.6	4.6	0.9	100.0	514.6	100 tpy	yes
PM10(F)	430.8	1209.8	6.0	6.0	0.3	15.0	1667.9	100 tpy	yes
TSP	1463.0	3459.0	16.8	16.8	0.3	25.0	4980.9	100 tpy	yes
NMVOG	23.4	65.6	0.6	0.6	0.3	25.0	115.5	50 tpy	yes

Notes: MK2 TSP tons/yr is the maximum permit limit instead of 4107.2 tons/yr PTE
 MK1 TSP tons/yr is the maximum permit limit instead of 1230.9 tons/yr PTE