



The  
NEW HAMPSHIRE DEPARTMENT OF ENVIRONMENTAL SERVICES

hereby issues

LARGE GROUNDWATER WITHDRAWAL PERMIT

NO. LGWP-2008-0002A

to the permittee

MERIDEN VILLAGE WATER DISTRICT  
P.O. BOX 171  
MERIDEN, NH 03770-0171  
(603-469-3486)

for the withdrawal of the following volumes of groundwater from the following wells for the purpose of community water supply:


Well A	57,600 gallons over any 24-hour period
Well B	79,200 gallons over any 24-hour period

Date of Issuance: August 24, 2018  
Date of Expiration: June 30, 2028

Pursuant to authority in N.H. RSA 485-C:21, the New Hampshire Department of Environmental Services (NHDES), hereby grants this permit to withdraw groundwater from well A and well B subject to the following conditions:

1. The permittee shall comply with the requirements of Env-Wq 403 and RSA 485-C at all times.
2. Water Conservation: The permittee shall continue to implement the approved Water Conservation Plan, dated January 21, 2008, in accordance with Env-Wq 2101 and NHDES' conditional approval dated March 26, 2008.
3. Metering Requirements: Withdrawals from all sources must be metered at all times. All meters must be selected, installed, tested, and maintained in accordance with the AWWA standards. The permittee shall read source water meters to adequately report the following volumes to the reporting program referenced in condition No. 5 of this permit:
  - a) The 24-hour peak volume withdrawn from the source during each month and the date the water use occurred; and
  - b) The cumulative total volume of water withdrawn from the source during each month.
4. Mitigation Requirements
  - a) In the event that adverse impacts occur, the permittee shall comply with all of the impact mitigation and source replacement requirements of Env-Wq 403.
  - b) Where the status of an unanticipated impact is not clear, the permittee shall gather information needed to quantify the impact and determine its status relative to adverse impact criteria defined under RSA 485-C:21 V-c.
5. The permittee shall maintain compliance with the requirements of the Water Use Registration and Reporting Program established by RSA 488, and Env-Wq 2102.
6. The permittee shall apply for renewal of this permit no more than six months prior to its expiration date in accordance with Env-Wq 403. The permittee shall continue to comply with all conditions in this permit until the permit is renewed or the facility is closed in accordance with all applicable requirements, regardless of whether a renewal application is filed.

Any person aggrieved by any terms or conditions of this permit may appeal in accordance with RSA 21-O:7,IV within 30 days.



Rene Pelletier, P.G.,  
Assistant Director Water Division