



The  
NEW HAMPSHIRE DEPARTMENT OF ENVIRONMENTAL SERVICES

hereby issues

LARGE GROUNDWATER WITHDRAWAL PERMIT

NO. LGWP-2008-0003A

to the permittee

BELMONT WATER DEPARTMENT  
143 MAIN STREET  
P.O. BOX 310  
BELMONT, NH 03220-0310  
(603-267-8301)

for the withdrawal of the following volume of groundwater from the following well for the purpose of community water supply:


GPW-3, 648,000 gallons over any 24-hour period;  
GPW-3, GPW-2, GPW-1[Backup Only] a total of 936,000 gallons over any 24-hour period.

Date of Issuance: September 10, 2018  
Date of Expiration: September 10, 2028

Pursuant to authority in N.H. RSA 485-C:21, the New Hampshire Department of Environmental Services (NHDES), hereby grants this permit to withdraw groundwater from well GPW-3 subject to the following conditions:

1. The permittee shall comply with the requirements of Env-Wq 403 and RSA 485-C at all times.
2. Water Conservation: The permittee shall implement the approved Water Conservation Plan, dated June 14, 2007, in accordance with Env-Wq 2101 and NHDES' conditional approval dated July 2, 2007.
3. Metering Requirements: Withdrawals from all sources must be metered at all times. All meters must be selected, installed, tested, and maintained in accordance with Env-Wq 2101. The permittee shall read source water meters to adequately report the following volumes to the reporting program referenced in condition No. 5 of this permit:
  - a) The 24-hour peak day volume withdrawn from the wells and the date the water use water use occurred; and
  - b) The cumulative volume of water withdrawn from the well field during each month.
4. Mitigation Requirements
  - a) In the event that adverse impacts occur, the permittee shall comply with all of the requirements below and with the impact mitigation and source replacement requirements of Env-Wq 403.
  - b) Where the status of an unanticipated impact is not clear, the permittee shall gather information needed to quantify the impact and determine its status relative to adverse impact criteria defined under RSA 485-C:21 V-c and provide this information to NHDES within 48 hours of being notified by NHDES. A verified adverse impact shall be mitigated in accordance with Env-Wq 403.
5. The permittee shall maintain compliance with the requirements of the Water Use Registration and Reporting Program established by RSA 488 and Env-Wq 2102.
6. The permittee shall apply for renewal of this permit no more than six months prior to its expiration date in accordance with Env-Wq 403. The permittee shall continue to comply with all conditions in this permit until the permit is renewed or the facility is closed in accordance with all applicable requirements, regardless of whether a renewal application is filed.

Any person aggrieved by any terms or conditions of this permit may appeal in accordance with RSA 21-O:7,IV within 30 days.



Rene Pelletier, P.G.,  
Assistant Director Water Division