



The
NEW HAMPSHIRE DEPARTMENT OF ENVIRONMENTAL SERVICES

hereby issues

LARGE GROUNDWATER WITHDRAWAL PERMIT

NO. LGWP-2008-0004A

to the permittee

VILLAGE DISTRICT OF EASTMAN
P.O. BOX 990
GRANTHAM, NH 03753
(603-863-6512)

for the withdrawal of the following volume of groundwater from the following on-site well located west of Bog Brook in Springfield, New Hampshire (Town of Springfield Tax Map 31-033,299) for the purpose of community water supply:


BRW6 120,960 gallons over any 24-hour period

Date of Issuance: September 19, 2018
Date of Expiration: September 15, 2028

Pursuant to authority in N.H. RSA 485-C:21, the New Hampshire Department of Environmental Services (NHDES), hereby grants this permit to withdraw groundwater from BRW6 subject to the following conditions:

1. The permittee shall comply with the requirements of Env-Wq 403 and RSA 485-C at all times.
2. Water Conservation: Implement the approved Water Conservation Plan dated July 30, 2007 and approved on August 31, 2007 in accordance with Env-Ws 390.
3. Metering Requirements: Withdrawals from all sources must be metered at all times. The permittee shall read source water meters at least once every 30 days. All meters must be selected, installed, tested, and maintained in accordance with Env-Wq 2101. The permittee shall read source water meters to adequately report the following volumes to the reporting program referenced in condition No. 5 of this permit:
 - a) The 24-hour peak volume withdrawn from the source during each month and the date the water use occurred; and
 - b) The cumulative total volume of water withdrawn from the source during each month.
4. Mitigation Requirements
 - a) In the event that an adverse impact occurs, the permittee shall comply with all of the requirements below and with the impact mitigation and source replacement requirements of Env-Wq 403.
 - b) Where the status of unanticipated impact is not clear, the permittee shall gather information needed to quantify the impact and determine its status relative to adverse impact criteria defined under RSA 485-C:21 V-c and provide this information to NHDES within 48 hours of being notified by NHDES.
5. The permittee shall maintain compliance with the requirements of the Water Use Registration and Reporting Program established by RSA 488 and Env-Wq 2102.
6. The permittee shall apply for renewal of this permit no more than six months prior to its expiration date in accordance with Env-Wq 403. The permittee shall continue to comply with all conditions in this permit until the permit is renewed or the facility is closed in accordance with all applicable requirements, regardless of whether a renewal application is filed.

Any person aggrieved by any terms or conditions of this permit may appeal in accordance with RSA 21-O:7,IV within 30 days.



Rene Pelletier, P.G.,
Assistant Director Water Division