



The State of New Hampshire
Department of Environmental Services



January 26, 2007

Neil Helberg
Lewis Engineering
44 Stark Lane
Litchfield, New Hampshire 03052

**Subject: CWS BELMONT: Lakeland Management; EPA ID: 0202010
Water Conservation Plan; NHDES # 997199**

Dear Mr. Helberg:

The purpose of this letter is to approve the Water Conservation Plan for the subject water system. This decision is based on a review of your January 10, 2007 Water Conservation Plan, submitted to meet the requirements of Env-Ws 390, *Water Conservation Rules*.

The Water Conservation Plan shall be implemented when the new well is approved and connected to the water system. Every three years from the date of this letter the water system shall supply the New Hampshire Department of Environmental Services (NHDES) with documentation of compliance with the plan. This information shall be supplied on a form provided by NHDES and shall include contact information for the water system owner and the person responsible for carrying out the tasks of the plan, all data relating to leak detection, water use audits and meter reading, if applicable, and the dates these tasks were performed.


Technical assistance related to water audits and leak detection, meter calibration, and/or estimating unaccounted for water may be obtained by contacting Derek Bennett at 271-4087, or dbennett@des.state.nh.us.

If you have any questions about this letter feel free to call me at 271-2947 or email me at dmorgan@des.state.nh.us.

Sincerely,

Diana W. Morgan, Professional Geologist
Drinking Water & Groundwater Bureau

Cc: Jim Gill, Derek Bennett, DWGB
Mark Mooney, Lakeland Mgt
Wade Crawshaw, C & C Water Scvs



**Report Form for
Water Conservation Plans
Small Community Water Systems
December 2006***

PROJECT NAME: Lakeland Management Company CWS
Well No. 5
TOWN/CITY: Belmont, New Hampshire
DATE: December 2006
EPA ID # 0202010

PURPOSE: This form will provide the information needed for small community water systems to meet the reporting requirements of Env-Ws 390, *Water Conservation Rules*. Once completed, this form can fulfill the requirements of Env-Ws 390.10. You don't have to use this form. However, based on experience, the Department has found that use of a form speeds the application process. If you prefer to produce an original report, remember to provide all the information required under the rules and the Department recommends that you use this form as a checklist to help ensure your report is complete. Helpful information and reminders are provided throughout the form and are printed in *italics*. Copies of this form, the rules, a summary of the rules, educational materials for public distribution, and other useful publications may be found at the following website: http://www.des.nh.gov/h2o_conservation.htm.

INSTRUCTIONS:

- A. Obtain copies of the following materials from either the Department's Public Information Center (603) 271-2975 or by direct download from the above website.
- Administrative Rule, Env-Ws 390, *Water Conservation Rules*.
 - The fact sheet, *Summary of the Water Conservation Rule*.
 - Any pertinent water efficiency fact sheet.
 - Extra copies of this form.

- B. Review the water conservation rules and guidance materials obtained above. You should use these materials to prepare your water conservation plan. It is suggested that you submit a draft plan for review prior to meeting your public notification requirements in case substantive changes to the plan are necessary. Resubmittal of the report to the public entities can be avoided if initial review is performed by the Department.

- C. Complete the form by answering all questions and providing the appropriate attachments. Answer the questions from top to bottom, unless instructed to skip to another section. Helpful information and reminders are provided throughout the form and are printed in *italics*.

- D. Before submitting, review the form to ensure all questions are answered and all attachments are included. When complete submit to:

Water Conservation Plans
Small Community Well Siting Program
Water Supply Engineering Bureau
29 Hazen Drive, Post Office Box 95
Concord, NH 03302 -0095

For help with this form or other water conservation planning concerns call Diana Morgan at (603) 271-2947.

*Information contained in this form is current as of October 2005. Statutory or regulatory changes that may occur after October 2005 may cause part or all of the information to be invalid. If there are any questions concerning the status of the information please contact DES at (603) 271-2947.

Section 1.0 GENERAL INFORMATION

WELL SITING:

Has a Preliminary Well Siting report been submitted to the Department? *(If your answer is NO, please contact the Department at 603-271-2947 before you proceed further.)*

YES NO

(The section below asks you to identify the people and companies responsible for the water conservation plan application. This information will help ensure clear communication during the application process.)

1.1 Project Contacts / System Ownership

1.1a Project Contact: *(Person completing this form?)*

Name: **Neil W. Helberg**
Address: 44 Stark Lane, Litchfield, NH 03052
Company: **Lewis Engineering, PLLC**
Phone Number: 603-886-4985

1.1b Project Owner: *(Who is responsible for compliance with the water conservation plan, as approved by the Department?)*

Name: **Mark Mooney**
Address: 100 Diamond Place, Laconia, NH 03246
Company: **Lakeland Management Company**
Phone Number: 603-527-1140 603-267-6529

1.1c Person responsible for completing the activities outlined in this plan: *(Please note that the person completing water conservation plan activities must be a certified water system operator or water system personnel supervised by the certified operator.)*

Name: **Wade Crawshaw**
Address: P.O. Box 7394 , Guilford, NH 03247
Company: **C & C Water Services Inc**
Phone Number: 603-293-8580

1.1d Will ownership of the water system be transferred at a future date from the person listed in 1.1b to a Homeowner's Association or other entity?

YES ___ NO ___

If **YES**, indicate below the contact information for the new owner of the water system.

Name:
Address: **N/A**
Company:
Phone Number:

Section 2.0 Metering & Leak Detection

(This information is needed to help ensure the water conservation plan will meet the intended purpose and that the plan is designed appropriately.)

2.1 Water System *(All systems must complete Sections 3.0-6.0)*

Is this a new water system? YES ___ NO (If YES, go to Sections 2.2, 2.3d and 2.3e)

Is this a new source for an existing water system? YES NO ___ (If YES, go to Section 2.3)

2.2 Metering of New Small Community Water Systems

(Meters must be installed on all sources of water and at each service connection on new small community water systems.)

2.2a Describe below the size of both the source and service connection meters to be utilized by the water system. *(In selecting, installing, and maintaining water meters, the water system must comply with procedures and protocols described in "Manual of Water Supply Practices, Water Meters", document AWWA M6, available from the American Water Works Association.)*

2.2b Describe below the frequency in which each type of meter will be read. *(Source meters must be read at least every 30 days and service meters must be read at least every 90 days.)*

2.2c Estimating Unaccounted-For Water

Describe below how the water system will estimate the volume and percentage of unaccounted-for water. Also note how often the water system proposes estimating unaccounted-for water. *(All new small community water systems and all existing small community water systems opting for metering and water accounting, or existing small community systems that are adding new connections, must meet this requirement. Estimates of unaccounted-for water must be performed at least once a year. If unaccounted-for water exceeds 15%, the system shall develop a response plan in accordance with Env-Ws 390.05(j) and (k), and submit it to the Department within 60 days.)*

2.3 Metering of Existing Small Community Water Systems

(If no further expansion of an existing small community water system is planned the water system may either install meters on all service connections within 3 years of approval of the plan and estimate unaccounted-for water [see section 2.3d], or the system may opt to conduct a comprehensive leak detection survey every 2 years and repair all leaks identified by the survey [See section 2.3e]. If further expansion of the system is proposed, meters must be installed on all new services, regardless of whether the system opts to conduct a leak detection audit rather than metering. Meters are also required on all sources of water for existing small community water systems.)

2.3a Is your system choosing to install meters on your existing system to track unaccounted-for water or is your system adding new service connections to your existing system?

YES NO Meters are installed at all water customers

If **YES**, your system must estimate unaccounted-for water annually, go to sections 2.3b, 2.3c and 2.3d. If you answered **NO**, your system must perform a leak detection survey every 2 years, go to section 2.3e.

2.3b Describe below the size of both the source and service connection meters to be utilized by the water system. *(In selecting, installing, and maintaining water meters, the water system must comply with procedures and protocols described in "Manual of Water Supply Practices, Water Meters", document AWWA M6, available from the American Water Works Association.)*

Lakeland Management Company, and C&C Water Services, Inc. follow the above AWWA procedures and protocols in the installation and maintenance of water meters.

2.3c Describe below the frequency in which each type of meter will be read. *(Source meters must be read at least every 30 days and service meters must be read at least every 90 days.)*

Source meters (well meters and pump station discharge meter) are read at least 5 days per week. Service meters are read quarterly.

2.3d Estimating Unaccounted-For Water

Describe below how the water system will estimate the volume and percentage of unaccounted-for water. Also note how often the water system proposes estimating unaccounted-for water. *(All new small community water systems and all existing small community water systems opting for metering and water accounting, or existing small community systems that are adding new connections, must meet this requirement. Estimates of unaccounted-for water must be performed at least once a year. If unaccounted-for water exceeds 15%, the system shall develop a response plan in accordance with Env-Ws 390.05(j) and (k), and submit it to the Department within 60 days.)*

C&C Water Services, Inc. will calculate the percentage of unaccounted- for-water percentage at least twice a year. Unaccounted- for- water is the difference between the total water pumped from the pump station, and the customer metered usage. One calculation will be during a winter month and the other during the month of May, June, July or August. If the percentage of unaccounted- for-water vs. pumped water exceeds 15%; C&C Water Services, Inc. will develop a response plan (with a leak detection survey) to be submitted to the NHDES WSEB within 60 days.

2.3e Water Audit and Leak Detection Program

Describe below who will be responsible for conducting a leak detection survey, the frequency of the surveys and a brief text description of how those surveys will be conducted. *(Surveys for existing systems that are opting out of metering service connections shall be performed at least every two years. Leaks identified by the survey must be repaired within at least 60 days unless a waiver is obtained from the Department. The requirements of this section of the rule must follow the standards set forth in AWWA M36, "Manual of Water Supply Practices, Water Audits and Leak Detection", available from the American Water Works Association .)*

N/A

Section 3.0 Pressure Reduction

(Pressure reduction shall be implemented upon obtaining approval of a new source of water when it is technically feasible, consistent with industry standards, and consistent with public health and safety considerations. Existing small community water systems have one year after approval of the conservation plan to implement this requirement, if feasible. All pressure reduction measures must meet the requirements of Env-Ws 372, Design Standards for Small Community Public Water Systems.)

Is pressure reduction possible for this system? If **YES**, explain below how it will be accomplished for the system. If **NO**, explain why below.

YES ___ NO ___ **X** ___

Well water is presently pumped from the pump house to the water storage tank. Pressure leaving the pump house is 150+/- psi. The pressure at the highest buildings is in the range of 20 to 35 +/- psi. The lowest building with the highest pressure is the pump house at the existing gravel well. The pressure leaving the new pump house will be adjustable using the booster pump controller.

Section 4.0 Conservation Rate Structure

(Unless a small community water system is owned by a landlord who supplies water only to tenants and includes water service in a rental fee, all new small community water systems must adopt a rate structure, and existing systems that either add new service connections or choose to meter existing service connections as part of leak monitoring must adopt a rate structure , as described in Env-Ws 390.04 & .05.)

4.1 Is this system owned by a landlord who supplies water only to tenants and includes water service in a rental fee? If **YES**, go to section 5.0; if **NO**, go to section 4.2.

YES ___ NO ___ **X** ___

4.2 Describe below the conservation rate structure the water system proposes adopting, or if not practical or feasible for the system, describe below how the water system will manage water service fees to meet the intent of the rule and promote water conservation. (You will need to fill out a waiver application form found at the end of this document.)

Lakeland Management Company, Inc. Utility Water Rates

NHPUC No. Water
Lakeland Management Co., Inc.
(Water Utility Division)

Third Revised Page 10
Issued in lieu of Second
REVISED PAGE 10

RATE SCHEDULE

Availability: This schedule is applicable to all metered water service in the franchised territory.

Character of Service: Water is obtained from two wells at a present total pumping capacity of approximately 86,400 gallons/day and at approximately 70 pounds of pressure. Water service is available to customers whose premises abut any public street, road or right of way in which the Company has water mains, provided, however, that water service shall only be rendered pursuant to the rules and regulations prescribed in other sections of this tariff.

Customer Classes: Rates - Quarterly

| | | |
|---------------------------|--|--------------------------|
| Commercial: | | |
| Class A (Telephone co.) | | \$833.00 + 12.1873 p/cuf |
| Class B | | \$278.00 + 4.2729 p/cuf |
| Residential: | | |
| Orchard Hill I | | \$ 62.00 + 3.4617 p/cuf |
| Orchard Hill II | | \$ 62.00 + 3.4617 p/cuf |
| Granite Ridge Condominium | | \$ 62.00 + 3.4617 p/cuf |
| Other | | \$ 62.00 + 3.4617 p/cuf |

Surcharge: In accordance with the NHPUC Order, the existing surcharge of \$3.65 per customer per quarter should be continued beginning at the end of the existing surcharge from a prior proceeding until the amount of \$3,057.00 is recovered.

Terms of payment: Bills under these rates will be rendered quarterly and are due and payable upon presentation. If payment is not made within 30 days from the postmarked date, disconnect action may be taken in accordance with NHPUC regulations.

Issued: October 18, 1996. Issued By: Ruth P. Mooney
Effective: July 1, 1996. Title: President

Authorized by NHPUC Order #22,212 Dated September 10, 1996 in Docket No. DK 96-002.

The standard residential customer charge is \$62.00/quarter.

The quarterly volumetric charge is:

**\$3.4617 per 100 Cubic Feet
100 Cubic Feet = 748 gallons**

Section 5.0 Public Notification

(Within 7 days of submitting the final water conservation plan for review by the Department a small community water system must provide a copy of this report via certified mail to the governing board of the municipality in which a proposed source is located, to all wholesale customers [if any], and to the regional planning commission for the location of the proposed source. The water system shall supply the governing boards with a copy of a summary of the requirements of Env-Ws 390. This document can be found on the website noted at the beginning of this form. You must also note in your correspondence to the above-mentioned governing boards that a copy of the Well Siting Application is available for their review at the Department and provide them with Department contact information. The water system shall request that the governing boards amend any site plan submitted to them for review so that it reflects the requirements of Env-Ws 390 and promotes water conservation landscaping principals.)

List the names and addresses of the governing boards receiving public notification. Attach a copy of the cover letter sent to the governing boards and a copy of the certified mail receipts when available. List the educational/outreach materials that the system is providing to the municipalities for review.

| | |
|---|--|
| K. Jeanne Beaudin Town Administrator Town of Belmont P.O. Box 310, Belmont, NH 03220-0310 | Ms. Kimon Koulet Executive Director Lakes Region Planning Commission 103 Main Street, Suite 3 Meredith, NH 03253 |
|---|--|

Section 6.0 Educational Outreach Initiative

(Such an initiative may be achieved in many ways, but must be implemented immediately upon approval of the conservation plan and should include the pertinent water efficiency fact sheets that can be found at the website listed at the beginning of this report. These educational mailings can be included with wellhead protection program educational mailings as required by Env-Ws 378.18 or with the water system service bills. Other acceptable outreach initiatives include water system or homeowner's association newsletters, posting of water conservation fact sheets in public areas used by water system customers, or any other initiative that meets the intent of the rules.)


Provide a brief description of your educational outreach initiative. Include implementation procedures, the person responsible for the initiative, the content of educational mailings proposed (if any), and the wording of any newsletter insertions or public postings. *(There is no need to provide copies of educational outreach materials that you are acquiring from the Department website. Only provide copies of educational outreach materials generated by the water system.)*

Educational Outreach fact sheets will be distributed yearly with the Consumer Confidence Report or with monthly water bills. Educational outreach materials will be obtained from AWWA or NHDES WSEB.

Before submitting, thoroughly check this form to be sure all applicable questions are answered, all information is provided, and all necessary attachments are included. Incomplete submittals will significantly slow the approval process.

If strict compliance with any of the requirements of Env-Ws 390 is not feasible, the small community water system may apply for a waiver to a specific portion of the rule. A waiver application form is provided at the end of this document for your convenience.

Preparer's Signature: _____



Date: _____



As a reminder, have you included the following?

- Educational outreach initiative documentation and materials created by the water system.
- Public notification documentation (certified mail receipts).
- Public notification cover letters and pertinent documents.
- Other pertinent or supportive materials.