

Wetlands Applications Decision Report

Decisions Taken
05/25/2020 to 05/31/2020

DISCLAIMER:

This document is published for information purposes only and does not constitute an authorization to conduct work. Work in jurisdiction may not commence until the applicant has received a posting permit.

Decisions are subject to appeal, and are reviewed by the federal agencies for compliance with Section 404 of the Federal Clean Water Act.

APPEAL:

Any party aggrieved by a decision may file an appeal within 30 days of the date of this decision as specified in RSA 482-A:10, RSA 21-O:14, and the rules adopted by the Wetlands Council, Env-WtC 100-200.

The appeal must be filed directly with the Council, c/o the Council Appeals Clerk, who may be contacted at (603) 271-6072 or atappeals@des.nh.gov. The notice of appeal must set forth fully every ground upon which it is claimed that the decision complained of is unlawful or unreasonable. Only those grounds set forth in the notice of appeal can be considered by the council.

05/25/2020 to 05/31/2020

PERMIT CATEGORY: MAJOR IMPACT PROJECT

2020-00775 OWNER: PAUGUS BAY VIEW CONDO ASSOC

CITY: LACONIA WATERBODY: LAKE WINNIPESAUKEE

Requested Action:

Impact 865 square feet along 73 linear feet of bank in order to replace an existing concrete patio with a pervious patio, replace an existing deck with a 150 square foot perched beach with 4 foot wide steps to the water and replace an existing concrete retaining wall with a pre-cast block wall along 80 linear feet of frontage on Lake Winnepesaukee in Laconia.

APPROVE PERMIT

Impact 865 square feet along 73 linear feet of bank in order to replace an existing concrete patio with a pervious patio, replace an existing deck with a 150 square foot perched beach with 4 foot wide steps to the water and replace an existing concrete retaining wall with a pre-cast block wall along 80 linear feet of frontage on Lake Winnepesaukee in Laconia.

With Conditions:

All work shall be in accordance with plans by Terrain Planning & Design, LLC., dated March 9, 2020 and as received by the NH Department of Environmental Services (NHDES) on April 17, 2020 as required pursuant to Env-Wt 307.16.

No more than 10 cubic yards of sand shall be used and all sand shall be located above the normal high water line in accordance with Env-Wt 511.06(a)(3).

Steps for access to and from a water access structures shall not exceed 6 feet in width and shall be constructed or installed such that all portions of the steps are landward of the normal high, in accordance with Env-Wt 511.04(f).

Revegetation of the disturbed area by planting trees, shrubs, and ground covers shall represent the density and species diversity of the existing stand of vegetation removed for the project; and begin at a distance no greater than 5 feet landward from the water access structures footprint, in accordance with Env-Wt 511.05(b).

All portions of the proposed deck shall be sloped away from any adjacent surface water in accordance with 511.04(e).

Repair of the existing retaining wall shall result in no change in height, length, location, or configuration in accordance with 514.07(a).

All development activities associated with any project shall be conducted in compliance with applicable requirements of RSA 483-B and Env-Wq 1400 during and after construction as required pursuant to RSA 483-B:3.

Pursuant to RSA 483-B:9.V, (a)(2)(d)(v), this permit does not authorize the removal of trees or saplings within the waterfront buffer that would result in a tree and sapling point score below the minimum required per RSA 483-B:9, V, (a)(2)(D)(iv).

Work shall be carried out in a time and manner such that there are no discharges in or to fish or shellfish spawning or nursery areas during spawning seasons as required pursuant to Env-Wt 307.04. Impacts to such areas shall be avoided or minimized to the maximum extent practicable during all other times of the year.

Work shall be carried out in a time and manner to avoid disturbances to migratory waterfowl breeding and nesting areas as required pursuant to Env-Wt 307.04. Impacts to such areas shall be avoided or minimized to the maximum extent practicable during all other times of the year.

Water quality control measures capable of minimizing erosion; collecting sediment and suspended and floating materials; and filtering fine sediment shall be selected and implemented as appropriate based on the size and nature of the project and the physical characteristics of the site, including slope, soil type, vegetative cover, and proximity to jurisdictional areas as required pursuant to Env-Wt 307.03(c).

Water quality control measures shall be installed prior to start of work and in accordance with the manufacturer's recommended specifications or, if none, the applicable requirements of Env-Wq 1506 or Env-Wq 1508, shall be maintained so as to ensure continued effectiveness in minimizing erosion and retaining sediment on-site during and after construction, and removed upon completion of work and the effective stabilization of disturbed surfaces as required pursuant to Env-Wt 307.03(c).

Work authorized shall be carried out in accordance with Env-Wt 307 such that appropriate turbidity controls are in place to protect water quality, that no turbidity escapes the immediate dredge area, and that appropriate turbidity controls shall remain until suspended particles have settled and water at the work site has returned to normal clarity.

All dredged and excavated material and construction-related debris shall be placed outside of those areas subject to RSA 482-A or RSA-483-B unless a permit for the deposition of materials within those areas has been obtained as required per

05/25/2020 to 05/31/2020

RSA 482-A:3 or RSA 483-B:5-b respectively.

No activity shall be conducted in such a way as to cause or contribute to any violation of surface water quality standards specified in RSA 485-A:8 or Env-Wq 1700; ambient groundwater quality standards established under RSA 485-C; limitations on activities in a sanitary protective area established under Env-Dw 302.10 or Env-Dw 305.10; or any provision of RSA 485-A, Env-Wq 1000, RSA 483-B, or Env-Wq 1400 that protects water quality as required pursuant to Env-Wt 307.03(a). Pursuant to RSA 482-A:14, RSA 482-A:14-b, and RSA 482-A:14-c, NHDES is authorized to take appropriate compliance actions should it be determined that, based upon additional information which becomes available, any of the structures depicted as "existing" on the plans submitted by or on behalf of the permittee were not previously permitted or grandfathered.

With Findings:

The project is classified as a major impact per Rule Env-Wt 511.06(d), the aggregate area impacted by water access structures exceeds 500 SF.

The Department finds that the project as proposed and conditioned meets the requirements of RSA 482-A and the Wetlands Program Code of Administrative Rules Chapters Env-Wt 100 - 900. No waivers of RSA 482-A or the Wetlands Program Code of Administrative Rules Chapters Env-Wt 100 - 900 were requested or approved under this permit action.

PERMIT CATEGORY: MINOR IMPACT PROJECT

2019-01528 OWNER: LANDING BOAT CLUB

CITY: NEWBURY WATERBODY: SUNAPEE LAKE

Requested Action:

Remove two fender pilings and replace them with two ice protection clusters on 77.3 feet frontage along Sunapee Lake in Newbury.

APPROVE PERMIT

Remove two fender pilings and replace them with two ice protection clusters on 77.3 feet frontage along Sunapee Lake in Newbury.

With Conditions:

All work shall be in accordance with revised plans by Watermark Marine Construction revision dated May 9, 2020. This permit is not valid and effective until it has been recorded with the appropriate county Registry of Deeds by the applicant. Prior to starting work under this permit, the permittee shall submit a copy of the recorded permit to the DES Wetlands Program by certified mail, return receipt requested.

All development activities associated with this project shall be conducted in compliance with applicable requirements of RSA 483-B and N.H. Code of Administrative Rules Env-Wq 1400 during and after construction.

Work shall be carried out in a time and manner to avoid disturbances to migratory waterfowl breeding and nesting areas. Appropriate turbidity controls shall be installed prior to construction, shall be maintained during construction such that no turbidity escapes the immediate dredge area and shall remain until suspended particles have settled and water at the work site has returned to normal clarity.

All construction-related debris shall be placed outside of the areas subject to RSA 482-A. Any spoil material deposited within 250 feet of any surface water shall comply with RSA-483-B.

Only those structures shown on the approved plans shall be installed or constructed along this frontage.

This permit shall not preclude NHDES from initiating appropriate action if NHDES later determines that any of the structures depicted as "existing" on the plans submitted by or on behalf of the permittee were not previously permitted or grandfathered.

With Findings:

This is a minor impact project per Administrative Rule Env-Wt 303.03(m), installation of ice clusters which do not, by their presence, add boat slips to an existing docking system.

The applicant has provided evidence which demonstrates that this proposal is the alternative with the least adverse impact to areas and environments under the department's jurisdiction per Env-Wt 302.03. The applicant has demonstrated by plan and example that each factor listed in Env-Wt 302.04(a) Requirements for Application Evaluation, has been considered in the design of the project. The installation of ice cluster shall not provide by their presence, add boat slips to an existing docking system. This application was filed and deemed complete prior to December 15, 2019, and therefore, was reviewed for compliance with Administrative Rules Chapters Env-Wt 100 - 900 in effect on the date of filing.

2020-00722 OWNER: PRESCOTT, GAIL/GREGG

CITY: STODDARD WATERBODY: HIGHLAND LAKE

Requested Action:

Impact 450 square feet of bank along 19.2 linear feet of shoreline to construct a 18 foot x 16 foot square shaped perched beach on an average of 97 feet of frontage along Highland Lake in Stoddard.

APPROVE PERMIT

Impact 450 square feet of bank along 19.2 linear feet of shoreline to construct a 18 foot x 16 foot square shaped perched beach on an average of 97 feet of frontage along Highland Lake in Stoddard.

With Conditions:

All work shall be in accordance with plans by Donald R. Scott, RLA., dated March 9, 2020 and as received by the NH Department of Environmental Services (NHDES) on April 8, 2020 as required pursuant to Env-Wt 307.16. No more than 20 cubic yards of sand shall be used and all sand shall be located above the normal high water line in accordance with Env-Wt 511.06(b)(1). Steps for access to and from a water access structures shall not exceed 6 feet in width and shall be constructed or installed such that all portions of the steps are landward of the normal high, in accordance with Env-Wt 511.04(f). Revegetation of the disturbed area by planting trees, shrubs, and ground covers shall represent the density and species diversity of the existing stand of vegetation removed for the project; and begin at a distance no greater than 5 feet landward from the water access structures footprint, in accordance with Env-Wt 511.05(b). All development activities associated with any project shall be conducted in compliance with applicable requirements of RSA 483-B and Env-Wq 1400 during and after construction as required pursuant to RSA 483-B:3. Pursuant to RSA 483-B:9,V, (a)(2)(d)(v), this permit does not authorize the removal of trees or saplings within the waterfront buffer that would result in a tree and sapling point score below the minimum required per RSA 483-B:9, V, (a)(2)(D)(iv). Work shall be carried out in a time and manner such that there are no discharges in or to fish or shellfish spawning or nursery areas during spawning seasons as required pursuant to Env-Wt 307.04. Impacts to such areas shall be avoided or minimized to the maximum extent practicable during all other times of the year. Work shall be carried out in a time and manner to avoid disturbances to migratory waterfowl breeding and nesting areas as required pursuant to Env-Wt 307.04. Impacts to such areas shall be avoided or minimized to the maximum extent practicable during all other times of the year. Water quality control measures capable of minimizing erosion; collecting sediment and suspended and floating materials; and filtering fine sediment shall be selected and implemented as appropriate based on the size and nature of the project and the physical characteristics of the site, including slope, soil type, vegetative cover, and proximity to jurisdictional areas as required pursuant to Env-Wt 307.03(c). Water quality control measures shall be installed prior to start of work and in accordance with the manufacturer's recommended specifications or, if none, the applicable requirements of Env-Wq 1506 or Env-Wq 1508, shall be maintained so as to ensure continued effectiveness in minimizing erosion and retaining sediment on-site during and after construction, and removed upon completion of work and the effective stabilization of disturbed surfaces as required pursuant to Env-Wt 307.03(c). Work authorized shall be carried out in accordance with Env-Wt 307 such that appropriate turbidity controls are in place to protect water quality, that no turbidity escapes the immediate dredge area, and that appropriate turbidity controls shall remain until suspended particles have settled and water at the work site has returned to normal clarity.

05/25/2020 to 05/31/2020

All dredged and excavated material and construction-related debris shall be placed outside of those areas subject to RSA 482-A or RSA-483-B unless a permit for the deposition of materials within those areas has been obtained as required per RSA 482-A:3 or RSA 483-B:5-b respectively.

No activity shall be conducted in such a way as to cause or contribute to any violation of surface water quality standards specified in RSA 485-A:8 or Env-Wq 1700; ambient groundwater quality standards established under RSA 485-C; limitations on activities in a sanitary protective area established under Env-Dw 302.10 or Env-Dw 305.10; or any provision of RSA 485-A, Env-Wq 1000, RSA 483-B, or Env-Wq 1400 that protects water quality as required pursuant to Env-Wt 307.03(a). Pursuant to RSA 482-A:14, RSA 482-A:14-b, and RSA 482-A:14-c, NHDES is authorized to take appropriate compliance actions should it be determined that, based upon additional information which becomes available, any of the structures depicted as "existing" on the plans submitted by or on behalf of the permittee were not previously permitted or grandfathered.

With Findings:

The project is classified as a minor impact per Rule Env-Wt 511.06(b), the aggregate area impacted by water access structures shall not exceed 500 SF.

The Department finds that the project as proposed and conditioned meets the requirements of RSA 482-A and the Wetlands Program Code of Administrative Rules Chapters Env-Wt 100 - 900. No waivers of RSA 482-A or the Wetlands Program Code of Administrative Rules Chapters Env-Wt 100 - 900 were requested or approved under this permit action.

PERMIT CATEGORY: MINIMUM IMPACT PROJECT

2014-03561 OWNER: BAY REACH REALTY GROUP LLC

CITY: LACONIA WATERBODY: LAKE WINNIPESAUKEE

Requested Action:

Request permit time extension to construct 37 linear ft. of stone retaining wall and 6 ft. wide stone steps to perch an existing beach and replenish 900 sq. ft. of beach with sand on an average of 427 ft. of frontage along Lake Winnepesaukee in Laconia.

Conservation Commission/Staff Comments:

1/9/15 Con Com has comments and recommendations. See letter in file.

APPROVE TIME EXTENSION

Construct 37 linear ft. of stone retaining wall and 6 ft. wide stone steps to perch an existing beach and replenish 900 sq. ft. of beach with sand on an average of 427 ft. of frontage along Lake Winnepesaukee in Laconia.

With Conditions:

1. All work shall be in accordance with plans by Watermark Marine Construction dated November 30, 2014, as received by the NH Department of Environmental Services (DES) on December 29, 2014.
2. Appropriate siltation, erosion, and turbidity controls shall be in place prior to construction, shall be maintained during construction, and remain in place until the area is stabilized. Silt fence(s) must be removed once the area is stabilized.
3. Stone placed along the beach front for the purpose of retaining sand shall be placed above and/or landward of those rocks currently located along the normal high water line (Elevation 504.32). Those rocks existing at the normal high water line shall remain otherwise undisturbed such that the natural shoreline remains identifiable.
4. The steps installed for access to the water shall be located completely landward of the normal high water line.
5. No more than 10 cu. yd. of sand may be used and all sand shall be located above the normal high water line.
6. This permit shall be used only once, and does not allow for annual beach replenishment.
7. The permittee shall provide appropriate diversion of surface water runoff to prevent erosion of beach area.
8. This permit shall not preclude DES from taking any enforcement or revocation action if DES later determines that any of the structures depicted as "existing" on the plans submitted by the applicant were not previously permitted or grandfathered.

05/25/2020 to 05/31/2020

9. All activities shall be in accordance with the Shoreland Water Quality Protection Act, RSA 483-B. The owner is responsible for obtaining any Shoreland Permit that may be required per RSA 483-B, for construction, excavation or fill that will occur within the Protected Shoreland.

With Findings:

1. The owner, authorized agent or applicant certifies that this permit qualifies for a permit extension in accordance with RSA 482-A:3, XIV-a, and Env-Wt 502.01.
2. This permit has been extended in accordance with RSA 482-A:3, XIV-a and Env-Wt 502.01.

2019-03763 OWNER: ZABLOUDIL, RONALD

CITY: NOTTINGHAM WATERBODY: Unnamed Wetland

Requested Action:

Fill a total of 1,535 square feet (SF) of palustrine scrub shrub wetland in three locations within a deeded access to construct stone fords to access 12 acres of woodlot. Wetland restoration of 132 SF of unauthorized wetland impact is addressed under separate cover.

APPROVE PERMIT

Fill a total of 1,535 square feet (SF) of palustrine scrub shrub wetland in three locations within a deeded access to construct stone fords to access 12 acres of woodlot. Wetland restoration of 132 SF of unauthorized wetland impact is addressed under separate cover.

With Conditions:

1. All work shall be in accordance with plans by Landry Surveying, LLC dated November 2019 and revised April 2020 as received by the NH Department of Environmental Services (NHDES) on April 27, 2020.
2. A NH certified wetland scientist shall supervise construction of the work.
3. This permit is contingent upon execution of the NHDES Restoration Plan Approval dated May 26, 2020.
4. Any temporary impact areas shall be restored to original condition upon completion of work and supervised by a NH certified wetland scientist.
5. Any further alteration of areas on this property that are subject to RSA 482-A jurisdiction will require a new application and further permitting.
6. No person undertaking any activity shall cause or contribute to, or allow the activity to cause or contribute to, any violations of the surface water quality standards in RSA 485-A and Env-Wq 1700.
7. Work shall be done during low flow.
8. Appropriate siltation and erosion controls shall be in place prior to construction, shall be maintained during construction, and shall remain until the area is stabilized. Temporary controls shall be removed once the area has been stabilized.
9. The contractor responsible for completion of the work shall use techniques described in the New Hampshire Stormwater Manual, Volume 3, Erosion and Sediment Controls During Construction (December 2008).
10. Extreme precautions shall be taken within riparian areas to prevent unnecessary removal of vegetation during construction. Areas cleared of vegetation must be revegetated with like native species within three days of the completion of the disturbance.
11. Construction equipment shall be inspected daily for leaking fuel, oil, and hydraulic fluid prior to entering surface waters or wetlands or operating in an area where such fluids could reach groundwater, surface waters, or wetlands.
12. The permittee's contractor shall maintain appropriate oil/diesel fuel spill kits on site that are readily accessible at all times during construction, and shall train each operator in the use of the kits.
13. All refueling of equipment shall occur outside of surface waters or wetlands during construction. Machinery shall be staged and refueled in upland areas only.
14. Within three days of final grading or temporary suspension of work in an area that is in or adjacent to wetlands or surface waters, all exposed soil areas shall be stabilized by seeding and mulching during the growing season, or if not within the growing season, by mulching with tackifiers on slopes less than 3:1 or netting and pinning on slopes steeper than 3:1.

With Findings:

1. This is a Minimum Impact Project per Administrative Rule Env-Wt 303.04(f), as it involves impacting less than 3,000 square feet of scrub shrub wetland to allow access to 12 acres of woodlot for cutting firewood.
2. The applicant has provided evidence which demonstrates that this proposal is the alternative with the least adverse impact to areas and environments under the department's jurisdiction per New Hampshire Administrative Rule Env-Wt 302.03.
3. The location of the wetland crossing is based on the original subdivision plan which identified an access easement for the applicant's lot through an abutting lot to the north on Tax Map 46/Lot 5-1.
4. On November 2, 2018, the applicant's agent, West Environmental, Inc., conducted a site inspection with the property owner of Tax Map 46, Lot 5-1 to investigate possible routes for the woods road within the access easement.
5. The access easement language includes the following: "The land herein described as conveyed together with a right to cross and recross over a portion of Lot 5-1 as shown on the above referenced plan...Subdivision Plan, Tax Map 46, Lot 5-2 on Deerfield Road and Stevens Hill Road, Nottingham, NH prepared by Corner Stone Survey Associates, Inc. dated January 2000.
6. The applicant has provided documentation demonstrating that a woods road constructed entirely on applicants property (Lot 5-2) would require approximately 4,950 square of wetland fill which is more than three times greater wetland impact than the current proposal.
7. The woods road has been proposed at the narrowest point of the wetland areas and within an access easement on the abutting lot specifically granted for the purpose of this access, thereby minimizing impacts that would otherwise occur from the applicant's property.
8. In accordance with New Hampshire Administrative Rule Env-Wt 304.04, in correspondence dated February 18, 2020, the abutting land owner (Tax Map 46/Lot 5-1) whose property is located within 20 feet of the project and the access easement was unresponsive to the applicant's repeated efforts to obtain concurrence.
9. In accordance with New Hampshire Administrative Rule Env-Wt 204.02, the applicant has requested that the Department waive New Hampshire Administrative Rule Env-Wt 304.04.
10. In accordance with New Hampshire Administrative Rule Env-Wt 204.05, the waiver request is granted as the project will not have an adverse impact to the environment or natural resources of the state, public health, or public safety, and will not result in an impact on abutting properties that is more significant than that which would result from complying with the rule.
11. The Natural Heritage Bureau report submitted with the application (NHB19-3914) indicates no recorded occurrences for sensitive species near this project area.
12. No further comments or concerns have been received by NHDES from abutters or local governing organizations.
13. The applicant has demonstrated by plan and example that each factor listed in New Hampshire Administrative Rule Env-Wt 302.04(b) Requirements for Application Evaluation, has been considered in the design of the project.

2020-00004 OWNER: D'ALELIO FAMILY IRREVOCABLE TRUST UAD 12-17-12

CITY: SUNAPEE WATERBODY: SUNAPEE LAKE

Requested Action:

Repair an existing 13 foot x 16 foot pier supported by a 12 foot x 10 foot crib and accessed by a 4 foot x 9 foot access walkway on frontage along Sunapee Lake in Sunapee.

APPROVE PERMIT

Repair an existing 13 foot x 16 foot pier supported by a 12 foot x 10 foot crib and accessed by a 4 foot x 9 foot access walkway on frontage along Sunapee Lake in Sunapee.

With Conditions:

All work shall be done in accordance with revised plans by Docks Plus revision dated May 7, 2020 as received by the NH Department of Environmental Services (NHDES) on May 7, 2020 as required pursuant to Env-Wt 307.16. This permit shall not be effective until it has been recorded in the Sullivan County Registry of Deeds and a copy of the

05/25/2020 to 05/31/2020

recorded permit has been provided to the department as required pursuant to RSA 482-A:3, and Env-Wt 314.02. Only those structures shown on the approved plans shall be installed or constructed along this frontage as required per Env-Wt 513.22, (a).

Any subdivision of the property frontage will require removal of a sufficient portion of the docking structures to comply with the dock size and density requirements in effect at the time of the subdivision as required pursuant to Env-Wt 314.02.

Work authorized shall be carried out in accordance with Env-Wt 307 such that appropriate turbidity controls are in place to protect water quality, that no turbidity escapes the immediate dredge area, and that appropriate turbidity controls shall remain until suspended particles have settled and water at the work site has returned to normal clarity.

Water quality control measures capable of minimizing erosion; collecting sediment and suspended and floating materials; and filtering fine sediment shall be selected and implemented as appropriate based on the size and nature of the project and the physical characteristics of the site, including slope, soil type, vegetative cover, and proximity to jurisdictional areas as required pursuant to Env-Wt 307.03(c).

Water quality control measures shall be installed prior to start of work and in accordance with the manufacturer's recommended specifications or, if none, the applicable requirements of Env-Wq 1506 or Env-Wq 1508, shall be maintained so as to ensure continued effectiveness in minimizing erosion and retaining sediment on-site during and after construction, and removed upon completion of work and the effective stabilization of disturbed surfaces as required pursuant to Env-Wt 307.03(c).

No activity shall be conducted in such a way as to cause or contribute to any violation of surface water quality standards specified in RSA 485-A:8 or Env-Wq 1700; ambient groundwater quality standards established under RSA 485-C; limitations on activities in a sanitary protective area established under Env-Dw 302.10 or Env-Dw 305.10; or any provision of RSA 485-A, Env-Wq 1000, RSA 483-B, or Env-Wq 1400 that protects water quality as required pursuant to Env-Wt 307.03(a).

Work shall be carried out in a time and manner such that there are no discharges in or to fish or shellfish spawning or nursery areas during spawning seasons as required pursuant to Env-Wt 307.04. Impacts to such areas shall be avoided or minimized to the maximum extent practicable during all other times of the year.

Work shall be carried out in a time and manner to avoid disturbances to migratory waterfowl breeding and nesting areas as required pursuant to Env-Wt 307.04. Impacts to such areas shall be avoided or minimized to the maximum extent practicable during all other times of the year.

All development activities associated with any project shall be conducted in compliance with applicable requirements of RSA 483-B and Env-Wq 1400 during and after construction as required pursuant to RSA 483-B:3.

No construction, modification, or maintenance activity that is contrary to RSA 482-A:26 shall be conducted.

Owners of permanent docking structures which are not maintained so as to be structurally sound and usable for their intended purpose shall remove those docking structures in accordance with Env-Wt 513.22(c), to prevent hazards to public safety, navigation, and recreation.

Pursuant to RSA 482-A:14, RSA 482-A:14-b, and RSA 482-A:14-c, NHDES is authorized to take appropriate compliance actions should it be determined that, based upon additional information which becomes available, any of the structures depicted as "existing" on the plans submitted by or on behalf of the permittee were not previously permitted or grandfathered.

With Findings:

This is a minimum impact project per Administrative Rule Env-Wt 513.24(a)(2), for the repair or replacement of an existing legal docking structure.

The Department finds that the project as proposed and conditioned meets the requirements of RSA 482-A and the Wetlands Program Code of Administrative Rules Chapters Env-Wt 100 - 900. No waivers of RSA 482-A or the Wetlands Program Code of Administrative Rules Chapters Env-Wt 100 - 900 were requested or approved under this permit action.

2020-00559 OWNER: MARY C CRANE 3/97 REVOCABLE TRUST

CITY: BRIDGEWATER WATERBODY: NEWFOUND LAKE

Requested Action:

Remove an existing seasonal pier, install a 6 foot x 40 foot seasonal pier with a seasonal 6 foot x 8 foot section in a "L" configuration, a single seasonal boatlift and an anchoring pad along an average of 84 feet of frontage on Newfound Lake in Bridgewater.

05/25/2020 to 05/31/2020

APPROVE PERMIT

Remove an existing seasonal pier, install a 6 foot x 40 foot seasonal pier with a seasonal 6 foot x 8 foot section in a "L" configuration, a single seasonal boatlift and an anchoring pad along an average of 84 feet of frontage on Newfound Lake in Bridgewater.

With Conditions:

All work shall be in accordance with revised plans by Walker Magrauth dated March 3, 2020 as received by the NH Department of Environmental Services (NHDES) on March 19, 2020 as required pursuant to Env-Wt 307.16.

This permit shall not be effective until it has been recorded in the Grafton County Registry of Deeds and a copy of the recorded permit has been provided to the department as required pursuant to RSA 482-A:3, and Env-Wt 314.02.

The pre-existing seasonal pier shall be removed from the frontage prior to the installation of the new pier.

Any subdivision of the property frontage will require removal of a sufficient portion of the docking structures to comply with the dock size and density requirements in effect at the time of the subdivision as required to maintain compliance with Env-Wt 314.02 and Env-Wt 513.12.

Only those structures shown on the approved plans shall be installed or constructed along this frontage as required per Env-Wt 513.22, (a).

All portions of the docking structures shall be located at least 20 feet from the abutting property lines and no watercraft shall be secured to the docking facility such that it crosses over the imaginary extension of the property lines over the surface water as required by RSA 482-A:3, XIII.

No portion of the docking structures shall extend more than 40 feet from the shoreline at full lake elevation (Elev. 589.12) pursuant to Env-Wt 513.22, (a).

All seasonal structures, including watercraft lifts, shall be removed for the non-boating season as required per Env-Wt 513.22.

The concrete pad shall be constructed landward of the normal high water line (Elev. 589.12) as required per Env-Wt 513.13, (d).

All development activities associated with any project shall be conducted in compliance with applicable requirements of RSA 483-B and Env-Wq 1400 during and after construction as required pursuant to RSA 483-B:3.

Pursuant to RSA 483-B:9,V, (a)(2)(d)(v), this permit does not authorize the removal of trees or saplings within the waterfront buffer that would result in a tree and sapling point score below the minimum required per RSA 483-B:9, V, (a)(2)(D)(iv).

Water quality control measures capable of minimizing erosion; collecting sediment and suspended and floating materials; and filtering fine sediment shall be selected and implemented as appropriate based on the size and nature of the project and the physical characteristics of the site, including slope, soil type, vegetative cover, and proximity to jurisdictional areas as required pursuant to Env-Wt 307.03(c).

Water quality control measures shall be installed prior to start of work and in accordance with the manufacturer's recommended specifications or, if none, the applicable requirements of Env-Wq 1506 or Env-Wq 1508, shall be maintained so as to ensure continued effectiveness in minimizing erosion and retaining sediment on-site during and after construction, and removed upon completion of work and the effective stabilization of disturbed surfaces as required pursuant to Env-Wt 307.03(c).

Work shall be carried out in a time and manner such that there are no discharges in or to fish or shellfish spawning or nursery areas during spawning seasons as required pursuant to Env-Wt 307.04. Impacts to such areas shall be avoided or minimized to the maximum extent practicable during all other times of the year.

Work shall be carried out in a time and manner to avoid disturbances to migratory waterfowl breeding and nesting areas as required pursuant to Env-Wt 307.04. Impacts to such areas shall be avoided or minimized to the maximum extent practicable during all other times of the year.

No activity shall be conducted in such a way as to cause or contribute to any violation of surface water quality standards specified in RSA 485-A:8 or Env-Wq 1700; ambient groundwater quality standards established under RSA 485-C; limitations on activities in a sanitary protective area established under Env-Dw 302.10 or Env-Dw 305.10; or any provision of RSA 485-A, Env-Wq 1000, RSA 483-B, or Env-Wq 1400 that protects water quality as required pursuant to Env-Wt 307.03(a). Pursuant to RSA 482-A:14, RSA 482-A:14-b, and RSA 482-A:14-c, NHDES is authorized to take appropriate compliance actions should it be determined that, based upon additional information which becomes available, any of the structures depicted as "existing" on the plans submitted by or on behalf of the permittee were not previously permitted or grandfathered.

With Findings:

This is a minimum impact project per Administrative Rule Env-Wt 513.24(a)(1), for the construction of a seasonal pier.

The Department finds that the project as proposed and conditioned meets the requirements of RSA 482-A and the Wetlands Program Code of Administrative Rules Chapters Env-Wt 100 - 900. No waivers of RSA 482-A or the Wetlands Program Code of Administrative Rules Chapters Env-Wt 100 - 900 were requested or approved under this permit action.

PERMIT CATEGORY: X-EXPEDITED MINIMUM

2019-01489 OWNER: APPALACHIAN MTN CLUB

CITY: MEREDITH WATERBODY: LAKE WINNIPESAUKEE

Requested Action:

Applicant request amendment in order to repair an additional two cribs on site.

APPROVE AMENDMENT

Amend file to read: Replace, in kind, 18 dock pile, ice protection clusters and a 6 foot x 5.9 foot, 6 foot x 6 foot, 6 foot x 4 foot cribs on 1,360 linear feet of frontage along Lake Winnepesaukee on Three Mile Island and in accordance with plans submitted by Winnepesaukee Marine Const. plans dated May 9, 2019 and as received by NH Department of Environmental Services (NHDES) on April 30, 2020.

With Conditions:

1. All work shall be in accordance with plans by Winnepesaukee Marine Const. plans dated May 9, 2019 and as received by NH Department of Environmental Services (NHDES) on April 30, 2020.
2. This permit is not valid and effective until it has been recorded with the appropriate county Registry of Deeds by the applicant. Prior to starting work under this permit, the permittee shall submit a copy of the recorded permit to the DES Wetlands Program by certified mail, return receipt requested.
3. All development activities associated with this project shall be conducted in compliance with applicable requirements of RSA 483-B and N.H. Code of Administrative Rules Env-Wq 1400 during and after construction.
4. Work shall be carried out in a time and manner to avoid disturbances to migratory waterfowl breeding and nesting areas.
5. Appropriate turbidity controls shall be installed prior to construction, shall be maintained during construction such that no turbidity escapes the immediate dredge area and shall remain until suspended particles have settled and water at the work site has returned to normal clarity.
6. All construction-related debris shall be placed outside of the areas subject to RSA 482-A.
7. Any subdivision of the property frontage will require removal of a sufficient portion of the docking structures to comply with the dock size and density requirements in effect at the time of the subdivision.
8. Only those structures shown on the approved plans shall be repaired along this frontage.
9. No person undertaking any activity shall cause or contribute to, or allow the activity to cause or contribute to, any violations of the surface water quality standards in RSA 485-A and Env-Wq 1700.
10. This permit shall not preclude NHDES from initiating appropriate action if NHDES later determines that any of the structures depicted as "existing" on the plans submitted by or on behalf of the permittee were not previously permitted or grandfathered.
11. The repairs shall maintain the size, location, and configuration of the pre-existing structures.

With Findings:

1. This project is classified as a minimum impact project per Rule Env-Wt 303.04(v), repair of existing docking structures with no change in size, location or configuration.
2. The applicant has provided evidence which demonstrates that this proposal is the alternative with the least adverse impact to areas and environments under the department's jurisdiction per Env-Wt 302.03.
3. The applicant has demonstrated by plan and example that each factor listed in Env-Wt 302.04(b) Requirements for Application Evaluation, has been considered in the design of the project.

PERMIT CATEGORY: X-PERMIT BY NOTIFICATION

2015-00585 OWNER: GOODWIN, CARI-ANNE/DAVID

CITY: TUFTONBORO WATERBODY: LAKE WINNIPESAUKEE

Requested Action:

Request permit time extension to maintenance, repair, and replacement in-kind of existing docking structures, such as breakwaters, docks, boat houses, or other docking facilities, provided no change in location, configuration, construction type, or dimensions is proposed in accordance with plans dated February 18, 2015.

APPROVE TIME EXTENSION

Maintenance, repair, and replacement in-kind of existing docking structures, such as breakwaters, docks, boat houses, or other docking facilities, provided no change in location, configuration, construction type, or dimensions is proposed in accordance with plans dated February 18, 2015.

With Findings:

- 1.The owner, authorized agent or applicant certifies that this permit qualifies for a permit extension in accordance with RSA 482-A:3, XIV-a, and Env-Wt 502.01.
- 2.This permit has been extended in accordance with RSA 482-A:3, XIV-a and Env-Wt 502.01.

PERMIT CATEGORY: SHORELAND STANDARD

2017-02534 OWNER: VAN SICLEN REVOCABLE TRUST, JOHN

CITY: NEWBURY WATERBODY: SUNAPEE LAKE

Requested Action:

The applicant requests that the permit be amended to allow revisions to approved structure footprints and a new shed attached to the primary structure.

APPROVE AMENDMENT

Amend permit to read: Impact 34,311 square feet of protected shoreland in order to replace an existing residential structure, construct a septic system, patios, pathway, stormwater management system, garage, and driveway.

With Conditions:

- 1. All work shall be in accordance with plans by Horizons Engineering Inc. revised through May 2020 and received by the NH Department of Environmental Services (NHDES) on May 11, 2020.
- 2. Neither the new primary structure nor the proposed septic system may be constructed until the system is approved by the NHDES Subsurface Systems Bureau.
- 3. Orange construction fencing shall be installed at the limits of the temporary impact area as shown on the approved plans prior to the start of work and shall be maintained throughout the project in order to prevent accidental encroachment into areas in which impacts have not been approved.
- 4. No more than 20% of the area of the lot within the protected shoreland shall be covered by impervious surfaces unless additional approval is obtained from NHDES.

05/25/2020 to 05/31/2020

5. Cleared areas within the waterfront buffer legally developed prior to July 1, 2008 may be maintained but not enlarged.
6. Prior to the occupancy of the residential structure the Permittee shall provide documentation, including photos, showing that all impacted area within the waterfront buffer have been restored through stabilization and planting, to the NHDES Wetlands Bureau.
7. All planting areas within the waterfront buffer shall be allowed to revert back to a natural state. The regeneration of ground cover shall not be suppressed by the use of bark mulch or other materials; hay mulch may be used temporarily to establish vegetation.
8. The plantings shall be inspected at the beginning and end of the growing season for a period of 3 years after initial plantings have been completed during which time any failed plantings shall immediately be replaced by the owner of the property.
9. At the completion of the 3 year monitoring period the Owner of the property shall submit a report including photographs of the planted buffer to the Department.
10. Native vegetation within an area of at least 6,007 sq. ft. within the Natural Woodland Buffer located between 50 and 150 ft. landward of the reference line shall be retained in an unaltered state in order to comply with RSA 483-B:9, V, (b), (2).
11. Erosion and siltation control measures shall be installed prior to the start of work, be maintained throughout the project, and remain in place until all disturbed surfaces are stabilized.
12. Erosion and siltation controls shall be appropriate to the size and nature of the project and to the physical characteristics of the site, including slope, soil type, vegetative cover, and proximity to wetlands or surface waters.
13. No person undertaking any activity in the protected shoreland shall cause or contribute to, or allow the activity to cause or contribute to, any violations of the surface water quality standards established in Env-Wq 1700.
14. Any fill used shall be clean sand, gravel, rock, or other suitable material.
15. The proposed stormwater management structures shall be installed and maintained to effectively absorb and infiltrate stormwater.
16. Photographs documenting the construction of the proposed stormwater management structures shall be submitted to the Department prior to any party taking up occupancy of the new residential primary structure.
17. All pervious technologies used shall be installed and maintained to effectively absorb and infiltrate stormwater.
18. Within three days of final grading or temporary suspension of work in an area that is in or adjacent to wetlands or surface waters, all exposed soil areas shall be stabilized by seeding and mulching during the growing season, or if not within the growing season, by mulching with tack or netting and pinning on slopes steeper than 3:1.
19. The individual responsible for completion of the work shall utilize techniques described in the New Hampshire Stormwater Manual, Volume 3, Erosion and Sediment Controls During Construction (December 2008).
20. This permit shall not be interpreted as acceptance or approval of any impact that will occur within wetlands jurisdiction regulated under RSA 482-A including all wetlands, surface waters and their banks, the tidal-buffer zone, and sand dunes. The owner is responsible for maintaining compliance with RSA 482-A and Administrative Rules Env-Wt 100 - 900 and obtaining any Wetland Impact Permit that may be required prior to construction, excavation or fill that will occur within Wetlands jurisdiction.
21. This permit shall not preclude NHDES from taking any enforcement or revocation action if NHDES later determines that any of the structures depicted as "existing" on the plans submitted by the applicant were not previously permitted or grandfathered.

2018-00246 OWNER: BLATCHFORD, KEVIN

CITY: MOULTONBOROUGH WATERBODY: LAKE WINNIPESAUKEE

Requested Action:

The Applicant requests that the permit be amended to reflect the re-alignment of the proposed leach field within the previously approved impact area and the correct 250 foot limit of protected shorelands.

APPROVE AMENDMENT

Impact 3,524 square feet (SF) of protected shoreland in order to install a new leach field and driveway within 250 feet of the shoreline.

05/25/2020 to 05/31/2020

With Conditions:

Amend the conditions to read:

All work shall be in accordance with plans by Varney Engineering LLC dated January 4, 2018 and revised April 24, 2020, as received by the NH Department of Environmental Services (DES) on May 15, 2020.

2. Neither the new primary structure nor the proposed septic system may be constructed until the system is approved by the DES Subsurface Systems Bureau.
3. Orange construction fencing shall be installed at the limits of the temporary impact area as shown on the approved plans prior to the start of work and shall be maintained throughout the project in order to prevent accidental encroachment into areas in which impacts have not been approved.
4. No more than 20% of the area of the lot within the protected shoreland shall be covered by impervious surfaces unless additional approval is obtained from DES.
5. Erosion and siltation control measures shall be installed prior to the start of work, be maintained throughout the project, and remain in place until all disturbed surfaces are stabilized.
6. Erosion and siltation controls shall be appropriate to the size and nature of the project and to the physical characteristics of the site, including slope, soil type, vegetative cover, and proximity to wetlands or surface waters.
7. No person undertaking any activity in the protected shoreland shall cause or contribute to, or allow the activity to cause or contribute to, any violations of the surface water quality standards established in Env-Wq 1700.
8. Any fill used shall be clean sand, gravel, rock, or other suitable material.
9. Within three days of final grading or temporary suspension of work in an area that is in or adjacent to wetlands or surface waters, all exposed soil areas shall be stabilized by seeding and mulching during the growing season, or if not within the growing season, by mulching with tack or netting and pinning on slopes steeper than 3:1.
10. This permit shall not be interpreted as acceptance or approval of any impact that will occur within wetlands jurisdiction regulated under RSA 482-A including all wetlands, surface waters and their banks. The owner is responsible for maintaining compliance with RSA 482-A and Administrative Rules Env-Wt 100 - 900 and obtaining any Wetland Impact Permit that may be required prior to construction, excavation or fill that will occur within Wetlands jurisdiction.
11. This permit shall not preclude DES from taking any enforcement or revocation action if DES later determines that any of the structures depicted as "existing" on the plans submitted by the applicant were not previously permitted or grandfathered.

2019-02626 OWNER: BARKIE, DAVID

CITY: WASHINGTON WATERBODY: ISLAND POND

Requested Action:

Applicant request amendment in order to construct addition to a garage.

APPROVE AMENDMENT

Amend permit to read: Impact 11,100 square feet of protected shoreland in order to construct a primary structure, driveway, walkway, garage, patio and septic system.

With Conditions:

1. All work shall be in accordance with revised plans by A.C.Engineering & Consulting revision dated May 13, 2020 and received by the NH Department of Environmental Services (NHDES) on May 20, 2020.
2. Neither the new primary structure nor the proposed septic system may be constructed until the system is approved by the NHDES Subsurface Systems Bureau.
3. Orange construction fencing shall be installed at the limits of the temporary impact area as shown on the approved plans prior to the start of work and shall be maintained throughout the project in order to prevent accidental encroachment into areas in which impacts have not been approved.
4. No more than 14.8% of the area of the lot within the protected shoreland shall be covered by impervious surfaces unless additional approval is obtained from NHDES.

05/25/2020 to 05/31/2020

5. Native vegetation within an area of at least 2,633 square feet within the Natural Woodland Buffer located between 50 and 150 feet landward of the reference line shall be retained in an unaltered state in order to comply with RSA 483-B:9, V, (b), (2).
6. Erosion and siltation control measures shall be installed prior to the start of work, be maintained throughout the project, and remain in place until all disturbed surfaces are stabilized.
7. Erosion and siltation controls shall be appropriate to the size and nature of the project and to the physical characteristics of the site, including slope, soil type, vegetative cover, and proximity to wetlands or surface waters.
8. No person undertaking any activity in the protected shoreland shall cause or contribute to, or allow the activity to cause or contribute to, any violations of the surface water quality standards established in Env-Wq 1700.
9. Any fill used shall be clean sand, gravel, rock, or other suitable material.
10. All pervious technologies used shall be installed and maintained to effectively absorb and infiltrate stormwater.
11. Within three days of final grading or temporary suspension of work in an area that is in or adjacent to wetlands or surface waters, all exposed soil areas shall be stabilized by seeding and mulching during the growing season, or if not within the growing season, by mulching with tack or netting and pinning on slopes steeper than 3:1.
12. The individual responsible for completion of the work shall utilize techniques described in the New Hampshire Stormwater Manual, Volume 3, Erosion and Sediment Controls During Construction (December 2008).
13. This permit shall not be interpreted as acceptance or approval of any impact that will occur within wetlands jurisdiction regulated under RSA 482-A including all wetlands, surface waters and their banks, the tidal-buffer zone, and sand dunes. The owner is responsible for maintaining compliance with RSA 482-A and Administrative Rules Env-Wt 100 - 900 and obtaining any Wetland Impact Permit that may be required prior to construction, excavation or fill that will occur within Wetlands jurisdiction.
14. This permit shall not preclude NHDES from taking any enforcement or revocation action if NHDES later determines that any of the structures depicted as "existing" on the plans submitted by the applicant were not previously permitted or grandfathered.

2019-03979 OWNER: HIGGINS, MICHAEL

CITY: ALTON WATERBODY: LAKE WINNIPESAUKEE

Requested Action:

Impact 1,556 square feet of protected shoreland in order to construct an open porch onto the nonconforming primary structure with a temporary work access and stormwater management.

APPROVE PERMIT

Impact 1,556 square feet of protected shoreland in order to construct an open porch onto the nonconforming primary structure with a temporary work access and stormwater management.

With Conditions:

All work shall be in accordance with plans by Eckman Engineering LLC dated March 2, 2020 and revised April 4, 2020 as received by the NH Department of Environmental Services (NHDES) on April 9, 2020 pursuant to 483-B:5-b Permit Required; Exemption, I, (a).

Orange construction fencing shall be installed at the limits of the temporary impact area as shown on the approved plans prior to the start of work and shall be maintained throughout the project in order to prevent accidental encroachment into areas in which impacts have not been approved as required per Rule Env-Wq 1406.20, (e).

No more than 37.7% of the area of the lot within the protected shoreland shall be covered by impervious surfaces unless additional approval is obtained from NHDES in order to ensure compliance with RSA 483-B:9, V, (g).

Pursuant to RSA 483-B:9, V, (b), (2), no native vegetation shall be removed from within the Natural Woodland Buffer located between 50 and 150 feet landward of the reference line.

Native vegetation within an area of at least 6,009 square feet within the Woodland Buffer located between 50 and 150 feet landward of the reference line shall be retained as natural woodlands in an unaltered state in order to comply with RSA 483-B:9, V, (b), (2).

Erosion and siltation control measures shall be installed prior to the start of work, be maintained throughout the project, and

05/25/2020 to 05/31/2020

remain in place until all disturbed surfaces are stabilized as required per Rule Env-Wq 1406.20, (a).
 Erosion and siltation controls shall be appropriate to the size and nature of the project and to the physical characteristics of the site, including slope, soil type, vegetative cover, and proximity to wetlands or surface waters as required per Rule Env-Wq 1406.20, (b).
 No person undertaking any activity in the protected shoreland shall cause or contribute to, or allow the activity to cause or contribute to, any violations of the surface water quality standards established in Env-Wq 1700 as required per Rule Env-Wq 1406.20, (c).
 Any fill used shall be clean sand, gravel, rock, or other suitable material as required per Rule Env-Wq 1406.20, (d).
 The proposed infiltration trenching shall be installed and maintained to effectively absorb and infiltrate stormwater in order to ensure compliance with RSA 483-B:9, V, (g).
 Photographs documenting the construction of the proposed infiltration trenching shall be submitted to the Department prior to any party taking up occupancy of the new residential primary structure as required per RSA 483-B:6, II and Rule Env-Wq 1406.15, (c) in order to ensure compliance with RSA 483-B:9, V, (g).
 All pervious technologies used shall be installed and maintained to effectively absorb and infiltrate stormwater as required per RSA 483-B:6, II and Rule Env-Wq 1406.15, (c) in order to ensure compliance with RSA 483-B:9, V, (g).
 Within three days of final grading or temporary suspension of work in an area that is in or adjacent to wetlands or surface waters, all exposed soil areas shall be stabilized by seeding and mulching during the growing season, or if not within the growing season, by mulching with tack or netting and pinning on slopes steeper than 3:1 as required pursuant to RSA 483-B:9, V, (d) Erosion and Siltation, (1).
 The individual responsible for completion of the work shall utilize techniques described in the New Hampshire Stormwater Manual, Volume 3, Erosion and Sediment Controls During Construction (December 2008) as required pursuant to RSA 483-B:9, V, (d) Erosion and Siltation, (1).
 This permit shall not be interpreted as acceptance or approval of any impact that will occur within wetlands jurisdiction regulated under RSA 482-A including all wetlands, surface waters and their banks, the tidal-buffer zone, and sand dunes. The owner is responsible for maintaining compliance with RSA 482-A and Administrative Rules Env-Wt 100 - 900 and obtaining any Wetland Impact Permit that may be required prior to construction, excavation or fill that will occur within Wetlands jurisdiction as required pursuant to RSA 483-B:6, I, (c).
 This permit shall not preclude NHDES from taking any enforcement or revocation action as authorized pursuant to 483-B:5, I, if NHDES later determines that any of the structures depicted as "existing" on the plans submitted by the applicant were not previously permitted or grandfathered.

2020-00095 OWNER: GALLIPEAU, DOUGLAS/VICKI

CITY: ALTON WATERBODY: LAKE WINNIPESAUKEE

Requested Action:

Impact 4,880 square feet of protected shoreland in order to construct a primary structure, a retaining wall, an access path, and walkway, and install a septic system.

APPROVE PERMIT

Impact 4,880 square feet of protected shoreland in order to construct a primary structure, a retaining wall, an access path, and walkway, and install a septic system.

With Conditions:

All work shall be in accordance with plans by Doug G. dated November 12, 2019 and revised as received by the NH Department of Environmental Services (NHDES) on March 10, 2020 with the septic system placement plan design by Varney Engineering LLC dated April 28, 2020 as received NHDES on May 13, 2020 pursuant to 483-B:5-b Permit Required; Exemption, I, (a).
 The proposed septic system shall not be constructed until the system is approved by the NHDES Subsurface Systems Bureau as required pursuant to RSA 483-B:6, I, (c).
 Neither the new primary structure nor the proposed septic system may be constructed until the system is approved by the NHDES Subsurface Systems Bureau as required pursuant to RSA 483-B:6, I, (c).

05/25/2020 to 05/31/2020

Orange construction fencing shall be installed at the limits of the temporary impact area as shown on the approved plans prior to the start of work and shall be maintained throughout the project in order to prevent accidental encroachment into areas in which impacts have not been approved as required per Rule Env-Wq 1406.20, (e).

No more than 5.1% of the area of the lot within the protected shoreland shall be covered by impervious surfaces unless additional approval is obtained from NHDES in order to ensure compliance with RSA 483-B:9, V, (g).

Pursuant to RSA 483-B:9, V, (b), (2), no native vegetation shall be removed from within the Natural Woodland Buffer located between 50 and 150 feet landward of the reference line.

Native vegetation within an area of at least 2,500 square feet within the Woodland Buffer located between 50 and 150 feet landward of the reference line shall be retained as natural woodlands in an unaltered state in order to comply with RSA 483-B:9, V, (b), (2).

Erosion and siltation control measures shall be installed prior to the start of work, be maintained throughout the project, and remain in place until all disturbed surfaces are stabilized as required per Rule Env-Wq 1406.20, (a).

Erosion and siltation controls shall be appropriate to the size and nature of the project and to the physical characteristics of the site, including slope, soil type, vegetative cover, and proximity to wetlands or surface waters as required per Rule Env-Wq 1406.20, (b).

No person undertaking any activity in the protected shoreland shall cause or contribute to, or allow the activity to cause or contribute to, any violations of the surface water quality standards established in Env-Wq 1700 as required per Rule Env-Wq 1406.20, (c).

Any fill used shall be clean sand, gravel, rock, or other suitable material as required per Rule Env-Wq 1406.20, (d).

Within three days of final grading or temporary suspension of work in an area that is in or adjacent to wetlands or surface waters, all exposed soil areas shall be stabilized by seeding and mulching during the growing season, or if not within the growing season, by mulching with tack or netting and pinning on slopes steeper than 3:1 as required pursuant to RSA 483-B:9, V, (d) Erosion and Siltation, (1).

The individual responsible for completion of the work shall utilize techniques described in the New Hampshire Stormwater Manual, Volume 3, Erosion and Sediment Controls During Construction (December 2008) as required pursuant to RSA 483-B:9, V, (d) Erosion and Siltation, (1).

This permit shall not be interpreted as acceptance or approval of any impact that will occur within wetlands jurisdiction regulated under RSA 482-A including all wetlands, surface waters and their banks, the tidal-buffer zone, and sand dunes.

The owner is responsible for maintaining compliance with RSA 482-A and Administrative Rules Env-Wt 100 - 900 and obtaining any Wetland Impact Permit that may be required prior to construction, excavation or fill that will occur within Wetlands jurisdiction as required pursuant to RSA 483-B:6, I, (c).

This permit shall not preclude NHDES from taking any enforcement or revocation action as authorized pursuant to 483-B:5, I, if NHDES later determines that any of the structures depicted as "existing" on the plans submitted by the applicant were not previously permitted or grandfathered.

2020-00331 OWNER: ROGERS, CARIN/NATHAN

CITY: WINDHAM WATERBODY: ROCK POND

Requested Action:

Impact 12,500 square feet of protected shoreland in order to demolish the nonconforming primary structure to construct a nonconforming primary structure with a front walkway, a stepped walkway, a porch, a deck, an attached garage, and stormwater management, construct a shed, construct a driveway, temporary access to well, and install a septic system.

APPROVE PERMIT

Impact 12,500 square feet of protected shoreland in order to demolish the nonconforming primary structure to construct a nonconforming primary structure with a front walkway, a stepped walkway, a porch, a deck, an attached garage, and stormwater management, construct a shed, construct a driveway, temporary access to well, and install a septic system.

With Conditions:

All work shall be in accordance with plans by Benchmark Engineering, Inc. dated October 12, 2019 and revised on May 7, 2020 as received by the NH Department of Environmental Services (NHDES) on May 12, 2020.

05/25/2020 to 05/31/2020

Neither the new primary structure nor the proposed septic system may be constructed until the system is approved by the NHDES Subsurface Systems Bureau.

Orange construction fencing shall be installed at the limits of the temporary impact area as shown on the approved plans prior to the start of work and shall be maintained throughout the project in order to prevent accidental encroachment into areas in which impacts have not been approved.

The area disturbed for temporary access to the well shall have all fill materials for access to the well removed, the area shall be returned to original grade, planted per Env-Wq 1412.03, and allowed to return to an unaltered state.

No more than 29.6% of the area of the lot within the protected shoreland shall be covered by impervious surfaces unless additional approval is obtained from NHDES.

Native vegetation within an area of at least 2,492 square feet within the Woodland Buffer located between 50 and 150 feet landward of the reference line shall be retained in an unaltered state in order to comply with RSA 483-B:9, V, (b), (2).

Erosion and siltation control measures shall be installed prior to the start of work, be maintained throughout the project, and remain in place until all disturbed surfaces are stabilized.

Erosion and siltation controls shall be appropriate to the size and nature of the project and to the physical characteristics of the site, including slope, soil type, vegetative cover, and proximity to wetlands or surface waters.

No person undertaking any activity in the protected shoreland shall cause or contribute to, or allow the activity to cause or contribute to, any violations of the surface water quality standards established in Env-Wq 1700.

Any fill used shall be clean sand, gravel, rock, or other suitable material.

The proposed drip-line trenches shall be installed and maintained to effectively absorb and infiltrate stormwater.

Photographs documenting the construction of the proposed drip-line trenches shall be submitted to the Department prior to any party taking up occupancy of the new residential primary structure.

Within three days of final grading or temporary suspension of work in an area that is in or adjacent to wetlands or surface waters, all exposed soil areas shall be stabilized by seeding and mulching during the growing season, or if not within the growing season, by mulching with tack or netting and pinning on slopes steeper than 3:1.

The individual responsible for completion of the work shall utilize techniques described in the New Hampshire Stormwater Manual, Volume 3, Erosion and Sediment Controls During Construction (December 2008).

This permit shall not be interpreted as acceptance or approval of any impact that will occur within wetlands jurisdiction regulated under RSA 482-A including all wetlands, surface waters and their banks,. The owner is responsible for maintaining compliance with RSA 482-A and Administrative Rules Env-Wt 100 - 900 and obtaining any Wetland Impact Permit that may be required prior to construction, excavation or fill that will occur within Wetlands jurisdiction.

With Findings:

Standards for Approval

1. Pursuant to RSA 483-B:3 Consistency Required, I, state and local permits for work within the protected shorelands shall be issued only when consistent with the policies of RSA 483-B.
2. RSA 483-B:1 Purpose, I-a, states "[t]he general court finds that... A natural woodland buffer, consisting of trees and other vegetation located in areas adjoining public waters, functions to intercept surface runoff, wastewater, subsurface flow, and deeper groundwater flows from upland sources and to remove or minimize the effects of nutrients, sediment, organic matter, pesticides, and other pollutants and to moderate the temperature of the near-shore waters."
3. In accordance with RSA 483-B:2 Minimum Standards Required, III, the development standards provided in, and adopted under, RSA 483-B shall be the minimum standards necessary to protect the public waters of the state of New Hampshire and shall serve to prevent and control water pollution.
4. In accordance with RSA 483-B:2 Minimum Standards Required, IV, the development standards provided in, and adopted under, RSA 483-B shall be the minimum standards necessary to protect fish spawning grounds, aquatic life, and bird and other wildlife habitats.
5. In accordance with RSA 483-B:2 Minimum Standards Required, V, the development standards provided in, and adopted under, RSA 483-B shall be the minimum standards necessary to protect buildings and lands from flooding and accelerated erosion.
6. Pursuant to RSA 483-B:9 Minimum Shoreland Protection Standards, II, (b), within the protected shoreland, primary structures shall be set back behind the primary building line which is 50 feet from the reference line.
7. Pursuant to RSA 483-B:9 V, (a) (2) ((C) No natural ground cover shall be removed except as necessary for a foot path to water and access ways as provided under RSA 483-B:9, V(a)(2)(D), (viii) and (ix), for normal maintenance, to protect the waterfront buffer, cutting those portions that have grown over 3 feet in height for the purpose of providing a view, to provide access to natural areas or shoreline, or as specifically approved by the department, pursuant to RSA 482-A or RSA 483-B.
8. Pursuant to RSA 483-B:9 V, (b) Maintenance of Vegetation within the Woodland Buffer (1) The woodland buffer shall be those protected shorelands within 150 feet of the reference line. The purpose of the woodland buffer shall be to protect the quality of public waters by minimizing erosion, preventing siltation and turbidity, stabilizing soils, preventing excess nutrient and chemical pollution, maintaining natural water temperatures, maintaining a healthy tree canopy and understory, preserving fish and wildlife habitat, and respecting the overall natural condition of the protected shoreland. The first 50 feet of this buffer is designated the waterfront buffer and is subject to the additional requirements of subparagraph (a).

05/25/2020 to 05/31/2020

9. Pursuant to RSA 483-B:9 V, (b) Maintenance of Vegetation within the Woodland Buffer, (2)(A), on a given lot, at least 25 percent of the woodland buffer area located between 50 feet and 150 feet from the reference line shall be maintained as natural woodland.
10. Pursuant to RSA 483-B:9, V, (c) Septic Systems, (2) the minimum required setback for all new leaching portions of new septic systems adjacent to lakes and ponds shall be at least 75 feet from the reference line.
11. Pursuant to RSA 483-B:9, V, (c) Septic Systems, (3) the placement of all septic tanks and leaching portions of septic systems for replacement systems shall comply with the requirements of subparagraph (c)(2), to the maximum extent feasible.
12. Pursuant to RSA 483-B:4, XI-c. "Nonconforming lot of record" means an existing lot which does not conform to the provisions of RSA 483-B.
13. Pursuant to RSA 483-B:4, XI-d. "Nonconforming structure" means a structure that, either individually or when viewed in combination with other structures on the property, does not conform to the provisions of this chapter, including but not limited to the impervious surface limits of RSA 483-B:9, V(g).
14. RSA 483-B:10 Nonconforming Lots of Record, I, provides that present and successive owners of an individual, nonconforming undeveloped lot of record that is located within the protected shoreland may, except when otherwise prohibited by law, construct a single family residential dwelling and appurtenant accessory structures on it, notwithstanding the provisions of RSA 483-B.
15. RSA 483-B:10 Nonconforming Lots of Record, I, further provides that conditions may be imposed on the construction of said single family residential dwelling and appurtenant accessory structures which, in the opinion of the commissioner, more nearly meet the intent of this chapter, while still accommodating the applicant's rights.
16. Pursuant to RSA 483-B:11, Non-Conforming Structures, I, "Except as otherwise prohibited by law or applicable municipal ordinance, nonconforming structures located within the protected shoreland may be repaired, replaced in kind, reconstructed in place, altered, or expanded. Repair, replacement-in kind, or reconstruction in place may alter or remodel the interior design or existing foundation of the nonconforming structure, but shall result in no expansion or relocation of the existing footprint within the waterfront buffer. However, alteration or expansion of a nonconforming structure may expand the existing footprint within the waterfront buffer, provided the structure is not extended closer to the reference line and the proposal or property is made more nearly conforming than the existing structure or the existing conditions of the property. This provision shall not allow for the enclosure, or conversion to living space, of any deck or open porch located between the primary structure and the reference line and within the waterfront buffer."
17. Pursuant to RSA 483-B:11, Non-Conforming Structures, II, "For the purposes of this section, a proposal that is "more nearly conforming" means alteration of the location or size of the existing footprints, or redevelopment of the existing conditions of the property, such that the structures or the property are brought into greater conformity with the design standards of this chapter. Methods for achieving greater conformity include, without limitation, reducing the overall square footage of structural footprints, enhancing stormwater management, adding infiltration areas and landscaping, upgrading wastewater treatment, improving traffic management, or other enhancements that improve wildlife habitat or resource protection."
18. Pursuant to RSA 483-B:11, Non-Conforming Structures, IV, "Under paragraph I, and except as otherwise prohibited by law or applicable municipal ordinance, primary nonconforming structures may be entirely demolished and reconstructed, with continued encroachment into the waterfront buffer, provided the replacement structure is located farther back from the reference line than the preexisting nonconforming structure."

Findings of Fact

1. On February 27, 2020 the Department received an application for 12,500 square feet of impacts to protected shorelands along Rock Pond in Windham in order to demolish the nonconforming primary structure to construct a nonconforming primary structure with a front walkway, a stepped walkway, a porch, a deck, an attached garage, and stormwater management, construct a shed, construct a driveway, temporary access to well, and install a septic system.
2. The property on which the impacts are proposed is identified as Lot# 420 on Windham Tax Map 25-E (the "Property").
3. The existing primary structure is a 35-foot x 34-foot L shaped seasonal residential structure located entirely within the 50-foot primary building setback and thus is considered a non-conforming structure under RSA 483-B.
4. Only 9,967 square feet of the 19,211 square foot lot are located beyond the primary building setback and outside of the waterfront buffer.
5. It is stated on the Shoreland Application Worksheet submitted with the Application that vegetation meeting the definition of natural woodlands remains within 2,492 square feet of the 9,967 square foot area of woodland buffer beyond the waterfront buffer.
6. Any proposed new residential structure on the Property will require the construction of a new septic system.
7. There is minimal space on this lot in which a septic system meeting the 75-foot setback as required per RSA 483-B:9, V, (c), (2), could be constructed.
8. The plans submitted with the Application show that the applicant has appropriately placed the proposed septic system in the location to comply with the requirements of RSA 483-B:9, V, (c), (2), to the maximum extent feasible.

05/25/2020 to 05/31/2020

- 9. The Applicant proposes to construct a new non-conforming 2,900 square foot residential structure with an attached garage in a new footprint, located in part, within the primary building setback.
- 10. The configuration of the Property is such that it is not possible to construct 2,900 square foot residential structure with an attached garage on the Property without encroaching on the 50-foot primary building setback required per RSA 483-B:9, (II), (b).
- 11. The required location of the proposed septic system, in combination with the construction of the new primary structure and driveway will result in the permanent removal of natural woodlands from the woodland buffer leaving only of 2,200 square feet of natural woodlands, after restoration of temporary impacts; 292 square feet less area than normally required to comply with RSA 483-B:9 V, (b), (2)(A).
- 12. The Applicant proposed that the project would meet the requirements of RSA 483-B:11.
- 13. The Department determined that the project could not meet the requirements of RSA 483-B:11.
- 14. The Department found that the proposal should be reviewed in accordance with the provisions of RSA 483-B:10.

Rulings in Support of the Decision

- 1. The project as proposed relocates the primary structure footprint within the waterfront buffer and therefore cannot be considered "repair, replacement-in kind, or reconstruction in place" as allowed under RSA 483-B:11, I.
- 2. The project as proposed completely removes the pre-existing non-conforming structure and therefore cannot be considered alteration or expansion of the pre-existing footprint as allowed under RSA 483-B:11, I.
- 3. Were the applicant to remove the existing primary structure prior to the filing of an application for the construction of a new primary structure the subsequent application would be reviewed as provided for in RSA 483-B:10.
- 4. The Department finds that the restoration of the grading and vegetation within the waterfront buffer as required per Project Specific Condition #4 is the minimum action necessary to meet the purposes of RSA 483-B as identified in RSA 483-B:2, III, IV, and V to mitigate the loss of functionality of the natural woodland buffer as identified in RSA 483-B:1 Purpose, I-a, is necessary to more nearly meet the intent of this chapter while still accommodating the applicant's rights as provided under RSA 483-B:10.

2020-00766 OWNER: SHEEHAN, SALLY

CITY: RYE WATERBODY: ATLANTIC OCEAN

Requested Action:

Impact 1,742 square feet of protected shoreland in order to demolish primary structure with a deck and remove a retaining wall, dog house, and concrete pad to construct a primary structure with a deck, install a pervious patio, expand the driveway, and install a septic system.

APPROVE PERMIT

Impact 1,742 square feet of protected shoreland in order to demolish primary structure with a deck and remove a retaining wall, dog house, and concrete pad to construct a primary structure with a deck, install a pervious patio, expand the driveway, and install a septic system.

With Conditions:

All work shall be in accordance with plans by Civilworks New England dated March 27, 2020 and revised on May 15, 2020 as received by the NH Department of Environmental Services (NHDES) on May 18, 2020 pursuant to 483-B:5-b Permit Required; Exemption, I, (a).

The proposed septic system shall not be constructed until the system is approved by the NHDES Subsurface Systems Bureau as required pursuant to RSA 483-B:6, I, (c).

Neither the new primary structure nor the proposed septic system may be constructed until the system is approved by the NHDES Subsurface Systems Bureau as required pursuant to RSA 483-B:6, I, (c).

Orange construction fencing shall be installed at the limits of the temporary impact area as shown on the approved plans prior to the start of work and shall be maintained throughout the project in order to prevent accidental encroachment into areas in which impacts have not been approved as required per Rule Env-Wq 1406.20, (e).

No additional square footage of the area of the lot within the protected shoreland than currently shown on the proposed plans shall be covered by impervious surfaces unless additional approval is obtained from NHDES in order to ensure compliance

05/25/2020 to 05/31/2020

with RSA 483-B:9, V, (g).

Pursuant to RSA 483-B:9, V, (b), (2), no native vegetation shall be removed from within the Natural Woodland Buffer located between 50 and 150 feet landward of the reference line.

Erosion and siltation control measures shall be installed prior to the start of work, be maintained throughout the project, and remain in place until all disturbed surfaces are stabilized as required per Rule Env-Wq 1406.20, (a).

Erosion and siltation controls shall be appropriate to the size and nature of the project and to the physical characteristics of the site, including slope, soil type, vegetative cover, and proximity to wetlands or surface waters as required per Rule Env-Wq 1406.20, (b).

No person undertaking any activity in the protected shoreland shall cause or contribute to, or allow the activity to cause or contribute to, any violations of the surface water quality standards established in Env-Wq 1700 as required per Rule Env-Wq 1406.20, (c).

Any fill used shall be clean sand, gravel, rock, or other suitable material as required per Rule Env-Wq 1406.20, (d).

All pervious technologies used shall be installed and maintained to effectively absorb and infiltrate stormwater as required per RSA 483-B:6, II and Rule Env-Wq 1406.15, (c) in order to ensure compliance with RSA 483-B:9, V, (g).

Within three days of final grading or temporary suspension of work in an area that is in or adjacent to wetlands or surface waters, all exposed soil areas shall be stabilized by seeding and mulching during the growing season, or if not within the growing season, by mulching with tack or netting and pinning on slopes steeper than 3:1 as required pursuant to RSA 483-B:9, V, (d) Erosion and Siltation, (1).

The individual responsible for completion of the work shall utilize techniques described in the New Hampshire Stormwater Manual, Volume 3, Erosion and Sediment Controls During Construction (December 2008) as required pursuant to RSA 483-B:9, V, (d) Erosion and Siltation, (1).

This permit shall not be interpreted as acceptance or approval of any impact that will occur within wetlands jurisdiction regulated under RSA 482-A including all wetlands, surface waters and their banks, the tidal-buffer zone, and sand dunes.

The owner is responsible for maintaining compliance with RSA 482-A and Administrative Rules Env-Wt 100 - 900 and obtaining any Wetland Impact Permit that may be required prior to construction, excavation or fill that will occur within Wetlands jurisdiction as required pursuant to RSA 483-B:6, I, (c).

This permit shall not preclude NHDES from taking any enforcement or revocation action as authorized pursuant to 483-B:5, I, if NHDES later determines that any of the structures depicted as "existing" on the plans submitted by the applicant were not previously permitted or grandfathered.

2020-00780 OWNER: FARRELL, ADAM

CITY: NASHUA WATERBODY: NASHUA RIVER

Requested Action:

Impact 20,034 square feet of protected shoreland in order to construct a primary structure with a deck and stormwater management, to construct a detached garage and driveway, and install a septic system.

APPROVE PERMIT

Impact 20,034 square feet of protected shoreland in order to construct a primary structure with a deck and stormwater management, to construct a detached garage and driveway, and install a septic system.

With Conditions:

All work shall be in accordance with plans by Meridian Land Services, Inc. dated March 10, 2020 and received by the NH Department of Environmental Services (NHDES) on April 17, 2020 pursuant to 483-B:5-b Permit Required; Exemption, I, (a). Neither the new primary structure nor the proposed septic system may be constructed until the system is approved by the NHDES Subsurface Systems Bureau as required pursuant to RSA 483-B:6, I, (c).

Orange construction fencing shall be installed at the limits of the temporary impact area as shown on the approved plans prior to the start of work and shall be maintained throughout the project in order to prevent accidental encroachment into areas in which impacts have not been approved as required per Rule Env-Wq 1406.20, (e).

No more than 5.6% of the area of the lot within the protected shoreland shall be covered by impervious surfaces unless additional approval is obtained from NHDES in order to ensure compliance with RSA 483-B:9, V, (g).

05/25/2020 to 05/31/2020

Native vegetation within an area of at least 6,125 square feet within the Woodland Buffer located between 50 and 150 feet landward of the reference line shall be retained as natural woodlands in an unaltered state in order to comply with RSA 483-B:9, V, (b), (2).

Erosion and siltation control measures shall be installed prior to the start of work, be maintained throughout the project, and remain in place until all disturbed surfaces are stabilized as required per Rule Env-Wq 1406.20, (a).

Erosion and siltation controls shall be appropriate to the size and nature of the project and to the physical characteristics of the site, including slope, soil type, vegetative cover, and proximity to wetlands or surface waters as required per Rule Env-Wq 1406.20, (b).

No person undertaking any activity in the protected shoreland shall cause or contribute to, or allow the activity to cause or contribute to, any violations of the surface water quality standards established in Env-Wq 1700 as required per Rule Env-Wq 1406.20, (c).

Any fill used shall be clean sand, gravel, rock, or other suitable material as required per Rule Env-Wq 1406.20, (d).

Within three days of final grading or temporary suspension of work in an area that is in or adjacent to wetlands or surface waters, all exposed soil areas shall be stabilized by seeding and mulching during the growing season, or if not within the growing season, by mulching with tack or netting and pinning on slopes steeper than 3:1 as required pursuant to RSA 483-B:9, V, (d) Erosion and Siltation, (1).

The individual responsible for completion of the work shall utilize techniques described in the New Hampshire Stormwater Manual, Volume 3, Erosion and Sediment Controls During Construction (December 2008) as required pursuant to RSA 483-B:9, V, (d) Erosion and Siltation, (1).

This permit shall not be interpreted as acceptance or approval of any impact that will occur within wetlands jurisdiction regulated under RSA 482-A including all wetlands, surface waters and their banks, the tidal-buffer zone, and sand dunes.

The owner is responsible for maintaining compliance with RSA 482-A and Administrative Rules Env-Wt 100 - 900 and obtaining any Wetland Impact Permit that may be required prior to construction, excavation or fill that will occur within Wetlands jurisdiction as required pursuant to RSA 483-B:6, I, (c).

This permit shall not preclude NHDES from taking any enforcement or revocation action as authorized pursuant to 483-B:5, I, if NHDES later determines that any of the structures depicted as "existing" on the plans submitted by the applicant were not previously permitted or grandfathered.

2020-00852 OWNER: PARKER, BARBARA/DANIEL

CITY: MEREDITH WATERBODY: LAKE WINNIPESAUKEE

Requested Action:

Impact 4,060 square feet of protected shoreland in order to remove a graveled parking area, patio and stairs to construct 2 permeable patios, stairs, 2 retaining walls, stormwater management, and a walkway, landscaping, and install a septic system.

APPROVE PERMIT

Impact 4,060 square feet of protected shoreland in order to remove a graveled parking area, patio and stairs to construct 2 permeable patios, stairs, 2 retaining walls, stormwater management, and a walkway, landscaping, and install a septic system.

With Conditions:

All work shall be in accordance with plans by Terrain Planning & Design LLC dated October 9, 2019 and received by the NH Department of Environmental Services (NHDES) on April 27, 2020.

This permit is contingent on approval by the NHDES Subsurface Systems Bureau.

Orange construction fencing shall be installed at the limits of the temporary impact area as shown on the approved plans prior to the start of work and shall be maintained throughout the project in order to prevent accidental encroachment into areas in which impacts have not been approved.

No more than 27.8% of the area of the lot within the protected shoreland shall be covered by impervious surfaces unless additional approval is obtained from NHDES.

Native vegetation within an area of at least 485 square feet within the Woodland Buffer located between 50 and 150 feet landward of the reference line shall be retained in an unaltered state in order to comply with RSA 483-B:9, V, (b), (2).

Erosion and siltation control measures shall be installed prior to the start of work, be maintained throughout the project, and

05/25/2020 to 05/31/2020

remain in place until all disturbed surfaces are stabilized.

Erosion and siltation controls shall be appropriate to the size and nature of the project and to the physical characteristics of the site, including slope, soil type, vegetative cover, and proximity to wetlands or surface waters.

No person undertaking any activity in the protected shoreland shall cause or contribute to, or allow the activity to cause or contribute to, any violations of the surface water quality standards established in Env-Wq 1700.

Any fill used shall be clean sand, gravel, rock, or other suitable material.

The proposed swale and stormwater infiltration area shall be installed and maintained to effectively absorb and infiltrate stormwater.

Photographs documenting the construction of the proposed swale and stormwater infiltration area shall be submitted to the Department within 30 days of the completion of construction.

All pervious technologies used shall be installed and maintained to effectively absorb and infiltrate stormwater.

Within three days of final grading or temporary suspension of work in an area that is in or adjacent to wetlands or surface waters, all exposed soil areas shall be stabilized by seeding and mulching during the growing season, or if not within the growing season, by mulching with tack or netting and pinning on slopes steeper than 3:1.

The individual responsible for completion of the work shall utilize techniques described in the New Hampshire Stormwater Manual, Volume 3, Erosion and Sediment Controls During Construction (December 2008).

This permit shall not be interpreted as acceptance or approval of any impact that will occur within wetlands jurisdiction regulated under RSA 482-A including all wetlands, surface waters and their banks, the tidal-buffer zone, and sand dunes.

The owner is responsible for maintaining compliance with RSA 482-A and Administrative Rules Env-Wt 100 - 900 and obtaining any Wetland Impact Permit that may be required prior to construction, excavation or fill that will occur within Wetlands jurisdiction.

This permit shall not preclude NHDES from taking any enforcement or revocation action if NHDES later determines that any of the structures depicted as "existing" on the plans submitted by the applicant were not previously permitted or grandfathered.

2020-00854 OWNER: TOWN OF BROOKLINE

CITY: BROOKLINE WATERBODY: NISSITISSIT RIVER

Requested Action:

Impact 12,282 Square feet (SF) of protected shoreland in order to construct approximately 2,400 linear feet of bituminous asphalt sidewalk in two segments. The first segment is 2,300 linear feet along South Main Street from the intersection with NH 130 to the Rail Trail including a pedestrian bridge over the Nitissitissit River. The second segment is a pedestrian bridge adjacent to Mason Road over the Nitissitissit River with about 100 linear feet of incidental bituminous asphalt sidewalk to connect into the existing facilities. The project includes the removal of vegetation within a right-of-way.

APPROVE PERMIT

Impact 12,282 Square feet (SF) of protected shoreland in order to construct approximately 2,400 linear feet of bituminous asphalt sidewalk in two segments. The first segment is 2,300 linear feet along South Main Street from the intersection with NH 130 to the Rail Trail including a pedestrian bridge over the Nitissitissit River. The second segment is a pedestrian bridge adjacent to Mason Road over the Nitissitissit River with about 100 linear feet of incidental bituminous asphalt sidewalk to connect into the existing facilities. The project includes the removal of vegetation within a right-of-way.

With Conditions:

All work shall be in accordance with plans by Dubois & King dated April 1, 2020 and received by the NH Department of Environmental Services (NHDES) on April 28, 2020.

Orange construction fencing shall be installed at the limits of the temporary impact area as shown on the approved plans prior to the start of work and shall be maintained throughout the project in order to prevent accidental encroachment into areas in which impacts have not been approved.

No more than 38% of the area of the lot within the protected shoreland shall be covered by impervious surfaces unless additional approval is obtained from NHDES.

Native vegetation within an area of at least 1,163 SF within the Natural Woodland Buffer located between 50 and 150 feet

05/25/2020 to 05/31/2020

landward of the reference line shall be retained in an unaltered state in order to comply with RSA 483-B:9, V, (b), (2). Erosion and siltation control measures shall be installed prior to the start of work, be maintained throughout the project, and remain in place until all disturbed surfaces are stabilized.

Erosion and siltation controls shall be appropriate to the size and nature of the project and to the physical characteristics of the site, including slope, soil type, vegetative cover, and proximity to wetlands or surface waters.

No person undertaking any activity in the protected shoreland shall cause or contribute to, or allow the activity to cause or contribute to, any violations of the surface water quality standards established in Env-Wq 1700.

Any fill used shall be clean sand, gravel, rock, or other suitable material.

Within three days of final grading or temporary suspension of work in an area that is in or adjacent to wetlands or surface waters, all exposed soil areas shall be stabilized by seeding and mulching during the growing season, or if not within the growing season, by mulching with tack or netting and pinning on slopes steeper than 3:1.

The individual responsible for completion of the work shall utilize techniques described in the New Hampshire Stormwater Manual, Volume 3, Erosion and Sediment Controls During Construction (December 2008).

This permit shall not be interpreted as acceptance or approval of any impact that will occur within wetlands jurisdiction regulated under RSA 482-A including all wetlands, surface waters and their banks. The owner is responsible for maintaining compliance with RSA 482-A and Administrative Rules Env-Wt 100 - 900 and obtaining any Wetland Impact Permit that may be required prior to construction, excavation or fill that will occur within Wetlands jurisdiction.

This permit shall not preclude NHDES from taking any enforcement or revocation action if NHDES later determines that any of the structures depicted as "existing" on the plans submitted by the applicant were not previously permitted or grandfathered.

2020-00856 OWNER: STREET, STACIE/STEVEN

CITY: MOULTONBOROUGH WATERBODY: LAKE WINNIPESAUKEE

Requested Action:

Impact, 9,590 square feet of protected shoreland in order to demolish non-conforming primary structure with a deck, a detached garage, and driveway to construct a conforming primary structure with attached garage and patio, and install a septic system.

APPROVE PERMIT

Impact, 9,590 square feet of protected shoreland in order to demolish non-conforming primary structure with a deck, a detached garage, and driveway to construct a conforming primary structure with attached garage and patio, and install a septic system.

With Conditions:

All work shall be in accordance with plans by David M. Dolan dated April 8, 2020 and received by the NH Department of Environmental Services (NHDES) on April 28, 2020.

Neither the new primary structure nor the proposed septic system may be constructed until the system is approved by the NHDES Subsurface Systems Bureau.

Orange construction fencing shall be installed at the limits of the temporary impact area as shown on the approved plans prior to the start of work and shall be maintained throughout the project in order to prevent accidental encroachment into areas in which impacts have not been approved.

No more than 25.7% of the area of the lot within the protected shoreland shall be covered by impervious surfaces unless additional approval is obtained from NHDES.

Native vegetation within an area of at least 990 square feet within the Woodland Buffer located between 50 and 150 feet landward of the reference line shall be retained in an unaltered state in order to comply with RSA 483-B:9, V, (b), (2).

Erosion and siltation control measures shall be installed prior to the start of work, be maintained throughout the project, and remain in place until all disturbed surfaces are stabilized.

Erosion and siltation controls shall be appropriate to the size and nature of the project and to the physical characteristics of the site, including slope, soil type, vegetative cover, and proximity to wetlands or surface waters.

No person undertaking any activity in the protected shoreland shall cause or contribute to, or allow the activity to cause or

05/25/2020 to 05/31/2020

contribute to, any violations of the surface water quality standards established in Env-Wq 1700.

Any fill used shall be clean sand, gravel, rock, or other suitable material.

All pervious technologies used shall be installed and maintained to effectively absorb and infiltrate stormwater.

Within three days of final grading or temporary suspension of work in an area that is in or adjacent to wetlands or surface waters, all exposed soil areas shall be stabilized by seeding and mulching during the growing season, or if not within the growing season, by mulching with tack or netting and pinning on slopes steeper than 3:1.

The individual responsible for completion of the work shall utilize techniques described in the New Hampshire Stormwater Manual, Volume 3, Erosion and Sediment Controls During Construction (December 2008).

This permit shall not be interpreted as acceptance or approval of any impact that will occur within wetlands jurisdiction regulated under RSA 482-A including all wetlands, surface waters and their banks, the tidal-buffer zone, and sand dunes.

The owner is responsible for maintaining compliance with RSA 482-A and Administrative Rules Env-Wt 100 - 900 and obtaining any Wetland Impact Permit that may be required prior to construction, excavation or fill that will occur within Wetlands jurisdiction.

This permit shall not preclude NHDES from taking any enforcement or revocation action if NHDES later determines that any of the structures depicted as "existing" on the plans submitted by the applicant were not previously permitted or grandfathered.

**2020-00860 OWNER:
OWNER: MURPHY, JOSEPH/SUSAN**

CITY: HEBRON WATERBODY: NEWFOUND LAKE

Requested Action:

Impact 1,380 square feet (SF) of protected shoreland in order to install 14 foot x 14 foot second story screen room, deck stairs and stone steps to access the lower patio from the screen room and a farmer's porch on the front of the residence. A portion of the asphalt driveway will be removed and replaced with 206 SF of permeable pavers to decrease the amount of impervious surface on the subject parcel.

APPROVE PERMIT

Impact 1,380 square feet (SF) of protected shoreland in order to install 14 foot x 14 foot second story screen room, deck stairs and stone steps to access the lower patio from the screen room and a farmer's porch on the front of the residence. A portion of the asphalt driveway will be removed and replaced with 206 SF of permeable pavers to decrease the amount of impervious surface on the subject parcel.

With Conditions:

All work shall be in accordance with revised plans by Terrain Planning & Design, LLC dated April 8, 2020 and received by the NH Department of Environmental Services (NHDES) on April 28, 2020.

Orange construction fencing shall be installed at the limits of the temporary impact area as shown on the approved plans prior to the start of work and shall be maintained throughout the project in order to prevent accidental encroachment into areas in which impacts have not been approved.

No more than 29.9% of the area of the lot within the protected shoreland shall be covered by impervious surfaces unless additional approval is obtained from NHDES.

Native vegetation within an area of at least 430 SF within the Natural Woodland Buffer located between 50 and 150 feet landward of the reference line shall be retained in an unaltered state in order to comply with RSA 483-B:9, V, (b), (2).

Erosion and siltation control measures shall be installed prior to the start of work, be maintained throughout the project, and remain in place until all disturbed surfaces are stabilized.

Erosion and siltation controls shall be appropriate to the size and nature of the project and to the physical characteristics of the site, including slope, soil type, vegetative cover, and proximity to wetlands or surface waters.

No person undertaking any activity in the protected shoreland shall cause or contribute to, or allow the activity to cause or contribute to, any violations of the surface water quality standards established in Env-Wq 1700.

Any fill used shall be clean sand, gravel, rock, or other suitable material.

The proposed (stormwater management structures) shall be installed and maintained to effectively absorb and infiltrate stormwater.

05/25/2020 to 05/31/2020

Photographs documenting the construction of the proposed (stormwater management structures) shall be submitted to the Department prior to any party taking up occupancy of the new residential primary structure.

All pervious technologies used shall be installed and maintained to effectively absorb and infiltrate stormwater.

Within three days of final grading or temporary suspension of work in an area that is in or adjacent to wetlands or surface waters, all exposed soil areas shall be stabilized by seeding and mulching during the growing season, or if not within the growing season, by mulching with tack or netting and pinning on slopes steeper than 3:1.

The individual responsible for completion of the work shall utilize techniques described in the New Hampshire Stormwater Manual, Volume 3, Erosion and Sediment Controls During Construction (December 2008).

This permit shall not preclude NHDES from taking any enforcement or revocation action if NHDES later determines that any of the structures depicted as "existing" on the plans submitted by the applicant were not previously permitted or grandfathered.

2020-00875 OWNER: MEDEIROS, JOHN/KAREN

CITY: CENTER BARNSTEAD WATERBODY: LOCKE LAKE

Requested Action:

Impact 4,218 square feet (SF) of protected shoreland in order to remove a multi-tiered deck, construct a 12 foot x 12 foot screen room on lower level of house, expand existing decks, add a new set of stairs walkway, construct retaining and grade areas to a level state, install vegetation, remove a set of wood and gravel stairs and replace with stone steps.

APPROVE PERMIT

Impact 4,218 square feet (SF) of protected shoreland in order to remove a multi-tiered deck, construct a 12 foot x 12 foot screen room on lower level of house, expand existing decks, add a new set of stairs walkway, construct retaining and grade areas to a level state, install vegetation, remove a set of wood and gravel stairs and replace with stone steps.

With Conditions:

All work shall be in accordance with revised plans by Terrain Planning & Design, LLC dated March 26, 2020 and received by the NH Department of Environmental Services (NHDES) on April 28, 2020.

Orange construction fencing shall be installed at the limits of the temporary impact area as shown on the approved plans prior to the start of work and shall be maintained throughout the project in order to prevent accidental encroachment into areas in which impacts have not been approved.

No more than 21.2% of the area of the lot within the protected shoreland shall be covered by impervious surfaces unless additional approval is obtained from NHDES.

Native vegetation within an area of at least 1,375 SF within the Natural Woodland Buffer located between 50 and 150 feet landward of the reference line shall be retained in an unaltered state in order to comply with RSA 483-B:9, V, (b), (2).

Erosion and siltation control measures shall be installed prior to the start of work, be maintained throughout the project, and remain in place until all disturbed surfaces are stabilized.

Erosion and siltation controls shall be appropriate to the size and nature of the project and to the physical characteristics of the site, including slope, soil type, vegetative cover, and proximity to wetlands or surface waters.

No person undertaking any activity in the protected shoreland shall cause or contribute to, or allow the activity to cause or contribute to, any violations of the surface water quality standards established in Env-Wq 1700.

Any fill used shall be clean sand, gravel, rock, or other suitable material.

All pervious technologies used shall be installed and maintained to effectively absorb and infiltrate stormwater.

Within three days of final grading or temporary suspension of work in an area that is in or adjacent to wetlands or surface waters, all exposed soil areas shall be stabilized by seeding and mulching during the growing season, or if not within the growing season, by mulching with tack or netting and pinning on slopes steeper than 3:1.

This permit shall not preclude NHDES from taking any enforcement or revocation action if NHDES later determines that any of the structures depicted as "existing" on the plans submitted by the applicant were not previously permitted or grandfathered.

05/25/2020 to 05/31/2020

2020-00878 OWNER: MORRIS FAMILY TRUST

CITY: WAKEFIELD WATERBODY: GREAT EAST LAKE

Requested Action:

Impact 5,048 square feet of protected shoreland in order to replace and enlarge patio with an infiltration garden, construct garage patio with an infiltration garden, and replace a shed.

APPROVE PERMIT

Impact 5,048 square feet of protected shoreland in order to replace and enlarge patio with an infiltration garden, construct garage patio with an infiltration garden, and replace a shed.

With Conditions:

All work shall be in accordance with plans by Fernstone Associates for the Natural Resources dated March 25, 2020 and received by the NH Department of Environmental Services (NHDES) on April 28, 2020.

Orange construction fencing shall be installed at the limits of the temporary impact area as shown on the approved plans prior to the start of work and shall be maintained throughout the project in order to prevent accidental encroachment into areas in which impacts have not been approved.

No more than 22.9% of the area of the lot within the protected shoreland shall be covered by impervious surfaces unless additional approval is obtained from NHDES.

Native vegetation within an area of at least 5,085 square feet within the Woodland Buffer located between 50 and 150 feet landward of the reference line shall be retained in an unaltered state in order to comply with RSA 483-B:9, V, (b), (2).

Erosion and siltation control measures shall be installed prior to the start of work, be maintained throughout the project, and remain in place until all disturbed surfaces are stabilized.

Erosion and siltation controls shall be appropriate to the size and nature of the project and to the physical characteristics of the site, including slope, soil type, vegetative cover, and proximity to wetlands or surface waters.

No person undertaking any activity in the protected shoreland shall cause or contribute to, or allow the activity to cause or contribute to, any violations of the surface water quality standards established in Env-Wq 1700.

Any fill used shall be clean sand, gravel, rock, or other suitable material.

The proposed infiltration gardens surrounding the 2 patios shall be installed and maintained to effectively absorb and infiltrate stormwater.

Photographs documenting the construction of the proposed infiltration gardens surrounding the 2 patios) shall be submitted to the Department within 30 days of the completion of construction.

Within three days of final grading or temporary suspension of work in an area that is in or adjacent to wetlands or surface waters, all exposed soil areas shall be stabilized by seeding and mulching during the growing season, or if not within the growing season, by mulching with tack or netting and pinning on slopes steeper than 3:1.

The individual responsible for completion of the work shall utilize techniques described in the New Hampshire Stormwater Manual, Volume 3, Erosion and Sediment Controls During Construction (December 2008).

This permit shall not be interpreted as acceptance or approval of any impact that will occur within wetlands jurisdiction regulated under RSA 482-A including all wetlands, surface waters and their banks, the tidal-buffer zone, and sand dunes.

The owner is responsible for maintaining compliance with RSA 482-A and Administrative Rules Env-Wt 100 - 900 and obtaining any Wetland Impact Permit that may be required prior to construction, excavation or fill that will occur within Wetlands jurisdiction.

This permit shall not preclude NHDES from taking any enforcement or revocation action if NHDES later determines that any of the structures depicted as "existing" on the plans submitted by the applicant were not previously permitted or grandfathered.

2020-00879 OWNER: UNITED SOUTH END SETTLEMENTS -CAMP HALE

CITY: SANDWICH WATERBODY: SQUAM LAKE

05/25/2020 to 05/31/2020

Requested Action:

Impact 23,500 square feet (SF) of protected shoreland in order to conduct improve to an existing camp for the overall safety of the campers by installing the following: a handicap access pathway to beach, a new 300 SF deck with 6 foot wide wooden steps to the Outdoor Education Building; a concrete wall under new deck to provide additional support to deck; (2) rain gardens and native sod to disturbed areas to mitigate erosion and absorb stormwater runoff, replacement of the existing failing railroad tie retaining wall in-kind with a stone wall with perimeter drain and the replacement of the existing failing timber steps with reclaimed granite.

APPROVE PERMIT

Impact 23,500 square feet (SF) of protected shoreland in order to conduct improve to an existing camp for the overall safety of the campers by installing the following: a handicap access pathway to beach, a new 300 SF deck with 6 foot wide wooden steps to the Outdoor Education Building; a concrete wall under new deck to provide additional support to deck; (2) rain gardens and native sod to disturbed areas to mitigate erosion and absorb stormwater runoff, replacement of the existing failing railroad tie retaining wall in-kind with a stone wall with perimeter drain and the replacement of the existing failing timber steps with reclaimed granite.

With Conditions:

All work shall be in accordance with plans by Stephens Landscaping Professionals dated April 1, 2020 and received by the NH Department of Environmental Services (NHDES) on April 28, 2020.

Orange construction fencing shall be installed at the limits of the temporary impact area as shown on the approved plans prior to the start of work and shall be maintained throughout the project in order to prevent accidental encroachment into areas in which impacts have not been approved.

No more than 9% of the area of the lot within the protected shoreland shall be covered by impervious surfaces unless additional approval is obtained from NHDES.

Native vegetation within an area of at least 40,237 SF within the Natural Woodland Buffer located between 50 and 150 feet landward of the reference line shall be retained in an unaltered state in order to comply with RSA 483-B:9, V, (b), (2).

Erosion and siltation control measures shall be installed prior to the start of work, be maintained throughout the project, and remain in place until all disturbed surfaces are stabilized.

Erosion and siltation controls shall be appropriate to the size and nature of the project and to the physical characteristics of the site, including slope, soil type, vegetative cover, and proximity to wetlands or surface waters.

No person undertaking any activity in the protected shoreland shall cause or contribute to, or allow the activity to cause or contribute to, any violations of the surface water quality standards established in Env-Wq 1700.

Any fill used shall be clean sand, gravel, rock, or other suitable material.

Within three days of final grading or temporary suspension of work in an area that is in or adjacent to wetlands or surface waters, all exposed soil areas shall be stabilized by seeding and mulching during the growing season, or if not within the growing season, by mulching with tack or netting and pinning on slopes steeper than 3:1.

This permit shall not be interpreted as acceptance or approval of any impact that will occur within wetlands jurisdiction regulated under RSA 482-A including all wetlands, surface waters and their banks. The owner is responsible for maintaining compliance with RSA 482-A and Administrative Rules Env-Wt 100 - 900 and obtaining any Wetland Impact Permit that may be required prior to construction, excavation or fill that will occur within Wetlands jurisdiction.

This permit shall not preclude NHDES from taking any enforcement or revocation action if NHDES later determines that any of the structures depicted as "existing" on the plans submitted by the applicant were not previously permitted or grandfathered.

2020-00908 OWNER: SOOY, ROBERT/WREN

CITY: WAKEFIELD WATERBODY: PINE RIVER POND

05/25/2020 to 05/31/2020

Requested Action:

Impact 4,396 square feet of protected shoreland in order to install stormwater quality improvement structures within and adjacent to an existing driveway and garage.

APPROVE PERMIT

Impact 4,396 square feet of protected shoreland in order to install stormwater quality improvement structures within and adjacent to an existing driveway and garage.

With Conditions:

All work shall be in accordance with plans by Fernstone Associates for the Natural Resources dated April 17, 2020 and received by the NH Department of Environmental Services (NHDES) on May 04, 2020 pursuant to 483-B:5-b Permit Required; Exemption, I, (a).

Orange construction fencing shall be installed at the limits of the temporary impact area as shown on the approved plans prior to the start of work and shall be maintained throughout the project in order to prevent accidental encroachment into areas in which impacts have not been approved as required per Rule Env-Wq 1406.20, (e).

No more than 25.6% of the area of the lot within the protected shoreland shall be covered by impervious surfaces unless additional approval is obtained from NHDES in order to ensure compliance with RSA 483-B:9, V, (g).

Pursuant to RSA 483-B:9, V, (b), (2), no native vegetation shall be removed from within the Natural Woodland Buffer located between 50 and 150 ft. landward of the reference line.

Native vegetation within an area of at least 3,128 square feet within the Woodland Buffer located between 50 and 150 feet landward of the reference line shall be retained as natural woodlands in an unaltered state in order to comply with RSA 483-B:9, V, (b), (2).

Any fill used shall be clean sand, gravel, rock, or other suitable material as required per Rule Env-Wq 1406.20, (d).

The proposed stormwater management structures shall be installed and maintained to effectively absorb and infiltrate stormwater in order to ensure compliance with RSA 483-B:9, V, (g).

All pervious technologies used shall be installed and maintained to effectively absorb and infiltrate stormwater as required per RSA 483-B:6, II and Rule Env-Wq 1406.15, (c) in order to ensure compliance with RSA 483-B:9, V, (g).

No person undertaking any activity in the protected shoreland shall cause or contribute to, or allow the activity to cause or contribute to, any violations of the surface water quality standards established in Env-Wq 1700 as required per Rule Env-Wq 1406.20, (c).

Erosion and siltation control measures shall be installed prior to the start of work, be maintained throughout the project, and remain in place until all disturbed surfaces are stabilized as required per Rule Env-Wq 1406.20, (a).

Erosion and siltation controls shall be appropriate to the size and nature of the project and to the physical characteristics of the site, including slope, soil type, vegetative cover, and proximity to wetlands or surface waters as required per Rule Env-Wq 1406.20, (b).

The individual responsible for completion of the work shall utilize techniques described in the New Hampshire Stormwater Manual, Volume 3, Erosion and Sediment Controls During Construction (December 2008) as required pursuant to RSA 483-B:9, V, (d) Erosion and Siltation, (1).

This permit shall not preclude NHDES from taking any enforcement or revocation action as authorized pursuant to 483-B:5, I, if NHDES later determines that any of the structures depicted as "existing" on the plans submitted by the applicant were not previously permitted or grandfathered.

2020-00924 OWNER: GADBOIS, CARRIE/LAURENCE

CITY: DOVER WATERBODY: COCHECO RIVER

Requested Action:

Impact 2,755 square feet of protected shoreland in order to construct an addition to an existing dwelling, construct porches, balcony, shed, walkways, bulkhead, and replace an existing stairway towards the shore. An existing shed and concrete pad will be removed.

05/25/2020 to 05/31/2020

APPROVE PERMIT

Impact 2,755 square feet of protected shoreland in order to construct an addition to an existing dwelling, construct porches, balcony, shed, walkways, bulkhead, and replace an existing stairway towards the shore. An existing shed and concrete pad will be removed.

With Conditions:

1. All work shall be in accordance with plans by Atlantic Survey, Co., LLC and Carrie Gadbois dated April 15, 2020 and received by the NH Department of Environmental Services (DES) on May 5, 2020.
2. Orange construction fencing shall be installed at the limits of the temporary impact area as shown on the approved plans prior to the start of work and shall be maintained throughout the project in order to prevent accidental encroachment into areas in which impacts have not been approved.
3. No more than 18.6% of the area of the lot within the protected shoreland shall be covered by impervious surfaces unless additional approval is obtained from DES.
4. Native vegetation within an area of at least 2,727 square feet within the Natural Woodland Buffer located between 50 and 150 feet landward of the reference line shall be retained in an unaltered state in order to comply with RSA 483-B:9, V, (b), (2).
5. Erosion and siltation control measures shall be installed prior to the start of work, be maintained throughout the project, and remain in place until all disturbed surfaces are stabilized.
6. Erosion and siltation controls shall be appropriate to the size and nature of the project and to the physical characteristics of the site, including slope, soil type, vegetative cover, and proximity to wetlands or surface waters.
7. No person undertaking any activity in the protected shoreland shall cause or contribute to, or allow the activity to cause or contribute to, any violations of the surface water quality standards established in Env-Wq 1700.
8. Any fill used shall be clean sand, gravel, rock, or other suitable material.
9. Within three days of final grading or temporary suspension of work in an area that is in or adjacent to wetlands or surface waters, all exposed soil areas shall be stabilized by seeding and mulching during the growing season, or if not within the growing season, by mulching with tack or netting and pinning on slopes steeper than 3:1.
10. The individual responsible for completion of the work shall utilize techniques described in the New Hampshire Stormwater Manual, Volume 3, Erosion and Sediment Controls During Construction (December 2008).
11. This permit shall not be interpreted as acceptance or approval of any impact that will occur within wetlands jurisdiction regulated under RSA 482-A including all wetlands, surface waters and their banks. The owner is responsible for maintaining compliance with RSA 482-A and Administrative Rules Env-Wt 100 - 900 and obtaining any Wetland Impact Permit that may be required prior to construction, excavation or fill that will occur within Wetlands jurisdiction.
12. This permit shall not preclude DES from taking any enforcement or revocation action if DES later determines that any of the structures depicted as "existing" on the plans submitted by the applicant were not previously permitted or grandfathered.

PERMIT CATEGORY: SEASONAL DOCK SPN

2020-01118 OWNER: WAMPLER, TRAVIS

CITY: HENNIKER WATERBODY: LONG POND

Requested Action:

Disqualify seasonal dock notification.

05/25/2020 to 05/31/2020

DISQUALIFY TRAIL/FORESTRY/DOCK NOTIFICTN
Disqualify seasonal dock notification.

2020-01142 OWNER: BEAVER COVE LLC

CITY: WHITEFIELD WATERBODY: BURNS POND

Requested Action:

Install a seasonal pier not to exceed 6 foot x 30 foot on frontage along Burns Pond in Whitefield.

COMPLETE NOTIFICATION

Install a seasonal pier not to exceed 6 foot x 30 foot on frontage along Burns Pond in Whitefield.

2020-01150 OWNER: THEIDE, DAVID

CITY: BARNSTEAD WATERBODY: LOCKE LAKE

Requested Action:

Install a seasonal pier not to exceed 4 feet x 28 feet on frontage along Locke Lake in Barnstead.

COMPLETE NOTIFICATION

Install a seasonal pier not to exceed 4 feet x 28 feet on frontage along Locke Lake in Barnstead.

2020-01151 OWNER: BOWLER, THOMAS

CITY: STEWARTSTOWN WATERBODY: BIG DIAMOND POND

Requested Action:

Install a seasonal pier not to exceed 4 feet x 30 feet on frontage along Big Diamond Pond in Stewartstown.

05/25/2020 to 05/31/2020

COMPLETE NOTIFICATION

Install a seasonal pier not to exceed 4 feet x 30 feet on frontage along Big Diamond Pond in Stewartstown.

PERMIT CATEGORY: FORESTRY SPN

2020-01154 **OWNER: SCOTT, ARNOLD**

CITY: WILMOT WATERBODY: Unnamed Stream

COMPLETE NOTIFICATION
WILMOT; TAX MAP# 13; LOT# 27

2020-01155 **OWNER: DARTMOUTH HITCHCOCK MEDICAL CENTER**

CITY: HANOVER WATERBODY: Unnamed Stream

COMPLETE NOTIFICATION
HANOVER; TAX MAP# 12; LOT# 23

2020-01157 **OWNER: STEARNS, SHARON**

CITY: SALISBURY WATERBODY: Unnamed Stream

COMPLETE NOTIFICATION
SALISBURY; TAX MAP# 204; LOT# 1

2020-01158 **OWNER: PAPPAJOHN, CHRIS**

CITY: CONWAY WATERBODY: Unnamed Stream

05/25/2020 to 05/31/2020

COMPLETE NOTIFICATION
CONWAY; TAX MAP# 284; LOT# 7

2020-01179 OWNER: REINER WOODLAND CONSERVATION TRUST

CITY: SALISBURY WATERBODY: Unnamed Stream

COMPLETE NOTIFICATION
Salisbury, Tax Map #1 & 216, Lot #3 & 5

PERMIT CATEGORY: UTILITY SPN

2020-01186 OWNER: TOWN OF EXETER WATER & SEWER DEPT.

CITY: EXETER WATERBODY: Unnamed Stream

COMPLETE NOTIFICATION
Vegetative maintenance within ROW

PERMIT CATEGORY: CULVERT REPAIR AND REPLACEMENT SPN

2020-01149 OWNER: TOWN OF WOLFEBORO

CITY: WOLFEBORO WATERBODY: Unnamed Stream

COMPLETE REGISTRATION
Replace five 12" inch diameter culverts with 15" inch diameter culverts.

05/25/2020 to 05/31/2020

PERMIT CATEGORY: RR1: CULVERT REPLACEMENT OR REPAIR

2020-01131 OWNER: JEFFERY, SHAUN

CITY: GRANTHAM WATERBODY: Unnamed Stream

COMPLETE REGISTRATION
RR-1: Culvert Replacement or Repair

2020-01188 OWNER: TOWN OF LONDONDERRY

CITY: LONDONDERRY WATERBODY: Unnamed Stream

COMPLETE REGISTRATION
RR1: Culvert Replacement or Repair

PERMIT CATEGORY: EXP - EXPEDITED TIMELINE

2020-00753 OWNER: SHEEHAN, SALLY

CITY: RYE WATERBODY: ATLANTIC OCEAN

Requested Action:

Impact 623 square feet within the previously-developed 100-foot tidal buffer zone to raze the existing dwelling and rebuild a new dwelling in the same footprint on piers to raise the structure above FIRM AE flood and velocity zones.

APPROVE PERMIT

Impact 623 square feet within the previously-developed 100-foot tidal buffer zone to raze the existing dwelling and rebuild a new dwelling in the same footprint on piers to raise the structure above FIRM AE flood and velocity zones.

With Conditions:

In accordance with Env-Wt 307.16, all work shall be done in accordance with the 'Wetland Permit Plan' dated 3-27-2020 by Civilworks New England as received by the NH Department of Environmental Services (NHDES) on April 15, 2020.

In accordance with Env-Wt 310.03(a), no other work shall be done on the subject property pursuant to another expedited permit (EXP) or a statutory permit-by-notification (SPN) for a period of 12 months from the date the EXP was issued unless

05/25/2020 to 05/31/2020

the property owner submits information, including a plan, to demonstrate that the proposed work is wholly unrelated to and separate from the work already done under the EXP or SPN; and the proposed work and the work already done under the EXP or SPN do not, when combined, constitute a project for which a standard permit is required.

In accordance with Env-Wt 307.07, all development activities associated with any project shall be conducted in compliance with applicable requirements of RSA 483-B and Env-Wq 1400 during and after construction.

All work shall be conducted and maintained in such a way as to protect water quality as required by Rule Env-Wt 307.03(a) through (h).

In accordance with Env-Wt 307.11(a), fill shall be clean sand, gravel, rock, or other material that meets the projects specifications for its use; and does not contain any material that could contaminate surface or groundwater or otherwise adversely affect the ecosystem in which it is used. 6. All temporary and permanent filling activities shall meet all of the conditions listed in Rule Env-Wt 307.11(a) through (l).

In accordance with Env-Wt 307.11(c), slopes shall be immediately stabilized by a method specified in Env-Wq 1506 or Env-Wq 1508, as applicable, to prevent erosion into adjacent wetlands or surface waters.

In accordance with Env-Wt 307.11(b), limits of fill shall be clearly identified prior to commencement of work and controlled in accordance with Env-Wt 307.03 to ensure that fill does not spill over or erode into any area where filling is not authorized.

In accordance with Env-Wt 307.11(d), no fill shall be allowed to achieve setbacks to septic systems specified in Env-Wq 1000.

In accordance with Env-Wt 310.03(b), the work shall comply with all applicable conditions specified in Env-Wt 307.

With Findings:

This is classified as a minimum impact project per Rule Env-Wt 610.17(c)(1) for any dredging, filling, or construction activity, or any combination thereof that is in a previously developed upland area, is within 100 feet of the Highest Observable Tide Line (HOTL), and will disturb less than 3,000 square feet.

Per Rule Env-Wt 306.05, the applicant has addressed all of the required planning items that are used to determine the appropriate impact classification of a project and the type of approval required.

Per Rule Env-Wt 310.01(h), the application for this expedited permit (EXP) included a signed statement from the municipal conservation commission certifying that the conservation commission waives its right to intervene on the project.

Per Rule Env-Wt 605.01, for projects in coastal areas, the applicant has demonstrated that the avoidance and minimization requirements in Env-Wt 307, Env-Wt 311.07, Env-Wt 313, and Env-Wt 603.04 have been met, and has demonstrated that all of the requirements listed in Env-Wt 605.01(a) through (c) have been met.

Per Env-Wt 605.02, the applicant for a permit for work in or adjacent to tidal waters/wetlands or the tidal buffer zone has demonstrated that adverse impacts listed in (a) through (d) have been avoided or minimized as required by Env-Wt 313.04.

Per Rule Env-Wt 604.02(c), the project in or on a tidal buffer zone preserves the self-sustaining ability of the buffer area to provide habitat values, protect tidal environments from potential sources of pollution, provide stability of the coastal shoreline, and maintain existing buffers intact where the lot has disturbed area defined under RSA 483- B:4, VI.

2020-00954 OWNER: PARKER, ROBERT

CITY: SPOFFORD WATERBODY: SPOFFORD LAKE

Requested Action:

Temporarily impact 152 square feet along 32 linear feet of bank in order to repair an existing retaining wall on frontage along Spofford Lake in Spofford.

APPROVE PERMIT

Temporarily impact 152 square feet along 32 linear feet of bank in order to repair an existing retaining wall on frontage along Spofford Lake in Spofford.

With Conditions:

All work shall be in accordance with plans as received by the NH Department of Environmental Services (NHDES) on May 7, 2020 as required pursuant to Env-Wt 307.16.

05/25/2020 to 05/31/2020

Repair of the existing retaining wall shall be conducted in the dry and shall result in no change in height, length, location, or configuration in accordance with 514.07(a).

Pursuant to RSA 483-B:9,V, (a)(2)(d)(v), this permit does not authorize the removal of trees or saplings within the waterfront buffer that would result in a tree and sapling point score below the minimum required per RSA 483-B:9, V, (a)(2)(D)(iv).

All development activities associated with any project shall be conducted in compliance with applicable requirements of RSA 483-B and Env-Wq 1400 during and after construction as required pursuant to RSA 483-B:3.

Work shall be carried out in a time and manner such that there are no discharges in or to fish or shellfish spawning or nursery areas during spawning seasons as required pursuant to Env-Wt 307.04. Impacts to such areas shall be avoided or minimized to the maximum extent practicable during all other times of the year.

Work shall be carried out in a time and manner to avoid disturbances to migratory waterfowl breeding and nesting areas as required pursuant to Env-Wt 307.04. Impacts to such areas shall be avoided or minimized to the maximum extent practicable during all other times of the year.

Water quality control measures capable of minimizing erosion; collecting sediment and suspended and floating materials; and filtering fine sediment shall be selected and implemented as appropriate based on the size and nature of the project and the physical characteristics of the site, including slope, soil type, vegetative cover, and proximity to jurisdictional areas as required pursuant to Env-Wt 307.03(c).

Water quality control measures shall be installed prior to start of work and in accordance with the manufacturer's recommended specifications or, if none, the applicable requirements of Env-Wq 1506 or Env-Wq 1508, shall be maintained so as to ensure continued effectiveness in minimizing erosion and retaining sediment on-site during and after construction, and removed upon completion of work and the effective stabilization of disturbed surfaces as required pursuant to Env-Wt 307.03(c).

All dredged and excavated material and construction-related debris shall be placed outside of those areas subject to RSA 482-A or RSA-483-B unless a permit for for the deposition of materials within those areas has been obtained as required per RSA 482-A:3 or RSA 483-B:5-b respectively.

No activity shall be conducted in such a way as to cause or contribute to any violation of surface water quality standards specified in RSA 485-A:8 or Env-Wq 1700; ambient groundwater quality standards established under RSA 485-C; limitations on activities in a sanitary protective area established under Env-Dw 302.10 or Env-Dw 305.10; or any provision of RSA 485-A, Env-Wq 1000, RSA 483-B, or Env-Wq 1400 that protects water quality as required pursuant to Env-Wt 307.03(a).

Pursuant to RSA 482-A:14, RSA 482-A:14-b, and RSA 482-A:14-c, NHDES is authorized to take appropriate compliance actions should it be determined that, based upon additional information which becomes available, any of the structures depicted as "existing" on the plans submitted by or on behalf of the permittee were not previously permitted or grandfathered.

With Findings:

The project is classified as a minimum impact per Administrative Rule Env-Wt 514.07(a)(3), repair of the existing retaining wall conducted in the dry and results in no change in height, length, location, or configuration. wall.

The Department finds that the project as proposed and conditioned meets the requirements of RSA 482-A and the Wetlands Program Code of Administrative Rules Chapters Env-Wt 100 - 900. No waivers of RSA 482-A or the Wetlands Program Code of Administrative Rules Chapters Env-Wt 100 - 900 were requested or approved under this permit action.

PERMIT CATEGORY: SMALL MOTOR MINERAL DREDGE

2020-00975 OWNER: LUND, TERRY

CITY: (ALL TOWNS) WATERBODY: Unnamed Stream

APPROVE PERMIT
RTE 112/302, BATH, WILD AMMONOOSUC RIVER; RTE 118, WARREN, BAKER RIVER

05/25/2020 to 05/31/2020

2020-01187 OWNER: LANGELIER, JAMES

CITY: (ALL TOWNS) WATERBODY: Unnamed Stream

APPROVE PERMIT
BATH, WILD AMMONOOSUC RIVER

PERMIT CATEGORY: WETLAND PBN

2020-00938 OWNER: MARCONI, FRANCESCA/GENO

CITY: PORTSMOUTH WATERBODY:

Requested Action:

Temporarily impact 85 square feet of shoreline in order to repair an existing granite block retaining wall and replace six damaged fender piles in-kind.

Conservation Commission/Staff Comments:
5-12-20 - No adverse effect per DHR.

PBN IS COMPLETE

Temporarily impact 85 square feet of shoreline in order to repair an existing granite block retaining wall and replace six damaged fender piles in-kind.

With Conditions:

All work shall be done in accordance with plans by Geno Marconi as received by the NH Department of Environmental Services (NHDES) on May 06, 2020 as required pursuant to Env-Wt 307.16.

This permit shall not be effective until it has been recorded in the Rockingham County Registry of Deeds and a copy of the recorded permit has been provided to the department as required pursuant to RSA 482-A:3, and Env-Wt 314.02.

Work shall be done in accordance with the standard conditions in En-Wt 307.

Work shall be done by a barge or upland to prevent the driving of construction equipment in or through tidal waters/wetlands or on the bottom of the inter-tidal zone as required per Env-Wt 606.05(b).

Only those structures shown on the approved plans shall be installed or constructed along this frontage as required per Env-Wt 513.22, (a).

Water quality control measures capable of minimizing erosion; collecting sediment and suspended and floating materials; and filtering fine sediment shall be selected and implemented as appropriate based on the size and nature of the project and the physical characteristics of the site, including slope, soil type, vegetative cover, and proximity to jurisdictional areas as required pursuant to Env-Wt 307.03(c).

No activity shall be conducted in such a way as to cause or contribute to any violation of surface water quality standards specified in RSA 485-A:8 or Env-Wq 1700; ambient groundwater quality standards established under RSA 485-C; limitations on activities in a sanitary protective area established under Env-Dw 302.10 or Env-Dw 305.10; or any provision of RSA 485-A, Env-Wq 1000, RSA 483-B, or Env-Wq 1400 that protects water quality as required pursuant to Env-Wt 307.03(a).

Work shall be carried out in a time and manner such that there are no discharges in or to fish or shellfish spawning or nursery areas during spawning seasons as required pursuant to Env-Wt 307.04. Impacts to such areas shall be avoided or minimized to the maximum extent practicable during all other times of the year.

05/25/2020 to 05/31/2020

Work shall be carried out in a time and manner to avoid disturbances to migratory waterfowl breeding and nesting areas as required pursuant to Env-Wt 307.04. Impacts to such areas shall be avoided or minimized to the maximum extent practicable during all other times of the year.

All development activities associated with any project shall be conducted in compliance with applicable requirements of RSA 483-B and Env-Wq 1400 during and after construction as required pursuant to RSA 483-B:3.

Pursuant to RSA 482-A:14, RSA 482-A:14-b, and RSA 482-A:14-c, NHDES is authorized to take appropriate compliance actions should it be determined that, based upon additional information which becomes available, any of the structures depicted as "existing" on the plans submitted by or on behalf of the permittee were not previously permitted or grandfathered.

2020-01070 OWNER: THOMAS & JOAN CALLAHAN REVOCABLE TRUST

CITY: GILFORD WATERBODY: LAKE WINNIPESAUKEE

Requested Action:

Replace an existing 6 foot x 40 foot piling dock supported and install one seasonal boatlift adjacent to the western side of the dock and two personal watercraft lifts along the eastern side of the dock on 117 feet of frontage along Lake Winnepesaukee in Gilford.

PBN IS COMPLETE

Replace an existing 6 foot x 40 foot piling dock supported and install one seasonal boatlift adjacent to the western side of the dock and two personal watercraft lifts along the eastern side of the dock on 117 feet of frontage along Lake Winnepesaukee in Gilford.

With Conditions:

All work shall be done in accordance with plans by Watermark Marine Construction, dated March 13, 2020 as received by the NH Department of Environmental Services (NHDES) on May 18, 2020 as required pursuant to Env-Wt 307.16.

This permit shall not be effective until it has been recorded in the Belknap County Registry of Deeds and a copy of the recorded permit has been provided to the department as required pursuant to RSA 482-A:3, and Env-Wt 314.02.

Only those structures shown on the approved plans shall be installed or constructed along this frontage as required per Env-Wt 513.22, (a).

All seasonal structures, including watercraft lifts, shall be removed for the non-boating season as required per Env-Wt 513.22.

Any subdivision of the property frontage will require removal of a sufficient portion of the docking structures to comply with the dock size and density requirements in effect at the time of the subdivision as required pursuant to Env-Wt 314.02.

Work authorized shall be carried out in accordance with Env-Wt 307 such that appropriate turbidity controls are in place to protect water quality, that no turbidity escapes the immediate dredge area, and that appropriate turbidity controls shall remain until suspended particles have settled and water at the work site has returned to normal clarity.

Water quality control measures capable of minimizing erosion; collecting sediment and suspended and floating materials; and filtering fine sediment shall be selected and implemented as appropriate based on the size and nature of the project and the physical characteristics of the site, including slope, soil type, vegetative cover, and proximity to jurisdictional areas as required pursuant to Env-Wt 307.03(c).

Water quality control measures shall be installed prior to start of work and in accordance with the manufacturer's recommended specifications or, if none, the applicable requirements of Env-Wq 1506 or Env-Wq 1508, shall be maintained so as to ensure continued effectiveness in minimizing erosion and retaining sediment on-site during and after construction, and removed upon completion of work and the effective stabilization of disturbed surfaces as required pursuant to Env-Wt 307.03(c).

No activity shall be conducted in such a way as to cause or contribute to any violation of surface water quality standards specified in RSA 485-A:8 or Env-Wq 1700; ambient groundwater quality standards established under RSA 485-C; limitations on activities in a sanitary protective area established under Env-Dw 302.10 or Env-Dw 305.10; or any provision of RSA 485-A, Env-Wq 1000, RSA 483-B, or Env-Wq 1400 that protects water quality as required pursuant to Env-Wt 307.03(a).

Work shall be carried out in a time and manner such that there are no discharges in or to fish or shellfish spawning or nursery areas during spawning seasons as required pursuant to Env-Wt 307.04. Impacts to such areas shall be avoided or

05/25/2020 to 05/31/2020

minimized to the maximum extent practicable during all other times of the year.

Work shall be carried out in a time and manner to avoid disturbances to migratory waterfowl breeding and nesting areas as required pursuant to Env-Wt 307.04. Impacts to such areas shall be avoided or minimized to the maximum extent practicable during all other times of the year.

All development activities associated with any project shall be conducted in compliance with applicable requirements of RSA 483-B and Env-Wq 1400 during and after construction as required pursuant to RSA 483-B:3.

No construction, modification, or maintenance activity that is contrary to RSA 482-A:26 shall be conducted.

Owners of permanent docking structures which are not maintained so as to be structurally sound and usable for their intended purpose shall remove those docking structures in accordance with Env-Wt 513.22(c), to prevent hazards to public safety, navigation, and recreation.

Pursuant to RSA 482-A:14, RSA 482-A:14-b, and RSA 482-A:14-c, NHDES

Pursuant to RSA 482-A:14, RSA 482-A:14-b, and RSA 482-A:14-c, NHDES is authorized to take appropriate compliance actions should it be determined that, based upon additional information which becomes available, any of the structures depicted as "existing" on the plans submitted by or on behalf of the permittee were not previously permitted or grandfathered.

With Findings:

This is a minimum impact project per Administrative Rule Env-Wt 513.24(a)(2), for the repair or replacement of an existing legal docking structure.

2020-01077 OWNER: SAMOSET CONDOMINIUM ASSOCIATION

CITY: GILFORD WATERBODY: LAKE WINNIPESAUKEE

Requested Action:

Repair a 303 foot pile supported wharf with thirteen 2 foot x 24 foot fingers, 16 tie off piles and 2 ice protection clusters along 834 feet of frontage along Lake Winnepesaukee in Gilford.

PBN IS COMPLETE

Repair a 303 foot pile supported wharf with thirteen 2 foot x 24 foot fingers, 16 tie off piles and 2 ice protection clusters along 834 feet of frontage along Lake Winnepesaukee in Gilford.

With Conditions:

All work shall be done in accordance with plans by Folsom Design & Construction Management, dated May 12, 2020 as received by the NH Department of Environmental Services (NHDES) on May 18, 2020 as required pursuant to Env-Wt 307.16.

This permit shall not be effective until it has been recorded in the Belknap County Registry of Deeds and a copy of the recorded permit has been provided to the department as required pursuant to RSA 482-A:3, and Env-Wt 314.02.

Only those structures shown on the approved plans shall be installed or constructed along this frontage as required per Env-Wt 513.22, (a).

Any subdivision of the property frontage will require removal of a sufficient portion of the docking structures to comply with the dock size and density requirements in effect at the time of the subdivision as required pursuant to Env-Wt 314.02.

Work authorized shall be carried out in accordance with Env-Wt 307 such that appropriate turbidity controls are in place to protect water quality, that no turbidity escapes the immediate dredge area, and that appropriate turbidity controls shall remain until suspended particles have settled and water at the work site has returned to normal clarity.

Water quality control measures capable of minimizing erosion; collecting sediment and suspended and floating materials; and filtering fine sediment shall be selected and implemented as appropriate based on the size and nature of the project and the physical characteristics of the site, including slope, soil type, vegetative cover, and proximity to jurisdictional areas as required pursuant to Env-Wt 307.03(c).

Water quality control measures shall be installed prior to start of work and in accordance with the manufacturer's recommended specifications or, if none, the applicable requirements of Env-Wq 1506 or Env-Wq 1508, shall be maintained so as to ensure continued effectiveness in minimizing erosion and retaining sediment on-site during and after construction,

05/25/2020 to 05/31/2020

and removed upon completion of work and the effective stabilization of disturbed surfaces as required pursuant to Env-Wt 307.03(c).

No activity shall be conducted in such a way as to cause or contribute to any violation of surface water quality standards specified in RSA 485-A:8 or Env-Wq 1700; ambient groundwater quality standards established under RSA 485-C; limitations on activities in a sanitary protective area established under Env-Dw 302.10 or Env-Dw 305.10; or any provision of RSA 485-A, Env-Wq 1000, RSA 483-B, or Env-Wq 1400 that protects water quality as required pursuant to Env-Wt 307.03(a).

Work shall be carried out in a time and manner such that there are no discharges in or to fish or shellfish spawning or nursery areas during spawning seasons as required pursuant to Env-Wt 307.04. Impacts to such areas shall be avoided or minimized to the maximum extent practicable during all other times of the year.

Work shall be carried out in a time and manner to avoid disturbances to migratory waterfowl breeding and nesting areas as required pursuant to Env-Wt 307.04. Impacts to such areas shall be avoided or minimized to the maximum extent practicable during all other times of the year.

All development activities associated with any project shall be conducted in compliance with applicable requirements of RSA 483-B and Env-Wq 1400 during and after construction as required pursuant to RSA 483-B:3.

No construction, modification, or maintenance activity that is contrary to RSA 482-A:26 shall be conducted.

Owners of permanent docking structures which are not maintained so as to be structurally sound and usable for their intended purpose shall remove those docking structures in accordance with Env-Wt 513.22(c), to prevent hazards to public safety, navigation, and recreation.

Pursuant to RSA 482-A:14, RSA 482-A:14-b, and RSA 482-A:14-c, NHDES is authorized to take appropriate compliance actions should it be determined that, based upon additional information which becomes available, any of the structures depicted as "existing" on the plans submitted by or on behalf of the permittee were not previously permitted or grandfathered.

With Findings:

This is a minimum impact project per Administrative Rule Env-Wt 513.24(a)(2), for the repair or replacement of an existing legal docking structure.

2020-01139 OWNER: ERB, DEBORA/DOUGLAS

CITY: LANDAFF WATERBODY:

Requested Action:

Temporarily impact 2135 square feet (impacting 215 linear feet) of wet meadow for the installation of an underground residential sewer line.

PBN IS COMPLETE

Temporarily impact 2135 square feet (impacting 215 linear feet) of wet meadow for the installation of an underground residential sewer line.

With Conditions:

In accordance with Env-Wt 307.16, all work shall be done in accordance with plans dated May 9, 2020 by Far North Designs, as received by the NH Department of Environmental Services (NHDES) on May 26, 2020.

In accordance with Env-Wt 307.10(a), no dredging shall occur that would create violations of any set-backs specified in RSA 485-A or 483-B relative to protecting water quality; or Env-Wq 1000 relative to septic systems.

In accordance with Env-Wt 307.03(h), equipment shall be staged and refueled outside of jurisdictional areas (unless allowed) and in accordance with Env-Wt 307.15.

In accordance with Env-Wt 307.03(a), no activity shall be conducted in such a way as to cause or contribute to any violation of surface water quality standards specified in RSA 485-A:8 or Env-Wq 1700; ambient groundwater quality standards established under RSA 485-C; limitations on activities in a sanitary protective area established under Env-Dw 302.10 or

05/25/2020 to 05/31/2020

Env-Dw 305.10; or any provision of RSA 485-A, Env-Wq 1000, RSA 483-B, or Env-Wq 1400 that protects water quality.

In accordance with Env-Wt 307.03(c)(3), water quality control measures shall be installed prior to start of work and in accordance with the manufacturer's recommended specifications or, if none, the applicable requirements of Env-Wq 1506 or Env-Wq 1508.

In accordance with Env-Wt 307.03(c)(5), water quality control measures shall be maintained so as to ensure continued effectiveness in minimizing erosion and retaining sediment on-site during and after construction.

In accordance with Env-Wt 307.03(c)(7), temporary water quality control methods shall be removed upon completion of work when compliance with Env-Wt 307.03(c)(6) is achieved.

Restoration of all temporary impacts shall meet all of the conditions listed in Rule Env-Wt 307.12(a) through (i).

With Findings:

This project meets the minimum impact provisions of Env-Wt 521.06(a)(7), installation of residential utilities to a single-family home.