

Comparison of Satellite and 90-day Storage Area Requirements

Satellite Storage Area Requirements	90-day Area Storage Requirements
Written monthly inspection if >10 gallons	Written inspections every 7 days or less
At or near the point of generation	50' from property line if ignitable or reactive
Under the control of the process operator	50' from surface water or floor drains
	75' from private wells
	outside protective radius of public water supply well
Labeled with the words "Hazardous Waste, and a description of the contents at the moment the accumulation begins	Labeled with the words "hazardous waste", the accumulation date, the waste code, and a description of the contents
Labeled with the date and waste code when the accumulation reaches its limit	
Must store less than 55 gallons of non-acute or 1 quart of acute hazardous waste	No accumulation limit
Move to 90-day area within 3 days of reaching accumulation limit	Shipped off-site within 90 days
Preparedness and prevention items are not required	Preparedness & Prevention items within 100 feet:
	a. internal communication/alarm
	b. external communication system (phone)
	c. Portable fire control
	d. water or foam at adequate volume
	e. Phone posting:
	i. Steps to take in an emergency
	ii. Contact numbers for emergency responders
	iii. Location of fire extinguishers, spill control, emergency alarms
Containers in good condition	
Maintain 2 feet of aisle space	
Containers compatible with the waste in them	
Containers closed unless actively adding or removing	
Store containers on an impervious surface	
Secondary containment near floor drains, sinks, etc...	
Must be compatible with other materials nearby unless separated by a physical barrier	
Labels legible and accessible	
Outdoor storage:	
a. Artificial or natural barrier	
b. Signage - "Danger - Unauthorized personnel keep out"	
c. Locked Gate	
d. Secondary containment	
e. Cover to protect containers and secondary containment from the elements	