





The State of New Hampshire
Department of Environmental Services

Robert R. Scott, Commissioner



Inter-Departmental Memorandum
SENT VIA ELECTRONIC MAIL

TO: Honorable Chuck Morse, President of the Senate
Honorable Sherman Packard, Speaker of the House
Honorable Kevin Avar, Chair, Senate Energy and Natural Resources Committee
Honorable Howard Pearl, Chair, House Environment and Agriculture Committee
Tammy Wright, Clerk of the Senate
Paul Smith, Clerk of the House

FROM: 
Robert R. Scott, Commissioner

RE: Status Report on the Occurrence of Per- and Polyfluoroalkyl Substances

DATE: December 27, 2021

Pursuant to the Laws of the State of New Hampshire, January Session of 2018 Chapter 306:2 (HB 1766), the New Hampshire Department of Environmental Services (NHDES) hereby submits a copy of its status report through September 2021 on the occurrence of per- and polyfluoroalkyl substances (PFAS) in New Hampshire.

If you have any questions regarding this report, please do not hesitate to contact me.

STATUS REPORT ON THE OCCURRENCE OF PER- AND POLYFLUOROALKYL SUBSTANCE (PFAS) CONTAMINATION IN NEW HAMPSHIRE

This report has been developed to satisfy the requirements of the

Laws of New Hampshire

January Session of 2018, Chapter 306:2 (HB 1766)

Prepared by

New Hampshire Department of Environmental Services

Robert R. Scott, Commissioner

December 2021



PO Box 95, Concord, NH 03302-0095

www.des.nh.gov

Table of Contents

1. Introduction	3
2. Coakley Landfill Superfund Site	4
3. Former Pease Air Force Base Superfund Site.....	4
4. Statewide Public Water Supplies	10
5. Statewide PFAS Data	10
5.1 Solid Waste Facilities.....	11
5.2 Hazardous Waste Remediation Sites	11
5.3 Oil Remediation Sites	11
5.4 Groundwater Discharge Permit Sites (Wastewater Disposal to Groundwater).....	12
APPENDICES.....	13
Appendix 1	14
House Bill 1766-FN- Final Version	14
Table 1 – Public Water System PFAS Water Quality Summary	
Table 2 – Solid Waste Facility PFAS Water Quality Summary	
Table 3 – Hazardous Waste Remediation Sites PFAS Water Quality Summary	
Table 4 – Oil Remediation Sites PFAS Water Quality Summary	
Table 5 – Groundwater Discharge Permit Sites PFAS Water Quality Summary	

LIST OF COMMON ACRONYMS

AGQS – Ambient Groundwater Quality Standard

EPA – United States Environmental Protection Agency

NHDES – New Hampshire Department of Environmental Services

PFAS – Per- and polyfluoroalkyl substances

PFOA – Perfluorooctanoic Acid

PFOS – Perfluorooctanesulfonic Acid

PFHxS - Perfluorohexane Sulfonic Acid

PFNA - Perfluorononanoic Acid

PWS – Public Water System

1. Introduction

The New Hampshire Department of Environmental Services (NHDES) is engaged in an ongoing investigation into per- and polyfluoroalkyl substances (PFAS) in New Hampshire drinking water. New Hampshire and several other northeast states are dealing with several sites where there have been widespread PFAS impacts on drinking water supplies. In recognition of public concern regarding the issue of water quality in the Seacoast area and at areas of environmental interest across the state relative to PFAS, the Laws of New Hampshire, January Session of 2018 Chapter 306:2 (House Bill 1766) requires NHDES to report to the general court regarding bedrock testing and PFAS contamination in the Seacoast area and at other landfills and hazardous waste sites. This status report reflects an update to NHDES' June 2021 report, and has been developed to satisfy the twice yearly reporting requirements established in Chapter 306:2 (House Bill 1766).

Per- and polyfluoroalkyl substances or PFAS are a family of over 5,000 man-made chemicals, some of which have been more widely used and studied than others¹. PFAS have been widely used since the 1940s in commercial, industrial, and household products and applications, including production of water resistant materials, fire suppression foams, non-stick cookware, stain removers, etc. PFAS are used for their properties to resist heat, oil, grease and water. Once released to the environment, PFAS are persistent and some do not biodegrade or breakdown.

In 2019, NHDES adopted administrative rules that establish health-based Maximum Contaminant Levels (MCLs) and Ambient Groundwater Quality Standards (AGQS) for four per- and polyfluoroalkyl substances (PFAS) that include: 12 ppt for perfluorooctanoic acid (PFOA), 15 ppt for perfluorooctane sulfonic acid (PFOS), 18 ppt for perfluorohexane sulfonic acid (PFHxS), and 11 ppt for perfluorononanoic acid (PFNA). While enforcement of these standards was temporarily stayed by a court injunction, the MCLs and AGQS were established as a matter of law by House Bill 1264, which became effective July 23, 2020. MCLs are drinking water quality standards that non-transient public water systems (water systems serving the same 25 people more than 6 months per year) must comply with. An AGQS is the standard used to require site investigations and remedial action at and around contamination sites. AGQS are also used to identify where the provision of alternate drinking water is required when waste sites have contaminated private and/or public water supply wells. Please note that these rules do not require testing by owners of private water wells. NHDES does recommend for health reasons that private wells meet the AGQS.

This status report provides a brief summary of PFAS information available to date at the Coakley Landfill and former Pease Air Force Base superfund sites, both of which are located in the seacoast area of New Hampshire. This information includes a description of recent investigations at the Coakley site, and efforts to treat groundwater and drinking water at the Pease site. The report also presents PFAS data for public drinking water supplies, and groundwater data compiled from known PFAS sites statewide.

NHDES notes that its PFAS data are contained in several different databases, which impacts the ease with which PFAS information can be queried. Data provided in this status report generally is current for most NHDES programs through October 2021. Since new data are continuously provided to NHDES, readers may wish to access more up-to-date information using the following resources:

¹ <https://www.fda.gov/food/chemicals-and-polyfluoroalkyl-substances-pfas>

- Data viewer summarizing up to date PFOA and PFOS sampling results at <https://www4.des.state.nh.us/nh-pfas-investigation/> (under “Maps and Data”); and
- An online, searchable database referred to as “OneStop” comprised of environmental information and data compiled by select NHDES programs. OneStop does not provide access to all existing PFAS NHDES data, however, it is considered to be a valuable resource. The database can be found at <https://www4.des.state.nh.us/DESONestop/BasicSearch.aspx>.

This status report is required to be updated every six months and provided to the legislature. NHDES anticipates updates to the report will be available June and December of each year.

2. Coakley Landfill Superfund Site

The Coakley Landfill Superfund Site (Coakley) is a closed 27-acre former municipal/industrial solid waste disposal facility located in North Hampton. The landfill operated from 1972 to 1982 and received incinerator ash from the Portsmouth Refuse-to-Energy Facility through 1985. The site was listed on the National Priorities List (Superfund) in 1983 and construction of selected remedies was completed in 1999. Sampling for the emerging contaminants 1,4-dioxane and PFAS in 2009 and 2016, respectively, confirmed their presence, and prompted extensive follow-on investigations. Currently, the Coakley Landfill Group (CLG), a consortium of the parties responsible for the contamination, is conducting an investigation that will further develop the conceptual site model, and refine the source, fate, and transport of these emerging contaminants.

The following provides an update regarding ongoing activities in part related to the investigation of PFAS at Coakley generally through October 2021. For additional site-specific information please visit NHDES’ OneStop database at: <https://www4.des.state.nh.us/DESONestop/BasicSearch.aspx> or EPA’s website at: <https://cumulis.epa.gov/supercpad/cursites/csinfo.cfm?id=0101107>. The NHDES Site ID associated with the Coakley is NHDES #198712001.

- The on-going Deep Bedrock Investigation at the site is nearing completion with the conclusion of a groundwater pump test in late June. The final report, due to the agencies by the end of December 2021, will further refine the conceptual model of bedrock groundwater flow. Once received, NHDES will work with EPA to evaluate the data from this investigation and determine if there is existing or potential for future migration of Site contaminants that may pose an unacceptable risk or environmental impact. Should unacceptable condition(s) be identified, NHDES and EPA will consider options to manage the issue(s), including possible remedy modifications.
- Following the November 2020 pilot study for the removal of PFAS from Berrys Brook, the CLG has entered into a contract with XDD Environmental to proceed with developing other surface water treatment alternatives. XDD is to provide a report that suggests an optimal remedial approach and identifies data gaps that will further refine treatability and/or pilot test planning. NHDES has not yet received this report.
- The CLG conducted another round of sampling of stormwater runoff from the landfill cap and drainage system during summer 2021. Stormwater runoff was previously sampled in 2018 and

2019 and analyzed for PFAS compounds. The analytical results from the most recent round of sampling have not yet been received.

- As directed by EPA in a March 10, 2021 letter, documented in the prior PFAS Summary Report, the CLG conducted a replicate sampling event during the spring groundwater monitoring round and had those samples analyzed by two different laboratories to help explain the disparities in prior analytical results for perfluoro-octane-sulfonamide (PFOSA). Samples from private supply wells and onsite monitoring wells were sent to two different laboratories for PFOSA analysis. The study concluded that the occurrence of PFOSA from the laboratory where it has been detected is most likely due to groundwater matrix interference. This finding was supported by laboratory data that did not show a corresponding increase in PFOSA concentrations in samples that had been spiked with a known amount of PFOSA (stated more simply, it appears that PFOSA is not actually present). As a result, the agencies have approved the CLG to utilize the laboratory having no matrix interferences with regard to PFOASA for future analytical needs. PFOSA is a PFAS compound for which there are currently no federal or state standards.
- The CLG conducted the scheduled semi-annual sampling in October 2021, including sampling of more than 20 private wells. Validated private well sampling data for the spring 2021 round were provided to private property owners by the CLG on October 21, 2021. Results were consistent with historic data.
- EPA completed its fifth Five-Year Review (FYR) for Coakley with the issuance of a report on September 24, 2021. EPA's five-year review process requires the periodic review of the effectiveness of the remedial actions implemented at a Superfund site. The FYR included interviews with community officials, residents living near the site, and other stakeholders. The FYR report summarizes the actions taken at the site and details the data collected since the last five-year review (2016). The FYR report also provides an assessment of the protectiveness of the current remedy at the Site of human health and the environment, and provides recommendations for making sure the remedy remains protective in the long-term.

Based on a thorough review of the actions being taken and the data collected at the site, the FYR concluded that the remedy being implemented at the site currently protects human health and the environment because remediation has addressed the contaminant source and institutional controls and access controls are in place that prevent exposure to site sources and downgradient groundwater. In addition, access to surface water that exceeds risk-based screening levels for PFAS compounds is limited by property access, site conditions and warning signs. And, a risk evaluation of surface water data that exceeds screening levels found that the human health risk estimates for PFOA and PFOS were below the EPA acceptable hazard quotient of 1.0, and that there are currently no unacceptable risks to a recreator through exposure to surface water.

The FYR also made recommendations for the remedy to remain protective of human health and the environment in the long-term, including the following:

- Complete the deep-bedrock investigations to delineate the extent of contamination in bedrock groundwater, as well as, fate and transport of PFAS compounds and site contaminants of concern in groundwater and determine if further action is warranted.

- Design and implement a background study, including sampling and analysis, as necessary, to determine if the concentrations of arsenic and manganese are reflective of background conditions or rather are the result of mobilization due to the reducing conditions created by the landfill. Results from the background study will be used to assess natural attenuation and time to cleanup for arsenic and manganese.
- Continued sampling of on-site monitoring wells and area private wells, surface water, sediment, and stormwater runoff including analysis for PFAS compounds to monitor trends and continue to compare against current screening levels and established standards.
- Continue to evaluate the need for institutional and access controls for areas outside of the current groundwater management zone (GMZ), based on plume delineation and future land use.

The CLG continues to be responsible for the implementation of the remedy and the recommendation from the FYR, with oversight by EPA and NHDES.

For further details on submittals and agency responses, please see hyperlinks provided in the table below.

Documents added to NHDES website between April 1, 2021 and October 31, 2021:

Date	Document
April 26, 2021	Town of Greenland Letter to Commissioner Scott: Summary of 4/14/2021 CLG Executive Committee mtg. http://www4.des.state.nh.us/IISProxy/IISProxy.dll?ContentId=4921018
April 27, 2021	EPA EMAIL: Response to Mindi Messmer on landfill gas sampling for PFAS http://www4.des.state.nh.us/IISProxy/IISProxy.dll?ContentId=4922926
May 6, 2021	CLG submittal: PFOSA Investigation Replicate Sampling Work Plan http://www4.des.state.nh.us/IISProxy/IISProxy.dll?ContentId=4958687
May 7, 2021	NHDES letter to CLG: Follow up to 4/26/2021 letter from Town of Greenland http://www4.des.state.nh.us/IISProxy/IISProxy.dll?ContentId=4920988
May 10, 2021	CLG response to NHDES: Follow up to 5/7/2021 letter from NHDES http://www4.des.state.nh.us/IISProxy/IISProxy.dll?ContentId=4921835
May 11, 2021	CLG submittal: Direct Push Technology Investigation Results http://www4.des.state.nh.us/IISProxy/IISProxy.dll?ContentId=4930552
May 12, 2021	CLG submittal: Draft 2020 Annual Summary Report http://www4.des.state.nh.us/IISProxy/IISProxy.dll?ContentId=4935349
May 13, 2021	EPA letter to CLG: Comments on May 6, 2021 PFOSA Investigation Replicate Sampling Work Plan http://www4.des.state.nh.us/IISProxy/IISProxy.dll?ContentId=4922927
May 21, 2021	NHDES letter to Greenland Board of Selectmen: Follow up on Greenland's 4/26/2021 letter http://www4.des.state.nh.us/IISProxy/IISProxy.dll?ContentId=4922725
July 1, 2021	EPA letter to CLG: Comments on May 11 submittal, Direct Push Technology Investigation Results http://www4.des.state.nh.us/IISProxy/IISProxy.dll?ContentId=4934662
July 1, 2021	EPA letter to CLG: Surface Water Evaluation and Bedrock Investigation Remaining Task Summary http://www4.des.state.nh.us/IISProxy/IISProxy.dll?ContentId=4938447
September 24, 2021	EPA document: Fifth Five-Year Review Report http://www4.des.state.nh.us/IISProxy/IISProxy.dll?ContentId=4949546
September 30, 2021	EPA letter to CLG: Comments on Draft 2020 Annual Report http://www4.des.state.nh.us/IISProxy/IISProxy.dll?ContentId=4958686
October 21, 2021	CLG submittal: Spring 2021 Private Water Supply Well Sampling Results http://www4.des.state.nh.us/IISProxy/IISProxy.dll?ContentId=4956053

3. Former Pease Air Force Base Superfund Site

The following provides an update regarding ongoing activities specific to the investigation and remediation of PFAS at the former Pease Air Force Base Superfund Site (Pease). NHDES notes that the Air Force maintains the official Administrative Record for Pease. Reports summarizing investigations and other site-specific documents are public record on the U.S. Air Force Civil Engineering Center (AFCEC) Administrative Record website <https://ar.afcec-cloud.af.mil/Search.aspx>. Once there, select *BRAC>Pease AFB>OU-9 PFC Operable Unit* then click “Search” to view the document listing.

- **Pease Tradeport Municipal Water Supply.** The Haven well, the most productive of the three municipal supply wells on the Tradeport, was taken off-line immediately upon the discovery of PFAS in samples collected in April 2014 (including PFOS and PFOA at concentrations above the then applicable EPA Provisional Health Advisory levels). The other two Tradeport municipal supply wells (Smith and Harrison wells) did not have PFAS impacts above actionable concentrations and, therefore, remained on-line. The City of Portsmouth, under an agreement with the Air Force, installed a preliminary filtration system at its existing Grafton Road Treatment Plant for the Smith and Harrison wells in September 2016 using granular activated carbon (GAC). Regular monitoring for the presence of PFAS has been continuously conducted on the four municipal water supply wells that actively draw groundwater from the Pease aquifer (Smith, Harrison, and two off-base wells, Portsmouth and Collins) and also on a network of sentry monitoring wells distributed throughout the southern portion of the Pease aquifer. The City completed construction of a full-scale treatment plant using state-of-the-art ion-exchange resin in conjunction with GAC at their Grafton Road site in spring 2021 that allows for operation and treatment of the Smith, Harrison and Haven wells. Since bringing the Haven well back online in summer 2021, monitoring results of the Haven and surrounding monitoring wells show marked decreases in PFAS concentrations from 2014 levels, supporting positive impacts of the aquifer restoration efforts described below. The City posts the water supply well monitoring results and other pertinent information on their website.

NHDES notes the following links for additional updates regarding Pease Tradeport information:

PEASE TRADEPORT WATER SUPPLY UPDATE

http://files.cityofportsmouth.com/files/water/PeaseWtrSupplyUpdate9_23_2021.pdf

PEASE COMPREHENSIVE PFC SAMPLING DATA

<http://files.cityofportsmouth.com/files/ww/PeasePFAS08.2020.pdf>

PEASE TRADEPORT WATER SYSTEM OVERVIEW

<http://files.cityofportsmouth.com/publicworks/PeaseWaterSystemOperationsUpdate033115.pdf>

- **Off-site Private Wells.** In June 2014 the Air Force began an inventory and sampling program for private off-site supply wells within 1-mile of Pease in the towns of Newington, Greenland and Portsmouth. To date, 45 residential drinking water wells have been sampled, five of which were documented to have PFOS/PFOA at concentrations near or above the 2016 AGQS. All five were initially supplied with bottled water; four were provided with point-of-entry treatment (POET) systems, one was taken out of use. Of the four wells provided with POE systems, a permanent solution was agreed upon between the Air Force and three property owners to connect to Portsmouth’s municipal supply system that already services parts of Newington. Two of those

wells were successfully connected to the municipal system in December 2019; the Air Force is still seeking resolution with the third owner. The owner of the fourth well opted to take over operation and maintenance of their POET system from the Air Force rather than connect to the municipal supply.

In October 2019 NHDES sent letters to six additional private supply well owners to notify them of the development of new AGQSs for four PFAS because at least one PFAS concentration was detected in a past water quality sample above one or more of the new more stringent PFAS standards. The letters were intended to ensure the residents were aware of the new standards and to provide them with updated information and resources relative to PFAS. One of those six wells is on the Great Bay National Wildlife Refuge; U.S. Fish and Wildlife Service subsequently confirmed that it is not used for potable purposes.

Following reestablishment of the AGQS, as signed into law in July 2020, NHDES requested Air Force compliance with our standards and response actions including providing bottled water and permanent mitigation for affected private well owners. In correspondence dated September 2, 2020 the Air Force responded to NHDES that it would not take corrective action on private well issues unless detected concentrations exceed the EPA's Lifetime Health Advisory levels (70 ppt for PFOS/PFOA). Subsequent entreaties from New Hampshire's Congressional representatives and from Governor Sununu for the Air Force to take actions based on AGQS violations were met with the same response.

As a result, NHDES coordinated bottled water delivery to four of the residences (the fifth installed their own filtration system). NHDES subsequently contracted permanent mitigation actions at two of the properties: connection to the municipal supply at one and installation of a point-of-entry treatment system at another. A third owner declined NHDES' offer to connect them to the municipal supply. NHDES is evaluating the need for mitigation at the fourth of these impacted wells pending follow-on water quality monitoring results in 2021.

Since 2014, long-term monitoring has occurred on a regular basis for all residential wells where the owners have elected to participate. The long-term monitoring plan is continually evaluated and modified, as appropriate, based on the results. All sampling results are provided to each individual well owner.

- **Base-wide Hydrogeological Investigation.** Concurrent with initial response actions and completion of a CERCLA Preliminary Assessment for PFAS to identify areas where fluorinated Aqueous Film-Forming Foam (AFFF) was released, the source of the widespread PFAS at Pease, the Air Force conducted a base-wide PFAS site investigation (SI) to better understand the nature and extent of PFAS in soil and overburden and bedrock groundwater. The SI was completed in 2016. This information was used to develop a conceptual site model of PFAS contamination and to develop a groundwater remediation plan called the Airfield Interim Mitigation System (AIMS).

A supplemental PFAS investigation, designated as Expanded Site Inspection (ESI), was conducted in 2018 and 2019 to further refine the relationship between overburden and bedrock groundwater and surface waters, both base-wide and with particular focus in Newington, north of Site 8. The ESI also included PFAS characterization and an exposure assessment of other media (soil, sediment, surface water, and shellfish). Results of the ESI were shared with the

public at the 2019 Pease Restoration Advisory Board (RAB) meetings. Key conclusions of the ESI include: additional investigation and risk assessment is warranted and will occur as part of the next CERCLA phase, a Remedial Investigation (RI); and though PFAS were detected in shellfish collected from various locations, the detected concentrations did not exceed the Screening Levels (SLs) established for three PFAS by EPA. Because of the detection, NHDES' Environmental Health Program conducted a site-specific evaluation of PFAS in shellfish and concluded that a shellfish consumption advisory for PFAS was not warranted. The Final ESI report was published in March 2020 and is posted on the AFCEC Administrative Record website.

The Air Force has begun the Pease PFAS RI. A comprehensive outreach effort to property owners in the vicinity of Pease was conducted in fall 2020 to gather additional information about the presence of surface waters, springs, seep and non-potable wells on off-base properties as well as agricultural practices in the community to better inform the development of the Human Health Risk Assessment and Ecological Risk Assessment being conducted as part of the RI. Several technical sessions were held in early 2021 to seek input from Pease stakeholders including concerned community members as well as the City of Portsmouth and Pease Development Authority. This information was considered during the development of the RI Work Plan. The first phase of field work to refine the nature and extent of PFAS contamination began this spring and will be used to support follow-on investigation and the risk assessments required under the RI.

- **Airfield Interim Mitigation System (AIMS).** The AIMS objectives include: intercepting PFAS-impacted groundwater upgradient of the Haven Well through a network of groundwater extraction wells; treatment of the intercepted water in a centrally-located treatment plant using best available technology; reinjection of the treated groundwater back into the Pease aquifer to restore the aquifer, supporting the City's reactivation of the Haven Well and providing hydraulic protection of the southern Pease aquifer supply wells. Installation of the AIMS extraction and infiltration wells was completed in 2018. Construction of the AIMS treatment plant was completed and the Air Force started operation in April 2019. Since startup the AIMS has treated more than 487 million gallons of groundwater.
- **Former Fire Training Area No. 2 (Site 8).** Concurrent with the base-wide PFAS Site Investigation, a separate investigation was conducted at the former fire training area where AFFF was known to have been used by the Air Force beginning in the early 1970s up through the late 1980s. Extensive investigations in the 1990s were conducted to address petroleum and solvent contamination. A remedy including a hydraulic containment system had been operated since 1995 and was demonstrated to have mitigated off-site migration of those contaminants. Based on the Site 8 PFAS investigation a design was developed to augment the hydraulic containment system to better mitigate PFAS migration. That system and its associated state-of-the-art PFAS treatment plant began operating in spring 2018. System design and operations are regularly evaluated to optimize performance. Due to the unexpected presence of elevated iron concentrations in several of the Site 8 IMS extraction wells, the Air Force augmented the Site 8 IMS with an iron mitigation treatment phase. Operation, optimization and performance monitoring of the Site 8 IMS is on-going. Since operation began, the Site 8 Interim Mitigation System has treated more than 52 million gallons of groundwater.

- **Community Involvement.** Since discovery of PFAS in the municipal supply wells in May 2014 the community has been actively engaged and has participated in numerous public meetings hosted by NHDES and New Hampshire Department of Health and Human Services (NH DHHS). In addition, the following community groups have been developed for Pease PFAS-related issues:
 - Restoration Advisory Board (RAB). In 2015 NHDES requested the Air Force re-establish Pease’s RAB, a stakeholder group that meets quarterly to discuss ongoing environmental restoration of Pease. The RAB provides community members an open forum to talk with the Air Force and regulatory agencies about environmental restoration activities. The Pease RAB consists of local volunteer community members (including the NH Air National Guard) and appointed members representing the Air Force, regulatory agencies, the Pease Development Authority and the City of Portsmouth. RAB information can be accessed on the Air Force Civil Engineering Center website: <https://www.afcec.af.mil/Home/BRAC/Pease.aspx>
 - Community Assistance Panel (CAP): The initial forum that was created for community input on PFAS-related health concerns was the Community Advisory Board. To build on the community involvement started with the Board, the Agency for Toxic Substances and Disease Registry (ATSDR) formed the Pease CAP as a way for the community to participate directly in ATSDR’s health activities. CAP information can be accessed on the ATSDR website for Pease: <https://www.atsdr.cdc.gov/pfas/Pease-CAP.html>

Information on the Pease Study, the first in the nation health study to better understand the effects of PFAS exposure, can be accessed on the ATSDR website for Pease: <https://www.atsdr.cdc.gov/sites/pease/index.html>.

ATSDR’s Health Consultation on PFAS in the Pease Tradeport Public Water System can be accessed on the ATSDR website for Pease: https://www.atsdr.cdc.gov/HAC/pha/pease/Pease_Air_Force_Base_HC-508.pdf

ATSDR’s draft Health Consultation on PFAS in the Private Residential Drinking Water Wells was available for public comment through July 30, 2020. Although that report has not yet been finalized, the draft version can still be accessed on the ATSDR website for Pease: https://www.atsdr.cdc.gov/HAC/pha/pease/Pease_AFB_HC-PC_April_2020-508.pdf

4. Statewide Public Water Supplies

NHDES began a statewide initiative to test drinking water from all community water supplies for PFAS in 2016. Of the 1,880 sources of drinking water that supply public water systems in New Hampshire, as of November 2021, approximately 78% (1,474 sources) have been sampled for PFAS with approximately 30% of wells having detections of PFOA, PFOS, PFHxS, and PFNA.

Information included on the attached Table 1 summarizes sampling results for PFOA, PFOS, PFHxS, and PFNA. NHDES notes that exceedances of the current MCLs for the four PFAS compounds occurred at 102 water supply wells, which have or may require that the owners of these wells install treatment or take the wells out of service. Table 1 presents only one sample result for each source, representing the most recent concentration of PFOA, PFOS, PFHxS, and PFNA detected. Given the fact that treatment systems for PFAS removal have been, and are in-process of being installed at some PFAS-impacted water

systems, some of the sampling results shown in Table 1 reflect low or no presence of PFAS due to operation of these systems.

5. Statewide PFAS Data

The following summarizes PFAS information that NHDES has compiled to date from various sources at existing solid waste facilities, hazardous waste remediation sites, oil remediation sites, and groundwater discharge sites. Please refer to the additional resources referenced in Section 1 above for up-to-date and/or additional site-specific information.

5.1 Solid Waste Facilities

There are roughly 200 unlined/lined solid waste disposal facilities or synthetic lined wastewater treatment lagoons in New Hampshire for which the owner/operator is responsible for monitoring water quality. These sites have either a groundwater release detection permit (GDP) or groundwater management permit (GMP) that have been issued by NHDES, in accordance with applicable administrative rules. These permits prescribe programs for periodic groundwater quality monitoring and reporting, provide for groundwater remediation either through active measures or natural attenuation, specify performance standards for remedies, and describe procedures for performing site investigations and implementing remedial action plans.

NHDES has required groundwater sampling for PFAS at all of these sites. As of September 2021, 88% have sampled, and of those sites sampled, approximately 85% have PFAS detections, and 71% have exceedances of the AGQS for PFOA, PFOS, PFHxS, and/or PFNA. Refer to Table 2 for a summary of maximum PFOA, PFOS, PFHxS, and PFNA concentrations at each of the sites where data has been compiled by NHDES.

5.2 Hazardous Waste Remediation Sites

Hazardous waste remediation sites include all sites where a hazardous substance or waste has been released, and which often have a long-term remediation and management component prescribed and regulated through an NHDES-issued groundwater management permit or remedial action plan. There are 660 waste sites, including State-listed hazardous waste, Comprehensive Environmental Response, Compensation, and Liability Act (CERCLA), and Brownfield sites, that have an open status and are currently regulated by NHDES, in accordance with its administrative rules.

As outlined in a letter to responsible parties, site owners, and/or permittees dated May 18, 2017, and clarified in a follow-up letter dated October 19, 2017, NHDES is requiring waste sites that meet certain criteria to complete an initial screening for the presence of PFAS per the provisions of the NH Code of Administrative Rules, Chapters Env-Or 600 and Env-Or 700, as applicable. As of September 2021, 37% have sampled and of those sites sampled, approximately 94% have detected PFAS and 75% have exceedances of the AGQS for PFOA, PFOS, PFHxS, and/or PFNA. Refer to Table 3 for a summary of maximum PFOA, PFOS, PFHxS, and PFNA concentrations at each of the sites where data has been compiled by NHDES.

5.3 Oil Remediation Sites

Oil remediation sites include all sites where long-term remediation and management of petroleum contamination occurs primarily through a NHDES-issued GMP or remedial action plan. There are

roughly 1,500 active petroleum sites, including, but not limited to, leaking underground/above ground storage tank sites, motor vehicle salvage yards, and spills that have an open status and are currently regulated by NHDES in accordance with the administrative rules.

NHDES undertook an initiative in 2018 requesting a small initial subset of these petroleum sites to voluntarily complete an initial screening for the presence of PFAS. As of September 2021, less than 1% of all petroleum sites have sampled and reported data to NHDES for PFAS. Of the sites sampled, several have exceedances of the AGQS for PFOA, PFOS, PFHxS, and/or PFNA. NHDES notes however, that in all cases to date, it has been concluded that the source and release mechanism(s) have not been attributable to the petroleum discharge. PFAS exceedances in groundwater were observed in the general vicinity of areas where fire suppression foam was used and motor oil additives or other fluids were stored or discharged at motor vehicle salvage yards or unpermitted solid waste facilities. Refer to Table 4 for a summary of maximum PFOA, PFOS, PFHxS, and PFNA concentrations at each of the sites where data has been compiled by NHDES.

5.4 Groundwater Discharge Permit Sites (Wastewater Disposal to Groundwater)

NHDES regulates 87 facilities that dispose of wastewater to the ground through such practices as discharges to unlined lagoons, rapid infiltration basins, spray irrigation systems, very large leach fields, and septage lagoons. These sites are managed under a Groundwater Discharge Permit (GDP), which allows the discharge in accordance with administrative rules that protect against impact to other properties and drinking water supply wells. NHDES has required sampling for PFAS at all of these sites. To date, 94% have sampled and of those sites sampled, approximately 79% have detected PFAS and 43% have exceedances of the AGQS for PFOA, PFOS, PFHxS, and PFNA. Refer to Table 5 for a summary of maximum PFOA, PFOS, PFHxS, and PFNA concentrations at each of the sites where data has been compiled by NHDES.

APPENDICES

Appendix 1

House Bill 1766-FN- Final Version

(The following document is an image of the final bill text of House Bill (HB) 1766-FN- Final Version)

CHAPTER 306
HB 1766-FN - FINAL VERSION

04/26/2018 1630s
23May2018... 1983-CofC

2018 SESSION

18-2503
08/04

HOUSE BILL *1766-FN*

AN ACT requiring the department of environmental services to report to the general court regarding bedrock testing and perfluorochemical contamination in the Seacoast area and at other landfills and hazardous waste sites.

SPONSORS: Rep. Messmer, Rock. 24; Rep. Cushing, Rock. 21; Rep. Bean, Rock. 21; Rep. Edgar, Rock. 21; Rep. T. Le, Rock. 31; Rep. P. Gordon, Rock. 29; Sen. Fuller Clark, Dist 21

COMMITTEE: Environment and Agriculture

AMENDED ANALYSIS

 This bill requires the department of environmental services to report to the general court regarding perfluorinated chemical contamination at the Seacoast and at landfills and other hazardous waste sites.

Explanation: Matter added to current law appears in ***bold italics***.
 Matter removed from current law appears ~~[in brackets and struck through]~~
 Matter which is either (a) all new or (b) repealed and reenacted appears in regular type.

CHAPTER 306
HB 1766-FN - FINAL VERSION

04/26/2018 1630s
23May2018... 1983-CofC

18-2503
08/04

STATE OF NEW HAMPSHIRE

In the Year of Our Lord Two Thousand Eighteen

AN ACT requiring the department of environmental services to report to the general court regarding bedrock testing and perfluorochemical contamination in the Seacoast area and at other landfills and hazardous waste sites.

Be it Enacted by the Senate and House of Representatives in General Court convened:

1 306:1 Findings. The general court acknowledges the public concern regarding the
2 issue of water quality in the Seacoast area and at areas of environmental interest all
3 over the state. The general court further finds that in view of bedrock testing due to
4 begin in the Seacoast area during the summer of 2018, and in view of the impending first
5 ever study of per and polyfluoroalkyl (PFAS) exposure, the general court shall be
6 informed, on a regular basis, of contaminant monitoring and contaminant migration,
7 and advised regarding new research on contaminant exposure and any developments in
8 remediation technology.

9 306:2 Department of Environmental Services; Reports Required.

10 I. The department of environmental services shall submit an initial report to the
11 general court by December 1, 2018, and shall submit interim reports every 6 months
12 thereafter, on the results of monitoring, testing, and any other analysis or data relative
13 to perfluorooctanesulfonic acid (PFOS) and perfluorooctanoic acid (PFOA) levels at
14 statewide sites that it has identified as sources of those contaminants. The reports shall
15 include preliminary results from bedrock testing conducted at the Coakley Landfill site
16 beginning in the summer of 2018. The department shall submit interim reports on the
17 bedrock testing by July 1, 2019 and December 1, 2019, and a final report within 6 months
18 of when such testing is completed. Other Seacoast area sites shall include, but not be
19 limited to, the Pease International Tradeport and its vicinity, the Hampton Landfill, the
20 Coakley Landfill, the Rye Breakfast Hill Landfill, the Rye Grove Landfill, the Garland
21 Well and nearby well sites, the former Cibor Airport, the Hampton Airport, and other
22 municipal and commercial operations within the Seacoast area deemed relevant by the
23 department. The department shall also include in such reports the PFOS and PFOA
24 levels at any landfill, hazardous waste, and other sites statewide where it currently
25 requires testing.

26 II. Copies of the reports required in paragraph I shall be submitted to:

27 (a) The president of the senate.

CHAPTER 306
HB 1766-FN - FINAL VERSION
- Page 2 -

1 (b) The speaker of the house of representatives.

2 (c) The chairman of the senate energy and natural resources committee, or
3 the successor committee with jurisdiction over energy and natural resource issues.

4 (d) The chairman of the environment and agriculture committee, or the
5 successor committee with jurisdiction over energy and natural resource issues.

6 (e) The joint legislative fiscal committee of the general court.

7 306:3 Senate and House of Representatives Committees; Duties. The senate energy
8 and natural resources committee and the house environment and agriculture committee,
9 or their successor committees as specified in section 2, paragraph II of this act, shall
10 collect and evaluate the reports required in section 2 of this act along with any other
11 reports, data, and information the committees deem relevant. The committees shall
12 solicit information from commissions and informed citizens in southeastern New
13 Hampshire and shall solicit information from the United States Environmental
14 Protection Agency regarding the reports required in section 2.

15 306:4 Effective Date. This act shall take effect July 1, 2018.

Approved: June 25, 2018
Effective Date: July 01, 2018

TABLES



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE NAME	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
0015010-001	ACWORTH PRIMARY SCH	ACWORTH	07/20/20	ND	ND	ND	ND
0022010-501	WILDWOOD DEV	ALBANY	03/10/20	ND	ND	ND	ND
0023010-001	PIPER MEADOWS PRIVATE COMMUNITY	ALBANY	03/29/21	ND	ND	ND	ND
0032010-501	LEDGES AT NEWFOUND LAKE	ALEXANDRIA	11/05/19	ND	ND	ND	ND
043020-511	OLDE TOWNE	ALLENSTOWN	09/23/20	ND	ND	ND	ND
043040-505	CATAMOUNT HILL	ALLENSTOWN	03/25/20	ND	ND	ND	ND
0052010-001	PAPERMILL VILLAGE	ALSTEAD	04/21/21	ND	ND	ND	ND
0052010-503	PAPERMILL VILLAGE	ALSTEAD	07/13/21	ND	ND	ND	ND
0053010-504	WELL HILL	ALSTEAD	01/20/21	ND	ND	ND	ND
0055010-501	ALSTEAD VILAS SCH	ALSTEAD	07/20/20	ND	ND	ND	ND
0055020-001	ALSTEAD PRIMARY SCH	ALSTEAD	07/20/20	ND	ND	ND	ND
0055030-001	ORCHARD SCHOOL	ALSTEAD	12/04/19	ND	ND	ND	ND
0059010-001	MOLE HILL THEATRE/LEAF CHARTER	ALSTEAD	12/21/20	ND	ND	ND	ND
0061010-503	ALTON WATER WORKS	ALTON	07/21/21	ND	3.78	ND	3.85
0061010-502	ALTON WATER WORKS	ALTON	03/10/21	ND	ND	ND	ND
0062010-501	EAGLES REST MHP	ALTON	01/04/21	ND	ND	ND	ND
0062050-501	LAKESIDE AT WINNIPESAUKEE	ALTON	11/05/19	ND	ND	ND	ND
0063020-501	MERRYMEETING MHP	ALTON	03/10/21	ND	ND	ND	ND
0065020-501	PROSPECT MOUNTAIN HIGH SCH	ALTON	12/10/20	ND	ND	ND	ND
0078090-501	MEETING PLACE	AMHERST	07/21/21	2.20	2.51	ND	5.58
0072080-001	GOWING WOODS	AMHERST	07/20/21	4.18	ND	ND	ND
0076070-001	MC SQUARE	AMHERST	04/29/21	4.54	ND	ND	ND
0076130-501	COLONIAL PARK	AMHERST	09/24/21	6.18	ND	ND	4.76
0072070-501	SOUHEGAN WOODS	AMHERST	10/06/21	6.96	ND	ND	ND
0076070-501	MC SQUARE	AMHERST	08/25/21	7.50	ND	ND	ND
0072090-501	CONNOR COURT	AMHERST	04/12/21	7.57	ND	ND	ND
0076040-002	SALZBURG SQUARE AMHERST	AMHERST	09/24/21	9.52	4.67	ND	ND
0073030-000	RIDGEWOOD ESTATES	AMHERST	11/05/19	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE NAME	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
0075060-501	AMHERST MEDICAL CENTER	AMHERST	01/04/21	ND	ND	ND	ND
0075070-001	CHRISTS CHURCH OF AMHERST	AMHERST	01/25/21	ND	ND	ND	ND
0081010-002	ANDOVER VILLAGE DIST	ANDOVER	02/20/20	ND	ND	ND	ND
0086030-001	BELLETETES	ANDOVER	03/09/21	ND	ND	ND	ND
0091010-501	ANTRIM SEWER AND WATER DEPT	ANTRIM	02/11/20	ND	ND	ND	ND
0092010-001	STEELE POND DEV	ANTRIM	08/05/16	ND	ND	ND	ND
0095010-001	OVERSEAS UNITED EDUC FNDTN	ANTRIM	06/22/21	ND	ND	ND	ND
0101010-504	ASHLAND WATER DEPT	ASHLAND	07/22/21	ND	ND	ND	ND
0101010-505	ASHLAND WATER DEPT	ASHLAND	07/22/21	ND	ND	ND	ND
0102010-500	ROPEWALK SERVICES	ASHLAND	03/06/20	ND	ND	ND	ND
0102020-000	VILLAGE AT RIVERBEND	ASHLAND	02/12/20	ND	ND	ND	ND
106010-502	ROCHESTER SHOE TREE	ASHLAND	09/24/20	ND	ND	ND	ND
0112080-021	WALNUT RIDGE/BRYANT WDS	ATKINSON	06/17/19	1.80	1.80	1.80	ND
0112080-011	WALNUT RIDGE/BRYANT WDS	ATKINSON	06/17/19	2.10	0.89	0.70	ND
0112100-502	ATKINSON WOODS	ATKINSON	07/07/21	2.42	ND	ND	ND
0112080-009	WALNUT RIDGE/BRYANT WDS	ATKINSON	06/17/19	2.60	1.10	0.88	ND
0112080-012	WALNUT RIDGE/BRYANT WDS	ATKINSON	06/17/19	2.70	ND	0.80	ND
0116010-501	PEU/PIONEER COMMERCE PARK	ATKINSON	07/20/21	2.96	ND	ND	ND
0112080-003	WALNUT RIDGE/BRYANT WDS	ATKINSON	06/17/19	4.80	1.40	1.50	0.26
0112030-501	WRIGHT FARM CONDOS	ATKINSON	07/13/21	4.90	ND	ND	2.65
0112080-001	WALNUT RIDGE/BRYANT WDS	ATKINSON	06/17/19	5.90	1.60	2.10	ND
0115060-001	LEARNING PATH CHILD CARE CTR	ATKINSON	05/14/21	6.12	ND	ND	ND
0112060-501	COMMONS OF ATKINSON	ATKINSON	07/13/21	7.11	4.68	ND	2.43
0116040-501	PALMER GAS	ATKINSON	07/22/21	7.43	3.19	ND	ND
0115010-502	ATKINSON ACADEMY SCH	ATKINSON	08/22/21	10.50	9.76	ND	2.57
0112080-004	WALNUT RIDGE/BRYANT WDS	ATKINSON	06/17/19	16.00	3.90	3.50	0.74
0112070-501	WATER WHEEL ESTATES	ATKINSON	02/04/20	ND	ND	ND	ND
0112080-013	WALNUT RIDGE/BRYANT WOODS	ATKINSON	05/26/16	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE NAME	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
0112090-501	DEARBORN RIDGE	ATKINSON	05/17/21	ND	ND	ND	ND
0116020-501	GEX	ATKINSON	08/16/21	ND	ND	ND	ND
0135010-502	AUBURN VILLAGE SCH	AUBURN	01/14/21	ND	ND	ND	ND
0135020-001	AUBURN CHILDRENS HOUSE	AUBURN	06/24/20	ND	ND	ND	ND
0135030-501	ITS A CHILDS WORLD	AUBURN	08/13/20	ND	ND	ND	ND
0142010-019	PEU LOCKE LAKE	BARNSTEAD	10/14/21	ND	ND	ND	ND
0142010-510	PEU/LOCKE LAKE	BARNSTEAD	02/11/20	ND	ND	ND	ND
0142010-517	PEU/LOCKE LAKE	BARNSTEAD	02/11/20	ND	ND	ND	ND
0145010-502	BARNSTEAD ELEMENTARY SCH	BARNSTEAD	11/14/19	ND	ND	ND	ND
0146040-501	BARNSTEAD BUSINESS PARK	BARNSTEAD	02/21/21	ND	ND	ND	ND
0153040-501	LEE OAK COOPERATIVE	BARRINGTON	04/22/21	3.94	ND	ND	ND
0153050-506	BARRINGTON MOBILE HOME ESTATES	BARRINGTON	08/11/21	4.27	ND	ND	ND
0156020-501	FOCUS HOLDINGS	BARRINGTON	05/11/21	4.79	5.79	ND	ND
0152020-501	OLD STAGE COACH ARMS	BARRINGTON	04/14/21	5.28	3.46	ND	ND
0153020-501	HALCYON HILL	BARRINGTON	08/02/21	5.49	8.39	ND	ND
0155050-501	BARRINGTON ELEMENTARY SCHOOL	BARRINGTON	09/21/21	ND	2.78	ND	6.16
0151010-503	SWAINS LAKE VILLAGE WATER	BARRINGTON	03/03/20	ND	ND	ND	ND
0152010-001	ELLISON FARM APARTMENTS	BARRINGTON	08/17/21	ND	ND	ND	ND
0152030-001	BARRINGTON HILLS APTS/LOWER	BARRINGTON	11/19/19	ND	ND	ND	ND
0152050-001	BARRINGTON HILLS APTS/UPPER	BARRINGTON	11/19/19	ND	ND	ND	ND
0152060-003	OYSTER RIVER APTS EAST/WEST	BARRINGTON	01/14/20	ND	ND	ND	ND
0152090-501	PEPPERIDGE WOODS	BARRINGTON	11/13/19	ND	ND	ND	ND
0153030-502	BARRINGTON OAKS	BARRINGTON	03/25/21	ND	ND	ND	ND
0153030-503	BARRINGTON OAKS	BARRINGTON	03/25/21	ND	ND	ND	ND
0153060-503	EMERALD ACRES	BARRINGTON	01/22/21	ND	ND	ND	ND
0155020-501	EARLY CHILDHOOD LEARNING CTR	BARRINGTON	11/18/19	ND	ND	ND	ND
0155070-501	FRISBIE HEALTH SERVICES	BARRINGTON	11/21/20	ND	ND	ND	ND
0155080-500	BARRINGTON MIDDLE SCH	BARRINGTON	02/16/21	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE NAME	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
0155100-001	BARRINGTON VLG ENRICHMENT CTR	BARRINGTON	08/04/21	ND	ND	ND	ND
0156030-501	ASSOCIATED BUYERS	BARRINGTON	06/21/21	ND	ND	ND	ND
0156040-004	TURBOCAM/PHASE I	BARRINGTON	03/18/20	ND	ND	ND	ND
0156040-005	TURBOCAM/PHASE I	BARRINGTON	03/18/20	ND	ND	ND	ND
0156060-001	MIDPOINT PROPERTIES	BARRINGTON	04/01/21	ND	ND	ND	ND
0156070-001	TURBOCAM B2	BARRINGTON	03/18/20	ND	ND	ND	ND
0162170-511	RIVER RUN CONDOS	BARTLETT	09/22/21	2.78	3.94	ND	ND
0162390-501	SUGARWOOD ON THE SACO	BARTLETT	05/28/21	4.20	7.51	ND	ND
0162160-503	COW HILL WELLHOUSE	BARTLETT	08/18/21	ND	2.05	ND	ND
0161010-003	BARTLETT VILLAGE PCT	BARTLETT	09/22/21	ND	ND	ND	ND
0161020-001	LOWER BARTLETT WATER PCT	BARTLETT	07/08/21	ND	ND	ND	ND
0161020-003	LOWER BARTLETT WATER PCT	BARTLETT	07/08/21	ND	ND	ND	ND
0162050-502	NORTH LEDGE	BARTLETT	02/11/20	ND	ND	ND	ND
0162070-000	LINDERHOF PROP OWNR ASSN	BARTLETT	03/12/20	ND	ND	ND	ND
0162100-002	RIVERSBEND	BARTLETT	03/12/20	ND	ND	ND	ND
0162140-502	RIVERSIDE COBB FARM	BARTLETT	03/12/20	ND	ND	ND	ND
0162160-001	COW HILL WELLHOUSE	BARTLETT	11/09/16	ND	ND	ND	ND
0162180-001	BLUEBERRY VILLAGE CONDOS	BARTLETT	10/23/19	ND	ND	ND	ND
0162190-502	CRAWFORD HILLS	BARTLETT	02/11/20	ND	ND	ND	ND
0162200-503	TOP NOTCH CONDOS	BARTLETT	03/12/20	ND	ND	ND	ND
0162210-502	MOUNTAINSIDE ON ATTITASH	BARTLETT	03/10/20	ND	ND	ND	ND
0162250-504	BARTLETT PLACE	BARTLETT	03/09/20	ND	ND	ND	ND
0162260-001	VILLAGGIO BIANCO	BARTLETT	03/09/20	ND	ND	ND	ND
0162270-505	NORDIC VILLAGE	BARTLETT	12/04/20	ND	ND	ND	ND
0162310-502	WHISPERING BROOK	BARTLETT	03/09/20	ND	ND	ND	ND
0162330-501	CRAWFORD POND	BARTLETT	02/11/20	ND	ND	ND	ND
0162340-001	BEAR VILLAGE SOUTH	BARTLETT	03/12/20	ND	ND	ND	ND
0162350-000	GOODRICH PROPERTY	BARTLETT	10/23/19	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE NAME	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
0162400-501	EAGLE RIDGE RESORT	BARTLETT	11/11/19	ND	ND	ND	ND
0162400-501	EAGLE RIDGE RESORT	BARTLETT	03/09/20	ND	ND	ND	ND
0162410-508	STILLINGS GRANT	BARTLETT	10/23/19	ND	ND	ND	ND
0162410-508	STILLINGS GRANT	BARTLETT	02/11/20	ND	ND	ND	ND
0162430-501	BEARFOOT CREEK	BARTLETT	10/23/19	ND	ND	ND	ND
0162430-501	BEARFOOT CREEK	BARTLETT	03/04/20	ND	ND	ND	ND
0167010-501	MT ATTITASH SKI AREA/LODGE	BARTLETT	11/14/19	ND	ND	ND	ND
0167010-501	MT ATTITASH SKI AREA/LODGE	BARTLETT	03/12/20	ND	ND	ND	ND
0168460-001	BEAR PEAK AT ATTITASH	BARTLETT	10/23/19	ND	ND	ND	ND
0168460-001	BEAR PEAK AT ATTITASH	BARTLETT	02/11/20	ND	ND	ND	ND
0171010-503	BATH VILLAGE WATER WORKS	BATH	12/04/19	ND	ND	ND	ND
0196280-501	292 ROUTE 101	BEDFORD	08/05/21	2.04	ND	ND	ND
0192060-501	ENGLISH WOODS	BEDFORD	01/21/21	2.29	ND	ND	ND
0196310-001	FRENCH ATWOOD MARKETPLACE	BEDFORD	09/24/21	2.66	ND	ND	ND
0195090-001	BETHANY COVENANT CHURCH	BEDFORD	08/25/21	6.05	ND	ND	ND
0196170-001	PINE TREE PLACE CONDOS	BEDFORD	09/17/21	7.94	ND	ND	ND
0196330-501	124 BEDFORD CENTER RD	BEDFORD	08/12/21	8.16	14.10	ND	ND
0196020-501	101 PLAZA	BEDFORD	70/20/21	12.60	ND	ND	ND
0192070-321	CABOT PRESERVE	BEDFORD	03/06/20	14.70	2.72	ND	ND
0196320-501	FAMILY MEDICAL CENTER	BEDFORD	09/24/21	16.20	4.20	ND	4.05
0195020-501	KELLOGG CHRISTIAN SCHOOL	BEDFORD	10/29/19	40.20	2.63	2.31	ND
0198010-001	OLDE ROAD II	BEDFORD	11/30/18	93.00	2.60	1.30	0.80
0197020-001	CAMP FOSTER	BEDFORD	05/09/17	ND	ND	3.00	ND
0195010-002	MONTESOR SCH OF BEDFORD	BEDFORD	03/17/21	ND	ND	ND	ND
0155100-501	BEDFORD VILLAGE MORNING SCHOOLE	BEDFORD	03/09/21	ND	ND	ND	ND
0196210-501	288 ROUTE 101	BEDFORD	02/03/20	ND	ND	ND	ND
0196270-501	EVERSOURCE ENERGY BEDFORD AWC	BEDFORD	09/21/20	ND	ND	ND	ND
0197030-001	CAMP KETTLEFORD	BEDFORD	05/09/17	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE NAME	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
0203070-502	GRANITE STATE CAMPGROUND	BELMONT	01/28/21	3.19	4.76	ND	ND
0206040-501	AFL TELECOMMUNICATIONS LLC	BELMONT	11/21/19	6.46	4.22	ND	ND
0205010-501	LAKES REGION DAYCARE	BELMONT	07/20/21	8.25	3.57	ND	ND
0203030-501	NORTHBROOK MHP	BELMONT	07/26/21	9.06	5.88	ND	8.49
0203030-001	NORTHBROOK MHP	BELMONT	07/26/21	9.81	9.99	ND	2.74
0201010-501	BELMONT WATER DEPT	BELMONT	10/30/19	ND	ND	ND	ND
0201010-502	BELMONT WATER DEPT	BELMONT	10/30/19	ND	ND	ND	ND
0201010-503	BELMONT WATER DEPT	BELMONT	07/13/21	ND	ND	ND	ND
0202010-005	ABENAKI WATER /LAKELAND	BELMONT	11/05/19	ND	ND	ND	ND
0202010-5041	ABENAKI WATER /LAKELAND	BELMONT	05/21/21	ND	ND	ND	ND
0202010-504	ABENAKI WATER /LAKELAND	BELMONT	01/18/21	ND	ND	ND	ND
0202020-500	SUNRAY SHORES WATER DIST	BELMONT	12/06/19	ND	ND	ND	ND
0202030-501	ABENAKI WATER/TIOGA	BELMONT	05/12/21	ND	ND	ND	ND
0202040-501	WESTVIEW MEADOWS	BELMONT	06/29/21	ND	ND	ND	ND
0202060-501	SUN LAKE VILLAGE	BELMONT	11/06/19	ND	ND	ND	ND
0203010-001	CATES MOBILE HOME PARK	BELMONT	02/11/20	ND	ND	ND	ND
0203020-501	LADD HILL MHP	BELMONT	07/30/21	ND	ND	ND	ND
0203040-000	PINE GARDENS MHP	BELMONT	03/03/20	ND	ND	ND	ND
0203060-504	SOLAR VILLAGE	BELMONT	02/11/21	ND	ND	ND	ND
0203080-000	MALLARDS LANDING	BELMONT	11/06/19	ND	ND	ND	ND
0203090-505	LAKES REGION MHP COOP II	BELMONT	09/23/21	ND	ND	ND	ND
0206020-501	BELMONT BUSINESS PARK	BELMONT	11/15/19	ND	ND	ND	ND
0206050-501	EASTGATE PARK	BELMONT	03/17/21	ND	ND	ND	ND
0209040-501	BELMONT MEDICAL CENTER	BELMONT	07/20/21	ND	ND	ND	ND
0211010-502	BENNINGTON WATER DEPT	BENNINGTON	02/21/20	ND	ND	ND	ND
0212010-501	SOUTH FACE CONDOS	BENNINGTON	01/05/21	ND	ND	ND	ND
0212030-000	BIRCHES OF BENNINGTON	BENNINGTON	01/05/21	ND	ND	ND	ND
0212020-501	MOUNTAINSIDE AT CROTCHED MTN	BENNINGTON	04/21/21	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE NAME	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
0212020-502	MOUNTAINSIDE AT CROTCHED MTN	BENNINGTON	07/16/21	ND	ND	ND	ND
0224010-004	GLENCLIFF HOME FOR THE ELDERLY	BENTON	06/04/20	ND	ND	ND	ND
0224010-504	GLENCLIFF HOME FOR THE ELDERLY	BENTON	01/17/20	ND	ND	ND	ND
0231010-004	BERLIN WATER WORKS	BERLIN	10/10/19	ND	ND	ND	ND
0231010-008	BERLIN WATER WORKS	BERLIN	11/06/19	ND	ND	ND	ND
0231010-009	BERLIN WATER WORKS	BERLIN	10/10/19	ND	ND	ND	ND
0241010-003	BETHLEHEM VILLAGE DIST	BETHLEHEM	08/10/21	ND	ND	ND	ND
0245010-502	PROFILE HIGH SCH	BETHLEHEM	12/29/20	ND	ND	ND	ND
0251010-002	PENACOOK BOSCAWEN WATER PCT	BOSCAWEN	12/29/20	ND	ND	ND	ND
0251010-003	PENACOOK BOSCAWEN WATER PCT	BOSCAWEN	12/29/20	ND	ND	ND	ND
0251010-004	PENACOOK BOSCAWEN WATER PCT	BOSCAWEN	12/29/20	ND	ND	ND	ND
0266110-501	BOW TECHNOLOGIES	BOW	09/13/21	2.56	2.24	ND	ND
0262050-501	PEU/WHITE ROCK SENIOR LIVING	BOW	07/08/21	3.10	ND	ND	ND
0261010-511	BOW MUNICIPAL WATER SYSTEM	BOW	10/06/21	4.66	4.69	ND	ND
0266240-001	GRAPPONE HONDA	BOW	05/21/21	4.82	6.66	ND	2.58
0266200-500	GRAPPONE TOYOTA	BOW	05/21/21	5.36	ND	ND	4.77
0265010-502	BOW MEMORIAL SCHOOL	BOW	09/21/21	5.67	ND	ND	ND
0266050-002	GRAPPONE FORD COMPLEX	BOW	05/21/21	7.06	11.6	ND	4.41
0266010-000	GSP/MERRIMACK STATION	BOW	07/08/21	7.09	8.52	ND	2.03
0266090-001	PITCO FRIALATOR	BOW	05/13/21	17.1	17.9	ND	13.1
0266090-501	PITCO FRIALATOR	BOW	08/23/21	19.6	7.68	ND	15.0
0262010-501	EVERGREEN DRIVE WATER	BOW	01/04/21	ND	ND	ND	ND
0262020-501	ABENAKI WATER/WHITE ROCK	BOW	09/26/21	ND	ND	ND	ND
0262030-502	BELA BROOK WATER	BOW	11/06/19	ND	ND	ND	ND
0262040-502	COTTAGES AT WINDCHIMES	BOW	04/06/21	ND	ND	ND	ND
0262060-501	PEU/STONE SLED FARM	BOW	03/04/20	ND	ND	ND	ND
0262060-502	PEU/STONE SLED FARM	BOW	03/04/20	ND	ND	ND	ND
0265020-502	BOW ELEMENTARY SCHOOL	BOW	09/21/21	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE NAME	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
0265030-502	BOW HIGH SCHOOL	BOW	09/21/21	ND	ND	ND	ND
0265040-001	JOYFUL NOISE	BOW	02/03/21	ND	ND	ND	ND
0265040-501	JOYFUL NOISE	BOW	02/03/21	ND	ND	ND	ND
0265050-001	BOW YOUTH CENTER	BOW	04/06/21	ND	ND	ND	ND
0265060-501	MEETING HOUSE MONTESSORI	BOW	11/13/19	ND	ND	ND	ND
0266020-001	BOVIE SCREEN PRINTING	BOW	07/23/21	ND	ND	ND	ND
0266130-002	RUGGLES III OFFICE BLDG	BOW	11/05/19	ND	ND	ND	ND
0266140-501	NH AUTO DEALERS ASSN	BOW	11/13/19	ND	ND	ND	ND
0266150-502	CONCORD GROUP	BOW	12/11/20	ND	ND	ND	ND
0266220-001	501 SOUTH STREET	BOW	01/11/21	ND	ND	ND	ND
0266250-501	BOW SAFETY BLDG	BOW	10/06/21	ND	ND	ND	ND
0269010-501	BOW MUNICIPAL BUILDING	BOW	10/06/21	ND	ND	ND	ND
0272010-001	FISHERFIELD TOWNHOUSES	BRADFORD	10/21/19	ND	ND	ND	ND
0275070-001	KEARSARGE REG ELEM SCH/BRADFRD	BRADFORD	12/23/20	ND	ND	ND	ND
0275080-501	NFI NORTH TRNS HSING	BRADFORD	07/14/21	ND	ND	ND	ND
0275090-501	CHILDRENS CTR FOR CREATVE LRNG	BRADFORD	06/29/21	ND	ND	ND	ND
0285010-502	SWASEY CENTRAL SCH	BRENTWOOD	06/25/21	2.11	ND	ND	ND
0284010-502	ROCKINGHAM COUNTY COMPLEX	BRENTWOOD	09/14/21	2.92	6.31	ND	9.18
0286060-500	ROCKINGHAM COUNTY COURTHOUSE	BRENTWOOD	08/16/21	3.33	ND	ND	ND
0284010-503	ROCKINGHAM COUNTY COMPLEX	BRENTWOOD	05/21/21	ND	3.39	7.86	ND
0282010-002	MILL POND CROSSING	BRENTWOOD	06/03/20	ND	ND	ND	ND
0285040-501	A PLACE TO GROW	BRENTWOOD	09/17/20	ND	ND	ND	ND
0286020-601	OWENS CORNING	BRENTWOOD	06/25/21	ND	ND	ND	ND
0292010-000	WHITTEMORE SHORES	BRIDGEWATER	11/06/19	ND	ND	ND	ND
0293010-002	NEWFOUND ACRES MHP	BRIDGEWATER	02/12/20	ND	ND	ND	ND
0295010-001	BRIDGEWATER/HEBRON VIL SCH	BRIDGEWATER	03/16/21	ND	ND	ND	ND
0297020-512	WHIP O WHILL CONDOS	BRIDGEWATER	04/08/21	ND	ND	ND	ND
0298040-001	NEWFOUND GROCERY	BRIDGEWATER	07/22/16	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE NAME	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
0301010-501	BRISTOL WATER WORKS	BRISTOL	04/02/21	ND	ND	ND	ND
0301010-502	BRISTOL WATER WORKS	BRISTOL	04/02/21	ND	ND	ND	ND
0301010-503	BRISTOL WATER WORKS	BRISTOL	04/02/21	ND	ND	ND	ND
0305010-501	NEWFOUND REGIONAL HS	BRISTOL	01/08/21	ND	ND	ND	ND
0305020-001	PB AND JS FAMILY CHILDCARE	BRISTOL	09/17/21	ND	ND	ND	ND
0325010-001	RICHARD MAGHAKIAN MEMORIAL SCH	BROOKLINE	12/21/20	ND	ND	ND	ND
0325050-501	CAPT SAMUEL DOUGLASS ACADEMY	BROOKLINE	12/22/20	ND	ND	ND	ND
0325060-001	STONE LEDGE PLAZA	BROOKLINE	07/20/21	ND	ND	ND	ND
0326020-501	DECCO	BROOKLINE	10/28/19	ND	ND	ND	ND
0346030-501	USFS WMNF ADMIN CMLX	CAMPTON	09/13/21	1.80	1.80	1.80	1.80
0341010-508	CAMPTON VILLAGE PCT	CAMPTON	04/02/21	ND	ND	ND	ND
0341010-509	CAMPTON VILLAGE PCT	CAMPTON	04/02/21	ND	ND	ND	ND
0341030-502	WATERVILLE ESTATES VLG DIST	CAMPTON	03/12/21	ND	ND	ND	ND
0342010-512	BEEBE RIVER	CAMPTON	01/27/21	ND	ND	ND	ND
0342020-001	TRIPPLEWOOD RESORT CONDOS	CAMPTON	04/02/21	ND	ND	ND	ND
0342050-000	DEER RUN	CAMPTON	02/18/20	ND	ND	ND	ND
0342060-002	BECKET HOUSE AT CAMPTON	CAMPTON	11/05/19	ND	ND	ND	ND
0342080-000	VALLEY VIEW CONDOS	CAMPTON	01/08/20	ND	ND	ND	ND
0342090-001	RED SLEIGH CONDOS	CAMPTON	12/08/20	ND	ND	ND	ND
0342100-000	COACHMAN CONDOS	CAMPTON	01/20/21	ND	ND	ND	ND
0343010-000	CHESLEYS MHP	CAMPTON	05/19/21	ND	ND	ND	ND
0343020-502	SIX FLAGS MHP	CAMPTON	02/03/21	ND	ND	ND	ND
0353010-002	COUNTRY VILLAGE MHP	CANAAN	02/03/21	0.50	ND	ND	ND
0355060-001	INDIAN RIVER SCH	CANAAN	09/07/21	6.30	8.09	ND	ND
0355030-001	MASCOMA VALLEY REG HIGH SCH	CANAAN	11/21/16	12.00	15.00	ND	ND
0351010-501	CANAAN WATER DEPT	CANAAN	03/11/21	ND	ND	ND	ND
0353010-001	COUNTRY VILLAGE MHP	CANAAN	02/03/21	ND	ND	ND	ND
0353020-001	MASCOMA VALLEY COOP	CANAAN	11/05/19	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE NAME	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
0354010-503	CARDIGAN MOUNTAIN SCH	CANAAN	1/10/2020	ND	ND	ND	ND
0355070-001	MACOMA COMM HEALTH CARE	CANAAN	01/28/21	ND	ND	ND	ND
0356020-001	BARKER STEEL	CANAAN	03/11/20	ND	ND	ND	ND
0363010-503	COUNTRY LANE MANOR	CANDIA	09/07/21	3.16	ND	ND	ND
0365040-001	REMINGTON EDUC CENTER	CANDIA	09/24/21	4.32	5.90	ND	ND
0362010-501	HILLCREST MANOR APTS	CANDIA	01/05/21	ND	ND	ND	ND
0362020-502	CANDIA CROSSING	CANDIA	10/19/21	ND	ND	ND	ND
0365010-503	HENRY W MOORE SCH	CANDIA	04/07/21	ND	ND	ND	ND
0365020-501	M AND C CHILDRENS LEARNING PL	CANDIA	05/24/21	ND	ND	ND	ND
0365020-502	M AND C CHILDRENS LEARNING PL	CANDIA	08/03/21	ND	ND	ND	ND
0366040-001	BIRCHWOOD PLAZA	CANDIA	01/25/21	ND	ND	ND	ND
0374010-102	CANTERBURY SPRUCES HOUSING	CANTERBURY	01/20/21	ND	ND	ND	ND
0375010-002	CANTERBURY ELEMENTARY SCH	CANTERBURY	01/20/21	ND	ND	ND	ND
0381010-514	CARROLL WATER WORKS	CARROLL	10/24/19	ND	ND	ND	ND
0382010-001	ROSEBROOK WATER	CARROLL	06/16/21	ND	ND	ND	ND
0382010-002	ROSEBROOK WATER	CARROLL	06/16/21	ND	ND	ND	ND
0398030-001	CENTER HARBOR INN	CENTER HARBOR	12/08/16	4.60	ND	ND	ND
0396020-000	SENTERS MARKET CONDOS	CENTER HARBOR	07/07/21	19.00	ND	ND	ND
0411010-502	CHARLESTOWN WATER WORKS	CHARLESTOWN	07/21/21	2.54	ND	ND	ND
0411010-004	CHARLESTOWN WATER WORKS	CHARLESTOWN	01/04/21	ND	ND	ND	ND
0411010-005	CHARLESTOWN WATER WORKS	CHARLESTOWN	01/04/21	ND	ND	ND	ND
0411020-511	NORTH CHARLESTOWN WATER DEPT	CHARLESTOWN	01/04/21	ND	ND	ND	ND
0411020-512	NORTH CHARLESTOWN WATER DEPT	CHARLESTOWN	01/04/21	ND	ND	ND	ND
0412010-000	MEADOWVIEW APTS	CHARLESTOWN	08/04/20	ND	ND	ND	ND
0413020-504	CONNECTICUT RIVER MHP	CHARLESTOWN	07/15/20	ND	ND	ND	ND
0413030-501	WINDY ACRES	CHARLESTOWN	08/04/20	ND	ND	ND	ND
0419010-501	LIFE FLLWSHP FOURSQRE CHURCH	CHARLESTOWN	01/20/21	ND	ND	ND	ND
0435060-501	CHESTER ACADEMY	CHESTER	07/15/21	2.20	ND	ND	6.40



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE NAME	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
0432030-502	CHESTER BROOK	CHESTER	09/13/21	2.90	ND	ND	ND
0432010-501	VILLAGES AT CHESTER CONDOS	CHESTER	10/22/19	ND	ND	ND	ND
0432020-502	OAK HILL	CHESTER	03/08/21	ND	ND	ND	ND
0432040-501	PEU/SHAKER HEIGHTS	CHESTER	02/12/20	ND	ND	ND	ND
0435070-001	PLAY LAUGH N GROW	CHESTER	10/03/19	ND	ND	ND	ND
0435080-501	CHESTERBROOK SCH OF NTRL LRNG	CHESTER	03/17/21	ND	ND	ND	ND
0437020-503	WASON POND COMMUNITY CENTER	CHESTER	02/10/20	ND	ND	ND	ND
0438010-001	SHAKER HEIGHTS PROF PLAZA	CHESTER	05/25/16	ND	ND	ND	ND
0445010-004	CHESTERFIELD CENTRAL SCH	CHESTERFIELD	12/18/21	ND	ND	ND	ND
0446020-502	UNITED NATURAL FOODS	CHESTERFIELD	10/18/21	ND	ND	ND	ND
0446030-501	NORTHEAST HOME LOAN	CHESTERFIELD	12/29/20	ND	ND	ND	ND
0449040-001	FEDEX FACILITY	CHESTERFIELD	12/29/20	ND	ND	ND	ND
0453020-001	ROBINSONS MHP/UPPER	CHICHESTER	02/03/21	ND	ND	ND	ND
0455010-501	CHICHESTER CENTRAL SCH	CHICHESTER	12/07/20	ND	ND	ND	ND
0456010-502	CAMPING WORLD OF NEW HAMPSHIRE	CHICHESTER	09/27/21	ND	ND	ND	ND
0461010-002	CLAREMONT WATER DEPT	CLAREMONT	02/04/20	ND	ND	ND	ND
0461010-002	CLAREMONT WATER DEPT	CLAREMONT	02/04/20	ND	ND	ND	ND
0481010-503	COLEBROOK WATER WORKS	COLEBROOK	09/30/21	ND	ND	ND	ND
0481010-504	COLEBROOK WATER WORKS	COLEBROOK	09/30/21	ND	ND	ND	ND
0486010-501	KHEOPS INTERNATIONAL	COLEBROOK	09/30/21	ND	ND	ND	ND
0493020-002	MOUNTAIN VIEW PARK ESTATES	COLUMBIA	08/30/31	ND	ND	ND	ND
0501010-505	CONCORD WATER DEPT	CONCORD	08/12/20	2.69	ND	ND	ND
0505010-002	SHAKER RD SCH	CONCORD	02/11/21	ND	ND	ND	ND
0501010-002	CONCORD WATER DEPT	CONCORD	04/16/20	ND	ND	ND	ND
0501010-504	CONCORD WATER DEPT	CONCORD	04/16/20	ND	ND	ND	ND
0501010-506	CONCORD WATER DEPT	CONCORD	04/16/20	ND	ND	ND	ND
0501010-507	CONCORD WATER DEPT	CONCORD	04/16/20	ND	ND	ND	ND
0512190-001	BROOK VIEW VILLAGE	CONWAY	03/03/21	2.83	2.24	3.38	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE NAME	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
0512150-501	DEERBROOK CONDOS	CONWAY	05/28/21	6.05	3.42	ND	ND
0511010-501	CONWAY VILLAGE FIRE DIST	CONWAY	08/04/20	ND	ND	ND	ND
0511010-502	CONWAY VILLAGE FIRE DIST	CONWAY	08/04/20	ND	ND	ND	ND
0511030-503	NORTH CONWAY WATER PCT	CONWAY	03/18/21	ND	ND	ND	ND
0511030-508	NORTH CONWAY WATER PCT	CONWAY	03/18/21	ND	ND	ND	ND
0511030-509	NORTH CONWAY WATER PCT	CONWAY	03/18/21	ND	ND	ND	ND
0511030-510	NORTH CONWAY WATER PCT	CONWAY	03/18/21	ND	ND	ND	ND
0512030-500	CATHEDRAL LEDGE	CONWAY	04/06/21	ND	ND	ND	ND
0512050-000	ECHO LAKE WOODS	CONWAY	03/10/20	ND	ND	ND	ND
0512060-501	FOREST EDGE	CONWAY	12/03/20	ND	ND	ND	ND
0512070-001	FOREST PARK VILLAGE	CONWAY	03/12/20	ND	ND	ND	ND
0512080-501	REBECCA LANE WATER SYS	CONWAY	03/17/20	ND	ND	ND	ND
0512110-502	NORTH PINES	CONWAY	09/27/21	ND	ND	ND	ND
0512120-501	SACO RIVER FOREST	CONWAY	03/03/21	ND	ND	ND	ND
0512130-501	WOODLAND GROVE	CONWAY	03/10/20	ND	ND	ND	ND
0512140-002	SOUTH PINES	CONWAY	03/17/20	ND	ND	ND	ND
0512170-501	OAKWOOD HEIGHTS	CONWAY	12/02/20	ND	ND	ND	ND
0512180-502	SACO PINES	CONWAY	03/10/20	ND	ND	ND	ND
0512200-503	CEDAR CREEK	CONWAY	10/17/19	ND	ND	ND	ND
0512200-503	CEDAR CREEK	CONWAY	03/10/20	ND	ND	ND	ND
0512210-501	NEAR LEDGE	CONWAY	03/12/20	ND	ND	ND	ND
0512230-502	MELODY PINES CONDOS	CONWAY	03/17/20	ND	ND	ND	ND
0512240-506	ROCKHOUSE MOUNTAIN	CONWAY	03/18/21	ND	ND	ND	ND
0512240-508	ROCKHOUSE MOUNTAIN	CONWAY	03/18/21	ND	ND	ND	ND
0512250-501	SACO WOODS CONDOS	CONWAY	03/12/20	ND	ND	ND	ND
0512260-502	DAVIS HILL	CONWAY	12/04/20	ND	ND	ND	ND
0512270-501	HALE ESTATES	CONWAY	10/24/19	ND	ND	ND	ND
0513100-501	MOUNTAIN VALE VILLAGE MHP	CONWAY	05/24/21	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE NAME	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
0515010-001	CONWAY COMMUNITY BLDG	CONWAY	09/20/16	ND	ND	ND	ND
0515020-001	NEW PINE TREE SCH	CONWAY	01/26/21	ND	ND	ND	ND
0515040-501	LITTLE HANDS BIG DREAMS	CONWAY	01/29/21	ND	ND	ND	ND
0516020-501	NORTHERN HUMAN SVCS	CONWAY	12/22/20	ND	ND	ND	ND
0516030-001	CONWAY MUNICIPAL CENTER	CONWAY	12/04/20	ND	ND	ND	ND
0516040-001	LUPINE	CONWAY	10/23/19	ND	ND	ND	ND
0519020-002	CONWAY TOWN HALL	CONWAY	12/03/20	ND	ND	ND	ND
0525010-502	CORNISH ELEM SCH	CORNISH	10/07/21	ND	ND	ND	ND
0545010-001	CROYDON VILLAGE SCH	CROYDON	12/18/20	ND	ND	ND	ND
0575010-001	DANBURY ELEMENTARY SCH	DANBURY	12/30/20	ND	ND	ND	ND
0578060-001	DANBURY COUNTRY STORE	DANBURY	12/08/16	ND	ND	ND	ND
0583050-505	ROCK RIMMON COOPERATIVE	DANVILLE	04/14/21	2.54	ND	ND	ND
0583010-502	SPRUCE VALLEY MHP	DANVILLE	09/30/21	2.72	2.18	ND	ND
0585010-502	DANVILLE ELEMENTARY	DANVILLE	07/06/21	2.94	ND	ND	ND
0583020-501	IRON WHEEL MHP	DANVILLE	07/13/21	2.97	ND	ND	ND
0583030-506	COTTON FARMS MHP	DANVILLE	09/13/21	3.17	ND	ND	ND
0583030-510	COTTON FARMS MHP	DANVILLE	09/13/21	6.56	6.26	ND	2.10
0583020-006	IRON WHEEL MHP	DANVILLE	10/14/21	12.2	7.62	ND	4.30
0583020-005	IRON WHEEL MHP	DANVILLE	07/13/21	14.4	9.45	ND	5.05
0582010-501	COLBY POND	DANVILLE	03/09/21	ND	ND	ND	ND
0594030-001	SHERBURN WOODS	DEERFIELD	12/05/20	0.70	ND	ND	ND
0594010-003	CORNERSTONE PLACE	DEERFIELD	07/28/21	3.16	2.41	ND	ND
0595010-501	GEORGE B WHITE BLDG	DEERFIELD	08/11/21	4.70	4.24	ND	ND
0594020-501	INN AT DEERFIELD	DEERFIELD	01/04/21	ND	ND	ND	ND
0595020-501	DEERFIELD COMMUNITY SCH	DEERFIELD	12/05/19	ND	ND	ND	ND
0595040-001	LONGVIEW SCH	DEERFIELD	11/21/19	ND	ND	ND	ND
0603010-502	LONGWOODS MHP	DEERING	07/16/21	ND	ND	ND	ND
0603020-001	JOHNSON CITY MHP	DEERING	01/29/20	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE NAME	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
0605010-501	ROBIN HILL FARM/BLUE HOUSE	DEERING	09/08/21	ND	ND	ND	ND
0607030-503	HIS MANSION DIN HALL	DEERING	01/21/21	ND	ND	ND	ND
0609010-501	HIS MANSION NEW BEGINNING	DEERING	01/21/21	ND	ND	ND	ND
0612170-502	MAPLE HAVEN	DERRY	10/02/19	1.90	ND	ND	ND
0615060-501	E DERRY MEMORIAL ELEM SCH	DERRY	08/26/21	3.28	8.41	ND	22.80
0618150-501	COWBELL CORNERS	DERRY	09/13/21	3.98	ND	ND	ND
0612220-501	AUTUMN WOODS	DERRY	07/20/21	4.25	ND	ND	ND
0612150-504	DREW WOODS	DERRY	07/15/21	4.91	ND	ND	ND
0612070-502	GLEN RIDGE DEV	DERRY	07/15/21	5.21	ND	ND	ND
0616040-511	BROOKSTONE PARK/EAST	DERRY	07/10/21	5.96	3.57	ND	ND
0612210-503	OLD COACH VILLAGE	DERRY	08/25/20	6.81	5.45	ND	ND
0613030-501	RUNNING BROOK	DERRY	05/01/21	6.86	2.16	3.77	ND
0612230-501	RAND SHEPARD HILL	DERRY	07/20/21	6.94	2.09	ND	ND
0613010-001	ANNIE OAKLEY	DERRY	09/25/21	7.39	3.02	ND	ND
0613060-513	CENTENNIAL ESTATES	DERRY	07/07/21	10.5	ND	ND	ND
0612040-501	BARKLAND ACRES	DERRY	09/14/21	13.4	7.26	ND	2.60
0612050-000	MORNINGSIDE DRIVE	DERRY	09/22/21	16	4.83	ND	5.11
0612140-004	HI AND LO ESTATES	DERRY	07/07/21	27.2	4.89	2.41	2.45
0612110-501	PEU/FARMSTEAD ACRES	DERRY	10/02/19	ND	ND	ND	ND
0612160-001	WOODLAND AT DERRY	DERRY	07/27/16	ND	ND	ND	ND
0612240-501	WILLOW BEND	DERRY	12/26/20	ND	ND	ND	ND
0651010-517	DOVER WATER DEPT	DOVER	09/01/21	7.57	3.49	ND	6.85
0651010-005	DOVER WATER DEPT - WELL NOT IN USE	DOVER	10/13/16	82.00	160.00	35.00	6.20
0651010-007	DOVER WATER DEPT - WELL NOT IN USE	DOVER	07/05/18	106.00	173.00	50.70	ND
0651010-003	DOVER WATER DEPT	DOVER	09/01/21	ND	ND	ND	ND
0651010-502	DOVER WATER DEPT	DOVER	09/01/21	ND	ND	ND	ND
0651010-505	DOVER WATER DEPT	DOVER	09/01/21	ND	ND	ND	ND
0651010-515	DOVER WATER DEPT	DOVER	09/01/21	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE NAME	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
0655030-501	MISS PATTYS CHILDCARE	DOVER	06/28/21	ND	ND	ND	ND
0666010-501	YANKEE PUBLISHING	DUBLIN	09/28/21	2.02	ND	ND	ND
0664020-501	DUBLIN SCHOOL	DUBLIN	10/10/19	2.19	ND	ND	ND
0666030-501	DUBLIN VILLAGE PARK	DUBLIN	07/20/21	4.11	5.54	ND	ND
0665010-501	DUBLIN CONSOLIDATED SCH	DUBLIN	10/25/21	4.44	2.50	ND	ND
0664010-502	DUBLIN CHRISTIAN ACADEMY	DUBLIN	12/01/20	ND	ND	ND	ND
0664010-503	DUBLIN CHRISTIAN ACADEMY	DUBLIN	12/01/20	ND	ND	ND	ND
0665030-501	PHOENIX HOUSE DUBLIN CENTER	DUBLIN	03/16/21	ND	ND	ND	ND
0665030-501	PHOENIX HOUSE DUBLIN CENTER	DUBLIN	08/19/21	ND	ND	ND	ND
0665050-501	MOUNTAIN SHADOWS SCH	DUBLIN	09/23/21	ND	ND	ND	ND
0685010-502	DUNBARTON ELEMENTARY SCH	DUNBARTON	12/27/20	ND	ND	ND	ND
0691010-502	UNH/DURHAM WATER SYS	DURHAM	03/16/21	1.95	ND	ND	ND
0691010-501	UNH/DURHAM WATER SYS	DURHAM	05/22/20	2.02	ND	ND	ND
0694010-501	BROOKDALE SPRUCE WOOD	DURHAM	07/06/21	2.42	ND	ND	ND
0691010-002	UNH/DURHAM WATER SYS	DURHAM	05/25/21	ND	ND	ND	ND
0691010-002	UNH/DURHAM WATER SYS	DURHAM	05/25/21	ND	ND	ND	ND
0691010-003	UNH/DURHAM WATER SYS	DURHAM	03/08/21	ND	ND	ND	ND
0691010-005	UNH/DURHAM WATER SYS	DURHAM	03/08/21	ND	ND	ND	ND
0692010-501	JOHNSON CREEK	DURHAM	11/25/19	ND	ND	ND	ND
0692020-501	STAGECOACH FARMS	DURHAM	04/15/21	ND	ND	ND	ND
0702030-502	MAPLEVALE AND CRICKET HILL	EAST KINGSTON	07/14/21	5.52	ND	ND	ND
0702010-003	BARTON MHP	EAST KINGSTON	06/02/21	ND	ND	ND	ND
0702020-003	BRANDYWINE	EAST KINGSTON	10/22/19	ND	ND	ND	ND
0702020-501	BRANDYWINE	EAST KINGSTON	04/14/21	ND	ND	ND	ND
0702040-504	COUNTRY HILLS OF EAST KINGSTON	EAST KINGSTON	02/21/20	ND	ND	ND	ND
0705020-502	E KINGSTON ELEMENTARY SCH	EAST KINGSTON	05/18/21	ND	ND	ND	ND
0705020-503	E KINGSTON ELEMENTARY SCH	EAST KINGSTON	10/18/21	ND	ND	ND	ND
0708040-501	POWWOW JUNCTION	EAST KINGSTON	09/14/21	ND	ND	ND	ND

Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE NAME	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
0732020-502	GREEN MOUNTAIN TREATMENT CTR	EFFINGHAM	02/04/21	ND	ND	ND	ND
0732030-000	LOST VALLEY	EFFINGHAM	03/17/20	ND	ND	ND	ND
0732040-503	18 HUGHES LN	EFFINGHAM	02/10/21	ND	ND	ND	ND
0735030-001	EFFINGHAM ELEMENTARY SCH	EFFINGHAM	12/14/20	ND	ND	ND	ND
0751010-002	ENFIELD WATER DEPT	ENFIELD	09/15/20	ND	ND	ND	ND
0751010-003	ENFIELD WATER DEPT	ENFIELD	09/15/20	ND	ND	ND	ND
0751010-005	ENFIELD WATER DEPT	ENFIELD	09/15/20	ND	ND	ND	ND
0751010-504	ENFIELD WATER DEPT	ENFIELD	09/15/20	ND	ND	ND	ND
0752020-001	LAKEVIEW CONDOS	ENFIELD	01/05/21	ND	ND	ND	ND
0752020-002	LAKEVIEW CONDOS	ENFIELD	11/06/19	ND	ND	ND	ND
0753010-001	WILSONS MHP	ENFIELD	03/27/21	ND	ND	ND	ND
0753020-502	DANIELS ACRES	ENFIELD	12/03/19	ND	ND	ND	ND
0753030-501	LOWER SHAKER VILLAGE	ENFIELD	03/11/20	ND	ND	ND	ND
0753030-501	LOWER SHAKER VILLAGE	ENFIELD	10/02/19	ND	ND	ND	ND
0762080-501	VILLAGES ON THE LAMPREY	EPPING	04/14/21	6.08	2.7	2.84	ND
0761010-507	EPPING WATER AND SEWER DEPT	EPPING	01/21/20	ND	ND	ND	ND
0761010-514	EPPING WATER AND SEWER DEPT	EPPING	01/21/20	ND	ND	ND	ND
0762040-501	MELLING GLEN	EPPING	04/01/20	ND	ND	ND	ND
0762050-502	GOVERNORS GREEN	EPPING	04/01/20	ND	ND	ND	ND
0762070-502	PLUMER COURT	EPPING	01/05/21	ND	ND	ND	ND
0762120-502	WOODLANDS	EPPING	02/12/20	ND	ND	ND	ND
0763010-501	EVANS TRAILER PARK	EPPING	10/01/19	ND	ND	ND	ND
0773030-504	SHELTERING PINES MHP	EPSOM	07/07/21	2.85	ND	ND	ND
0771010-501	EPSOM VILLAGE DIST	EPSOM	08/13/21	6.22	2.07	ND	6.50
0773020-002	COLBY BROOK ESTATES	EPSOM	08/03/21	7.45	4.06	ND	ND
0771010-502	EPSOM VILLAGE DIST	EPSOM	08/13/21	7.75	ND	ND	3.37
0771020-500	KINGS GRANT	EPSOM	06/01/21	ND	ND	ND	ND
0773010-504	KINGS TOWNE MHP	EPSOM	11/16/20	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE NAME	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
0773020-504	COLBY BROOK ESTATES	EPSOM	07/07/21	ND	ND	ND	ND
0774010-001	EPSOM HEALTHCARE CTR	EPSOM	02/05/21	ND	ND	ND	ND
0774030-002	MEADOW BROOK	EPSOM	01/27/21	ND	ND	ND	ND
0775020-511	EPSOM MED CTR	EPSOM	12/05/20	ND	ND	ND	ND
0781010-501	ERROL WATER WORKS	ERROL	03/09/21	ND	ND	ND	ND
0805010-501	BUILDING BLOCK COMMONS	EXETER	06/17/21	2.12	ND	ND	ND
0801010-002	EXETER WATER DEPT	EXETER	08/05/20	2.35	1.13	ND	ND
0803020-502	EXETER RIVER MOBILE HOME PARK	EXETER	07/14/21	2.48	3.10	ND	ND
0801010-004	EXETER WATER DEPT	EXETER	08/05/20	2.60	ND	ND	ND
0803030-501	LANDING AT EXETER RIVER	EXETER	07/14/21	2.91	ND	ND	ND
0803050-501	ICEY HILL COOPERATIVE	EXETER	07/14/21	3.44	3.23	ND	ND
0802010-001	PICKPOCKET WOODS	EXETER	09/07/21	3.80	2.30	1.70	0.79
0803040-501	BEECH HILL PARK	EXETER	07/14/21	3.86	6.24	ND	ND
0804020-001	EXETER HOSPITAL	EXETER	08/03/16	4.00	8.00	24.00	3.00
0802030-000	LOUISBURG CIRCLE	EXETER	07/07/21	4.80	2.25	ND	ND
0801010-003	EXETER WATER DEPT	EXETER	08/05/20	5.13	4.37	2.01	ND
0804010-001	EXETER HOSPITAL/SLEEP MED - WELL NOT IN USE	EXETER	08/03/16	7.00	15.00	34.00	19.00
0804010-001	EXETER HOSPITAL/SLEEP MED - WELL NOT IN USE	EXETER	08/03/16	7.00	15.00	34.00	19.00
0801010-507	EXETER WATER DEPT	EXETER	08/05/20	ND	ND	ND	ND
0802020-001	EXETER HIGHLANDS	EXETER	08/13/21	ND	ND	ND	ND
0802040-501	PEU/FOREST RIDGE	EXETER	02/12/20	ND	ND	ND	ND
0805030-501	EXETER UNITED METHODIST CHURCH	EXETER	10/23/19	ND	ND	ND	ND
0805040-501	EXETER HIGH SCH	EXETER	03/17/21	ND	ND	ND	ND
0811010-504	FARMINGTON WATER DEPT	FARMINGTON	03/05/20	ND	ND	ND	ND
0811010-506	FARMINGTON WATER DEPT	FARMINGTON	03/05/20	ND	ND	ND	ND
0823010-001	20 JAFFREY RD	FITZWILLIAM	07/20/21	6.13	7.07	ND	ND
0825010-501	GEORGE S EMERSON ELEM SCH	FITZWILLIAM	09/09/21	6.85	7.96	ND	ND
0827070-001	MEADOWOOD ASSEMBLY HALL	FITZWILLIAM	07/05/16	ND	15.00	7.00	ND

Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE NAME	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
0821010-501	FITZWILLIAM VILLAGE/PRIGGE	FITZWILLIAM	07/20/21	ND	ND	ND	ND
0821010-511	FITZWILLIAM VILLAGE/LAUGHNER	FITZWILLIAM	02/19/21	ND	ND	ND	ND
0821010-512	FITZWILLIAM VILLAGE/LAUGHNER	FITZWILLIAM	02/18/21	ND	ND	ND	ND
0821010-511	FITZWILLIAM VILLAGE/MASSIN	FITZWILLIAM	02/19/21	ND	ND	ND	ND
0831010-505	FRANCESTOWN VILLAGE WATER	FRANCESTOWN	03/03/20	ND	ND	ND	ND
0832010-501	CROTCHED MOUNTAIN MNTNC	FRANCESTOWN	10/30/19	ND	ND	ND	ND
0835010-501	FRANCESTOWN ELEMENTARY SCH	FRANCESTOWN	10/30/19	ND	ND	ND	ND
0841010-501	FRANCONIA VILLAGE WATER	FRANCONIA	03/03/20	ND	ND	ND	ND
0841020-004	MITTERSILL WATER DEPT	FRANCONIA	03/03/20	ND	ND	ND	ND
0841020-005	MITTERSILL WATER DEPT	FRANCONIA	03/03/20	ND	ND	ND	ND
0851010-001	FRANKLIN WATER WORKS	FRANKLIN	06/07/21	ND	ND	ND	ND
0851010-002	FRANKLIN WATER WORKS	FRANKLIN	06/07/21	ND	ND	ND	ND
0851010-003	FRANKLIN WATER WORKS	FRANKLIN	06/07/21	ND	ND	ND	ND
0851010-004	FRANKLIN WATER WORKS	FRANKLIN	06/07/21	ND	ND	ND	ND
0862020-501	PINE LANDING CONDOS	FREEDOM	09/14/21	4.02	ND	ND	ND
0861010-501	FREEDOM VILLAGE WATER PRECINCT	FREEDOM	03/10/20	ND	ND	ND	ND
0862010-501	LOV WATER	FREEDOM	03/16/20	ND	ND	ND	ND
0862030-503	FREEDOM VILLAGE CONDOS	FREEDOM	03/16/20	ND	ND	ND	ND
0875030-501	COUNTRY CLUB FOR KIDS	FREMONT	07/27/21	3.72	2.40	ND	ND
0874020-501	COLONIAL POPLIN NURSING HOME	FREMONT	09/29/21	10.8	11.7	ND	2.95
0878020-001	FREMONT PIZZERIA RESTAURANT	FREMONT	02/09/18	12.00	28.00	5.00	0.50
0875010-502	ELLIS SCHOOL - BEFORE TREATMENT WAS INSTALLED	FREMONT	10/01/19	15.50	15.80	15.80	34.90
0872010-501	GOVERNORS FOREST	FREMONT	12/21/20	ND	ND	ND	ND
0872020-501	BLACKROCKS VILLAGE	FREMONT	03/09/21	ND	ND	ND	ND
0875010-503	ELLIS SCHOOL - AFTER TREATMENT WAS INSTALLED	FREMONT	07/28/21	ND	ND	ND	ND
0875040-001	BARNYARD BUDDIES	FREMONT	12/18/20	ND	ND	ND	ND
0876030-001	COOPERS CORNER/EAST	FREMONT	2/20/2020	ND	ND	ND	ND
0886150-501	GILFORD MUNICIPAL BLDG COMPLEX	GILFORD	09/28/21	5.62	45.2	3.42	20.4



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE NAME	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
0881010-003	GILFORD VILLAGE WATER DIST	GILFORD	11/16/16	ND	ND	ND	ND
0881010-004	GILFORD VILLAGE WATER DIST	GILFORD	11/16/16	ND	ND	ND	ND
0881010-005	GILFORD VILLAGE WATER DIST	GILFORD	11/16/16	ND	ND	ND	ND
0881010-503	ABENAKI WATER/GILFORD VILLAGE	GILFORD	01/18/21	ND	ND	ND	ND
0881020-010	GUNSTOCK ACRES VILL DIST	GILFORD	07/22/21	ND	ND	ND	ND
0881020-505	GUNSTOCK ACRES VILL DIST	GILFORD	07/22/21	ND	ND	ND	ND
0882010-001	CHALET VILLAGE	GILFORD	10/11/19	ND	ND	ND	ND
0882020-501	GILFORD FOREST ESTATES	GILFORD	02/12/21	ND	ND	ND	ND
0882040-002	LIBERTY HIGHLANDS WATER	GILFORD	01/20/21	ND	ND	ND	ND
0882050-001	BRAKE HILL ACRES	GILFORD	03/02/20	ND	ND	ND	ND
0882050-002	BRAKE HILL ACRES	GILFORD	03/02/20	ND	ND	ND	ND
0882060-502	WINNSTOCK CONDOS	GILFORD	01/25/21	ND	ND	ND	ND
0882080-001	CHERRY VALLEY CONDOS	GILFORD	10/11/19	ND	ND	ND	ND
0882090-001	GUNSTOCK GLEN WATER	GILFORD	03/02/20	ND	ND	ND	ND
0882100-511	BELKNAP HEIGHTS WATER	GILFORD	01/20/21	ND	ND	ND	ND
0882130-503	BROADVIEW CONDOS	GILFORD	10/01/19	ND	ND	ND	ND
0882140-003	MARINA BAY CONDOS I AND II	GILFORD	01/08/21	ND	ND	ND	ND
0882150-502	LAKE SHORE PARK	GILFORD	01/18/21	ND	ND	ND	ND
0882160-500	SAMOSSET AT WINNI	GILFORD	01/20/21	ND	ND	ND	ND
0882170-001	COUNTRY VILLAGE WAY	GILFORD	12/05/20	ND	ND	ND	ND
0882180-502	BROOKSIDE CROSSING	GILFORD	12/05/19	ND	ND	ND	ND
0882190-502	DOCKHAM SHORES ESTATES	GILFORD	03/02/20	ND	ND	ND	ND
0882220-101	BRETTON WOODS DEV	GILFORD	01/20/21	ND	ND	ND	ND
0882410-501	HAMPSHIRE VILLAGE	GILFORD	01/20/21	ND	ND	ND	ND
0882420-501	STONEWALL VILLAGE	GILFORD	03/25/21	ND	ND	ND	ND
0882210-502	GILFORD MEADOWS	GILFORD	11/11/19	ND	ND	ND	ND
0883010-501	OLD LAKE SHORE	GILFORD	12/11/20	ND	ND	ND	ND
0883030-505	MOUNTAIN VIEW HOUSING	GILFORD	11/05/19	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE NAME	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
0883040-503	LRMHV	GILFORD	01/27/21	ND	ND	ND	ND
0883060-501	EDGE OF WOODS	GILFORD	10/22/19	ND	ND	ND	ND
0885010-001	GILFORD ELEMENTARY SCH	GILFORD	12/29/20	ND	ND	ND	ND
0885020-003	GILFORD MIDDLE AND HIGH SCH	GILFORD	01/27/21	ND	ND	ND	ND
0885050-501	GILFORD PROFESSIONAL PARK	GILFORD	01/27/21	ND	ND	ND	ND
0886040-001	UNDER HIS WING PRESCHOOL	GILFORD	01/27/21	ND	ND	ND	ND
0886120-002	VILLAGE WEST I	GILFORD	03/25/21	ND	ND	ND	ND
0886170-501	VILLAGE WEST II	GILFORD	11/15/19	ND	ND	ND	ND
0886190-501	NHDOS MARINE PATROL	GILFORD	03/17/21	ND	ND	ND	ND
0887050-001	GUNSTOCK AREA	GILFORD	10/26/21	ND	ND	ND	ND
0887050-002	GUNSTOCK AREA	GILFORD	10/26/21	ND	ND	ND	ND
0887150-001	MEADOWBROOK/CONFERENCE CENTER	GILFORD	12/08/16	ND	ND	ND	ND
0888390-001	AIRPORT COUNTRY STORE	GILFORD	12/08/16	ND	ND	ND	ND
0895010-502	GILMANTON ELEMENTARY SCH	GILMANTON	07/22/21	3.13	ND	ND	ND
0905010-001	GILSUM ELEMENTARY SCH	GILSUM	12/29/20	ND	ND	ND	ND
0906010-501	WS BADGER CO	GILSUM	07/20/20	ND	ND	ND	ND
0912050-502	MT LAUREL ESTATES	GOFFSTOWN	08/17/21	11.10	ND	ND	ND
0911010-004	GOFFSTOWN VILLAGE PCT	GOFFSTOWN	03/03/20	ND	ND	ND	ND
0911010-501	GOFFSTOWN VILLAGE PCT	GOFFSTOWN	03/03/20	ND	ND	ND	ND
0911010-502	GOFFSTOWN VILLAGE PCT	GOFFSTOWN	03/03/20	ND	ND	ND	ND
0912020-502	ORCHARD HIGHLANDS	GOFFSTOWN	10/23/19	ND	ND	ND	ND
0912040-501	BRIAR COURT ESTATES	GOFFSTOWN	08/19/21	ND	ND	ND	ND
0915020-501	LEARN AS WE PLAY CHLD CARE CTR	GOFFSTOWN	10/23/19	ND	ND	ND	ND
0926010-502	ANDRO RANGER STATION	GORHAM	07/21/21	1.80	1.80	1.80	1.80
0921010-005	GORHAM WATER AND SEWER DEPT	GORHAM	01/24/20	ND	ND	ND	ND
0921010-501	GORHAM WATER AND SEWER DEPT	GORHAM	01/24/20	ND	ND	ND	ND
0921020-501	GORHAM HILL SPRING	GORHAM	01/24/20	ND	ND	ND	ND
0951010-506	VILLAGE DIST OF EASTMAN	GRANTHAM	01/22/20	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE NAME	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
0952020-001	GRAY LEDGES	GRANTHAM	04/08/21	ND	ND	ND	ND
0955010-001	GRANTHAM VILLAGE SCH	GRANTHAM	12/31/20	ND	ND	ND	ND
0956040-001	GRANTHAM GREENWAY	GRANTHAM	11/05/19	ND	ND	ND	ND
0972010-517	CROTCHED MOUNTAIN REHAB CENTER	GREENFIELD	09/15/21	ND	ND	ND	4.37
0972010-010	CROTCHED MOUNTAIN REHAB CENTER	GREENFIELD	04/02/21	ND	ND	ND	ND
0972010-011	CROTCHED MOUNTAIN REHAB CENTER	GREENFIELD	04/02/21	ND	ND	ND	ND
0972010-512	CROTCHED MOUNTAIN REHAB CENTER	GREENFIELD	04/02/21	ND	ND	ND	ND
0974010-502	GREENFIELD COMMONS	GREENFIELD	04/22/21	ND	ND	ND	ND
0975020-501	GREENFIELD ELEMENTARY SCH	GREENFIELD	12/04/20	ND	ND	ND	ND
0987050-001	BREAKFAST HILL GOLF CLUB	GREENLAND	06/17/21	15.00	2.68	ND	ND
0991010-001	GREENVILLE WATER DEPT	GREENVILLE	02/01/20	ND	ND	ND	ND
0993030-501	FROST TRAILER PARK	GREENVILLE	02/18/21	ND	ND	ND	ND
1021010-501	HALES LOCATION	HALES LOCATION	05/28/21	2.43	ND	ND	ND
1036080-001	RAM PRINTING	HAMPSTEAD	01/14/21	2.15	2.62	ND	ND
1031010-525	HAMPSTEAD AREA WATER	HAMPSTEAD	07/19/21	2.18	ND	ND	ND
1034010-501	HAMPSTEAD HOSPITAL	HAMPSTEAD	09/17/21	2.21	ND	ND	3.05
1032070-001	COACH RUN CONDOS	HAMPSTEAD	05/07/21	2.37	7.24	10.7	ND
1031010-020	HAMPSTEAD AREA WATER	HAMPSTEAD	07/19/21	2.82	ND	ND	ND
1031010-524	HAMPSTEAD AREA WATER	HAMPSTEAD	11/11/19	3.30	ND	ND	ND
1032070-001	COACH RUN CONDOS	HAMPSTEAD	09/17/21	3.55	9.43	ND	13.10
1035050-001	HAMPSTEAD ACADEMY	HAMPSTEAD	05/12/21	3.81	2.88	ND	ND
1036090-002	THUNDERLINE Z	HAMPSTEAD	10/15/21	3.98	4.18	ND	ND
1031010-515	HAMPSTEAD AREA WATER	HAMPSTEAD	07/19/21	4.31	ND	ND	ND
1031010-522	HAMPSTEAD AREA WATER	HAMPSTEAD	07/19/21	4.59	2.69	ND	ND
1035020-501	AGES AND STAGES HAMPSTEAD	HAMPSTEAD	07/22/21	5.25	2.66	ND	2.09
1035110-501	HAZEL DRIVE KIDS	HAMPSTEAD	09/24/21	5.38	21.7	ND	3.50
1031010-526	HAMPSTEAD AREA WATER	HAMPSTEAD	07/19/21	5.50	ND	ND	ND
1031010-529	HAMPSTEAD AREA WATER	HAMPSTEAD	07/19/21	5.75	2.19	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE NAME	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
1036010-501	HAMPSTEAD SHOPPERS VILLAGE	HAMPSTEAD	09/23/21	6.07	10.2	ND	ND
1031010-512	HAMPSTEAD AREA WATER	HAMPSTEAD	07/19/21	6.22	3.71	ND	ND
1031010-502	HAMPSTEAD AREA WATER	HAMPSTEAD	07/19/21	6.63	3.26	ND	ND
1031010-523	HAMPSTEAD AREA WATER	HAMPSTEAD	07/19/21	8.45	2.24	ND	2.47
1031010-504	HAMPSTEAD AREA WATER	HAMPSTEAD	07/19/21	ND	4.36	ND	ND
1031010-007	HAMPSTEAD AREA WATER	HAMPSTEAD	07/19/21	ND	ND	ND	ND
1031010-013	HAMPSTEAD AREA WATER	HAMPSTEAD	03/09/21	ND	ND	ND	ND
1031010-510	HAMPSTEAD AREA WATER	HAMPSTEAD	03/09/21	ND	ND	ND	ND
1031010-527	HAMPSTEAD AREA WATER	HAMPSTEAD	11/11/19	ND	ND	ND	ND
1031010-528	HAMPSTEAD AREA WATER	HAMPSTEAD	03/09/21	ND	ND	ND	ND
1031010-530	HAMPSTEAD AREA WATER	HAMPSTEAD	07/19/21	ND	ND	ND	ND
1032090-501	GLENWOOD NORTH	HAMPSTEAD	12/03/20	ND	ND	ND	ND
1035040-501	HAMPSTEAD MIDDLE SCH - PFAS TREATMENT INSTALLED	HAMPSTEAD	09/27/21	ND	ND	ND	ND
1036040-001	STAGE ROAD JUNCTION	HAMPSTEAD	03/17/21	ND	ND	ND	ND
1051010-531	AQUARION WATER/NH	HAMPTON	07/13/20	2.24	ND	ND	ND
1051010-521	AQUARION WATER/NH	HAMPTON	01/11/21	2.34	ND	ND	ND
1051010-508	AQUARION WATER/NH	HAMPTON	07/13/20	2.48	ND	ND	ND
1051010-529	AQUARION WATER/NH	HAMPTON	01/11/21	3.08	3.22	ND	ND
1051010-504	AQUARION WATER/NH	HAMPTON	04/14/21	3.71	2.28	ND	ND
1053030-502	TAYLOR RIVER ESTATES	HAMPTON	07/06/21	4.54	5.09	ND	ND
1051010-536	AQUARION WATER/NH	HAMPTON	02/10/21	5.87	3.03	ND	ND
1051010-511	AQUARION WATER/NH	HAMPTON	11/20/20	ND	ND	ND	ND
1053010-002	FOUR SEASONS MOBILE HOME PARK	HAMPTON	01/15/20	ND	ND	ND	ND
1053020-504	HEMLOCK HAVEN	HAMPTON	01/15/20	ND	ND	ND	ND
1045010-001	LINCOLN AKERMAN SCH	HAMPTON FALLS	03/17/21	2.13	2.24	ND	ND
1048120-002	153 LAFAYETTE RD WATER SYSTEM	HAMPTON FALLS	03/22/18	23.00	22.00	8.00	2.00
1042010-501	MEADOWS AT GRAPEVINE RUN	HAMPTON FALLS	01/13/21	ND	ND	ND	ND
1045010-501	LINCOLN AKERMAN SCH	HAMPTON FALLS	09/27/21	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE NAME	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
1045040-501	HERONFIELD ACADEMY	HAMPTON FALLS	11/18/19	ND	ND	ND	ND
1046050-502	CRN REALTY	HAMPTON FALLS	11/25/19	ND	ND	ND	ND
1061010-501	HANCOCK WATER WORKS	HANCOCK	02/11/20	ND	ND	ND	ND
1071010-511	HANOVER WATER DEPT	HANOVER	01/08/20	ND	ND	ND	ND
1075010-001	HAMPSHIRE COOP NURSERY SCH	HANOVER	12/18/20	ND	ND	ND	ND
1075020-501	MONTESSORI CHILDRENS SCH	HANOVER	03/17/20	ND	ND	ND	ND
1085020-502	CHESHIRE MILLS BOARDING HOUSE	HARRISVILLE	07/27/21	3.65	6.10	ND	ND
1086010-502	HISTORIC HARRISVILLE	HARRISVILLE	09/27/21	5.79	18.60	ND	ND
1085010-001	WELLS MEMORIAL SCH	HARRISVILLE	03/12/21	ND	ND	ND	ND
1097020-002	CNSP DRY RIVER CAMPGROUND	HARTS LOCATION	09/19/16	ND	ND	ND	ND
1101010-501	PRECINCT OF HAVERHILL CORNER	HAVERHILL	11/26/19	ND	ND	ND	ND
1101020-501	NO HAVERHILL WATER AND LIGHT	HAVERHILL	02/25/20	ND	ND	ND	ND
1101040-002	WOODSVILLE WATER AND LIGHT	HAVERHILL	02/25/20	ND	ND	ND	ND
1101050-001	MOUNTAIN LAKES WATER DEPT	HAVERHILL	09/14/21	ND	ND	ND	ND
1101050-004	MOUNTAIN LAKES WATER DEPT	HAVERHILL	09/14/21	ND	ND	ND	ND
1102020-001	FRENCH POND ESTATES	HAVERHILL	02/25/20	ND	ND	ND	ND
1105010-511	OLIVERIAN EAST CAMPUS	HAVERHILL	09/08/21	ND	ND	ND	ND
1105020-001	BECKET HOUSE AT HALL FARM	HAVERHILL	09/08/21	ND	ND	ND	ND
1107030-001	OLIVERIAN SCH	HAVERHILL	09/08/21	ND	ND	ND	ND
1112010-002	STONEGATE ACRES	HEBRON	02/26/21	ND	ND	ND	ND
1113010-503	HILLSIDE INN CONDOS	HEBRON	02/12/20	ND	ND	ND	ND
1113010-504	HILLSIDE INN CONDOS	HEBRON	02/12/20	ND	ND	ND	ND
1121010-004	COGSWELL SPRINGS WATER WORKS	HENNIKER	03/18/21	ND	ND	ND	ND
1121010-005	COGSWELL SPRINGS WATER WORKS	HENNIKER	03/18/21	ND	ND	ND	ND
1123020-503	WOOD HILL VILLAGE	HENNIKER	02/03/21	ND	ND	ND	ND
1123020-504	WOOD HILL VILLAGE	HENNIKER	02/03/21	ND	ND	ND	ND
1126030-001	HHP	HENNIKER	08/13/21	ND	ND	ND	ND
1127030-503	PATS PEAK	HENNIKER	03/09/21	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE NAME	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
1131010-001	HILL WATER WORKS	HILL	09/15/16	ND	ND	ND	ND
1131010-002	HILL WATER WORKS	HILL	01/27/21	ND	ND	ND	ND
1141010-002	HILLSBOROUGH WATER WORKS	HILLSBOROUGH	01/14/20	ND	ND	ND	ND
1141020-001	EMERALD LAKE	HILLSBOROUGH	03/27/20	ND	ND	ND	ND
1141020-506	EMERALD LAKE	HILLSBOROUGH	03/27/20	ND	ND	ND	ND
1141020-512	EMERALD LAKE	HILLSBOROUGH	03/27/20	ND	ND	ND	ND
1145010-501	ROSEWALD FARM	HILLSBOROUGH	10/22/19	ND	ND	ND	ND
1145020-001	HILLSBORO BAPTIST CH	HILLSBOROUGH	03/15/21	ND	ND	ND	ND
1151010-503	NORTH HINSDALE WATER DEPT	HINSDALE	02/18/21	ND	ND	ND	ND
1151010-506	NORTH HINSDALE WATER DEPT	HINSDALE	02/19/21	ND	ND	ND	ND
1151020-501	HINSDALE WATER DEPT/DOWNTOWN	HINSDALE	02/18/21	ND	ND	ND	ND
1156010-001	GEORGES FIELD WATER SYSTEM	HINSDALE	3/9/2020	ND	ND	ND	ND
1162010-500	HIGHLAND COLONY	HOLDERNESS	1/8/2020	ND	ND	ND	ND
1163010-001	TOWN LINE VILLAGE	HOLDERNESS	12/08/20	ND	ND	ND	ND
1163010-503	TOWN LINE VILLAGE	HOLDERNESS	12/08/20	ND	ND	ND	ND
1165010-501	WHITE MTN MONT SCH	HOLDERNESS	01/20/21	ND	ND	ND	ND
1165020-501	HOLDERNESS CENTRAL SCH	HOLDERNESS	02/11/20	ND	ND	ND	ND
1167190-001	SLNSC BLUE HERON SCH	HOLDERNESS	02/11/20	ND	ND	ND	ND
1175050-503	HOLLIS BROOKLINE HS	HOLLIS	05/18/21	2.62	ND	ND	ND
1176010-502	HOLLIS VILLAGE MARKET PLACE	HOLLIS	07/21/21	2.82	ND	ND	ND
1176100-001	18 CLINTON DR BLDG	HOLLIS	05/19/21	3.05	ND	ND	ND
1176090-501	FARM DESIGN	HOLLIS	09/14/21	3.15	ND	ND	ND
1172020-503	RUNNELLS LANDING	HOLLIS	08/16/21	4.42	ND	ND	ND
1175060-001	HOLLIS MONT SCH	HOLLIS	09/22/21	6.57	5.19	ND	ND
1176080-501	PURITAN PRESS	HOLLIS	08/16/21	8.36	3.26	ND	ND
1173020-503	PITARYS MOBILE HOME PARK/WEST	HOLLIS	07/14/21	8.67	3.42	ND	ND
1173010-501	PITARYS MOBILE HOME PARK/EAST	HOLLIS	07/14/21	13.40	7.70	ND	2.01
1172030-501	SILVER LAKE ESTATES	HOLLIS	11/18/19	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE NAME	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
1175030-501	HOLLIS SCH DIST	HOLLIS	11/18/19	ND	ND	ND	ND
1176020-501	26 CLINTON DRIVE BLDG	HOLLIS	01/22/20	ND	ND	ND	ND
1176030-001	HOLLIS LINE MACHINE	HOLLIS	11/18/19	ND	ND	ND	ND
1176060-501	DIAMOND CASTING MACHINE	HOLLIS	04/06/21	ND	ND	ND	ND
1176070-001	ULTRASOURCE	HOLLIS	02/25/20	ND	ND	ND	ND
1186010-002	198 LONDONDERRY TURNPIKE	HOOKSETT	09/27/21	2.65	ND	ND	ND
1185010-501	PLACES YOU'LL GROW	HOOKSETT	09/21/21	5.35	ND	ND	ND
1181020-503	HOOKSETT VILLAGE WATER PCT	HOOKSETT	01/06/20	ND	ND	ND	ND
1181020-504	HOOKSETT VILLAGE WATER PCT	HOOKSETT	01/06/20	ND	ND	ND	ND
1181020-506	HOOKSETT VILLAGE WATER PCT	HOOKSETT	01/06/20	ND	ND	ND	ND
1181020-507	HOOKSETT VILLAGE WATER PCT	HOOKSETT	01/06/20	ND	ND	ND	ND
1889030-501	NHDOT BURUUAU TURNPIKE	HOOKSETT	04/02/21	ND	ND	ND	ND
1191020-002	HOPKINTON VILLAGE PCT	HOPKINTON	02/19/17	1.00	ND	1.80	ND
1192010-001	E PENACOOK RD WATER SYS	HOPKINTON	04/23/18	19.80	13.40	ND	ND
1191010-501	CONTOOCOOK VILLAGE PCT	HOPKINTON	02/24/20	ND	ND	ND	ND
1191020-001	HOPKINTON VILLAGE PCT	HOPKINTON	02/19/17	ND	ND	ND	ND
1191020-003	HOPKINTON VILLAGE PCT	HOPKINTON	03/10/21	ND	ND	ND	ND
1191020-502	HOPKINTON VILLAGE PCT	HOPKINTON	03/10/21	ND	ND	ND	ND
1193010-501	MEADOWS THE	HOPKINTON	01/29/20	ND	ND	ND	ND
1193020-503	ELM BROOK VILLAGE	HOPKINTON	10/15/21	ND	ND	ND	ND
1193030-000	DEER MEADOWS	HOPKINTON	01/29/20	ND	ND	ND	ND
1195040-001	BEECH HILL SCH	HOPKINTON	02/11/21	ND	ND	ND	ND
1196030-001	MCLANE NORTHEAST	HOPKINTON	02/03/21	ND	ND	ND	ND
1196050-502	YANKEE BOOK PEDDLER	HOPKINTON	02/03/21	ND	ND	ND	ND
1202010-503	FRANCOEUR APT/HUDSON MOTOR INN	HUDSON	08/03/21	2.95	ND	ND	ND
1203010-522	HUDSON MOBILE HOME ESTS	HUDSON	07/12/21	4.92	ND	ND	ND
1201010-501	HUDSON WATER DEPT	HUDSON	10/06/21	8.74	2.25	ND	ND
1201010-502	HUDSON WATER DEPT	HUDSON	06/01/21	13.60	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE NAME	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
1205060-001	KIDDIE KONNECTION	HUDSON	03/09/21	15.4	14.4	ND	2.69
1201010-008	HUDSON WATER DEPT	HUDSON	12/11/20	23.10	ND	2.98	ND
1205070-501	EARLY START LEARNING ACAD	HUDSON	09/09/21	ND	ND	ND	ND
1212110-502	EAGLE MOUNTAIN HOUSE	JACKSON	05/28/21	3.18	18.1	ND	4.41
1211010-501	JACKSON WATER PCT	JACKSON	02/11/20	ND	ND	ND	ND
1212030-501	WILDCAT TOWNHOUSE RESORT	JACKSON	09/22/21	ND	ND	ND	ND
1212050-511	MT JEFFERSON/WASHINGTON CONDOS	JACKSON	02/11/20	ND	ND	ND	ND
1212060-002	ELLIS RIVER VILLAGE	JACKSON	08/23/16	ND	ND	ND	ND
1212080-512	BLACK MOUNTAIN MEADOW CONDOS	JACKSON	03/09/20	ND	ND	ND	ND
1212090-501	HIGH PASTURES AT BLACK MTN	JACKSON	03/12/20	ND	ND	ND	ND
1212130-501	EAGLE BROOK	JACKSON	02/11/20	ND	ND	ND	ND
1212140-001	TYROL WELL A	JACKSON	03/18/20	ND	ND	ND	ND
1212140-001	TYROL WELL A	JACKSON	11/11/19	ND	ND	ND	ND
1218010-001	DANA PLACE	JACKSON	09/22/21	ND	ND	ND	ND
1221010-505	JAFFREY WATER WORKS	JAFFREY	08/09/21	2.93	13.90	ND	4.13
1221010-511	JAFFREY WATER WORKS	JAFFREY	08/09/21	9.35	2.63	ND	12.20
1221010-502	JAFFREY WATER WORKS	JAFFREY	12/01/20	ND	ND	ND	ND
1221010-506	JAFFREY WATER WORKS	JAFFREY	12/01/20	ND	ND	ND	ND
1241010-005	KEENE WATER DEPT	KEENE	01/29/20	ND	ND	ND	ND
1241010-006	KEENE WATER DEPT	KEENE	01/29/20	ND	ND	ND	ND
1241010-501	KEENE WATER DEPT	KEENE	01/29/20	ND	ND	ND	ND
1241010-502	KEENE WATER DEPT	KEENE	01/29/20	ND	ND	ND	ND
1241010-503	KEENE WATER DEPT	KEENE	01/29/20	ND	ND	ND	ND
1241010-504	KEENE WATER DEPT	KEENE	01/21/21	ND	ND	ND	ND
1245010-001	MONADNOCK WALDORF SCH	KEENE	12/10/20	ND	ND	ND	ND
1256010-503	UNITIL ENERGY SYS	KENSINGTON	04/14/20	9.25	7.18	ND	ND
1256010-003	UNITIL ENERGY SYS	KENSINGTON	4/14/2020	15.7	16.2	3.16	2.66
1255010-502	KENSINGTON ELEMENTARY SCH	KENSINGTON	11/27/20	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE NAME	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
1272040-500	ROWELL ESTATES	KINGSTON	04/14/21	2.91	ND	ND	ND
1275060-501	SANBORN REGIONAL HIGH SCH	KINGSTON	09/16/21	4.10	ND	ND	ND
1278060-501	CARRIAGE TOWN PLAZA	KINGSTON	08/13/21	5.28	ND	ND	13.80
1277090-001	COUNTRY SHORE CAMPGROUND	KINGSTON	07/01/19	20.80	ND	ND	ND
1277090-002	COUNTRY SHORE CAMPGROUND	KINGSTON	08/27/19	22.00	2.39	ND	ND
1272010-501	KINGSTON PINES ELDERLY HOUSING	KINGSTON	10/01/19	ND	ND	ND	ND
1272020-501	ANNS LANDING	KINGSTON	10/25/19	ND	ND	ND	ND
1272030-501	LAMPLIGHTER ESTATES	KINGSTON	03/09/21	ND	ND	ND	ND
1272050-501	COOPERS GROVE	KINGSTON	03/08/21	ND	ND	ND	ND
1272060-501	VILLAGE AT GRAN FIELDS	KINGSTON	05/17/21	ND	ND	ND	ND
1272070-502	KINGS LANDING	KINGSTON	03/09/21	ND	ND	ND	ND
1272080-501	ALL AMERICAN AL	KINGSTON	01/13/21	ND	ND	ND	ND
1275010-501	DANIEL J BAKIE SCH	KINGSTON	09/28/21	ND	ND	ND	ND
1276020-501	266 ROUTE 125	KINGSTON	10/16/19	ND	ND	ND	ND
1279010-511	KINGSTON CHILDREN CENTER	KINGSTON	12/18/20	ND	ND	ND	ND
1279040-001	KINGSTON TOWN HALL	KINGSTON	01/04/17	ND	ND	ND	ND
1285010-502	LACONIA CHRISTIAN SCH	LACONIA	09/13/21	3.47	ND	ND	ND
1281010-001	LACONIA WATER WORKS	LACONIA	03/09/21	ND	ND	ND	ND
1282010-501	MOUNTAIN VIEW APTS	LACONIA	04/06/21	ND	ND	ND	ND
1282020-001	WENTWORTH COVE ESTATES	LACONIA	03/02/20	ND	ND	ND	ND
1282030-001	PENDLETON COVE	LACONIA	03/02/20	ND	ND	ND	ND
1282050-500	WINDEMERE RIDGE	LACONIA	09/13/21	ND	ND	ND	ND
1289010-002	PRESCOTT FARM ENVIRON ED CTR	LACONIA	03/05/20	ND	ND	ND	ND
1291010-002	LANCASTER WATER DEPT	LANCASTER	03/31/21	ND	ND	ND	ND
1296010-001	EASTER SEALS YOUTH RES	LANCASTER	03/09/21	ND	ND	ND	ND
1305020-501	LANDAFF BLUE SCH	LANDAFF	12/29/21	ND	ND	ND	ND
1315010-002	FALL MOUNTAIN REGIONAL HS	LANGDON	07/15/20	ND	ND	ND	ND
1315020-002	SARAH PORTER SCH	LANGDON	07/15/20	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE NAME	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
1321010-002	LEBANON WATER DEPT	LEBANON	01/22/20	ND	ND	ND	ND
1323020-001	MASCOMA MEADOWS	LEBANON	11/05/19	ND	ND	ND	ND
1323030-002	OLYMPIC MOBILE HOME VILL/UPPER	LEBANON	11/05/19	ND	ND	ND	ND
1323040-002	CURRIERS MHP	LEBANON	11/05/19	ND	ND	ND	ND
1323050-001	OLYMPIC MOBILE HOME VILL/LOWER	LEBANON	11/05/19	ND	ND	ND	ND
1332020-502	DARBY FIELD COMMONS	LEE	04/22/21	4.25	ND	ND	ND
1333020-000	PINE KNOLL VILLAGE	LEE	04/29/21	5.49	ND	ND	ND
1335020-001	LIVE AND LEARN DAY CARE	LEE	08/31/21	6.06	9.16	ND	ND
1339030-001	WENTWORTH DOUGLASS MED OFFICE	LEE	08/26/21	12.40	ND	ND	ND
1332010-001	OYSTER RIVER CONDOS	LEE	01/27/21	ND	ND	ND	ND
1332030-501	GREYSTONE COMMONS	LEE	03/25/20	ND	ND	ND	ND
1332040-001	CEDAR WOOD ESTATES	LEE	02/19/21	ND	ND	ND	ND
1332050-501	PEU/THURSTON WOODS	LEE	02/12/20	ND	ND	ND	ND
1333010-501	HILL ACRES TRAILER PARK	LEE	04/01/21	ND	ND	ND	ND
1333030-501	EVERGREEN TERRACE	LEE	03/15/21	ND	ND	ND	ND
1333060-501	PACKERS FALLS VILLAGE	LEE	04/21/21	ND	ND	ND	ND
1334010-501	KIRKWOOD CORNERS SENIOR LIVING	LEE	11/25/19	ND	ND	ND	ND
1335010-501	MAST WAY ELEMENTARY SCH	LEE	11/25/19	ND	ND	ND	ND
1335030-002	GROWING PLACES	LEE	02/03/21	ND	ND	ND	ND
1336020-001	LEE MARKETPLACE	LEE	09/30/21	ND	ND	ND	ND
1336020-002	LEE MARKETPLACE	LEE	09/30/21	ND	ND	ND	ND
1336020-003	LEE MARKETPLACE	LEE	09/30/21	ND	ND	ND	ND
1336030-001	BENUCK AND RAINEY	LEE	11/21/20	ND	ND	ND	ND
1339010-501	LEE CONGREGATIONAL CH	LEE	02/03/21	ND	ND	ND	ND
1345010-503	LEMPSTER COMMUNITY SCH	LEMPSTER	07/14/21	10.20	ND	ND	ND
1351010-004	LINCOLN WATER WORKS	LINCOLN	02/04/20	ND	ND	ND	ND
1351010-005	LINCOLN WATER WORKS	LINCOLN	02/04/20	ND	ND	ND	ND
1351010-506	LINCOLN WATER WORKS	LINCOLN	02/04/20	ND	ND	ND	ND

Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE NAME	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
1361010-502	LISBON WATER DEPT	LISBON	02/04/20	ND	ND	ND	ND
1361010-503	LISBON WATER DEPT	LISBON	02/04/20	ND	ND	ND	ND
1378050-001	ROMANOS PIZZA - WELL NOT IN USE	LITCHFIELD	04/26/16	23.00	ND	ND	ND
1376010-001	LITCHFIELD TECHNOLOGY PARK - WELL NOT IN USE	LITCHFIELD	03/09/16	34.00	ND	ND	ND
1377020-001	MELS FUNWAY PARK - WELL NOT IN USE	LITCHFIELD	03/09/16	57.00	ND	ND	ND
1378060-001	NATICOOK GRILL - WELL NOT IN USE	LITCHFIELD	04/21/16	61.00	ND	ND	ND
1372020-001	LITCHFIELD APARTMENTS - WELL NOT IN USE	LITCHFIELD	03/13/16	87.00	ND	ND	ND
1378030-001	LITCHFIELD PLAZA - WELL NOT IN USE	LITCHFIELD	04/15/16	92.00	ND	ND	ND
1378010-001	CROFTERS PUB - WELL NOT IN USE	LITCHFIELD	05/06/16	110.00	ND	ND	ND
1378070-001	LOBSTER BOAT PLZ	LITCHFIELD	08/25/21	ND	ND	ND	ND
1379010-502	TABERNACLE CHRISTIION CH	LITCHFIELD	04/29/21	ND	ND	ND	ND
1381010-002	LITTLETON WATER AND LIGHT DEPT	LITTLETON	09/08/20	ND	ND	ND	ND
1381010-501	LITTLETON WATER AND LIGHT DEPT	LITTLETON	08/19/20	ND	ND	ND	ND
1386010-501	PEAK THREE	LITTLETON	04/02/21	ND	ND	ND	ND
1395090-501	ARK LEARNNG CENTER	LONDONDERRY	04/20/21	2.32	ND	ND	ND
1395140-501	VICTORY BAPTIST SCH	LONDONDERRY	06/29/21	2.77	ND	ND	2.49
1392050-501	BOUMIL GROVE CONDOS	LONDONDERRY	09/30/21	3.4	ND	ND	ND
1393060-502	PONDEROSA MHP	LONDONDERRY	09/06/21	4.08	ND	ND	ND
1392310-501	PEU/MINISTERIAL/PARRISH HILLS	LONDONDERRY	07/08/21	4.14	ND	ND	ND
1392040-501	PEU/PINEHAVEN WATER TRUST	LONDONDERRY	07/08/21	5.56	2.5	ND	ND
1395090-502	ARK LEARNNG CENTER	LONDONDERRY	10/21/21	5.99	3.16	ND	ND
1392010-500	OAKRIDGE CONDOS	LONDONDERRY	07/21/21	6.4	3.22	ND	ND
1392300-001	SOUTHVIEW CONDOS	LONDONDERRY	04/22/21	7.44	3.21	ND	ND
1696070-003	TOWNE SQUARE PROF CONDOS	LONDONDERRY	07/29/21	7.92	ND	ND	ND
1392320-001	BITIM APARTMENTS	LONDONDERRY	08/02/21	8.41	ND	ND	ND
1396060-501	ZOHL WPS INC	LONDONDERRY	02/22/21	9.74	2.12	ND	ND
1396060-501	HOLTON	LONDONDERRY	09/24/21	13.2	2.03	ND	ND
1392070-501	MIDRIDGE CONDOS	LONDONDERRY	08/02/21	13.3	3.15	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE NAME	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
1392220-501	ROLLING MEADOWS CONDOS III	LONDONDERRY	10/18/21	16.5	9.5	ND	4.25
1392180-502	CENTURY VILLAGE CONDOS	LONDONDERRY	07/08/21	18.2	7.14	ND	2.11
1393050-512	WAGON WHEEL	LONDONDERRY	07/30/21	18.50	ND	ND	ND
1396110-501	REEDS FERRY SMALL BLDG	LONDONDERRY	07/23/21	20.40	ND	ND	ND
1392030-512	OLDE COUNTRY VILLAGE	LONDONDERRY	09/08/21	23.2	5.19	ND	2.82
1392130-512	STONEHENGE APARTMENTS	LONDONDERRY	01/11/21	24.40	ND	ND	ND
1392200-001	ROLLING MEADOWS CONDOS I	LONDONDERRY	10/18/21	25.9	10	ND	3.67
1392230-001	ROLLING MEADOWS CONDOS IV	LONDONDERRY	10/18/21	26.8	8.74	ND	2.48
1392290-501	PEU/HARVEST VILLAGE	LONDONDERRY	07/08/21	ND	ND	ND	ND
1395110-501	28 BUTTRICK RD PROPERTY	LONDONDERRY	03/05/20	ND	ND	ND	ND
1403040-001	PRESIDENTIAL PINES/LOWER	LOUDON	04/16/21	3.11	4.40	ND	ND
1407020-001	NH MOTOR SPEEDWAY	LOUDON	09/29/20	ND	4.18	ND	ND
1402010-001	FLINTLOCK APTS	LOUDON	01/29/20	ND	ND	ND	ND
1402020-501	VILLAGES AT LOUDON	LOUDON	01/20/21	ND	ND	ND	ND
1402030-001	VOA/NNE SENIOR HOUSING	LOUDON	10/29/19	ND	ND	ND	ND
1403010-501	KOS MANUFACTURED HOUSING CMNTY	LOUDON	01/08/21	ND	ND	ND	ND
1403030-001	FREEDOM HILL/PINE RIDGE	LOUDON	01/13/21	ND	ND	ND	ND
1403020-501	PRESIDENTIAL PINES/UPPER	LOUDON	11/14/19	ND	ND	ND	ND
1405010-002	LOUDON ELEMENTARY SCH	LOUDON	11/14/19	ND	ND	ND	ND
1407060-001	NH MOTOR SPEEDWAY/MAIN OFFICE	LOUDON	06/24/20	ND	ND	ND	ND
1435050-001	LYME NURSERY SCHL	LYME	03/01/21	ND	2.30	ND	ND
1431010-001	LYME WATER	LYME	01/05/21	ND	ND	ND	ND
1431010-003	LYME WATER	LYME	01/05/21	ND	ND	ND	ND
1431010-004	LYME WATER	LYME	01/05/21	ND	ND	ND	ND
1432010-001	POND VIEW APTS	LYME	02/03/21	ND	ND	ND	ND
1435030-501	CROSSROADS ACADEMY	LYME	03/01/21	ND	ND	ND	ND
1435040-001	CROSSROADS ACADEMY/NORTH	LYME	03/17/20	ND	ND	ND	ND
1436020-501	PATHWAYS ORFORD ROAD RESIDENCE	LYME	10/22/19	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE NAME	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
1445010-001	LYNDEBOROUGH CENTRAL SCH	LYNDEBOROUGH	09/13/21	4.96	5.73	ND	5.18
1455010-501	MOHARIMET SCH	MADBURY	12/28/20	ND	ND	ND	ND
1456020-501	MADBURY WOODS APARTMENTS	MADBURY	10/01/19	ND	ND	ND	ND
1456030-501	CARRIAGE HILL AL	MADBURY	02/03/21	ND	ND	ND	ND
1458010-002	LITTLE TREE ED CTR	MADBURY	03/31/21	ND	ND	ND	ND
1463010-001	BROOKWOOD PARK	MADISON	07/15/21	2.08	ND	ND	ND
1466050-002	MACLEAN PRECISION MACHINE	MADISON	08/03/21	6.91	22.2	2.17	60.90
1461010-011	VILLAGE DISTRICT OF EIDELWEISS	MADISON	02/23/21	ND	ND	ND	ND
1461010-510	VILLAGE DISTRICT OF EIDELWEISS	MADISON	01/25/21	ND	ND	ND	ND
1462040-501	SILVER LAKE LANDING SR HOUSING	MADISON	3/10/2020	ND	ND	ND	ND
1465010-002	MADISON ELEMENTARY SCH	MADISON	01/27/21	ND	ND	ND	ND
1466020-000	MADISON LUMBER MILL	MADISON	10/03/19	ND	ND	ND	ND
1471010-001	MANCHESTER WATER WORKS	MANCHESTER	10/14/21	5.17	ND	ND	ND
1471010-003	MANCHESTER WATER WORKS	MANCHESTER	07/08/21	5.24	ND	ND	ND
1472030-501	ROCKWOOD TERRACE CONDOS	MANCHESTER	04/15/21	10.90	2.28	ND	ND
1481010-001	MARLBOROUGH WATER WORKS	MARLBOROUGH	03/16/21	ND	ND	ND	ND
1481010-504	MARLBOROUGH WATER WORKS	MARLBOROUGH	03/16/21	ND	ND	ND	ND
1482010-501	MARLBOROUGH ESTATES	MARLBOROUGH	10/29/19	ND	ND	ND	ND
1495010-001	JOHN D PERKINS SR ELEM SCH - NO TREATMENT INSTALLED	MARLOW	12/29/20	3.03	84.4	24	ND
1495010-501	JOHN D PERKINS SR ELEM SCH - PFAS TREATMENT INSTALLED	MARLOW	09/08/21	5.18	ND	ND	ND
1515010-501	MASON PUBLIC SCH	MASON	12/30/20	ND	ND	ND	ND
1522040-002	SANDS OF BROOKHURST	MEREDITH	04/14/21	3.63	2.62	ND	ND
1521010-003	MEREDITH WATER DEPT	MEREDITH	01/07/20	ND	ND	ND	ND
1522010-502	PATRICIAN SHORES	MEREDITH	03/09/20	ND	ND	ND	ND
1522020-501	EAST BLUFF HIGHLAND CONDOS	MEREDITH	01/27/21	ND	ND	ND	ND
1522030-001	EAST BLUFF VILLAGE CONDOS	MEREDITH	01/27/21	ND	ND	ND	ND
1522070-500	PINE HILL COMMUNITY ASSN	MEREDITH	10/22/19	ND	ND	ND	ND
1522090-500	GROUSE POINT CLUB	MEREDITH	12/05/20	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE NAME	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
1524010-000	FORESTVIEW MANOR	MEREDITH	02/10/21	ND	ND	ND	ND
1525010-001	INTER LAKES HIGH SCH	MEREDITH	02/19/20	ND	ND	ND	ND
1525020-502	INTER LAKES ELEMENTARY SCH	MEREDITH	02/19/20	ND	ND	ND	ND
1531010-008	MERRIMACK VILLAGE DIST	MERRIMACK	04/26/21	13.20	ND	ND	ND
1531010-505	MERRIMACK VILLAGE DIST	MERRIMACK	07/15/21	13.40	ND	ND	ND
1531010-504	MERRIMACK VILLAGE DIST	MERRIMACK	07/15/21	17.10	ND	ND	ND
1531010-003	MERRIMACK VILLAGE DIST	MERRIMACK	04/26/21	20.50	2.08	ND	ND
1531010-009	MERRIMACK VILLAGE DIST	MERRIMACK	04/26/21	20.70	ND	ND	ND
1531010-508	MERRIMACK VILLAGE DIST	MERRIMACK	07/15/21	26.20	2.74	ND	ND
1531010-007	MERRIMACK VILLAGE DIST	MERRIMACK	04/26/21	29.50	3.28	ND	ND
1531010-005	MERRIMACK VILLAGE DIST	MERRIMACK	04/26/21	42.20	ND	2.12	ND
1531010-011	MERRIMACK VILLAGE DIST	MERRIMACK	04/26/21	86.60	4.38	2.65	ND
1531010-509	MERRIMACK VILLAGE DIST	MERRIMACK	10/21/21	ND	ND	ND	ND
1542030-500	PEU/SUNRISE ESTATES	MIDDLETON	02/11/20	ND	ND	ND	ND
1545010-501	MIDDLETON ELEM SCH	MIDDLETON	07/14/21	ND	ND	ND	ND
1555010-002	MILAN VILLAGE SCH	MILAN	08/31/21	1.80	1.80	1.80	1.80
1553010-001	DEER ESTATES	MILAN	10/24/19	ND	ND	ND	ND
1562030-503	BADGER HILL	MILFORD	07/15/21	2.13	ND	ND	ND
1561010-504	MILFORD WATER UTILITIES DEPT	MILFORD	09/17/21	2.93	ND	ND	ND
1561010-509	MILFORD WATER UTILITIES DEPT	MILFORD	09/17/21	5.02	ND	ND	ND
1566020-501	MILFORD TECHNOLOGY CENTER	MILFORD	07/20/21	21.80	ND	ND	2.26
1565010-501	LITTLE ARROWS CC SVS	MILFORD	09/22/21	ND	2.01	ND	24.70
1562040-501	HERITAGE WAY	MILFORD	04/06/20	ND	ND	ND	ND
1563020-101	FAIRHAVEN MOBILE HOME PARK	MILFORD	07/12/21	ND	ND	ND	ND
1566040-501	115/119 EMERSON RD	MILFORD	11/20/19	ND	ND	ND	ND
1581010-502	MILTON WATER DIST	MILTON	03/09/21	ND	ND	ND	ND
1581010-504	MILTON WATER DIST	MILTON	03/09/21	ND	ND	ND	ND
1582010-501	SHORTRIDGE ACADEMY	MILTON	10/18/19	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE NAME	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
1583010-502	PINELAND PARK	MILTON	03/15/20	ND	ND	ND	ND
1585030-001	MILTON CHILDRENS CENTER	MILTON	11/07/19	ND	ND	ND	ND
1586040-001	INDEX PACKAGING	MILTON	07/23/21	ND	ND	ND	ND
1591010-511	MONROE WATER DEPT	MONROE	02/25/20	ND	ND	ND	ND
1591010-512	MONROE WATER DEPT	MONROE	02/25/20	ND	ND	ND	ND
1605010-501	MONT VERNON VILLAGE SCH	MONT VERNON	08/03/21	7.54	ND	ND	ND
1603010-516	ROLLING ACRES MHP	MONT VERNON	07/20/21	ND	ND	ND	ND
1612030-501	FAR ECHO HARBOR	MOULTONBOROUGH	04/23/21	3.18	6.29	5.80	ND
1616010-000	HARBOR PINES ON LAKE SHORE DR	MOULTONBOROUGH	08/02/21	4.30	ND	ND	ND
1615050-001	RED HILL BUSINESS CENTER	MOULTONBOROUGH	10/10/19	13.10	ND	ND	ND
1618240-001	HARBOR SQUARE SHOPPING CENTER	MOULTONBOROUGH	07/22/21	14.80	ND	ND	ND
1612220-000	HARBOURSIDE ON WINNI	MOULTONBOROUGH	07/01/21	ND	17.80	2.15	23.10
1612010-501	PARADISE SHORES	MOULTONBOROUGH	03/16/20	ND	ND	ND	ND
1612010-508	PARADISE SHORES	MOULTONBOROUGH	03/16/20	ND	ND	ND	ND
1612040-500	WEST POINT	MOULTONBOROUGH	03/09/20	ND	ND	ND	ND
1612080-501	WEST WYNDE VILLAGE	MOULTONBOROUGH	04/06/21	ND	ND	ND	ND
1612170-000	JONATHANS LANDING CONDOS	MOULTONBOROUGH	07/02/21	ND	ND	ND	ND
1612200-000	LANDS END	MOULTONBOROUGH	03/09/20	ND	ND	ND	ND
1612210-501	WINDWARD HARBOR CONDOS	MOULTONBOROUGH	02/11/20	ND	ND	ND	ND
1612230-001	KILNWOOD ON KANASATKA	MOULTONBOROUGH	04/02/21	ND	ND	ND	ND
1612250-511	WENTWORTH ACRES	MOULTONBOROUGH	12/18/20	ND	ND	ND	ND
1612260-000	CROSSWINDS	MOULTONBOROUGH	07/01/21	ND	ND	ND	ND
1612270-501	STANYAN ROAD	MOULTONBOROUGH	10/15/19	ND	ND	ND	ND
1615010-503	MOULTONBOROUGH CENTRAL SCH	MOULTONBOROUGH	12/03/19	ND	ND	ND	ND
1615020-501	MOULTONBOROUGH ACADEMY	MOULTONBOROUGH	12/18/20	ND	ND	ND	ND
1615030-002	A CHILDS PLACE	MOULTONBOROUGH	02/11/21	ND	ND	ND	ND
1616040-501	CRUCON CRUISE OUTLET	MOULTONBOROUGH	07/01/21	ND	ND	ND	ND
1621010-001	PENNICHUCK WATER WORKS	NASHUA	07/06/21	3.87	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE NAME	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
1625020-501	SECOND NATURE ACADEMY	NASHUA	09/13/21	4.15	ND	ND	ND
1621010-508	PENNICHUCK WATER WORKS	NASHUA	09/21/20	ND	ND	ND	ND
1622010-501	PWW/FARLEY RD ESTATES	NASHUA	10/04/19	ND	ND	ND	ND
1635010-501	NELSON ELEMENTARY SCH	NELSON	12/21/20	ND	ND	ND	ND
1646020-002	USAF NH SATELLITE TRACKING STN	NEW BOSTON	04/26/21	6.15	5.69	4.98	ND
1646020-001	USAF NH SATELLITE TRACKING STN	NEW BOSTON	04/15/21	9.04	7.5	4.95	ND
1645020-501	STRONG FOUNDATIONS	NEW BOSTON	09/22/21	17.80	ND	ND	ND
1645010-001	NEW BOSTON ELEMENTARY SCH	NEW BOSTON	11/29/20	ND	ND	ND	ND
1645030-501	CHESTNUT CHRISTIAN PRESCH	NEW BOSTON	03/31/21	ND	ND	ND	ND
1645040-501	ROSE MEADOW ACRES	NEW BOSTON	08/24/21	ND	ND	ND	ND
1675010-501	NEW DURHAM ELEMENTARY SCH	NEW DURHAM	09/20/21	2.93	ND	ND	ND
1672020-505	COPPLE CROWN VILL DIST	NEW DURHAM	09/29/21	ND	5.31	ND	ND
1672010-501	MANITOOS SHORES	NEW DURHAM	03/17/21	ND	ND	ND	ND
1675020-001	7 DEPOT ROAD BEING COOL	NEW DURHAM	12/05/20	ND	ND	ND	ND
1691010-002	NEW HAMPTON VILLAGE PCT	NEW HAMPTON	09/23/21	ND	ND	ND	ND
1691010-003	NEW HAMPTON VILLAGE PCT	NEW HAMPTON	11/06/19	ND	ND	ND	ND
1692030-501	MANSFIELD WOODS	NEW HAMPTON	04/23/21	ND	ND	ND	ND
1713010-504	FREEDOM POND	NEW IPSWICH	05/19/21	2.92	5.20	ND	ND
1716080-001	WARWICK MILLS	NEW IPSWICH	08/03/21	3.27	ND	ND	ND
1715060-501	HIGHBRIDGE HILL ELEM SCH	NEW IPSWICH	06/09/21	8.29	10.00	2.45	ND
1715020-501	MASCENIC REGIONAL HIGH SCH	NEW IPSWICH	06/09/21	12.50	6.63	2.20	ND
1712010-501	APPLETON GARDENS	NEW IPSWICH	02/18/21	ND	ND	ND	ND
1712040-511	WILDER VILLAGE CLUSTER	NEW IPSWICH	12/04/20	ND	ND	ND	ND
1715040-500	BOYNTON MIDDLE SCH	NEW IPSWICH	12/30/20	ND	ND	ND	ND
1716050-501	VANGUARD MANUFACTURING	NEW IPSWICH	02/19/21	ND	ND	ND	ND
1716060-001	APPLETON BUSINESS CENTER	NEW IPSWICH	02/12/20	ND	ND	ND	ND
1721010-008	NEW LONDON SPRINGFIELD WATER	NEW LONDON	02/05/20	ND	ND	ND	ND
1722010-501	SEASONS AT LAKE SUNAPEE	NEW LONDON	08/12/21	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE NAME	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
1722020-502	SLOPE N SHORE CLUB	NEW LONDON	02/03/21	ND	ND	ND	ND
1652050-001	NEWBURY ELDERLY HOUSING	NEWBURY	02/03/21	0.40	ND	ND	ND
1652020-506	CHALK POND WATER	NEWBURY	02/24/20	ND	ND	ND	ND
1652020-506	CHALK POND WATER	NEWBURY	11/18/19	ND	ND	ND	ND
1656010-001	NEWBURY HARBOR PLAZA	NEWBURY	03/09/21	ND	ND	ND	ND
1681010-501	NEWFIELDS VLG WATER AND SEWER	NEWFIELDS	07/22/20	3.1	ND	2.98	ND
1681010-501	NEWFIELDS VLG WATER AND SEWER	NEWFIELDS	10/01/19	4.05	ND	3.09	ND
1732030-514	GREAT BAY WATER SYSTEM	NEWMARKET	07/07/21	8.06	ND	ND	ND
1731010-506	NEWMARKET WATER WORKS	NEWMARKET	04/15/20	ND	ND	ND	ND
1731010-507	NEWMARKET WATER WORKS	NEWMARKET	04/15/20	ND	ND	ND	ND
1731010-508	NEWMARKET WATER WORKS	NEWMARKET	04/15/20	ND	ND	ND	ND
1732010-001	MOODY POINT	NEWMARKET	02/23/21	ND	ND	ND	ND
1732020-511	WADE FARM CONDOS	NEWMARKET	07/06/21	ND	ND	ND	ND
1741010-502	NEWPORT WATER WORKS	NEWPORT	02/12/20	ND	ND	ND	ND
1741010-503	NEWPORT WATER WORKS	NEWPORT	02/12/20	ND	ND	ND	ND
1742010-001	CARY AND ALLEN ST DEV	NEWPORT	03/24/21	ND	ND	ND	ND
1746020-001	LATVA MACHINE	NEWPORT	03/17/21	ND	ND	ND	ND
1749010-001	KIDS WORLD ACADEMY OF NH	NEWPORT	02/03/21	ND	ND	ND	ND
1755050-004	NEWTON LEARNING CENTER	NEWTON	05/17/21	6.83	ND	ND	ND
1752020-501	MEADOWVIEW APARTMENTS	NEWTON	10/02/19	ND	ND	ND	ND
1752030-511	PACKER MEADOWS	NEWTON	10/01/19	ND	ND	ND	ND
1752070-501	SARGENT WOODS	NEWTON	03/09/21	ND	ND	ND	ND
1753010-502	WILLOW GROVE TRAILER PARK	NEWTON	03/10/20	ND	ND	ND	ND
1755010-001	SANBORN MEM SCH/SEACOST LRNG	NEWTON	08/19/21	ND	ND	ND	ND
1755010-001	SANBORN REGIONAL MIDDLE SCH	NEWTON	12/28/20	ND	ND	ND	ND
1756040-503	TEREX ENVIRONMENTAL EQUIPMENT	NEWTON	05/24/21	ND	ND	ND	ND
1756050-502	ONE PUZZLE LANE	NEWTON	08/16/21	ND	ND	ND	ND
1773020-001	SEACOAST CAMPING AND RV RESORT	NORTH HAMPTON	09/26/16	1.90	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE NAME	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
1773020-102	SEACOAST CAMPING AND RV RESORT	NORTH HAMPTON	09/26/16	2.60	ND	ND	ND
1773020-002	SEACOAST CAMPING AND RV RESORT	NORTH HAMPTON	09/26/16	ND	ND	ND	ND
1777020-001	SAGAMORE/HAMPTON GOLF CLUB	NORTH HAMPTON	08/25/16	ND	ND	ND	ND
1777040-001	SAGAMORE GOLF CLUB/DWELLBUB 79	NORTH HAMPTON	08/25/16	ND	ND	ND	ND
1762010-501	HIGHLANDS VILLAGE DIST	NORTHFIELD	02/03/21	ND	ND	ND	ND
1763010-502	SODA BROOK	NORTHFIELD	03/17/21	ND	ND	ND	ND
1764010-502	SPAULDING YOUTH CENTER - PFAS TREATMENT	NORTHFIELD	06/16/21	ND	ND	ND	ND
1766030-001	YOUNG ENTERPRISES NH	NORTHFIELD	01/04/21	ND	ND	ND	ND
1767020-001	CANTERBURY CROSSING	NORTHFIELD	01/20/21	ND	ND	ND	ND
2351010-503	TILTON NORTHFIELD WATER DIST	NORTHFIELD	06/07/21	ND	ND	ND	ND
2351010-504	TILTON NORTHFIELD WATER DIST	NORTHFIELD	06/07/21	ND	ND	ND	ND
1781010-502	GROVETON WATER SYS	NORTHUMBERLAND	10/21/19	ND	ND	ND	ND
1781030-502	LOST NATION WATER	NORTHUMBERLAND	10/21/19	ND	ND	ND	ND
1793030-501	NORTHWOOD MOUNTAIN VIEW MHP	NORTHWOOD	04/15/21	2.12	6.76	6.80	ND
1792030-001	VLG OF NORTHWOOD RDG WTR DIST	NORTHWOOD	11/19/19	ND	ND	ND	ND
1792030-002	VLG OF NORTHWOOD RDG WTR DIST	NORTHWOOD	11/19/19	ND	ND	ND	ND
1792040-001	VILLAGE AT MEAD FIELD	NORTHWOOD	11/17/16	ND	ND	ND	ND
1792050-001	THE MEADOW AT NORTHWOOD	NORTHWOOD	01/27/20	ND	ND	ND	ND
1793010-501	TOWER VIEW	NORTHWOOD	04/06/20	ND	ND	ND	ND
1793020-103	LOON ESTATES	NORTHWOOD	12/07/20	ND	ND	ND	ND
1795020-001	COE BROWN NORTHWOOD ACADEMY	NORTHWOOD	03/25/21	ND	ND	ND	ND
1795040-001	COE BROWN NORTHWOOD ACADEMY	NORTHWOOD	03/25/21	ND	ND	ND	ND
1796010-001	HANNAFORD NORTHWOOD 8160	NORTHWOOD	09/11/20	ND	ND	ND	ND
1798030-502	JOHNSONS SEAFOOD AND STEAK	NORTHWOOD	01/26/20	ND	ND	ND	ND
1798060-502	COOPER HILL PIZZERIA	NORTHWOOD	04/22/21	ND	ND	ND	ND
1809020-002	NOTTINGHAM COMMUNITY CHURCH	NOTTINGHAM	05/06/21	2.25	5.88	ND	ND
1802020-501	CAMELOT COURT	NOTTINGHAM	03/09/21	ND	ND	ND	ND
1805050-501	NOTTINGHAM COMMUNITY SCH	NOTTINGHAM	12/07/20	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE NAME	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
1805060-001	ALL ABOARD PRESCH AND CHLDCARE	NOTTINGHAM	08/07/20	ND	ND	ND	ND
1831010-505	ORFORD VILLAGE DIST	ORFORD	01/20/21	ND	ND	ND	ND
1835010-002	RIVENDELL INTERSTATE SCH	ORFORD	03/03/20	ND	ND	ND	ND
1842030-503	INDIAN MOUND GOLF CLUB	OSSIPEE	04/20/21	2.12	ND	ND	ND
1841010-501	OSSIPEE WATER DEPT	OSSIPEE	11/18/19	ND	ND	ND	ND
1842010-505	BLUFFS AT OSSIPEE LAKE	OSSIPEE	03/17/20	ND	ND	ND	ND
1842020-505	INDIAN MOUND SHOPPING CTR	OSSIPEE	04/28/21	ND	ND	ND	ND
1842050-001	POLAND BROOK WOODS	OSSIPEE	06/07/21	ND	ND	ND	ND
1842060-501	DEER COVE WATER	OSSIPEE	03/12/20	ND	ND	ND	ND
1843010-000	OSSIPEE MTN ESTATES	OSSIPEE	02/10/21	ND	ND	ND	ND
1843020-503	SANDY RIDGE ESTATES	OSSIPEE	02/10/21	ND	ND	ND	ND
1844010-501	CARROL COUNTY COMPLEX	OSSIPEE	07/06/21	ND	ND	ND	ND
1844010-505	CARROL COUNTY COMPLEX	OSSIPEE	07/06/21	ND	ND	ND	ND
1845020-001	CORNERSTONE CHRISTIAN ACADEMY	OSSIPEE	07/21/20	ND	ND	ND	ND
1846090-501	HANNAFORD OSSIPEE 8159	OSSIPEE	07/21/20	ND	ND	ND	ND
1852110-501	PARADISE ESTATES CONDOS	PELHAM	05/18/21	2.18	ND	ND	ND
1855090-001	KINGS KIDS CHILD CARE CENTER	PELHAM	09/09/21	2.94	6.72	ND	ND
1856010-502	PELHAM PLAZA	PELHAM	06/24/21	3.02	ND	ND	ND
1851010-501	PEU/WILLIAMSBURG	PELHAM	07/07/21	4.85	ND	ND	ND
1852020-501	PEU/GAGE HILL	PELHAM	07/20/21	6.95	2.66	ND	ND
1852060-511	HIGHLANDS ESTATES	PELHAM	10/21/21	8.68	ND	ND	ND
1855060-001	PERFECT PLACE	PELHAM	09/01/21	11.00	7.66	ND	ND
1852080-542	OLD LAWRENCE ROAD	PELHAM	07/13/21	17.6	9.18	ND	6.54
1856050-501	AMERICAN FOODS	PELHAM	05/21/21	22.40	8.39	4.45	2.69
1852040-002	PROLYN TOWNHOUSE APARTMENTS - NO TREATMENT	PELHAM	04/22/21	23.00	9.81	6.74	2.60
1852040-505	PROLYN TOWNHOUSE APARTMENTS - PFAS TREATMENT	PELHAM	10/12/21	ND	ND	ND	ND
1852090-501	SIMPSON MILL ROAD	PELHAM	11/27/20	ND	ND	ND	ND
1852100-501	BOULDER HILLS	PELHAM	07/13/21	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE NAME	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
1852120-501	PEU/SKY VIEW ESTATES	PELHAM	02/04/20	ND	ND	ND	ND
1852130-501	GARLAND WOODS	PELHAM	01/13/21	ND	ND	ND	ND
1852140-502	LONG POND WOODS	PELHAM	05/18/21	ND	ND	ND	ND
1855070-001	DYNAMIC FOUNDATION FOR CHILDREN	PELHAM	11/24/20	ND	ND	ND	ND
1855080-001	COLONIAL WAY PLAZA	PELHAM	03/24/21	ND	ND	ND	ND
1856040-501	HANNAFORD PELHAM 8015	PELHAM	08/11/20	ND	ND	ND	ND
1856040-501	HANNAFORD PELHAM 8015	PELHAM	08/11/20	ND	ND	ND	ND
1856070-502	PELHAM INDUSTRIAL PARK I	PELHAM	09/14/21	ND	ND	ND	ND
1859040-001	CROSSROADS BAPTIST CHURCH	PELHAM	12/03/20	ND	ND	ND	ND
1861010-509	PEMBROKE WATER WORKS	PEMBROKE	10/12/21	2.57	9.13	ND	3.11
1861010-502	PEMBROKE WATER WORKS	PEMBROKE	08/19/20	5.88	19.20	6.69	ND
1861010-006	PEMBROKE WATER WORKS	PEMBROKE	08/19/20	ND	ND	ND	ND
1861010-503	PEMBROKE WATER WORKS	PEMBROKE	08/19/20	ND	ND	ND	ND
1861010-504	PEMBROKE WATER WORKS	PEMBROKE	08/19/20	ND	ND	ND	ND
1861010-507	PEMBROKE WATER WORKS	PEMBROKE	08/19/20	ND	ND	ND	ND
1862010-001	MEETING HOUSE WATER	PEMBROKE	08/06/21	ND	ND	ND	ND
1862030-501	BOROUGH RD APARTMENTS	PEMBROKE	11/19/19	ND	ND	ND	ND
1866030-501	NEW ENGLAND FLOWER FARM	PEMBROKE	06/02/21	ND	ND	ND	ND
1871010-501	PETERBOROUGH WATER WORKS	PETERBOROUGH	10/03/19	ND	ND	ND	ND
1871010-503	PETERBOROUGH WATER WORKS	PETERBOROUGH	10/03/19	ND	ND	ND	ND
1871010-504	PETERBOROUGH WATER WORKS	PETERBOROUGH	10/03/19	ND	ND	ND	ND
1879020-001	PETERBOROUGH PLAYERS THEATRE	PETERBOROUGH	04/14/16	ND	ND	ND	ND
1875010-501	HAPPY VALLEY SCH	PETERBOROUGH	03/16/21	ND	ND	ND	ND
1875020-001	WELL SCHOOL	PETERBOROUGH	06/02/21	ND	ND	ND	ND
1875030-511	MONADNOCK COMM EARLY LNCCTR	PETERBOROUGH	2/022/21	ND	ND	ND	ND
1885010-503	PIERMONT VILLAGE SCH	PIERMONT	01/13/21	ND	ND	ND	ND
1897020-501	AMC PINKHAM NOTCH CAMP	PINKHAMS GRANT	03/24/20	ND	ND	ND	ND
1901010-506	PITTSBURG WATER DEPT	PITTSBURG	04/15/21	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE NAME	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
1911010-501	PITTSFIELD AQUEDUCT	PITTSFIELD	01/14/21	ND	ND	ND	ND
1913010-001	GRIGGS MOBILE HOMES	PITTSFIELD	01/13/21	ND	ND	ND	ND
1921010-506	PLAINFIELD VILLAGE WATER DIST	PLAINFIELD	03/02/20	ND	ND	ND	ND
1921010-507	PLAINFIELD VILLAGE WATER DIST	PLAINFIELD	03/02/20	ND	ND	ND	ND
1921020-001	MERIDEN VILLAGE WATER DIST	PLAINFIELD	03/26/20	ND	ND	ND	ND
1921020-002	MERIDEN VILLAGE WATER DIST	PLAINFIELD	03/26/20	ND	ND	ND	ND
1921020-003	MERIDEN VILLAGE WATER DIST	PLAINFIELD	03/26/20	ND	ND	ND	ND
1926010-501	TOWNLINE EQUIP	PLAINFIELD	02/05/21	ND	ND	ND	ND
1932240-501	THE RESERVE AT SNOWS BROOK	PLAISTOW	07/07/21	2.15	ND	ND	ND
1936110-001	SCANDIA PLASTICS	PLAISTOW	09/08/21	2.71	ND	ND	ND
1932190-502	CHANDLER TERRACE	PLAISTOW	10/18/21	2.88	ND	ND	ND
1932180-501	TUXBURY MEADOWS	PLAISTOW	08/24/21	3.03	ND	ND	ND
1932050-512	TWIN RIDGE CONDOS	PLAISTOW	08/17/21	3.11	ND	ND	ND
1932090-501	GREENFIELD HILL ESTATES	PLAISTOW	07/07/21	3.17	ND	ND	ND
1932070-501	VALLEY FIELD APTS NORTHLAND	PLAISTOW	07/13/21	3.35	2.90	ND	ND
1938240-002	PLAISTOW COMM YMCA	PLAISTOW	09/21/21	3.39	ND	ND	ND
1935070-001	LITTLE EXPLORERS	PLAISTOW	09/20/21	3.41	ND	ND	ND
1938040-501	PLAISTOW REG HEALTHCARE	PLAISTOW	09/17/21	3.99	2.74	ND	ND
1936160-001	FITZGERALD SAFETY COMPLEX	PLAISTOW	08/04/17	4.00	ND	16.00	73.00
1932100-502	STRAWBERRY HILL	PLAISTOW	04/20/21	4.50	3.38	ND	ND
1932250-501	CHANDLER PLACE APTS	PLAISTOW	08/13/21	4.82	2.10	ND	ND
1932040-501	FOREST GLEN CONDOS	PLAISTOW	07/14/20	5.63	ND	2.34	ND
1932050-008	TWIN RIDGE CONDOS	PLAISTOW	04/20/21	6.57	3.67	ND	ND
1932220-501	SHADY LANE APARTMENTS	PLAISTOW	05/19/21	6.71	4.58	ND	8.66
1936100-501	PENTUCKET SHOPPING CENTER	PLAISTOW	12/16/20	8.03	2.37	ND	ND
1932210-500	WEST PINE CONDOS	PLAISTOW	07/21/21	8.16	7.50	ND	ND
1932060-501	MOONGATE FARM	PLAISTOW	04/20/21	10.20	7.32	ND	ND
1932020-502	GOLDEN HILL	PLAISTOW	07/19/21	10.30	3.15	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE NAME	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
1935010-003	POLLARD ELEMENTARY SCH	PLAISTOW	07/06/21	10.50	5.00	ND	2.39
1936310-511	ETHAN ALLEN PLAZA	PLAISTOW	06/23/21	10.90	6.62	ND	3.60
1932030-502	WEST VIEW PARK CONDOS	PLAISTOW	09/16/21	11.50	ND	ND	2.74
1936040-002	PLAZA 125	PLAISTOW	09/20/18	11.80	5.56	4.92	ND
1932140-001	RUTLEDGE PLACE	PLAISTOW	05/26/21	11.90	8.54	ND	3.38
1932120-501	CROSS RIDGE ESTATES	PLAISTOW	07/19/21	13.00	15.40	ND	ND
1936300-001	BARONS CONDOS	PLAISTOW	09/27/21	13.40	17.40	ND	23.30
1938090-501	BRICKYARD PLAZA	PLAISTOW	09/29/21	17.00	3.20	ND	4.04
1936230-523	3 / 11 PLAISTOW RD PLAZA	PLAISTOW	09/20/21	41.80	23.00	8.16	11.90
1932080-503	STONEBRIDGE VILLAGE	PLAISTOW	10/25/19	ND	ND	ND	ND
1932110-001	BRYANT BROOK	PLAISTOW	10/09/19	ND	ND	ND	ND
1932130-503	26 CHANDLER AVE CONDOS	PLAISTOW	10/18/21	ND	ND	ND	ND
1932150-501	BLUEBERRY KNOLL ESTATES	PLAISTOW	03/09/20	ND	ND	ND	ND
1932170-501	RAINBOW RIDGE	PLAISTOW	07/07/21	ND	ND	ND	ND
1932200-511	SWEET HILL ESTATES	PLAISTOW	04/19/21	ND	ND	ND	ND
1932230-501	LITTLE RIVER VILLAGE	PLAISTOW	07/07/21	ND	ND	ND	ND
1935020-001	TIMBERLANE MIDDLE SCH	PLAISTOW	10/03/19	ND	ND	ND	ND
1935030-511	TIMBERLANE REGIONAL HS	PLAISTOW	10/03/19	ND	ND	ND	ND
1936070-501	144 MAIN STREET	PLAISTOW	03/02/20	ND	ND	ND	ND
1936130-001	PLAISTOW COMMONS	PLAISTOW	06/22/20	ND	ND	ND	ND
1936150-503	MARKET BASKET	PLAISTOW	07/01/21	ND	ND	ND	ND
1936270-001	FIELDSTONE INDUSTRIAL PARK	PLAISTOW	02/17/20	ND	ND	ND	ND
1936280-001	SPARTON BECKWOOD	PLAISTOW	08/16/21	ND	ND	ND	ND
1938190-511	GREAT ELM PLAZA	PLAISTOW	03/02/20	ND	ND	ND	ND
1941010-501	PLYMOUTH VLG WATER AND SEWER	PLYMOUTH	01/15/21	ND	ND	ND	ND
1941010-502	PLYMOUTH VLG WATER AND SEWER	PLYMOUTH	01/15/21	ND	ND	ND	ND
1942010-003	TENNEY BROOK II	PLYMOUTH	01/27/21	ND	ND	ND	ND
1942010-501	TENNEY BROOK II	PLYMOUTH	01/27/21	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE NAME	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
1942020-001	TENNEY BROOK CONDOS	PLYMOUTH	08/19/21	ND	ND	ND	ND
1943010-007	WHIP O WILL	PLYMOUTH	04/26/21	ND	ND	ND	ND
1943010-106	WHIP O WILL	PLYMOUTH	04/26/21	ND	ND	ND	ND
1943010-501	WHIP O WILL	PLYMOUTH	04/26/21	ND	ND	ND	ND
1945010-001	MOUNTAIN VILLAGE SCH	PLYMOUTH	03/25/21	ND	ND	ND	ND
1949030-001	PLYMOUTH COMMERCE PARK	PLYMOUTH	03/24/21	ND	ND	ND	ND
1951010-506	PORTSMOUTH WATER WORKS	PORTSMOUTH	08/02/21	2.36	ND	ND	ND
1951010-501	PORTSMOUTH WATER WORKS	PORTSMOUTH	08/02/21	3.00	ND	ND	ND
1951010-507	PORTSMOUTH WATER WORKS	PORTSMOUTH	08/02/21	3.38	ND	ND	ND
1951010-516	PORTSMOUTH WATER WORKS	PORTSMOUTH	08/03/21	4.26	4.74	ND	2.21
1951010-504	PORTSMOUTH WATER WORKS	PORTSMOUTH	08/03/21	5.8	5.13	ND	2.64
1951010-503	PORTSMOUTH WATER WORKS	PORTSMOUTH	08/03/21	6.89	5.15	ND	6.55
1951010-502	PEASE TRADE PORT - WELL NOT IN USE	PORTSMOUTH	05/14/14	320.00	2400.00	830.00	14.00
1951010-508	PORTSMOUTH WATER WORKS	PORTSMOUTH	08/02/21	ND	ND	ND	ND
1951020-510	PEASE TRADE PORT - PFAS TREATMENT INSTALLED	PORTSMOUTH	44,413.00	ND	ND	ND	ND
1972010-505	PEU/LIBERTY TREE ACRES	RAYMOND	10/22/19	1.88	ND	ND	ND
1973050-502	HILL TOP	RAYMOND	07/19/21	4.43	2.25	ND	5.19
1972040-502	BRANCH RIVER APARTMENTS	RAYMOND	04/22/21	5.35	3.77	5.75	ND
1972020-501	RIVERVIEW MANOR CONDOS	RAYMOND	04/14/21	ND	2.17	2.17	ND
1971010-504	RAYMOND WATER DEPT	RAYMOND	10/24/19	ND	ND	ND	ND
1971010-505	RAYMOND WATER DEPT	RAYMOND	10/24/19	ND	ND	ND	ND
1971010-506	RAYMOND WATER DEPT	RAYMOND	10/24/19	ND	ND	ND	ND
1972050-501	PAWTUCKAWAY FARMS	RAYMOND	12/18/20	ND	ND	ND	ND
1972060-500	WESTGATE ESTATES	RAYMOND	10/30/19	ND	ND	ND	ND
1972070-501	PEU/CLEARWATER ESTATES	RAYMOND	02/12/20	ND	ND	ND	ND
1972080-501	BLACKSTONE RESERVE	RAYMOND	03/17/21	ND	ND	ND	ND
1973060-503	LEISURE VILLAGE	RAYMOND	11/21/19	ND	ND	ND	ND
1975010-001	RAYMOND HIGH SCH	RAYMOND	11/10/16	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE NAME	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
1985010-002	ST BENEDICT CENTER MONASTERY	RICHMOND	04/06/20	ND	ND	ND	ND
1996020-001	WAL MART STORE 2057	RINDGE	09/08/21	2.01	ND	ND	ND
1995010-001	RINDGE MEMORIAL SCH	RINDGE	07/07/21	2.15	ND	ND	ND
1996060-001	PHASE 10	RINDGE	07/07/21	3.28	ND	ND	ND
1996040-504	HANNAFORD RINDGE 8180	RINDGE	10/13/21	20.40	27.40	77.50	2.44
1996010-501	CHESHIRE MARKET PLACE	RINDGE	09/29/21	ND	2.25	ND	ND
1992020-106	DUNBAR PROPERTIES	RINDGE	12/05/20	ND	ND	ND	ND
1992040-502	HAMPSHIRE COURT WATER	RINDGE	09/15/21	ND	ND	ND	ND
1992050-001	CARRIAGE APTS	RINDGE	10/11/19	ND	ND	ND	ND
1992070-501	PAYSON VILLAGE	RINDGE	02/18/21	ND	ND	ND	ND
1993010-511	MONADNOCK TENANTS	RINDGE	01/06/20	ND	ND	ND	ND
1994010-502	FRANKLIN PIERCE UNIVERSITY	RINDGE	03/17/21	ND	ND	ND	ND
1995030-501	HAMPSHIRE COUNTRY SCH	RINDGE	06/26/21	ND	ND	ND	ND
1995050-501	HERITAGE CHRISTIAN SCH	RINDGE	03/12/21	ND	ND	ND	ND
2001010-503	ROCHESTER WATER DEPT	ROCHESTER	08/25/21	3.71	3.27	ND	ND
2004010-503	INN AT SECRETARIAT	ROCHESTER	07/01/21	4.86	ND	ND	ND
2002030-504	DUSTIN HOMESTEAD	ROCHESTER	08/31/21	7.64	5.96	ND	ND
2003030-511	PARADISE ESTATES	ROCHESTER	10/07/21	12.40	6.50	ND	2.45
2001010-001	ROCHESTER WATER DEPT	ROCHESTER	08/14/20	ND	ND	ND	ND
2001010-002	ROCHESTER WATER DEPT	ROCHESTER	08/25/21	ND	ND	ND	ND
2001020-001	COUNTRY RIDGE MHP	ROCHESTER	07/09/21	ND	ND	ND	ND
2002020-501	PROFILE APARTMENTS	ROCHESTER	07/21/21	ND	ND	ND	ND
2002040-501	MEADOWBROOK VILLAGE	ROCHESTER	07/12/21	ND	ND	ND	ND
2002050-500	GRANDVIEW ESTATES	ROCHESTER	12/23/20	ND	ND	ND	ND
2003020-506	ACORN TERRACE	ROCHESTER	07/08/21	ND	ND	ND	ND
2003020-508	ACORN TERRACE	ROCHESTER	07/08/21	ND	ND	ND	ND
2003040-000	STONY BROOK	ROCHESTER	02/03/20	ND	ND	ND	ND
2003090-001	WESTWIND ESTATES II	ROCHESTER	02/20/20	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE NAME	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
2006020-501	CORNERSTONE VNA ROCHESTER	ROCHESTER	10/05/21	ND	ND	ND	ND
2011010-509	ROLLINSFORD WATER SEWER DIST	ROLLINSFORD	01/05/21	9.72	4.68	2.22	ND
2011010-514	ROLLINSFORD WATER SEWER DIST	ROLLINSFORD	06/30/20	ND	ND	ND	ND
2032010-002	HAWTHORNE VILLAGE	RUMNEY	02/12/20	ND	ND	ND	ND
2035010-501	RUSSELL ELEMENTARY SCH	RUMNEY	02/12/20	ND	ND	ND	ND
2036010-001	STONEWALL CABLE	RUMNEY	02/12/20	ND	ND	ND	ND
2041010-006	RYE WATER DIST	RYE	10/04/21	2.32	ND	ND	ND
2041010-008	RYE WATER DIST	RYE	10/04/21	5.47	2.12	ND	2.26
2041010-501	RYE WATER DIST	RYE	10/04/21	7.72	7.97	ND	ND
2052030-503	LANCASTER FARMS	SALEM	07/07/21	2.92	ND	ND	ND
2056010-501	KLEIN MARINE SYSTEMS	SALEM	07/23/21	3.43	7.57	ND	ND
2051010-510	SALEM WATER DEPT	SALEM	04/13/20	3.47	ND	ND	ND
2055020-501	MERRIMACK VALLEY MONTESSOR SCH	SALEM	09/08/21	4.40	2.82	ND	2.07
2052010-002	MILLVILLE CIRCLE/SOUTH	SALEM	07/16/21	4.91	ND	ND	2.38
2053030-001	SHADOW LAKE MOBILE HOME PARK	SALEM	09/25/21	5.24	ND	ND	ND
2051010-009	SALEM WATER DEPT	SALEM	05/17/21	7.43	2.16	ND	ND
2053020-501	ACKERMAN RETIREMENT PARK	SALEM	09/27/21	8.01	8.82	ND	5.72
2055010-502	NORTH SALEM ELEMENTARY SCH	SALEM	09/14/21	9.56	3.79	ND	2.53
2052060-001	MILLVILLE CIRCLE/NORTH	SALEM	01/24/20	ND	ND	ND	ND
2052070-501	AUTUMN WOODS	SALEM	07/07/21	ND	ND	ND	ND
2056040-001	NORTH SALEM VILLAGE	SALEM	03/23/20	ND	ND	ND	ND
2057060-001	SCOTTISH HIGHLAND GOLF COURSE	SALEM	06/14/16	ND	ND	ND	ND
2065010-001	SALISBURY ELEMENTARY SCH	SALISBURY	12/30/20	ND	ND	ND	ND
2078010-505	STEELE HILL RESORT	SANBORNTON	09/15/21	2.73	ND	ND	ND
2078010-503	STEELE HILL RESORT	SANBORNTON	09/15/21	2.77	2.14	ND	ND
2075030-501	SAINT BANI MIDDLE BLDG	SANBORNTON	09/30/21	5.64	2.43	ND	ND
2075010-501	SAINT BANI UPPER BLDG	SANBORNTON	03/12/21	ND	ND	ND	ND
2075020-002	SANBORNTON CENTRAL SCH	SANBORNTON	12/29/20	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE NAME	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
2075070-001	SAPLINGS PRESCHOOL	SANBORNTON	12/05/20	ND	ND	ND	ND
2082050-501	STONEFORD	SANDOWN	07/14/21	2.60	ND	ND	ND
2085020-501	PLAYMATES LEARNING CENTER	SANDOWN	06/23/21	5.15	ND	ND	ND
2082010-503	PEU/BEAVER HOLLOW	SANDOWN	07/06/21	5.71	ND	ND	ND
2082040-502	PINE ACRES CONDOS	SANDOWN	08/09/21	9.85	6.60	ND	4.11
2082020-001	FAIRFIELD	SANDOWN	07/19/21	ND	ND	ND	ND
2082020-502	FAIRFIELD	SANDOWN	07/19/21	ND	ND	ND	ND
2082030-001	REEDS CROSSING	SANDOWN	03/13/21	ND	ND	ND	ND
2082060-501	CORNERSTONE ESTATES	SANDOWN	03/09/21	ND	ND	ND	ND
2082070-500	MILL PINE VILLAGE	SANDOWN	10/30/19	ND	ND	ND	ND
2082080-501	LITTLE MILL WOODS	SANDOWN	03/08/21	ND	ND	ND	ND
2082090-501	WATERFORD VILLAGE ESTATES	SANDOWN	03/09/21	ND	ND	ND	ND
2082110-501	TOWNHOUSES AT WELLS VILLAGE	SANDOWN	07/19/21	ND	ND	ND	ND
2085040-001	SANDOWN NORTH ELEMENTARY SCH	SANDOWN	10/31/19	ND	ND	ND	ND
2095020-501	SANDWICH CENTRAL SCH	SANDWICH	06/16/21	ND	ND	ND	ND
2095030-001	SANDWICH CHILDRENS CTR	SANDWICH	09/15/21	ND	ND	ND	ND
2111010-512	SEABROOK WATER DEPT	SEABROOK	07/12/21	3.98	ND	ND	ND
2111010-503	SEABROOK WATER DEPT	SEABROOK	07/23/21	4.00	ND	ND	ND
2111010-501	SEABROOK WATER DEPT	SEABROOK	07/23/21	8.32	3.81	ND	ND
2111010-514	SEABROOK WATER DEPT	SEABROOK	02/23/21	ND	ND	ND	ND
2111010-516	SEABROOK WATER DEPT	SEABROOK	07/13/21	ND	ND	ND	ND
2151010-005	SOMERSWORTH WATER WORKS	SOMERSWORTH	03/24/20	ND	ND	ND	ND
2151010-506	SOMERSWORTH WATER WORKS	SOMERSWORTH	03/24/20	ND	ND	ND	ND
2165020-501	BARNARD SCH	SOUTH HAMPTON	12/18/20	ND	ND	ND	ND
2185010-002	STARK VILLAGE SCH	STARK	05/10/21	ND	ND	ND	ND
2192020-001	NORTHERN VIEW APTS	STEWARTSTOWN	04/06/21	ND	ND	ND	ND
2195020-001	STEWARTSTOWN COMM SCH	STEWARTSTOWN	06/28/21	ND	ND	ND	ND
2205010-503	JAMES FAULKNER MEM SCH	STODDARD	09/01/21	ND	ND	ND	ND

Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE NAME	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
2206010-502	CARLISLE WIDE PLANK FLOORS	STODDARD	03/31/21	ND	ND	ND	ND
2212010-501	BOW LAKE ESTATES	STRAFFORD	03/09/21	ND	ND	ND	ND
2215010-502	STRAFFORD SCH	STRAFFORD	08/23/21	ND	ND	ND	ND
2215040-501	WHITEHOUSE EARLY LRNG CTR	STRAFFORD	04/15/21	ND	ND	ND	ND
2221010-502	NORTH STRATFORD WATER DEPT	STRAFFORD	06/28/21	ND	ND	ND	ND
2221010-503	NORTH STRATFORD WATER DEPT	STRAFFORD	06/28/21	ND	ND	ND	ND
2223010-001	PLEASANT VALLEY PARK ESTATES	STRATFORD	08/30/21	ND	ND	ND	ND
2223020-001	NORTH STRATFORD MHP	STRATFORD	03/09/21	ND	ND	ND	ND
2238060-503	STRATHAM PLZ/MARKET BASKET	STRATHAM	09/22/21	2.03	ND	ND	ND
2236170-001	LINDT AND SPRUNGLI USA/BLDG D	STRATHAM	08/19/20	2.46	ND	ND	ND
2236120-001	MILLBROOK OFFICE PARK	STRATHAM	05/18/21	2.83	ND	ND	ND
2236070-501	NP STRATHAM	STRATHAM	07/20/21	3.11	2.49	ND	ND
2239010-501	STRATHAM COMMUNITY CHURCH	STRATHAM	06/17/21	3.39	ND	ND	ND
2232070-511	MONTROSE CONDOS	STRATHAM	04/20/21	3.45	ND	ND	ND
2232140-501	JEWETT HILL	STRATHAM	07/14/21	4.72	3.92	ND	ND
2235060-501	CORNERSTONE SCHOOL	STRATHAM	05/25/21	4.74	3.13	ND	ND
2236150-501	BMW OF STRATHAM	STRATHAM	06/17/21	7.07	2.31	ND	ND
2236010-001	KINGS HIGHWAY PLAZA	STRATHAM	08/12/21	7.29	2.99	ND	ND
2232200-501	CHISHOLM FARM	STRATHAM	06/25/21	7.79	2.60	ND	ND
2232030-501	SALT RIVER CONDOS	STRATHAM	10/18/21	8.12	4.59	ND	2.22
2232010-504	GLENDARRY CONDOS	STRATHAM	07/13/21	11.30	6.53	ND	3.04
2236050-001	STRATHAM PLAZA	STRATHAM	09/20/21	12.50	5.38	ND	ND
2235050-501	STRATHAM MEMORIAL SCH	STRATHAM	09/23/21	13.80	5.27	ND	ND
2236090-002	RCN CONDOS	STRATHAM	09/27/21	22.40	7.40	ND	ND
2236140-501	STRATHAM CROSSING 7621	STRATHAM	10/18/21	30.20	ND	ND	ND
2236100-001	PIPERS LANDING	STRATHAM	08/11/21	53.00	44.30	ND	79.80
2236130-502	STRATHAM CENTRAL CONDOS	STRATHAM	10/15/21	87.50	216.00	ND	189.00
2236070-002	NP STRATHAM	STRATHAM	07/20/21	ND	21.00	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE NAME	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
2236040-001	BELL AND FLYNN	STRATHAM	08/25/21	ND	ND	ND	3.27
2232020-502	THORNHILL CONDOS	STRATHAM	04/06/20	ND	ND	ND	ND
2232040-000	PENINSULA AT WINDING BROOK	STRATHAM	03/03/20	ND	ND	ND	ND
2232050-501	STRATHAM GREEN CONDOS - PFAS TREATMENT	STRATHAM	07/14/21	ND	ND	ND	ND
2232060-001	BALMORAL CONDOS	STRATHAM	08/16/21	ND	ND	ND	ND
2232080-502	PHEASANT RUN CONDOS	STRATHAM	12/11/20	ND	ND	ND	ND
2232090-000	STRATHAM WOODS	STRATHAM	12/23/20	ND	ND	ND	ND
2232110-501	TURNBERRY	STRATHAM	01/08/21	ND	ND	ND	ND
2232130-502	MUIRFIELD CLUSTER	STRATHAM	01/27/21	ND	ND	ND	ND
2232150-512	ABERDEEN/WEST	STRATHAM	11/18/19	ND	ND	ND	ND
2232160-502	BURNHAVEN	STRATHAM	07/20/21	ND	ND	ND	ND
2232190-001	VINEYARDS	STRATHAM	03/25/21	ND	ND	ND	ND
2232210-501	ROLLINS HILL	STRATHAM	01/13/21	ND	ND	ND	ND
2235010-001	ACORN SCH	STRATHAM	04/15/21	ND	ND	ND	ND
2236180-502	LINDT AND SPRUNGLI USA/BLDG E	STRATHAM	03/16/20	ND	ND	ND	ND
2236190-501	149/151 PORTSMOUTH AVE	STRATHAM	09/07/21	ND	ND	ND	ND
2271010-002	SUNAPEE WATER WORKS	SUNAPEE	02/13/20	ND	ND	ND	ND
2271020-502	GEORGES MILLS WATER WORKS	SUNAPEE	02/13/20	ND	ND	ND	ND
2272020-502	MEADOW BROOK AT SUNAPEE	SUNAPEE	03/25/20	ND	ND	ND	ND
2275020-001	MOUNT ROYAL ACADEMY	SUNAPEE	12/30/20	ND	ND	ND	ND
2281010-001	SURRY VILLAGE WATER	SURRY	06/10/20	ND	ND	ND	ND
2285010-501	SURRY VILLAGE CHARTER SCH	SURRY	12/21/20	ND	ND	ND	ND
2296010-002	LABSPHERE	SUTTON	10/27/21	3.92	4.50	ND	ND
2295030-502	KEARSARGE REGIONAL MIDDLE SCH	SUTTON	10/05/21	8.20	ND	ND	ND
2295030-511	KEARSARGE REGIONAL MIDDLE SCH	SUTTON	03/04/20	150.00	ND	ND	6.34
2295010-502	KEARSARGE REGIONAL HIGH SCH	SUTTON	12/22/20	ND	ND	ND	ND
2295020-501	SUTTON CENTRAL SCH	SUTTON	12/22/20	ND	ND	ND	ND
2303010-508	PINE GROVE MOBILE HOME PARK	SWANZEY	08/19/21	2.09	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE NAME	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
2301020-501	WEST SWANZEY WATER	SWANZEY	07/15/20	ND	ND	ND	ND
2302010-001	ASHUELOT RIVER APTS	SWANZEY	10/30/19	ND	ND	ND	ND
2302040-505	EASTFIELD CROSSING	SWANZEY	11/05/19	ND	ND	ND	ND
2302050-500	FOREST VIEW ESTATES	SWANZEY	10/30/19	ND	ND	ND	ND
2303010-010	PINE GROVE MOBILE HOME PARK	SWANZEY	08/19/21	ND	ND	ND	ND
2303020-500	VIEW POINT COOP	SWANZEY	10/30/19	ND	ND	ND	ND
2305050-501	MONADNOCK REGIONAL HIGH SCH	SWANZEY	11/12/19	ND	ND	ND	ND
2306060-501	TOYOTA OF KEENE	SWANZEY	07/13/20	ND	ND	ND	ND
2306060-501	TOYOTA OF KEENE	SWANZEY	10/14/19	ND	ND	ND	ND
2313020-000	TAMWORTH PINES	TAMWORTH	08/12/21	2.96	ND	ND	ND
2311010-005	TAMWORTH WATER WORKS	TAMWORTH	03/10/20	ND	ND	ND	ND
2312020-501	MOUNTAIN VIEW ESTATES	TAMWORTH	04/06/21	ND	ND	ND	ND
2312030-501	WHITE LAKE ESTATES	TAMWORTH	03/10/20	ND	ND	ND	ND
2312050-503	REMICK ACRES	TAMWORTH	01/27/21	ND	ND	ND	ND
2312060-001	CHOCORUA WOODS	TAMWORTH	02/11/20	ND	ND	ND	ND
2312070-501	CHOCORUA MEADOWS	TAMWORTH	10/23/19	ND	ND	ND	ND
2312090-501	HIGHLAND PLACE	TAMWORTH	07/20/21	ND	ND	ND	ND
2313010-000	TAMWORTH MOBILE HOME PARK	TAMWORTH	10/23/19	ND	ND	ND	ND
2315010-501	KENNETH A BRETT SCH	TAMWORTH	03/15/21	ND	ND	ND	ND
2315020-001	TAMWORTH PRESCHOOL	TAMWORTH	12/29/20	ND	ND	ND	ND
2315030-501	COMMUNITY SCH	TAMWORTH	01/08/21	ND	ND	ND	ND
2318090-503	NORTHWAY APTS/DAYS INN	TAMWORTH	03/16/20	ND	ND	ND	ND
2342020-502	NORTHPOINTE WATER	THORNTON	04/22/21	5.41	ND	ND	ND
2342010-512	175 ESTATES	THORNTON	02/18/20	ND	ND	ND	ND
2342030-001	MOUNTAIN RIVER CONDOS	THORNTON	04/02/21	ND	ND	ND	ND
2342040-000	MOUNTAIN RIVER CONDOS EAST	THORNTON	04/02/21	ND	ND	ND	ND
2342060-002	WHITE MOUNTAIN RESORT/GATEWAY	THORNTON	02/18/20	ND	ND	ND	ND
2342070-002	WATERVILLE ACRES CONDOS	THORNTON	02/11/20	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE NAME	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
2342080-000	STAR RIDGE	THORNTON	02/03/21	ND	ND	ND	ND
2342090-001	BIRCH BEND	THORNTON	01/08/20	ND	ND	ND	ND
2342100-001	CONE RIDGE APTS	THORNTON	01/20/21	ND	ND	ND	ND
2342110-505	MILL BROOKE VILLAGE	THORNTON	03/09/21	ND	ND	ND	ND
2348110-500	OWLS NEST GC AND CONDOS	THORNTON	01/20/21	ND	ND	ND	ND
2345010-002	THORNTON CENTRAL SCH	THORNTON	02/12/20	ND	ND	ND	ND
2356020-001	TOWN LINE PLAZA	TILTON	06/18/21	2.09	3.05	ND	2.89
2351020-501	LOCHMERE VILLAGE DIST	TILTON	08/02/21	15.06	19.98	ND	66.00
2352010-002	WINNISQUAM RESORT CONDOS	TILTON	02/03/21	ND	ND	ND	ND
2352020-001	PEU/NORTHERN SHORES	TILTON	01/19/21	ND	ND	ND	ND
2352040-501	WINNISQUAM VILLAGE CONDOS	TILTON	05/01/21	ND	ND	ND	ND
2353010-501	RODGERS DEV	TILTON	11/06/19	ND	ND	ND	ND
2353020-501	WINDY HILL/NORTH	TILTON	04/02/21	ND	ND	ND	ND
2353040-502	COUNTRY MEADOWS	TILTON	02/26/21	ND	ND	ND	ND
2353090-002	WINDY HILL/SOUTH	TILTON	04/02/21	ND	ND	ND	ND
2356010-001	3M TILTON	TILTON	09/07/21	ND	ND	ND	ND
2356060-501	TANGER OUTLET CENTER	TILTON	11/06/19	ND	ND	ND	ND
2356080-001	BJS WHOLESALE CLUB 309	TILTON	03/31/21	ND	ND	ND	ND
2356100-001	AUTOSERV OF TILTON	TILTON	11/06/19	ND	ND	ND	ND
2356110-001	EVERSOURCE ENERGY TILTON AWC	TILTON	4/8/2021	ND	ND	ND	ND
2361010-503	TROY WATER WORKS	TROY	03/16/21	ND	ND	ND	ND
2361010-504	TROY WATER WORKS	TROY	03/16/21	ND	ND	ND	ND
2361010-505	TROY WATER WORKS	TROY	03/16/21	ND	ND	ND	ND
2361010-512	TROY WATER WORKS	TROY	03/16/21	ND	ND	ND	ND
2372020-002	HIDDEN VALLEY/MASON	TUFTONBORO	03/12/20	ND	ND	ND	ND
2372020-006	HIDDEN VALLEY/MASON	TUFTONBORO	03/12/20	ND	ND	ND	ND
23272050-501	WINMIR CONDOS	TUFTONBORO	06/23/21	ND	ND	ND	ND
2373010-000	NORTH COUNTRY VILLAGE	TUFTONBORO	01/13/21	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE NAME	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
2375010-502	TUFTONBORO CENTRAL SCH	TUFTONBORO	06/29/21	ND	ND	ND	ND
2376010-003	PAK 2000 OFFICE	TUFTONBORO	08/29/16	ND	ND	ND	ND
2384010-003	SULLIVAN COUNTY COMPLEX	UNITY	02/18/21	ND	ND	ND	ND
2384010-507	SULLIVAN COUNTY COMPLEX	UNITY	02/18/21	ND	ND	ND	ND
2384010-514	SULLIVAN COUNTY COMPLEX	UNITY	02/22/21	ND	ND	ND	ND
2385010-511	UNITY ELEMENTARY SCH	UNITY	03/12/21	ND	ND	ND	ND
2391010-502	SANBORNVILLE WATER DEPT	WAKEFIELD	09/08/21	ND	2.00	ND	ND
2391010-503	SANBORNVILLE WATER DEPT	WAKEFIELD	02/26/21	ND	ND	ND	ND
2392010-501	BEVERLY HILLS WATER	WAKEFIELD	04/14/21	ND	ND	ND	ND
2392020-001	WAKEFIELD ACRES	WAKEFIELD	02/10/21	ND	ND	ND	ND
2392030-500	MICHAWANIC VILLAGE CONDOS	WAKEFIELD	03/12/20	ND	ND	ND	ND
2395020-001	LEARNING WITH LOVE	WAKEFIELD	10/03/19	ND	ND	ND	ND
2395030-501	PINE RIVER POND CNTRY DAYCARE	WAKEFIELD	08/10/21	ND	ND	ND	ND
2401010-001	WALPOLE WATER DEPT	WALPOLE	07/14/20	ND	ND	ND	ND
2401010-502	WALPOLE WATER DEPT	WALPOLE	07/14/20	ND	ND	ND	ND
2401020-507	N WALPOLE VILLAGE DISTRICT/LOW	WALPOLE	09/30/21	ND	ND	ND	ND
2401020-508	N WALPOLE VILLAGE DISTRICT/LOW	WALPOLE	09/29/21	ND	ND	ND	ND
2401030-501	N WALPOLE VILLAGE DIST/HIGH	WALPOLE	09/30/21	ND	ND	ND	ND
2405010-501	DREWSVILLE CARRIAGE HOUSE	WALPOLE	01/20/21	ND	ND	ND	ND
2406010-101	BENSON WOODWORKING	WALPOLE	03/12/21	ND	ND	ND	ND
2411010-503	WARNER VILLAGE WATER DIST	WARNER	04/28/21	ND	ND	ND	ND
2411010-504	WARNER VILLAGE WATER DIST	WARNER	04/28/21	ND	ND	ND	ND
2413010-503	PLEASANT LAKE MHP	WARNER	09/16/21	ND	ND	ND	ND
2415010-501	NORTHEAST CATHOLIC COLLEGE	WARNER	10/03/19	ND	ND	ND	ND
2415010-501	MAGDALEN COLLEGE	WARNER	11/25/20	ND	ND	ND	ND
2421010-002	GLENCLIFF IMPROVEMENT	WARREN	09/13/21	ND	ND	ND	ND
2422010-502	SOUTH MAIN STREET WATER DIST	WARREN	09/14/21	ND	ND	ND	ND
2435020-001	WASHINGTON ELEMENTARY SCH	WASHINGTON	01/25/21	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE NAME	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
2441010-502	WATERVILLE VALLEY WATER DIST	WATERVILLE VALLEY	03/03/20	ND	ND	ND	ND
2441010-503	WATERVILLE VALLEY WATER DIST	WATERVILLE VALLEY	03/03/20	ND	ND	ND	ND
2441010-504	WATERVILLE VALLEY WATER DIST	WATERVILLE VALLEY	03/03/20	ND	ND	ND	ND
2455040-003	JOHN STARK REG HIGH SCH	WEARE	04/07/21	3.70	1.00	ND	ND
2459010-001	TOWN OFFICES	WEARE	08/05/21	ND	2.12	ND	ND
2452010-501	PEU/DANIELS LAKE	WEARE	07/08/21	ND	ND	ND	ND
2452030-514	SOUTH WEARE WATER	WEARE	11/05/19	ND	ND	ND	ND
2452030-515	SOUTH WEARE WATER	WEARE	11/20/19	ND	ND	ND	ND
2452040-501	COLLINS LANDING	WEARE	01/25/21	ND	ND	ND	ND
2453010-005	SUGAR HILL MANOR MHP	WEARE	12/18/20	ND	ND	ND	ND
2453020-000	KUNCANOWET HILLS MHP	WEARE	09/02/21	ND	ND	ND	ND
2455020-001	WEARE MIDDLE SCHOOL	WEARE	11/03/16	ND	ND	ND	ND
2455060-501	CENTER WOOD ELEM SCH	WEARE	04/07/21	ND	ND	ND	ND
2455080-001	WEARE MIDDLE SCH	WEARE	11/06/19	ND	ND	ND	ND
2456010-003	GRANITE STATE TELEPHONE	WEARE	08/05/16	ND	ND	ND	ND
2458030-002	COUNTRY THREE CORNERS	WEARE	08/09/18	ND	ND	ND	ND
2458060-001	WEARE CENTER PLAZA	WEARE	08/02/21	ND	ND	ND	ND
2458070-501	LANCTOTS CENTER	WEARE	01/23/20	ND	ND	ND	ND
2462040-003	PILLSBURY LAKE/FRANKLIN PIERCE	WEBSTER	04/28/21	ND	ND	ND	ND
2462040-500	PILLSBURY LAKE/FRANKLIN PIERCE	WEBSTER	04/28/21	ND	ND	ND	ND
2462050-502	PILLSBURY LAKE/PENINSULA	WEBSTER	04/28/21	ND	ND	ND	ND
2465010-001	WEBSTER ELEMENTARY SCH	WEBSTER	12/30/20	ND	ND	ND	ND
2475010-001	WENTWORTH ELEMENTARY SCH	WENTWORTH	02/12/20	ND	ND	ND	ND
2494010-006	CHESHIRE COUNTY COMPLEX	WESTMORELAND	10/08/19	ND	ND	ND	ND
2494010-007	CHESHIRE COUNTY COMPLEX	WESTMORELAND	10/08/19	ND	ND	ND	ND
2495030-001	WESTMORELAND ELEMENTARY SCH	WESTMORELAND	12/21/20	ND	ND	ND	ND
2501010-001	WHITEFIELD WATER	WHITEFIELD	04/28/21	ND	ND	ND	ND
2501010-008	WHITEFIELD WATER	WHITEFIELD	04/28/21	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE NAME	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
2501010-009	WHITEFIELD WATER	WHITEFIELD	04/28/21	ND	ND	ND	ND
2501010-010	WHITEFIELD WATER	WHITEFIELD	04/28/21	ND	ND	ND	ND
2501010-012	WHITEFIELD WATER	WHITEFIELD	04/28/21	ND	ND	ND	ND
2501010-514	WHITEFIELD WATER	WHITEFIELD	04/28/21	ND	ND	ND	ND
2505010-002	WHITE MTN REG HS	WHITEFIELD	03/31/21	ND	ND	ND	ND
2512010-001	POUND ROAD WATER WORKS	WILMOT	04/08/21	ND	ND	ND	ND
2525010-512	HIGH MOWING SCH	WILTON	07/15/21	4.02	ND	ND	ND
2521010-505	WILTON WATER WORKS	WILTON	09/16/20	ND	ND	ND	ND
2521010-506	WILTON WATER WORKS	WILTON	12/22/20	ND	ND	ND	ND
2525020-502	PINE HILL WALDORF SCH	WILTON	10/22/19	ND	ND	ND	ND
2525030-501	PINE HILL WALDORF CHLD VILLAGE	WILTON	10/22/19	ND	ND	ND	ND
2526040-501	KIMBALL PHYSICS	WILTON	02/12/20	ND	ND	ND	ND
2531010-501	WINCHESTER WATER DEPT	WINCHESTER	01/14/21	ND	ND	ND	ND
2531010-502	WINCHESTER WATER DEPT	WINCHESTER	01/14/21	ND	ND	ND	ND
2531010-503	WINCHESTER WATER DEPT	WINCHESTER	01/15/21	ND	ND	ND	ND
2533010-501	SOUTH PARRISH	WINCHESTER	07/13/20	ND	ND	ND	ND
2533020-000	GREEN VALLEY MOBILE HOME PARK	WINCHESTER	07/13/21	ND	ND	ND	ND
2542010-501	PEU/GOLDEN BROOK	WINDHAM	07/07/21	2.40	ND	ND	ND
2546250-502	GATEWAY PARK	WINDHAM	04/22/21	2.57	ND	ND	ND
2546150-001	COBBETTS PROF PARK	WINDHAM	08/25/21	2.68	ND	ND	ND
2546240-501	183 ROCKINGHAM ROAD	WINDHAM	08/11/21	3.33	ND	ND	ND
2546110-001	WINDHAM VILLAGE GREEN	WINDHAM	08/09/21	3.36	3.22	ND	ND
2542170-500	PEU/LAMPLIGHTER VILLAGE	WINDHAM	07/06/21	3.90	ND	ND	ND
2545040-501	WINDHAM CROSSING LEARNING CTR	WINDHAM	07/20/21	3.95	2.05	ND	ND
2542080-500	WYNRIDGE CONDOS	WINDHAM	09/16/21	4.21	ND	ND	ND
2546200-501	CYR LUMBER	WINDHAM	09/07/21	4.80	7.28	ND	ND
2546080-501	CASTLE COMMONS	WINDHAM	08/12/21	4.93	5.07	ND	4.54
2542070-501	VILLAGES OF WINDHAM	WINDHAM	07/19/21	5.82	2.08	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE NAME	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
2545100-501	WINDHAM HIGH SCH	WINDHAM	09/29/21	5.98	ND	ND	ND
2548170-001	HOWIE GLYNN AND SONS CONV STRE	WINDHAM	07/31/17	6.00	27.00	40.00	ND
2546220-501	FIVE INDUSTRIAL DR	WINDHAM	08/09/21	6.06	ND	ND	6.59
2542030-504	PEU/W AND E	WINDHAM	07/06/21	6.11	2.65	ND	ND
2546260-501	INDIAN ROCK OFFICE PARK II	WINDHAM	10/07/21	6.18	2.53	ND	ND
2546190-502	SHAWS SUPERMARKET 686	WINDHAM	07/12/21	6.22	3.37	ND	ND
2549050-001	NESMITH LIBRARY	WINDHAM	04/09/18	6.40	ND	0.99	ND
2546020-001	AP DAILEY	WINDHAM	08/11/21	6.51	2.73	ND	ND
2542030-003	PEU/W AND E	WINDHAM	07/06/21	6.59	2.36	ND	2.55
2542180-501	PEU/SPRUCE POND ESTS	WINDHAM	07/06/21	6.67	ND	ND	ND
2544010-501	WARDE REHABILITATION/NURSING	WINDHAM	07/13/21	6.68	4.26	ND	ND
2549020-001	SENIOR CITIZENS CENTER	WINDHAM	05/02/18	6.80	31.00	10.00	1.80
2542190-503	CAMELOT III	WINDHAM	08/11/21	6.93	ND	ND	ND
2546090-001	COMMONS AT WINDHAM 1/WEST BLDG	WINDHAM	07/20/17	7.00	6.00	10.00	ND
2546070-501	WINDHAM ACADEMY	WINDHAM	09/02/21	7.30	7.15	ND	15.50
2549010-001	TOWN HALL/PLANNING/DEV/TV STAT	WINDHAM	06/07/17	8.00	16.00	8.00	ND
2546230-501	MEDICUS OFFICES	WINDHAM	01/12/21	8.07	2.85	2.81	ND
2542060-503	PEU/HARDWOOD HTS BIRCH HILL	WINDHAM	07/06/21	8.44	4.9	ND	ND
2545080-501	KIDDIE ACADEMYU	WINDHAM	09/09/21	8.45	ND	ND	ND
2546170-001	CAPITAL TRANSPORTATION	WINDHAM	06/16/21	8.68	ND	ND	ND
2544020-501	WINDHAM TERRACE	WINDHAM	07/12/21	8.81	9.54	ND	4.37
2542160-502	HADLEIGH WOODS	WINDHAM	08/02/21	9.27	ND	ND	ND
2542140-501	PEU/CASTLE REACH	WINDHAM	07/06/21	9.96	ND	ND	ND
2546160-501	COMMONS AT WINDHAM 2/EAST BLDG	WINDHAM	09/10/21	10.3	12.9	ND	7.15
2545110-501	WEE CARE LEARNING CTR	WINDHAM	08/09/21	10.60	2.53	ND	5.82
2548180-001	WINDHAM TOWNE SHOPPES	WINDHAM	08/24/17	10.90	7.79	ND	ND
2548150-001	DUNKIN DONUTS /PC 346676 UNTREATED	WINDHAM	07/20/17	27.00	100.00	159.00	ND
2547060-501	WINDHAM WOODS SCH	WINDHAM	09/21/21	ND	2.30	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE NAME	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
2542130-001	MCAULEY COMMONS	WINDHAM	01/27/21	ND	ND	ND	ND
2542150-502	PEU/FLETCHER CORNER ESTATES	WINDHAM	02/04/20	ND	ND	ND	ND
2542200-501	WOOD MEADOW ESTATES	WINDHAM	01/20/21	ND	ND	ND	ND
2545010-502	WINDHAM CENTER SCH - PFAS TREATMENT INSTALLED	WINDHAM	09/22/21	ND	ND	ND	ND
2545020-501	GOLDEN BROOK SCH	WINDHAM	01/04/21	ND	ND	ND	ND
2545030-501	WINDHAM MIDDLE SCH	WINDHAM	09/22/21	ND	ND	ND	ND
2545090-001	WINDHAM COOPTVE KINDERGARTEN	WINDHAM	11/05/19	ND	ND	ND	ND
2546030-502	WINDHAM PLAZA	WINDHAM	03/10/21	ND	ND	ND	ND
2546180-001	KAHUNA	WINDHAM	02/04/20	ND	ND	ND	ND
2548150-001	DUNKIN DONUTS /PC 346676 TREATED	WINDHAM	07/20/17	ND	ND	ND	ND
2552010-501	WEDIKO SCHOOL	WINDSOR	07/12/21	4.69	7.16	ND	ND
2552010-502	WEDIKO SCHOOL	WINDSOR	02/03/21	ND	ND	ND	ND
2552010-513	WEDIKO SCHOOL	WINDSOR	02/03/21	ND	ND	ND	ND
2557060-501	WEDIKO KITCHEN	WINDSOR	02/03/21	ND	ND	ND	ND
2563010-000	BIRCH OF WOLFBORO COOP	WOLFEBORO	05/28/21	2.07	ND	ND	ND
2562010-001	WENTWORTH ESTATES	WOLFEBORO	07/12/21	ND	ND	ND	3.76
2561010-002	WOLFEBORO WATER AND SEWER	WOLFEBORO	08/19/20	ND	ND	ND	ND
2562030-001	POINT BREEZE CONDOS	WOLFEBORO	01/13/21	ND	ND	ND	ND
2562050-502	SHERWOOD FOREST	WOLFEBORO	01/08/20	ND	ND	ND	ND
2571020-502	WOODSTOCK WATER DEPT	WOODSTOCK	11/14/19	ND	ND	ND	ND
2571020-503	WOODSTOCK WATER DEPT	WOODSTOCK	11/14/19	ND	ND	ND	ND
2572010-501	JACK O LANTERN CONDOS	WOODSTOCK	02/03/20	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE NAME	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
-------------------------	-------------------	------	-----------------	---	---	---	--

Notes:

1. Concentrations shown are in parts per trillion (ppt) or nanograms per liter (ng/L).
2. Cells that are shaded gray indicate an exceedance of the current Maximum Contaminant Level (MCL) and the Ambient Groundwater Quality Standards (AGQS) included in Env-Or 600 Contaminated Site Management.
3. NH's four regulated PFAS compounds include: perfluorooctanoic acid (PFOA), perfluorooctane sulfonic acid (PFOS), perfluorohexane sulfonic acid (PFHxS), and perfluorononanoic acid (PFNA).
4. 'ND' indicates the analyzed PFAS was not detected above the laboratory reporting limit.
5. Data represents highest concentration detected at the Site.

Table 2 - Solid Waste Facility
PFAS Water Quality Summary

NHDES SITE #	SITE NAME	PROJECT TYPE	TOWN	Max PFOA Detected (ng/L) AGQS = 12	Max PFOS Detected (ng/L) AGQS = 15	Max PFNA Detected (ng/L) AGQS = 11	Max PFHxS Detected (ng/L) AGQS = 18
198400001	ACWORTH TOWN LANDFILL	LAND/UNLN	ACWORTH	93	11.2	ND	15.7
198802002	KANCAMAGUS LANDFILL	LAND/UNLN	ALBANY	ND	ND	ND	ND
198705017	INDECK ALEXANDRIA ENERGY CTR	LWW/LAG	ALEXANDRIA	ND	ND	ND	ND
199012032	TOWN OF ALLENSTOWN	LAND/UNLN	ALLENSTOWN	25.3	219	2	146
198400006	ALTON TOWN LANDFILL	LAND/UNLN	ALTON	63	15.1	ND	12.9
198704029	SOUHEGAN REG LANDFILL	LAND/UNLN	AMHERST	20	3.58	0.363	6.12
198704047	ANDOVER TOWN LANDFILL	LAND/UNLN	ANDOVER	9.54	ND	ND	ND
198904068	WASTEWATER TRT FACILITY	LWW/LAG	ANTRIM	17.6	7.26	ND	13.8
198705020	ASHLAND MUNICIPAL LANDFILL	LAND/UNLN	ASHLAND	ND	ND	ND	ND
198400026	GODIN SITE	LAND/UNLN	ATKINSON	11	20.8	ND	ND
199002015	AUBURN TOWN LANDFILL	LAND/UNLN	AUBURN	97	78	3.2	31.5
198806003	BARRINGTON LANDFILL	LAND/UNLN	BARRINGTON	11.4	ND	ND	ND
198704028	BARTLETT LANDFILL	LAND/UNLN	BARTLETT	ND	ND	ND	ND
198704084	BEDFORD LANDFILL	LAND/UNLN	BEDFORD	48	34	ND	78.4
198704071	HURRICANE ROAD STUMP DUMP	LAND/UNLN	BELMONT	ND	ND	ND	ND
198704042	BENNINGTON TRI-TOWN LANDFILL	LAND/UNLN	BENNINGTON	11	ND	ND	ND
198400055	CATES HILL LANDFILL	LAND/UNLN	BERLIN	89.1	ND	ND	5.54
198400054	BERLIN TOWN LANDFILL I	LAND/UNLN	BERLIN	116	90.9	ND	7.37
198704035	DUMMER YARD LANDFILL - JAMES RIVER	LAND/UNLN	BERLIN	424	740	13.2	21.6
198400060	WASTE WATER TREATMENT PLANT	LWW/LAG	BETHLEHEM	ND	ND	ND	ND
198704033	NORTH COUNTRY ENVIRONMENTAL SERVICES LF	LAND/LN	BETHLEHEM	64	12.6	8.72	11.3
198400057	BETHLEHEM TOWN LANDFILL (OLD)	LAND/UNLN	BETHLEHEM	75	99.6	8.4	24.1
199101052	CALIFORNIA FIELDS	LAND/UNLN	BOSCAWEN	17	10	ND	6
198901021	CORN HILL ROAD LANDFILL	LAND/UNLN	BOSCAWEN	189	59.6	4.87	108
198400065	MERRIMACK STATION AND ASH LANDFILL	LAND/LN	BOW	ND	ND	ND	ND
198400064	BOW TOWN LANDFILL	LAND/UNLN	BOW	3.7	3.6	ND	ND
198400069	FMR NAUGHTON LANDFILL & AUTOCRAFT SITE	LAND/UNLN	BRADFORD	57	56.7	ND	36.3
199101059	BRIDGEWATER DUMP/INCINERATOR	LAND/UNLN	BRIDGEWATER	7.81	ND	ND	4.6



Table 2 - Solid Waste Facility
PFAS Water Quality Summary

NHDES SITE #	SITE NAME	PROJECT TYPE	TOWN	Max PFOA Detected (ng/L) AGQS = 12	Max PFOS Detected (ng/L) AGQS = 15	Max PFNA Detected (ng/L) AGQS = 11	Max PFHxS Detected (ng/L) AGQS = 18
198704078	NEW HAMPTON LANDFILL	LAND/UNLN	BRISTOL	ND	ND	ND	ND
198400082	CANDIA TOWN LANDFILL	LAND/UNLN	CANDIA	78.5	56.6	1.99	7.3
198400084	CANTERBURY TOWN LANDFILL	LAND/UNLN	CANTERBURY	196	1337	4	791
198705080	CARROLL TOWN LANDFILL	LAND/UNLN	CARROLL	76.2	ND	ND	25
198809009	CENTER HARBOR LANDFILL	LAND/UNLN	CENTER HARBOR	11.2	20.8	ND	ND
198400087	CHARLESTOWN LANDFILL/TRANSFER STATION	LAND/UNLN	CHARLESTOWN	63.9	28.3	ND	5.06
198704036	CHESTER MUNICIPAL LF	LAND/UNLN	CHESTER	25.3	9.12	ND	4.5
198706002	CLAREMONT LANDFILL	LAND/UNLN	CLAREMONT	729	477	38.6	54.9
198400096	COLEBROOK MUNICIPAL LANDFILL	LAND/UNLN	COLEBROOK	191	20.6	8.65	51.6
201202055	TILLOTSON RUBBER LIQUID WASTE DISP AREA	LAND/UNLN	COLEBROOK	ND	ND	ND	ND
198401001	CONCORD CITY LANDFILL/TRANSFER STATION	LAND/UNLN	CONCORD	16.2	19.8	ND	5.34
198406038	OLD SUNCOOK ROAD LANDFILL (1)	LAND/UNLN	CONCORD	186	22.9	ND	29.1
198908068	LOWER MT WASHINGTON VALLEY LANDFILL	LAND/LN	CONWAY	40.6	4.31	5.47	8.18
198401017	CONWAY LANDFILL/SEPTAGE LAGOONS	LAND/UNLN	CONWAY	82.3	5.05	ND	14.9
199103019	CROYDON LANDFILL	LAND/UNLN	CROYDON	7.8	13	ND	3.2
198810003	OLD LANDFILL/X-FER STATION	LAND/UNLN	DALTON	58.9	9	828	ND
198401031	DEERFIELD LANDFILL	LAND/UNLN	DEERFIELD	14.4	4.47	ND	ND
198706001	DERRY MUNICIPAL LANDFILL	LAND/UNLN	DERRY	20.1	13.4	ND	5.6
198401060	DUBLIN SANITARY LANDFILL	LAND/UNLN	DUBLIN	26.4	81	ND	1.87
199006011	DURHAM LANDFILL	LAND/UNLN	DURHAM	28	41	0.66	26
198805021	EFFINGHAM TOWN LANDFILL	LAND/UNLN	EFFINGHAM	35.1	388	5.89	92.2
198401071	BULKY WASTE LANDFILL & OLD DUMP SITE	LAND/UNLN	EPPING	505	130	23.7	330
198406000	ERROL LANDFILL	LAND/UNLN	ERROL	20.6	5.08	ND	ND
198401081	CROSS ROAD LANDFILL/STUMP DUMP (TOWN)	LAND/UNLN	EXETER	7.53	7.04	ND	ND
198401085	FARMINGTON MUNICIPAL LANDFILL	LAND/UNLN	FARMINGTON	407	312	ND	98.4
198401092	CONCORD REG COOP RESIDUE LANDFILL	LAND/LN	FRANKLIN	ND	ND	ND	ND
198401090	OLD FRANKLIN LANDFILL	LAND/UNLN	FRANKLIN	33.9	34	ND	5.9
199101056	FREEDOM LANDFILL	LAND/UNLN	FREEDOM	24.9	54.1	ND	ND

Table 2 - Solid Waste Facility
PFAS Water Quality Summary

NHDES SITE #	SITE NAME	PROJECT TYPE	TOWN	Max PFOA Detected (ng/L) AGQS = 12	Max PFOS Detected (ng/L) AGQS = 15	Max PFNA Detected (ng/L) AGQS = 11	Max PFHxS Detected (ng/L) AGQS = 18
198906002	GILMANTON LANDFILL	LAND/UNLN	GILMANTON	387	212	8.34	57.9
198402003	GILSUM LANDFILL/SEPTAGE PIT	LAND/UNLN	GILSUM	56.1	653	6.52	ND
198402005	GOFFSTOWN MUNICIPAL LANDFILL	LAND/UNLN	GOFFSTOWN	12.4	10.9	ND	1.6
198705009	GOSHEN SANITARY LANDFILL/TRANSFER STA	LAND/UNLN	GOSHEN	317	1400	5.7	29
199102037	GRAFTON OLD LANDFILL	LAND/UNLN	GRAFTON	42.1	382	ND	77.1
199103005	GRANTHAM LANDFILL	LAND/UNLN	GRANTHAM	17.2	9.15	ND	ND
198708004	CROTCHED MOUNTAIN FOUNDATION	LAND/UNLN	GREENFIELD	ND	ND	ND	ND
199102032	GROTON TOWN DUMP	LAND/UNLN	GROTON	8.15	17.6	ND	0.58
198402023	HAMPTON MUNICIPAL LANDFILL	LAND/UNLN	HAMPTON	72.5	91.5	6	8.71
198705010	HANCOCK TOWN LANDFILL	LAND/UNLN	HANCOCK	140	1330	15	261
198708010	HARRISVILLE TOWN LANDFILL	LAND/UNLN	HARRISVILLE	97.1	93.5	2	11.3
198402028	HENNIKER TOWN LANDFILL/TRANSFER STATION	LAND/UNLN	HENNIKER	ND	55.4	ND	ND
198704004	HILLSBORO WWTF	LWW/LAG	HILLSBOROUGH	1.7	ND	ND	ND
198704088	HILLSBORO TOWN LANDFILL/X-FER STATION	LAND/UNLN	HILLSBOROUGH	430	370	110	11
198402035	HINSDALE PRODUCTS LANDFILL	LAND/UNLN	HINSDALE	18.6	ND	ND	ND
198402033	HINSDALE MUNICIPAL LANDFILL	LAND/UNLN	HINSDALE	826	1550	380	33
199009014	HOLDERNESS LANDFILL	LAND/UNLN	HOLDERNESS	89.5	107	712	16
198402043	HOOKSETT TRANSFER/HIGHWAY	LAND/UNLN	HOOKSETT	62.2	2.19	ND	28.7
199105019	HOPKINTON WASTEWATER TREATMENT FACILITY	LWW/LAG	HOPKINTON	5.92	ND	ND	7
198705021	HOPKINTON/WEBSTER LANDFILL	LAND/UNLN	HOPKINTON	19.3	ND	ND	9.88
199204002	BENSON PARK (FORMER BENSONS ANIMAL PARK)	LAND/UNLN	HUDSON	29.2	16.6	ND	ND
198402057	HUDSON TOWN LANDFILL	LAND/UNLN	HUDSON	186	33.5	2.61	11.1
198712013	JACKSON OLD LANDFILL	LAND/UNLN	JACKSON	7.66	9.5	ND	ND
198402073	JAFFREY LANDFILL & WWTF / ULWW LAGOONS	LAND/UNLN	JAFFREY	1.9	ND	ND	ND
198402076	JEFFERSON TOWN LANDFILL	LAND/UNLN	JEFFERSON	0.46	2.8	ND	0.66
198402082	KEENE OLD CITY LANDFILL	LAND/UNLN	KEENE	6.83	9.78	ND	4.52
199009001	KEENE MUNICIPAL LANDFILL	LAND/UNLN	KEENE	221	274	7.51	57.9
198705089	KINGSTON TOWN LANDFILL	LAND/UNLN	KINGSTON	4.99	ND	ND	ND



Table 2 - Solid Waste Facility
PFAS Water Quality Summary

NHDES SITE #	SITE NAME	PROJECT TYPE	TOWN	Max PFOA Detected (ng/L) AGQS = 12	Max PFOS Detected (ng/L) AGQS = 15	Max PFNA Detected (ng/L) AGQS = 11	Max PFHxS Detected (ng/L) AGQS = 18
198709021	LACONIA DISPOSAL GARDENS	LAND/UNLN	LACONIA	ND	ND	ND	ND
198705056	LANCASTER DISPOSAL FACILITY	LAND/UNLN	LANCASTER	20.8	27.9	ND	5.03
198710039	LEBANON LANDFILL	LAND/LN	LEBANON	88.8	15.1	ND	28.5
198403011	LEMPSTER TOWN LANDFILL	LAND/UNLN	LEMPSTER	ND	ND	ND	ND
198704025	LISBON TOWN LANDFILL AND LAGOONS	LAND/UNLN	LISBON	110	18.1	ND	23.6
199001001	NORTON CO LANDFILL	LAND/UNLN	LITTLETON	11	ND	ND	ND
198704045	LITTLETON TOWN LANDFILL	LAND/UNLN	LITTLETON	564	59	47.4	32.6
198804014	SPARTAN CONSOLIDATED	LAND/UNLN	LONDONDERRY	210	200	6.8	29
198801025	LOUDON LANDFILL/X-FER STATION	LAND/UNLN	LOUDON	282	51.9	8.39	33.8
198403039	MADISON LANDFILL	LAND/UNLN	MADISON	2.8	ND	ND	ND
198403055	MANCHESTER MUNICIPAL LANDFILL	LAND/UNLN	MANCHESTER	532	53.4	11	35.7
198403071	MARLBOROUGH MUNICIPAL LANDFILL	LAND/UNLN	MARLBOROUGH	48.6	62	ND	8.03
199103022	MARLOW MUNICIPAL LANDFILL	LAND/UNLN	MARLOW	139	1600	4.7	7.6
198403073	MEREDITH MUNICIPAL LANDFILL	LAND/UNLN	MEREDITH	91.1	36	3.7	12
198403083	MERRIMACK TOWN LANDFILL	LAND/UNLN	MERRIMACK	2450	1600	30	285
198908012	MILFORD TRANSFER STATION	LAND/UNLN	MILFORD	47.8	34.4	2	27.7
198708009	MILFORD SLUDGE DISPOSAL LAND (WWTF)	LAND/LN	MILFORD	60.3	78.8	6.37	15.4
198403092	TOWN W W T P	LWW/LAG	MILTON	ND	ND	ND	ND
198403093	MILTON TOWN LANDFILL	LAND/UNLN	MILTON	10.9	25	ND	ND
198705087	FORMER MOULTONBOROUGH TOWN LANDFILL	LAND/UNLN	MOULTONBOROUGH	555	601	19.4	342
200202018	ROUSSEL PARK	LAND/UNLN	NASHUA	253	2.18	4.28	11.4
200203021	LINCOLN PARK/COLISEUM AVE. (FMR ADS 207)	LAND/UNLN	NASHUA	90.4	21.8	5.61	7.02
198904055	BLUE LINE EXPRESS (WEBSTER SQUARE)	LAND/UNLN	NASHUA	78.4	32.5	ND	24.1
200009057	NASHUA RIVERSIDE LANDFILL	LAND/UNLN	NASHUA	23.6	43.9	ND	5.14
198705083	SHADY LANE LANDFILL (FORMER ADS 309)	LAND/UNLN	NASHUA	59.3	47.7	ND	9.73
198403099	FOUR HILLS LANDFILL NASHUA RECYCL CTR	LAND/UNLN	NASHUA	246	111	8.38	108
198404014	NEW BOSTON TRANSFER STATION	LAND/UNLN	NEW BOSTON	15.4	4.21	1.55	2.46
198811009	NEW DURHAM HIGHWAY DEPT	LAND/UNLN	NEW DURHAM	ND	ND	ND	ND

Table 2 - Solid Waste Facility
PFAS Water Quality Summary

NHDES SITE #	SITE NAME	PROJECT TYPE	TOWN	Max PFOA Detected (ng/L) AGQS = 12	Max PFOS Detected (ng/L) AGQS = 15	Max PFNA Detected (ng/L) AGQS = 11	Max PFHxS Detected (ng/L) AGQS = 18
198404017	NEW IPSWICH TOWN LANDFILL	LAND/UNLN	NEW IPSWICH	719	206	104	156
198710013	NEW LONDON STUMP DUMP	LAND/UNLN	NEW LONDON	8.73	13.7	ND	ND
198404020	NEW LONDON OLD TOWN LANDFILL	LAND/UNLN	NEW LONDON	39.5	42.3	2.7	2.2
198806028	NEWBURY DEMO DEBRIS LANDFILL	LAND/UNLN	NEWBURY	48	240	2.04	150
198704049	NEWMARKET LANDFILL	LAND/UNLN	NEWMARKET	12	12	ND	4
198908037	NEWPORT WWTF	LWW/LAG	NEWPORT	ND	ND	ND	ND
198705052	NEWPORT MUNICIPAL LANDFILL	LAND/UNLN	NEWPORT	35.7	20	ND	4.81
198404027	NH/VT SOLID WASTE PROJECT	LAND/LN	NEWPORT	ND	ND	ND	ND
199101029	NEWTON MUNICIPAL LANDFILL	LAND/UNLN	NEWTON	101	111	2.32	13.2
198404034	PIKE INDUSTRIES INC 700	LAND/UNLN	NORTHFIELD	4	ND	ND	ND
198704070	NORTHFIELD HIGHWAY GARAGE	LAND/UNLN	NORTHFIELD	21.4	585	4.56	264
198801023	GROVETON LANDFILL	LAND/UNLN	NORTHUMBERLAND	107	232	4.46	300
199001014	NOTTINGHAM MUNICIPAL SOLID WASTE FAC	LAND/UNLN	NOTTINGHAM	2360	239	354	87.6
198809004	ORFORD LANDFILL	LAND/UNLN	ORFORD	61.3	8.05	6	9.25
198404045	OSSIPEE LANDFILL/INCINERATOR	LAND/UNLN	OSSIPEE	29.1	31	10.7	23
198404052	ROKETENETZ LANDFILL	LAND/UNLN	PELHAM	900	3100	170	92
198404049	PEMBROKE LANDFILL	LAND/UNLN	PEMBROKE	15.3	19.5	ND	4.65
198905054	EMS PARCEL B SITE (OLD TOWN DUMP)	LAND/UNLN	PETERBOROUGH	ND	ND	ND	ND
198404057	PETERBOROUGH TOWN LANDFILL	LAND/UNLN	PETERBOROUGH	39	87	3.2	3.5
198903064	PIERMONT TOWN LANDFILL	LAND/UNLN	PIERMONT	7.87	16.1	ND	63.2
199004019	PITTSBURG TRANSFER STATION LF	LAND/UNLN	PITTSBURG	ND	ND	ND	ND
198901008	SW INCIN & TRSFR STA (BCEP)	LAND/UNLN	PITTSFIELD	26	27.6	ND	3.42
199105022	MERIDEN WASTEWATER TREATMENT FACILITY	LWW/LAG	PLAINFIELD	9.53	6.9	ND	ND
198404075	PLAISTOW MUNICIPAL LANDFILL	LAND/UNLN	PLAISTOW	47.9	170	5	13
198404078	PLYMOUTH INCINERATOR/ASH LF	LAND/UNLN	PLYMOUTH	17.6	29.5	3.08	4.6
198404088	PSNH SCHILLER STATION	LAND/UNLN	PORTSMOUTH	ND	7.51	ND	ND
198404087	JONES AVE LANDFILL & ASH CONTAINMENT	LAND/UNLN	PORTSMOUTH	33	21.8	ND	12.8
198808007	RANDOLPH LANDFILL OLD	LAND/UNLN	RANDOLPH	4	11	ND	ND

Table 2 - Solid Waste Facility
PFAS Water Quality Summary

NHDES SITE #	SITE NAME	PROJECT TYPE	TOWN	Max PFOA Detected (ng/L) AGQS = 12	Max PFOS Detected (ng/L) AGQS = 15	Max PFNA Detected (ng/L) AGQS = 11	Max PFHxS Detected (ng/L) AGQS = 18
198404092	RAYMOND LANDFILL	LAND/UNLN	RAYMOND	230	2400	7.1	180
198706006	TLR-II	LAND/LN	ROCHESTER	41	6.8	7.4	4.1
198706010	TLR-I (PHASES I-IV)	LAND/LN	ROCHESTER	460	70	16	20
198705045	ROCHESTER LANDFILL	LAND/UNLN	ROCHESTER	1100	311	24.9	148
198808005	RUMNEY LANDFILL	LAND/UNLN	RUMNEY	43.5	54.1	ND	7.48
198705029	RYE MUNICIPAL LANDFILL	LAND/UNLN	RYE	67	36	ND	14
198704080	RYE GROVE ROAD LANDFILL	LAND/UNLN	RYE	60.1	110	ND	25
198405030	SHANNON RD LANDFILL	LAND/UNLN	SALEM	458	631	ND	50.3
198405024	LL & S LANDFILL	LAND/UNLN	SALEM	680	1100	55	230
198405034	SALISBURY TOWN LANDFILL	LAND/UNLN	SALISBURY	22.1	ND	ND	ND
198405036	SANBORNTON TOWN LANDFILL	LAND/UNLN	SANBORNTON	12.4	ND	ND	4.49
198405037	SANDWICH LANDFILL	LAND/UNLN	SANDWICH	4.98	7.67	ND	ND
198910015	SHELBURNE LANDFILL	LAND/UNLN	SHELBURNE	15.4	21.4	ND	2.44
198405054	LAMPREY REGIONAL COOP/SLUDGE ASH LF	LAND/LN	SOMERSWORTH	16	19.8	ND	10
198405050	SPRINGFIELD POWER FMR HEMPHILL POWER	LWW/LAG	SPRINGFIELD	10.3	7.05	ND	ND
198500040	STARK MUNICIPAL LANDFILL	LAND/UNLN	STARK	ND	ND	ND	ND
198705031	JAMES RIVER BARK PILE	LAND/UNLN	STARK	7.1	ND	ND	ND
198500020	STRAFFORD LANDFILL	LAND/UNLN	STRAFFORD	48.4	150	ND	11
199102024	STRATFORD MUNICIPAL LANDFILL	LAND/UNLN	STRATFORD	ND	ND	ND	ND
198909004	STRATHAM LANDFILL	LAND/UNLN	STRATHAM	124	37.2	ND	80.7
198706016	MT CARBERRY LANDFILL	LAND/LN	SUCCESS	240	29.5	30.4	88.4
199103006	SUNAPEE LANDFILL	LAND/UNLN	SUNAPEE	406	271	110	19.5
199105015	W SWANZEY VILLAGE AREA WWTF	LWW/LAG	SWANZEY	ND	ND	ND	ND
198704017	TAMWORTH TOWN LANDFILL	LAND/UNLN	TAMWORTH	337	121	95.4	12.1
199101060	THORNTON LANDFILL	LAND/UNLN	THORNTON	13.9	ND	ND	ND
198405081	TOWN OF TROY LANDFILL	LAND/UNLN	TROY	62.9	57.9	65	18
198405083	TUFTONBORO TOWN LANDFILL	LAND/UNLN	TUFTONBORO	173	1.96	5.24	45.8
198809016	UNITY MUNICIPAL LANDFILL	LAND/UNLN	UNITY	3700	92	410	40

Table 2 - Solid Waste Facility
PFAS Water Quality Summary

NHDES SITE #	SITE NAME	PROJECT TYPE	TOWN	Max PFOA Detected (ng/L) AGQS = 12	Max PFOS Detected (ng/L) AGQS = 15	Max PFNA Detected (ng/L) AGQS = 11	Max PFHxS Detected (ng/L) AGQS = 18
198704018	WAKEFIELD TOWN LANDFILL	LAND/UNLN	WAKEFIELD	623	148	130	66.1
198705026	WALPOLE LANDFILL	LAND/UNLN	WALPOLE	54.1	126	ND	15.1
199102030	WARREN DUMP #1	LAND/UNLN	WARREN	ND	ND	ND	ND
198806031	WASHINGTON LANDFILL	LAND/UNLN	WASHINGTON	14	27.7	ND	ND
198704005	WEARE LF/SEPTAGE LAG/TOWN GARAGE	LAND/UNLN	WEARE	7.41	8.19	ND	ND
199102031	WENTWORTH LANDFILL	LAND/UNLN	WENTWORTH	47.3	ND	ND	23
199105008	CHESHIRE COUNTY HOME WWTF & JAIL	LWW/LAG	WESTMORELAND	ND	ND	ND	ND
198806027	WESTMORELAND LANDFILL	LAND/UNLN	WESTMORELAND	82.3	145	ND	7.19
198801018	DG WHITEFIELD LLC (FMR POWER & LIGHT CO)	LWW/LAG	WHITEFIELD	ND	ND	ND	ND
198406001	SEWAGE TREATMENT FAC	LWW/LAG	WHITEFIELD	ND	ND	ND	ND
199102009	WHITEFIELD LANDFILL	LAND/UNLN	WHITEFIELD	18.1	ND	ND	ND
200111035	MOUNTAIN VIEW GRAND RESORT & SPA	LAND/UNLN	WHITEFIELD	74.4	47.8	41	8.6
198704087	WILTON SANITARY LANDFILL	LAND/UNLN	WILTON	20.7	12.3	ND	ND
198704085	WINCHESTER TOWN LANDFILL	LAND/UNLN	WINCHESTER	ND	ND	ND	ND
198801019	WINDHAM TOWN LANDFILL	LAND/UNLN	WINDHAM	17	10.5	ND	6.25
199101048	WOLFEBORO ABANDONED DUMP	LAND/UNLN	WOLFEBORO	13	13	ND	8.4
198406014	WOLFEBORO ASH LANDFILL	LAND/UNLN	WOLFEBORO	242	91	7.28	107

Notes:

1. Concentrations shown are in parts per trillion (ppt) or nanograms per liter (ng/L).
2. Cells that are shaded gray indicate an exceedance of the current Ambient Groundwater Quality Standards (AGQS) included in Env-Or 600 Contaminated Site Management.
3. NH's four regulated PFAS compounds include: perfluorooctanoic acid (PFOA), perfluorooctane sulfonic acid (PFOS), perfluorohexane sulfonic acid (PFHxS), and perfluorononanoic acid (PFNA).
4. 'ND' indicates the analyzed PFAS was not detected above the laboratory reporting limit.
5. NA indicates that the specified PFAS was not analyzed at the site.
6. Data represents highest concentration detected at the Site.



Table 3 - Hazardous Waste Remediation Sites
PFAS Water Quality Summary

NHDES SITE #	SITE NAME	PROJECT TYPE	TOWN	Max PFOA Detected (ng/L) AGQS = 12	Max PFOS Detected (ng/L) AGQS = 15	Max PFNA Detected (ng/L) AGQS = 11	Max PFHxS Detected (ng/L) AGQS = 18
199902045	PERFECT FIT INDUSTRIES FMRTTHOMAS HODGSON	HAZWASTE	ALLENSTOWN	25	26	10	60
201701005	SOUTHERN PORTION OF CALDWELL DRIVE AREA	SITEEVALHW	AMHERST	1090	13	ND	ND
201701004	CENTRAL PORTION OF HOWE DRIVE AREA	SITEEVALHW	AMHERST	965	29.8	ND	ND
201605022	FORMER TCI FACILITY	HAZWASTE	AMHERST	18000	50	9.3	9.7
202004027	NORTH HOLLIS ROAD/SOUTH MERRIMACK ROAD	SITEEVALHW	AMHERST/HOLLIS	99	85	ND	5.3
200009045	L W PACKARD & CO INC	SITEEVALHW	ASHLAND	44.4	12.4	ND	ND
198703020	ATKINSON FIRE DEPT	SITEEVALHW	ATKINSON	225	5.59	ND	215
200210001	EMERY DRIVE SITE	HAZWASTE	ATKINSON	10.7	11.2	1.82	2.81
199707009	28 COMMERCIAL COURT (FMR 8 PRISCILLA LN)	HAZWASTE	AUBURN	3	2.38	ND	ND
199809034	88 PRISCILLA LANE PROPERTY	SITEEVALHW	AUBURN	24	100	2.7	33
199608027	FORMER INSURANCE SALVAGE AUCTION	HAZWASTE	AUBURN	3	ND	ND	ND
198406023	TIBBETTS ROAD DRUM SITE	CERCLA	BARRINGTON	2.46	2.71	0.385	0.576
200602025	NASHUA ROAD PROPERTY	HAZWASTE	BEDFORD	23.7	8.75	ND	ND
199709046	CHLOR ALKALI FACILITY (CROWN VANTAGE)	CERCLA	BERLIN	201	70.1	ND	8.99
202001022	FMR ISAACSON STRUCTURAL STEEL-MAP 105-14	SITEEVALHW	BERLIN	307	698	ND	6.17
201703005	FORMER SINCLAIR HOTEL PROPERTY	HAZWASTE	BETHLEHEM	ND	ND	ND	ND
198400061	ALLIED LEATHER CORP./QUEEN ST. LANDFILL	HAZWASTE	BOSCAWEN	ND	ND	ND	ND
198708008	FORMER GRAPHIC PACKAGING	HAZWASTE	BOW	8.84	9.52	1.08	3.78
198906062	ROCKINGHAM COUNTY COMPLEX	HAZWASTE	BRENTWOOD	3800	46000	4500	15000
200610095	OMNI TECHNOLOGIES CORPORATION	HAZWASTE	BRENTWOOD	ND	ND	ND	ND
198706012	FREUDENBERG NOK	HAZWASTE	BRISTOL	2920	534	48.3	75.2
199902022	FMR BEEBE RIVER MILL LAGOON	HAZWASTE	CAMPTON	ND	ND	ND	ND
198400091	BARNEY BASS COMPANY	HAZWASTE	CLAREMONT	1.4	1.3	ND	ND
200308070	T BIRD MINI MART	HAZWASTE	CLAREMONT	6	4	1	0.9
200911039	101 MULBERRY STREET PROPERTY	HAZWASTE	CLAREMONT	7.46	9.38	4.56	2.85
201805030	NORTH ST AND WASHINGTON ST AREA	SITEEVALHW	CLAREMONT	19	62	ND	98
199601023	FORMER SYNERGY GAS (ALLSTAR GAS)	HAZWASTE	CLAREMONT	19	62	ND	98
199807063	FORMER POWERAY INFRARED CORP.	HAZWASTE	CLAREMONT	2.43	ND	ND	ND



Table 3 - Hazardous Waste Remediation Sites
PFAS Water Quality Summary

NHDES SITE #	SITE NAME	PROJECT TYPE	TOWN	Max PFOA Detected (ng/L) AGQS = 12	Max PFOS Detected (ng/L) AGQS = 15	Max PFNA Detected (ng/L) AGQS = 11	Max PFHxS Detected (ng/L) AGQS = 18
198401012	BEEDE ELECTRICAL INSTRUMENTS	HAZWASTE	CONCORD	1.93	3.39	ND	ND
199212014	EXIT 13 COAL TAR POND	HAZWASTE	CONCORD	21.8	3.6	NA	2.88
198605043	FORMER ALLIED LEATHER TANNERY	HAZWASTE	CONCORD	18	57	0.9	8.9
199811043	DOT GULLY HILL STORAGE SHED	HAZWASTE	CONCORD	21	87.9	ND	92.5
198904063	CONCORD COAL GAS SITE	HAZWASTE	CONCORD	14.6	144	ND	5.92
198711003	ELECTROPAC WORLDWIDE (FMR VISHAY SPRAGUE	HAZWASTE	CONCORD	12.8	158	ND	16.2
200011034	CONCORD CLEANERS	HAZWASTE	CONCORD	67.9	177	21.2	13.1
201710012	RICHARD FLYNN FIRE ACADEMY	HAZWASTE	CONCORD	2200	35000	25000	5100
198708002	KEARSARGE METALLURGICAL CORP	CERCLA	CONWAY	25.3	2.9	2	2.9
199110087	WHITE MOUNTAIN LAUNDRY & DRY CLEANERS	HAZWASTE	CONWAY	6.11	ND	ND	ND
201802004	24 SCOBIE POND ROAD PROPERTY	SITEEVALHW	DERRY	59	24	2	38
202005042	ROYAL T CARWASH	HAZWASTE	DERRY	266	103	37.4	9.73
201511011	FORMER NH MARBLE & FIBERGLASS	HAZWASTE	DERRY	111	776	5.86	56.9
198401037	HADCO PRINTED CIRCUIT	HAZWASTE	DERRY	170	850	7	150
198710022	FMR TEXTRON AUTOMOTIVE COMPANY PROPERTY	HAZWASTE	DOVER	13.5	5.76	ND	1.84
199011005	HEIDELBERG WEB SYSTEMS INC (FRMLY HARRIS	HAZWASTE	DOVER	9.7	5.9	2	3.1
199203042	MOORE BUSINESS EQUIPMENT (FORMER)	HAZWASTE	DOVER	8.3	6.77	ND	25.3
199202044	DOVER PUBLIC WORKS GARAGE	HAZWASTE	DOVER	320	16	53	5
200707072	VARNEY'S CLEANERS	HAZWASTE	DOVER	8.13	17.9	ND	5.01
198401047	DOVER GAS WORKS	HAZWASTE	DOVER	200	23	78	21
200410018	16 INDUSTRIAL PARK DRIVE LLC	HAZWASTE	DOVER	7.56	29.5	ND	ND
200701053	COCHeco PARK	HAZWASTE	DOVER	12.5	74.5	ND	ND
198907059	ONE WASHINGTON CENTER INC	HAZWASTE	DOVER	28	124	9.7	8.52
198401046	FMR ELLIOTT & WILLIAMS ROSES	HAZWASTE	DOVER	42.3	520	ND	10.5
198803019	DOVER LANDFILL SUPERFUND SITE	CERCLA	DOVER	1100	890	430	1500
198705067	ELECTROCRAFT NEW HAMPSHIRE	HAZWASTE	DOVER	ND	ND	ND	ND
199812012	BUXTON OIL CO INC	HAZWASTE	EPPING	4.8	28	ND	ND
198710024	KEEFE ENVIR.	CERCLA	EPPING	306	46	2.6	12.5



Table 3 - Hazardous Waste Remediation Sites
PFAS Water Quality Summary

NHDES SITE #	SITE NAME	PROJECT TYPE	TOWN	Max PFOA Detected (ng/L) AGQS = 12	Max PFOS Detected (ng/L) AGQS = 15	Max PFNA Detected (ng/L) AGQS = 11	Max PFHxS Detected (ng/L) AGQS = 18
198908063	RESOURCES WASTE SERVICES LLC	HAZWASTE	EPPING	180	122	10.8	38
198605257	FMR. ALROSE SHOE CO., INC.	SITEEVALHW	EXETER	3.43	ND	ND	7.08
200502096	83-85 EPPING ROAD PROPERTY	HAZWASTE	EXETER	ND	ND	ND	ND
198401083	TEXTRON'S CARDINAL LANDFILL	HAZWASTE	FARMINGTON	6.42	5.44	ND	2.38
198603048	UNION TELEPHONE COMPANY	HAZWASTE	FARMINGTON	5	11.6	ND	3
198705014	COLLINS & AIKMAN PLANT (FMR TEXTRON)	CERCLA	FARMINGTON	34.5	94	4.29	14.3
200009052	MEADOWOOD ASSEMBLY HALL	HAZWASTE	FITZWILLIAM	35	1100	ND	370
201704004	FMR CIAO PASTA	SITEEVALHW	FRANKLIN	120	210	16	120
199306026	FRANKLIN FIRE STATION	HAZWASTE	FRANKLIN	890	10000	480	1500
198705001	ACME STAPLE COMPANY	HAZWASTE	FRANKLIN	ND	ND	ND	ND
198402001	GILFORD FIRE TRAINING SITE	HAZWASTE	GILFORD	6.01	85.1	ND	ND
200411113	LOWER LIBERTY HILL ROAD SITE	HAZWASTE	GILFORD	ND	ND	ND	ND
198908003	NUTTER CONSTRUCTION	HAZWASTE	GILMANTON	4.51	ND	ND	ND
200110023	FORMER GOFFSTOWN DPW GARAGE	HAZWASTE	GOFFSTOWN	8.6	2.5	1.8	1.5
201705038	FLETCHER MOUNTAIN - 14 DEPOT ST	SITEEVALHW	GOFFSTOWN	130	680	15	160
200001038	JOHNSON AND JOHNSTON ASSOCIATES, INC.	HAZWASTE	HAMPSTEAD	11	45	ND	7
198904009	HAMPTON MAIN TOLL PLAZA	HAZWASTE	HAMPTON	12	2.64	0.8	1.4
198805025	HESS 29202-LUCIER HOLDINGS	HAZWASTE	HAMPTON	22.8	10.3	9.79	9.63
201811034	610 LAFAYETTE ROAD	HAZWASTE	HAMPTON	27	31	4.9	2.3
198804018	HAMPTON FOREIGN AUTO	HAZWASTE	HAMPTON	22	52	3	ND
200007006	HANCOCK FORMER DUMP SITE	HAZWASTE	HANCOCK	5.07	140	39	25.7
199101025	COLD REGIONS RESEARCH & ENGINEERING LAB	HAZWASTE	HANOVER	8.2	5.9	1.8	10
199705006	HYPERTHERM INC	HAZWASTE	HANOVER	6	16	ND	ND
198802009	HANOVER CONSUMERS COOP SOCIETY	HAZWASTE	HANOVER	127	49.1	60.7	10.3
201111109	RENNIE FARM PROJECT	HAZWASTE	HANOVER	ND	ND	ND	ND
199606069	MCGOLDRICK PAPER CO INC	SITEEVALHW	HINSDALE	23.6	280	13	ND
199104013	CONTINENTAL INDUSTRIES	HAZWASTE	HINSDALE	2.74	ND	ND	ND
201801035	MARTIN'S FERRY	HAZWASTE	HOOKSETT	560	1	ND	81



Table 3 - Hazardous Waste Remediation Sites
PFAS Water Quality Summary

NHDES SITE #	SITE NAME	PROJECT TYPE	TOWN	Max PFOA Detected (ng/L) AGQS = 12	Max PFOS Detected (ng/L) AGQS = 15	Max PFNA Detected (ng/L) AGQS = 11	Max PFHxS Detected (ng/L) AGQS = 18
198709008	GE AVIATION	HAZWASTE	HOOKSETT	11.3	8.88	ND	4.37
199210027	AUTO WHOLESALER OF HOOKSETT/NAULT SUBARU	HAZWASTE	HOOKSETT	61.1	13.5	ND	6.32
198708005	MARKLIN CANDLE CO FMR AEROTRONIC FAC	HAZWASTE	HOPKINTON	221	1550	14.2	497
198806099	HUDSON LANDFILL (BURNS HILL RD)	HAZWASTE	HUDSON	63.7	28.5	0.665	4.16
198805019	COMPUTER OPTICS	HAZWASTE	HUDSON	41	54	ND	6
199805041	MELBA BURTON PROPERTY	HAZWASTE	HUDSON	7.94	ND	ND	ND
198402070	BURNS HILL RD SITE	HAZWASTE	HUDSON	ND	ND	ND	ND
198708007	WW CROSS TACK PILE	HAZWASTE	JAFFREY	9.4	21	ND	7.4
199908001	FMR BUSSIÈRE PROPERTY (ELITE LAUNDRY)	HAZWASTE	JAFFREY	16	110	1.6	13
200203055	JAFFREY WATER WORKS TURNPIKE RD. WELL	SITEEVALHW	JAFFREY	17.4	657	ND	81.7
199108021	HADLEY PROPERTIES	HAZWASTE	JAFFREY	ND	ND	ND	ND
200108004	ACHILLE AGWAY	HAZWASTE	KEENE	8.5	2.6	1.1	2.6
198402080	FINDINGS INC.	HAZWASTE	KEENE	7.75	3.03	ND	ND
199412009	PSNH 227 EMERALD ST	HAZWASTE	KEENE	10	5.9	0.91	2
199103010	RIVERSIDE PLAZA	HAZWASTE	KEENE	9.73	5.93	ND	3.47
198910006	TIMKEN SUPER PRECISION	HAZWASTE	KEENE	ND	6.13	ND	ND
200104006	AUBUCHON/MARTIAL ARTS CENTER	HAZWASTE	KEENE	27.5	13.6	ND	ND
198801029	CENTRAL SCREW/KEENE MILL	HAZWASTE	KEENE	ND	14.6	ND	18
199802052	PEOPLES LAUNDRY INC	HAZWASTE	KEENE	12	23	ND	4
201310007	32 WASHINGTON STREET SITE	HAZWASTE	KEENE	97.6	30.1	ND	21.1
199411051	FAIRBANKS PLAZA	HAZWASTE	KEENE	18.3	36.8	ND	4.63
198909019	FORMER ZINN'S BOWLING LANES	HAZWASTE	KEENE	7	ND	ND	6
199101014	MAIN STREET SUNOCO	HAZWASTE	KEENE	ND	ND	ND	ND
200401019	COLONY MILL MARKETPLACE	HAZWASTE	KEENE	ND	ND	ND	ND
199103103	KINGSTON FIRE DEPT	HAZWASTE	KINGSTON	400	110	130	32
199004006	OTTATI & GOSS/GREAT LAKES CONTAINER CORP	CERCLA	KINGSTON	3200	4750	28.8	65
199212023	LACONIA STATE SCHOOL	SITEEVALHW	LACONIA	3.5	2.5	ND	ND
200404044	FORMER VERNITRON PROPERTY	HAZWASTE	LACONIA	5.86	7.6	ND	ND



Table 3 - Hazardous Waste Remediation Sites
PFAS Water Quality Summary

NHDES SITE #	SITE NAME	PROJECT TYPE	TOWN	Max PFOA Detected (ng/L) AGQS = 12	Max PFOS Detected (ng/L) AGQS = 15	Max PFNA Detected (ng/L) AGQS = 11	Max PFHxS Detected (ng/L) AGQS = 18
199312038	MESSER STREET COAL TAR SITE	HAZWASTE	LACONIA	48	8.1	4300	4.4
201207059	FMR ABC FABRICATORS, INC.	HAZWASTE	LACONIA	32.2	27.1	ND	ND
199906039	LAKES REGION LINEN	HAZWASTE	LACONIA	14	160	5	5
198910016	FRED FULLER OIL CO INC (FMR ELECTRO-CIR)	HAZWASTE	LACONIA	150	180	2.2	470
199506014	BARON MACHINE COMPANY	HAZWASTE	LACONIA	2	ND	ND	ND
199204007	BOND OPTICS	HAZWASTE	LEBANON	16.2	4.46	110	ND
201704036	KLEEN DRYCLEANERS RETAIL SITE	HAZWASTE	LEBANON	7.82	16.3	2.69	154
198705054	TIMKEN AEROSPACE (FMR SPLIT BALLBEARING)	HAZWASTE	LEBANON	4.94	18.7	ND	ND
198801003	KLEEN LAUNDRY	HAZWASTE	LEBANON	16.8	18.8	2.69	154
199501031	BONNIE PLANTS (FOMERLY JOLLY FARMER)	SITEEVALHW	LEMPSTER	2.28	3.55	ND	ND
198902003	FMR FRAMATONE CONNECTORS USA(BURNDY LLC)	HAZWASTE	LINCOLN	61.2	296	31.2	37.8
199104012	TOWN OF LONDONDERRY (FORMER LAMONT LABS)	HAZWASTE	LONDONDERRY	77.6	9.13	ND	6.13
198802020	FLIGHT ONE OWNERS ASSOC. SITE	HAZWASTE	LONDONDERRY	52.4	17.2	2.68	11.8
198705068	PLAZA 28	HAZWASTE	LONDONDERRY	33	29.2	4.6	11.7
198803007	AUBURN ROAD LANDFILL	CERCLA	LONDONDERRY	201	38.9	6.16	14.4
201501009	IMPACTED WATER SUPPLY WELLS	HAZWASTE	LONDONDERRY	29.9	44.2	2.94	3.02
200009020	MANCHESTER AIRPORT SOUTH REGIONAL	HAZWASTE	LONDONDERRY	290	100	33	280
201708017	APPLETREE MALL	HAZWASTE	LONDONDERRY	470	192	568	27
201803016	SANBORN ROAD AREA SITE	HAZWASTE	LONDONDERRY	117	377	ND	1540
199004008	TINKHAM'S GARAGE	CERCLA	LONDONDERRY	831	758	19	99.7
200410259	COOKSON ELECTRONICS	HAZWASTE	LONDONDERRY	147	1310	14.9	1.26
198909017	NH MOTOR SPEEDWAY	HAZWASTE	LOUDON	38.7	240	31.1	229
198705022	NE METAL RECYCLING (FMR MADBURY METALS)	HAZWASTE	MADBURY	1700	1440	99.8	630
202103016	MADISON TOWN MUNICIPAL COMPLEX	SITEEVALHW	MADISON	26.3	2.49	429	14.2
199310024	RAY'S CHEVRON STATION	SITEEVALHW	MANCHESTER	28	10	ND	11
199712026	MANCHESTER TRANSIT AUTHORITY	HAZWASTE	MANCHESTER	25.1	10.1	ND	8.1
199702009	122 MCGREGOR STREET	HAZWASTE	MANCHESTER	11	14	ND	18
201808024	CINTAS CORP - 341 TAYLOR ST FACILITY	HAZWASTE	MANCHESTER	150	17	2.8	6.5



Table 3 - Hazardous Waste Remediation Sites
PFAS Water Quality Summary

NHDES SITE #	SITE NAME	PROJECT TYPE	TOWN	Max PFOA Detected (ng/L) AGQS = 12	Max PFOS Detected (ng/L) AGQS = 15	Max PFNA Detected (ng/L) AGQS = 11	Max PFHxS Detected (ng/L) AGQS = 18
198403040	UNIVERSITY CENTER AS (AMOSKEAG MACHINE)	HAZWASTE	MANCHESTER	27.4	18.9	ND	8.92
199402007	MANCHESTER PLACE	HAZWASTE	MANCHESTER	34.4	25	8.09	8.16
200205010	MORGAN SELF STORAGE SITE	HAZWASTE	MANCHESTER	44	31	2.9	14
198403058	RR DONNELLEY CO FMRMOORE BUSINESS FORMS	HAZWASTE	MANCHESTER	129	35.1	7.07	11.8
198912008	MILL WEST FMR ELBES ASSOCIATES	HAZWASTE	MANCHESTER	15.2	39.3	ND	11.9
199110029	PARK & ROYAL CLNRS (WEST SIDE SALVAGE)	HAZWASTE	MANCHESTER	15.8	82	3.31	2.26
198612003	E & R LAUNDRY	HAZWASTE	MANCHESTER	87	160	7.6	46
200305008	COMCAST OF NEW HAMPSHIRE	HAZWASTE	MANCHESTER	451	317	107	380
199307019	JCM MANAGEMENT	HAZWASTE	MANCHESTER	500	674	15.9	89.9
198904041	ALLTEX UNIFORM RENTAL SERVICE INC	HAZWASTE	MANCHESTER	120	1800	29	98
200102004	SUNSHINE FABRICARE	HAZWASTE	MANCHESTER	33.5	ND	ND	6.95
198605200	MEREDITH VILLAGE SAVINGS BANK FMR MOBIL	HAZWASTE	MEREDITH	3.43	NA	NA	7.08
198403080	LONGA DISPOSAL AREA	SITEEVALHW	MERRIMACK	130	8.7	0.8	7
198901022	HARCROS CHEMICAL GROUP	HAZWASTE	MERRIMACK	120	12	2.1	4.4
198406030	N.H. PLATING CO.	CERCLA	MERRIMACK	506	17	6.43	15
199610014	MARJAN/CORBIN SITE	SITEEVALHW	MERRIMACK	61.5	18.5	ND	2.84
198611001	MERRIMACK WELL #6 & #7 VILLAGE H2O DIST	SITEEVALHW	MERRIMACK	99	85	ND	5.3
201610175	TROWBRIDGE DR AREA PFC DETECTS	SITEEVALHW	MERRIMACK	35	102	2.12	4
198711006	NASHUA CORP	HAZWASTE	MERRIMACK	120	2000	12	74
199712055	SAINT GOBAIN PERFORMANCE PLASTICS	HAZWASTE	MERRIMACK	69500	2560	2960	200
198506002	FLETCHERS PAINT/MILL STREET SITE	CERCLA	MILFORD	11	3.11	ND	1.15
198506001	FLETCHERS PAINT/ELM STREET	CERCLA	MILFORD	7.27	14.7	ND	8.68
199109008	SPEAR NH (FORMERLY GAR-DOC)	HAZWASTE	MILFORD	18.2	60	2.23	ND
198505002	OK TOOL CO (OU-1)	CERCLA	MILFORD	ND	ND	ND	ND
199202008	OLD MILTON DUMP	SITEEVALHW	MILTON	69.4	303	ND	17.3
199810020	CAMP WINAUKEE	HAZWASTE	MOULTONBOROUGH	1.97	2.53	ND	ND
198404000	FIMBEL DOOR (GRANITE ST LEATHER)	SITEEVALHW	NASHUA	16.2	3.61	ND	ND
198603002	BRONZE CRAFT CORP	HAZWASTE	NASHUA	19	5	0.54	25



Table 3 - Hazardous Waste Remediation Sites
PFAS Water Quality Summary

NHDES SITE #	SITE NAME	PROJECT TYPE	TOWN	Max PFOA Detected (ng/L) AGQS = 12	Max PFOS Detected (ng/L) AGQS = 15	Max PFNA Detected (ng/L) AGQS = 11	Max PFHxS Detected (ng/L) AGQS = 18
198604324	FAB BRAZE CORP	HAZWASTE	NASHUA	39	5.33	ND	3.18
199810022	ENERGY NORTH NATURAL GAS	HAZWASTE	NASHUA	15	9.5	0.56	5.3
198910020	CLOCKTOWER PLACE/FMR SPRAGUE SITE	HAZWASTE	NASHUA	23	11	ND	12
198704027	HAMPSHIRE CHEMICAL CORP	HAZWASTE	NASHUA	28	26	NA	NA
198404001	ACT (FORMER SHELDAHL, FORMER IRI)	HAZWASTE	NASHUA	15	37	1.4	6.5
198605230	CLOCKTOWER PLACE	HAZWASTE	NASHUA	46	38	12	4
198708042	CORONIS CLEANERS INC	HAZWASTE	NASHUA	101	41	3	11
198904062	GL & V PULP GROUP (FMR INGERSOLL-RAND)	HAZWASTE	NASHUA	20	59	0.68	4.3
198106005	ELEXSYS INTERNATIONAL INC	HAZWASTE	NASHUA	46.4	60.7	13	4.43
199109039	NASHUA AIRPORT AUTHORITY	SITEEVALHW	NASHUA	19	68	ND	54
199410039	NASHUA MOTOR EXPRESS INC	HAZWASTE	NASHUA	120	80	3.6	110
200807038	323 DANIEL WEBSTER HIGHWAY	HAZWASTE	NASHUA	242	405	18.5	68.6
200409215	SCRAP METALS, INC.	HAZWASTE	NASHUA	370	560	77	66
198406029	GILSON ROAD SITE	CERCLA	NASHUA	470	1190	11.1	7.43
199612010	FORMER KOLLSMAN FACILITY	HAZWASTE	NASHUA	ND	ND	ND	ND
198710027	NEW BOSTON AIR FORCE STATION	HAZWASTE	NEW BOSTON	150	520	17	110
199505034	NEWFIELDS LIGHT INDUSTRIAL PRK	HAZWASTE	NEWFIELDS	4.5	2.7	ND	ND
198705051	SPRAGUE - RIVER ROAD TERMINAL	HAZWASTE	NEWINGTON	33	1.6	7.4	1.7
199001012	DEFENSE FUELS	HAZWASTE	NEWINGTON	453	2380	133	313
198404025	PAFB REMEDIATION UST GENERAL	HAZWASTE	NEWINGTON	130000	490000	290	31000
198708011	FMR ESSEX MILLS	HAZWASTE	NEWMARKET	7.73	13.1	ND	ND
201708036	41 EXETER RD. SITE	HAZWASTE	NEWMARKET	82	55	2.3	330
199805019	AMBARGIS PROPERTY	HAZWASTE	NEWPORT	2.36	2.92	ND	ND
200104007	STURM RUGER & CO INC (FMR DORR MILL)	HAZWASTE	NEWPORT	1960	16.5	553	2.44
198607029	PS MARSTON ASSOC INC (ABENAQUI CARRIERS)	SITEEVALHW	NORTH HAMPTON	180	12	4.3	5
198906065	PROWASH CARWASH AND LUBE	HAZWASTE	NORTH HAMPTON	380	270	123	360
201904026	227/227A ATLANTIC AVENUE AREA SITE	SITEEVALHW	NORTH HAMPTON	139	660	2	290
198712001	COAKLEY LANDFILL	CERCLA	NORTH HAMPTON	914	819	774	120



Table 3 - Hazardous Waste Remediation Sites
PFAS Water Quality Summary

NHDES SITE #	SITE NAME	PROJECT TYPE	TOWN	Max PFOA Detected (ng/L) AGQS = 12	Max PFOS Detected (ng/L) AGQS = 15	Max PFNA Detected (ng/L) AGQS = 11	Max PFHxS Detected (ng/L) AGQS = 18
200006031	WYMAN-GORDON INV CASTINGS INC	HAZWASTE	NORTHFIELD	18.1	175	13.3	ND
198404038	HARDING METALS	HAZWASTE	NORTHWOOD	334	1030	22.9	83.1
198404060	SOUTH MUNICIPAL WELL STUDY	CERCLA	PETERBOROUGH	4.29	8.33	NA	NA
198404058	BROWN'S SEPTAGE PITS	HAZWASTE	PETERBOROUGH	61	120	4.9	29
199710020	PITTSFIELD PUBLIC WORKS DEPT	SITEEVALHW	PITTSFIELD	5.53	1.86	ND	0.7
201612039	FREESE PROPERTIES INC	SITEEVALHW	PITTSFIELD	24.6	5.22	ND	2.31
198404061	PITTSFIELD WEAVING (FRMLY CAMBION)	HAZWASTE	PITTSFIELD	16.2	186	ND	ND
202004024	ELM/KINGSTON/HALE SPRING AREA SITE	SITEEVALHW	PLAISTOW	26	14	0.84	9.7
198404067	STATE LINE PLAZA	HAZWASTE	PLAISTOW	61	35	12	5.3
198404068	BEEDE WASTE OIL CORP(AKA CASH OIL SALES)	CERCLA	PLAISTOW	410	1700	11	600
198404076	CHART INDUSTRIES	HAZWASTE	PLAISTOW	6.32	ND	ND	2.97
199801091	BENGAL CLEANERS FACILITY	HAZWASTE	PORTSMOUTH	7.9	2.59	10.2	3.91
201801004	HANSCOM'S TRUCK STOP, INC.	HAZWASTE	PORTSMOUTH	6	7.4	2	10
201010003	FMR BOURNIVAL KIA SITE	HAZWASTE	PORTSMOUTH	17	25	3	4
199605033	PORTSMOUTH USED CAR CENTER	HAZWASTE	PORTSMOUTH	29.4	60.6	ND	ND
200512019	WENTWORTH SCRAP METAL PROPERTY	HAZWASTE	PORTSMOUTH	27.3	78.7	3.9	23.1
201005026	150 MIRONA ROAD PROPERTY	SITEEVALHW	PORTSMOUTH	47.9	119	4.7	12.8
199408047	FORMER COUNTRY MOTOR SALES	SITEEVALHW	PORTSMOUTH	15	200	4.3	66
198905023	PLAZA 800	HAZWASTE	PORTSMOUTH	100	340	13	6
198404081	ALLTEX UNIFORM/COLONIAL SERVICES	HAZWASTE	PORTSMOUTH	160	800	13	30
198704094	MOTTOLO WASTE SITE	CERCLA	RAYMOND	484	187	12	118
201110061	FORMER REGIS TANNERY - LOT 120	HAZWASTE	RAYMOND	1230	2410	4.31	769
198705081	FORMER REGIS TANNERY (AKA REX LEATHER)	HAZWASTE	RAYMOND	1230	2410	4.31	769
198405005	GONIC MILL	HAZWASTE	ROCHESTER	11.5	16.7	ND	ND
200309133	FMR ADVANCED RECYCLING	HAZWASTE	ROCHESTER	63	22	2.3	21
199705019	OFF PRICE OUTLET STORE	SITEEVALHW	ROCHESTER	131	662	11.5	20.6
199108024	DICK POULIN CHEVROOLET OLDS	SITEEVALHW	ROCHESTER	131	662	11.5	20.6
199611022	PEIRCE FORD	HAZWASTE	ROCHESTER	100	1100	2.9	67



Table 3 - Hazardous Waste Remediation Sites
PFAS Water Quality Summary

NHDES SITE #	SITE NAME	PROJECT TYPE	TOWN	Max PFOA Detected (ng/L) AGQS = 12	Max PFOS Detected (ng/L) AGQS = 15	Max PFNA Detected (ng/L) AGQS = 11	Max PFHxS Detected (ng/L) AGQS = 18
198405009	LYDALL INC	HAZWASTE	ROCHESTER	21000	7600	320	2400
199306038	SWD PROPERTY MANAGEMENT PARCEL	HAZWASTE	ROCHESTER	ND	ND	ND	ND
198909002	JANCO	HAZWASTE	ROLLINSFORD	14	18.9	ND	ND
200101009	FOYE'S CORNER MARKET & VACANT PARCEL	HAZWASTE	RYE	52.3	7.64	2.86	3.28
198405032	UNIVEX CORP.	HAZWASTE	SALEM	9.22	13.2	ND	2.59
198405027	KEEWAYDIN DRIVE	HAZWASTE	SALEM	62.6	13.2	3.06	13
199309056	KEY PACKAGING INDUSTRIES CORP	HAZWASTE	SALEM	24.5	18.6	10.4	6.34
199704003	HONDA MOTORCAR	HAZWASTE	SALEM	21.8	28.7	1.4	4.8
201812014	23 BUS ROAD SITE	HAZWASTE	SALEM	67.4	45	5.82	8.09
198405033	OLD SALEM WASTEWATER FACILITY	HAZWASTE	SALEM	209	337	8.32	46.6
200108010	DAISY CLEANERS	HAZWASTE	SALEM	146	618	44.4	23.2
198705069	DDR SEABROOK (FORMER VENTURE INDUSTRIES)	HAZWASTE	SEABROOK	4.6	2.3	1.1	ND
199211045	139 FOLLY MILL RD	HAZWASTE	SEABROOK	3.22	3.11	ND	ND
199202001	FOGG AUTO SALVAGE PROPERTY	HAZWASTE	SEABROOK	18.7	26	ND	ND
198405038	K J QUINN & CO INC	HAZWASTE	SEABROOK	19	10	ND	2.6
199708013	GENERAL ELECTRIC	HAZWASTE	SOMERSWORTH	14	13	ND	3.9
200411112	BRETON CLEANERS PROPERTY	HAZWASTE	SOMERSWORTH	52.9	17	8.26	13.7
198405055	SOMERSWORTH SANITARY LANDFILL	CERCLA	SOMERSWORTH	280	108	24.1	34.9
200210068	GH EVARTS & CO INC	HAZWASTE	SPRINGFIELD	1.2	5.9	ND	ND
198705075	ANTIQUE REPAIR COMPANY	HAZWASTE	STRATHAM	85	57	5.9	ND
199707014	DEMOULAS / MARKET BASKET	SITEEVALHW	STRATHAM	340	590	76	6.4
199507007	STRATHAM FIRE DEPT	HAZWASTE	STRATHAM	320	3900	4.3	940
199106008	BIG APPLE CONVENIENCE STORE	HAZWASTE	TILTON	15	ND	ND	ND
198405082	TROY MILLS ROCKWOOD BROOK LANDFILL	CERCLA	TROY	2140	10.9	57.3	22.5
199607014	PAK 2000	HAZWASTE	TUFTONBORO	108	5540	54	1100
199806071	CENTRAL PLATING & CO.	HAZWASTE	WALPOLE	1070	7080	0.72	806
202107008	GRAND POWER SYSTEMS	HAZWASTE	WARNER	3.53	34.5	ND	ND
199103001	WS PACKAGING GROUP INC FMR LABEL ART	HAZWASTE	WILTON	2.7	2.4	ND	ND



Table 3 - Hazardous Waste Remediation Sites
PFAS Water Quality Summary

NHDES SITE #	SITE NAME	PROJECT TYPE	TOWN	Max PFOA Detected (ng/L) AGQS = 12	Max PFOS Detected (ng/L) AGQS = 15	Max PFNA Detected (ng/L) AGQS = 11	Max PFHxS Detected (ng/L) AGQS = 18
198406006	A C LAWRENCE LEATHER	HAZWASTE	WINCHESTER	95.8	212	ND	17.6
200110005	WINDHAM MARINE SITE	HAZWASTE	WINDHAM	20.4	6.57	ND	5.89
201709003	WINDHAM SR. CENTER AREA	HAZWASTE	WINDHAM	94	200	42	274
201704035	CENTRAL METAL FINISHING	HAZWASTE	WINDHAM	89	730	16	8
199408043	WOLFEBORO POWER EQUIPMENT INC.	SITEEVALHW	WOLFEBORO	6.56	20.6	ND	ND

Notes:

1. Concentrations shown are in parts per trillion (ppt) or nanograms per liter (ng/L).
2. Cells that are shaded gray indicate an exceedance of the current Ambient Groundwater Quality Standards (AGQS) included in Env-Or 600 Contaminated Site Management.
3. NH's four regulated PFAS compounds include: perfluorooctanoic acid (PFOA), perfluorooctane sulfonic acid (PFOS), perfluorohexane sulfonic acid (PFHxS), and perfluorononanoic acid (PFNA).
4. 'ND' indicates the analyzed PFAS was not detected above the laboratory reporting limit.
5. NA indicates that the specified PFAS was not analyzed at the site.
6. Data represents highest concentration detected at the Site.



Table 4 - Oil Remediation Sites
PFAS Water Quality Summary

NHDES SITE #	SITE NAME	PROJECT TYPE	TOWN	Max PFOA Detected (ng/L) AGQS = 12	Max PFOS Detected (ng/L) AGQS = 15	Max PFNA Detected (ng/L) AGQS = 11	Max PFHxS Detected (ng/L) AGQS = 18
198402084	JOHNS TRUCK & AUTO	ETHER	KINGSTON	7.23	5.84	ND	3.98
198605555	FMR. HUNT'S AUTO REPAIR	ETHER	FRANCONIA	136	741	27.1	121
198903004	FORMER FLUFFYS CONVENIENCE STORE	LUST	TILTON	2.4	5.4	1.5	ND
198904023	EVERSOURCE ENERGY (FMR PSNH)	LUST	HILLSBOROUGH	434	235	161	7.88
198906013	HENRY HANGERS COMPANY	LUST	NASHUA	46	ND	ND	13
199004021	NH DOT HIGHWAY GARAGE 12	LUST	CONCORD	16.1	220	7.82	153
199006049	FORMER PHILIP SINGER REVOCABLE TRUST	LUST	PORTSMOUTH	27	11	4.1	3.9
199104009	FORMER JOHNSON & DIX BULK FUEL	LUST	CONCORD	41.9	12	ND	9.58
199203034	MOBIL 13052	ETHER	LEE	28	38	ND	ND
199209012	N HAVERHILL CONV INC FMR GARYS FUEL	MOST	HAVERHILL	376	ND	ND	745
199210004	WAKEFIELD GENERAL STORE INC	ETHER	WAKEFIELD	4.27	4.3	ND	ND
199312032	BROOKSIDE MINI MART	LUST	WILTON	7.36	13.2	ND	ND
199404022	UNITIL ENERGY SYSTEMS INC.	LUST	KENSINGTON	78.2	26.1	3.4	7.5
199407009	FORMER AL LAMBERTS GARAGE	ETHER	HOOKSETT	213	3900	51.8	1100
199409033	ALTON IRVING BULK TERMINAL	LAST	ALTON	31.5	240	4.48	129
199502055	YEATON OIL CO INC	LAST	PLYMOUTH	ND	ND	ND	ND
199503033	LAMPREY BROS BULK STORAGE	FUEL	NORTH HAMPTON	110	660	2	290
199506011	FORMER MIDWAY EXCAVATORS INC	MOST	SOUTH HAMPTON	16	11.8	2.46	2.76
199607056	ROWELL AND WATSON CO INC	LAST	ROLLINSFORD	8.23	3.94	2.38	ND
199907011	IRVING OIL CORPORATION	SPILL/RLS	ALTON	346	39500	47.4	3180
200009053	ESSLINGER OIL UNDERCOATING	MOST	ALSTEAD	ND	5.25	ND	ND
200109011	WEBER AUTO & TRUCK PARTS INC	LAST	DERRY	133	640	8	140
200203023	BROOKS PROPERTY	ETHER	WINDSOR	9.2	36	1.5	20
200203024	TRI-STATE CAR CRUSHING (FRMR BROOKS PROP	ETHER	LEMPSTER	3	6	ND	ND
200309090	KAPOTIS PROPERTY	LAST	HAVERHILL	ND	24	ND	ND
200412055	TIM & JONIS TOWING/AUTO RECYCLING	ETHER	EPPING	8.2	3.1	ND	17
200702049	MAJESTIC MOTORS	ETHER	MERRIMACK	650	34	10	42



Table 4 - Oil Remediation Sites
PFAS Water Quality Summary

NHDES SITE #	SITE NAME	PROJECT TYPE	TOWN	Max PFOA Detected (ng/L) AGQS = 12	Max PFOS Detected (ng/L) AGQS = 15	Max PFNA Detected (ng/L) AGQS = 11	Max PFHxS Detected (ng/L) AGQS = 18
201410048	SILVER RESIDENCE	OPUF	GILFORD	ND	ND	ND	ND
201507027	FARAN PROPERTY	OPUF	BRIDGEWATER	5.35	ND	ND	ND
201507028	MARCIANO RESIDENCE	OPUF	HAMPSTEAD	6.03	ND	ND	2.04
201612036	P & H TRANSPORTATION TANKER SPILL	SPILL/RLS	LONDONDERRY	278	22.6	15.9	21.3
201701036	CULLEN RESIDENCE	OPUF	DOVER	39	16	3.7	6.2
201703001	JANVRIN PROPERTY	OPUF	BARTLETT	ND	ND	ND	ND

Notes:

1. Concentrations shown are in parts per trillion (ppt) or nanograms per liter (ng/L).
2. Cells that are shaded gray indicate an exceedance of the current Ambient Groundwater Quality Standards (AGQS) included in Env-Or 600 Contaminated Site Management.
3. NH's four regulated PFAS compounds include: perfluorooctanoic acid (PFOA), perfluorooctane sulfonic acid (PFOS), perfluorohexane sulfonic acid (PFHxS), and perfluorononanoic acid (PFNA).
4. 'ND' indicates the analyzed PFAS was not detected above the laboratory reporting limit.
5. NA indicates that the specified PFAS was not analyzed at the site.
6. Data represents highest concentration detected at the Site.



Table 5 - Groundwater Discharge Permit Sites
PFAS Water Quality Summary

NHDES SITE #	SITE NAME	PROJECT TYPE	TOWN	Max PFOA Detected (ng/L) AGQS = 12	Max PFOS Detected (ng/L) AGQS = 15	Max PFNA Detected (ng/L) AGQS = 11	Max PFHxS Detected (ng/L) AGQS = 18
198400008	CEDAR COVE SEPTIC	SEPTIC	ALTON	55	ND	ND	ND
200506037	MEADOW BROOK CROSSING	SEPTIC	AMHERST	52	ND	ND	ND
200011029	ATKINSON COUNTRY CLUB	SPRAYIRR	ATKINSON	17.8	ND	ND	ND
200403086	BLUEBERRY STATION CAR WASH	SEPTIC	BARNSTEAD	5.13	9.82	ND	ND
199008008	WMNF HARTS LOCATION	RIB	BARTLETT	ND	ND	ND	ND
198812003	STILLINGS GRANT	SEPTIC	BARTLETT	ND	ND	ND	ND
199009032	STORYLAND	SEPTIC	BARTLETT	5.48	3.71	ND	ND
199512013	GRAND SUMMIT AT ATTITASH	SEPTIC	BARTLETT	ND	5	ND	ND
198400051	MONADNOCK PAPER MILL	UWW/LAG	BENNINGTON	8.7	6.7	ND	ND
199105012	MERRIMACK COUNTY COMPLEX UWW LAGOON	UWW/LAG	BOSCAWEN	9.9	4.7	ND	ND
198906062	ROCKINGHAM COUNTY COMPLEX SPRAY IRRIG	SPRAYIRR	BRENTWOOD	11	ND	ND	ND
198711013	CANAAN WWTF	RIB	CANAAN	8.2	ND	ND	ND
198400085	BRETTON WOODS RIB	RIB	CARROL	16.9	12.2	ND	ND
198710018	MT WASHINGTON HOTEL RESORT	RIB	CARROL	9.14	4.6	ND	ND
198401040	BALSAMS UWW LAGOON	UWW/LAG	DIXVILLE	8.76	ND	ND	ND
200012033	FARMINGTON RIB SITE MW-14	RIB	FARMINGTON	19.9	5	ND	5.63
198803020	CROTCHED MOUNTAIN RESORT	SPRAYIRR	FRANCESTOWN	ND	ND	ND	ND
198908055	GORHAM PAPER MILL UWW LAGOONS	UWW/LAG	GORHAM	21.4	43	ND	5.13
198801026	EASTMAN	UWW/LAG	GRANTHAM	5	7	ND	ND
198708004	CROTCHED MTN REHAB - TRENCH SEPT PLUS DRIP	SEPTIC	GREENFIELD	3.38	ND	ND	ND
199008008	USDA-FS	SEPTAGE-LAG	HARTS LOCATION	ND	ND	ND	ND
199406035	BROX GRAVEL PIT	SPRAYIRR	HOOKSET	ND	ND	ND	ND
199505004	MCLANE NORTHEAST TRUCK WASH	SEPTIC	HOPKINTON	4	ND	ND	ND
199103013	LANCASTER WWTF	UWW/LAG	LANCASTER	ND	ND	ND	ND
198705050	CARDIGAN MOUNTAIN	SEPTIC	LEBANON	9	ND	ND	13
198704055	LINCOLN WWTF UWW LAGOON	UWW/LAG	LINCOLN	8.2	29.3	ND	ND
199009018	SCHOFIELD SEPTAGE	SEPTAGE	LISBON	9.85	ND	ND	ND
199403026	DARTMOUTH SKIWAY MW-1	UWWLAG	LYME	ND	ND	ND	ND



Table 5 - Groundwater Discharge Permit Sites
PFAS Water Quality Summary

NHDES SITE #	SITE NAME	PROJECT TYPE	TOWN	Max PFOA Detected (ng/L) AGQS = 12	Max PFOS Detected (ng/L) AGQS = 15	Max PFNA Detected (ng/L) AGQS = 11	Max PFHxS Detected (ng/L) AGQS = 18
199907040	CAMP LAWRENCE	UWWLAG	MEREDITH	ND	ND	ND	ND
199907043	CAMP NOKOMIS	UWW/LAG	MEREDITH	ND	ND	ND	ND
199007020	BAY DISTRICT	UWW/LAG	MOULTONBOROUGH	5.21	ND	ND	ND
199810020	CAMP WINAUKEE	UWW/LAG	MOULTONBOROUGH	1.97	2.53	ND	ND
199103016	NEW HAMPTON WWTF MONITORING	UWWLAG	NEW HAMPTON	292	21.3	ND	14.7
198704058	MT SUNNAPEE LAGOON PLUS SPRAY IRRIG	UWW/LAG - SPRAYIRR	NEWBURY	ND	ND	ND	ND
198908064	BLODGETT LAING WWTF	RIB	NEWBURY	9.23	18.4	ND	ND
199806017	HIGHLANDS VIL DIST.	SEPTIC	NORTHFIELD	ND	ND	ND	ND
198404046	OSSIPEE TOWN SEPTIC LEACHFIELDS	SEPTIC	OSSIPEE	14.3	ND	ND	4.58
199103017	PETERBOROUGH WWTF	UWW/LAG	PETERBOROUGH	ND	ND	ND	ND
198712010	PITTSBURG SEPTAGE LAGOON	SEPTAGE	PITTSBURG	51.1	10.9	ND	6.48
198604204	PITTSBURG WWTF UWW LAGOON	UWW/LAG	PITTSBURG	59.2	ND	ND	4.77
199105022	MERIDAN WWTF RIB	RIB	PLAINFIELD	9.53	6.9	ND	ND
199606073	WALMART DISTRIB CENTER SEPTIC	SEPTIC	RAYMOND	4.72	5.7	ND	ND
199601006	CAMP TAKODAH YMCA	UWW/LAG	RICHMOND	29	23	ND	ND
199312051	FRANKLIN PIERCE	RIB	RINDGE	2.9	ND	ND	ND
198712014	JARVIS CUTTING TOOLS	SEPTIC	ROCHESTER	3.53	ND	ND	ND
201004021	EVOLVE HEALTH CARE	SEPTIC	RYE	ND	ND	ND	ND
199706032	97 SHOPPES - COMMERC SEPTIC SYSTEM	SEPTIC	SALEM	7.73	8.19	ND	ND
199907047	CAMP HALE UWW LAGOON	UWW/LAG	SAWICH	ND	8.13	ND	ND
199007007	MT WASHINGTON OBSERVATORY	SEPTIC	SARGENTS PURCHASE	ND	ND	ND	ND
199907046	MANCHESTER YMCA CAMP FOSS	UWW/LAG	STRAFFORD	5	ND	ND	ND
198910049	STRATFORD SEPTAGE FACILITY	SEPTAGE	STRATFORD	ND	ND	ND	ND
200304015	SEWALL FARM COO ASSSOC SEPTIC LEACHFIELD	SEPTIC	STRATHAM	ND	ND	ND	ND
200210028	TRICKET STRATHAM IRVING CAR WASH	SEPTIC	STRATHAM	2.39	3.69	ND	ND
199105014	TROY WASTEWATER TP	UWW/LAG	TROY	ND	ND	ND	ND
198907053	WAKEFIELD WWTF RIB PLUS SEPTIC	RIB - SEPTAGE	WAKEFIELD	7.31	ND	ND	ND
199007031	WARDE HEALTH CTR SISTERS OF MERCY LEACHFIELD	SEPTIC	WINDHAM	15.5	11.3	ND	ND



Table 5 - Groundwater Discharge Permit Sites
PFAS Water Quality Summary

NHDES SITE #	SITE NAME	PROJECT TYPE	TOWN	Max PFOA Detected (ng/L) AGQS = 12	Max PFOS Detected (ng/L) AGQS = 15	Max PFNA Detected (ng/L) AGQS = 11	Max PFHxS Detected (ng/L) AGQS = 18
198705015	WOLFEBORO SPRAY	SPRAYIRR	WOLFEBORO	7.23	11.8	ND	20.8
198404040	NORTHWOOD SEPTAGE FACILITY	SEPTAGE	NORTHWOOD	102	39.6	96.9	14.4
198909013	NORTHUMBERLA OVERLA FLOW	SEPTIC	NORTHUMBERLA	61.7	44.8	54.90	6.37
198401070	EPPING WWTF	UWW/LAG	EPPING	61.1	34.4	35.3	ND
198909017	NH MOTOR SPEEDWAY	SEPTIC	LOUDON	38.7	240	31.1	229
198704011	SUTTON SEPTAGE FACILITY	SEPTAGE	SUTTON	445	94.1	21.1	62
198705021	HOPKINTON/WEBSTER LANDFILL & LAGOONS	SEPTAGE-LAG	HOPKINTON	200	106	18.9	44
198405011	ROCHESTER WWTF UWW LAGOON	UWW/LAG	ROCHESTER	197	23	18	11.3
199705002	ASHLAND WWTF UWW LAGOON	UWWLAG	ASHLAND	11	13.7	13.6	ND
198706001	DERRY UWW LAGOON	UWWLAG	DERRY	38.1	119	9.88	7.66
199105007	CHARLESTOWN WWTF	UWW/LAG	CHARLESTOWN	17.4	72.2	9.63	ND
198801025	LOUDON LANDFILL SEPTAGE LAGOON	SEPTAGE-LAG	LOUDON	282	46.3	8.39	25.5
198401079	EXETER WWTF UWW/LAG	UWWLAG	EXETER	75	54.4	8.1	18
198712011	PITTSBURG RIB SITE	RIB	PITTSBURG	49.5	ND	7.99	ND
198402027	BOUDREAU SEPTAGE LAGOON	SEPTAGE-LAG	HAVERHILL	98	14.7	7.9	14.9
198402073	TOWN OF JAFFREY UWW/LAG	UWW/LAG	JAFFREY	20.6	26.3	7.62	4.22
199105009	Colebrook WWTF	UWW/LAG	COLEBROOK	4.33	7.72	7.00	ND
198907055	NORTH CONWAY RIB	RIB	CONWAY	27.4	292	6.71	178
199807009	SARGENT CAMP NATURE CLASSROOM WW LAG	UWW/LAG	HANCOCK	9.38	6.4	6.14	ND
199009012	WATERVILLE VALLEY WWTF UWW LAGOON	UWW/LAG	WATERVILLE VALLEY	13	4	6	ND
198404044	CARROL COUNTY COMPLEX OVERLA FLOW	SEPTIC	OSSIPEE	7.45	25.5	5.43	ND
198912004	CONWAY VILLAGE FIRE DISTRICT	UWW/LAG	CONWAY	16.2	10.9	5.1	ND
200403117	GROVETON WWTF	UWW/LAG	GROVETON	9.53	12	4.5	ND
19910510	GLENCLIFF HOME	SEPTIC	BENTON	5.24	36.8	4.49	ND
200707014	WOLFEBORO RIB SITE	RIB	WOLFEBORO	6.19	8.37	4.49	9.49
199812019	WARWICK MILLS SEPTIC	SEPTIC	NEW IPSWICH	25	6	4.00	ND



Table 5 - Groundwater Discharge Permit Sites
PFAS Water Quality Summary

NHDES SITE #	SITE NAME	PROJECT TYPE	TOWN	Max PFOA Detected (ng/L) AGQS = 12	Max PFOS Detected (ng/L) AGQS = 15	Max PFNA Detected (ng/L) AGQS = 11	Max PFHxS Detected (ng/L) AGQS = 18
-----------------	-----------	-----------------	------	--	--	--	---

Notes:

1. Concentrations shown are in parts per trillion (ppt) or nanograms per liter (ng/L).
2. Cells that are shaded gray indicate an exceedance of the Ambient Groundwater Quality Standard (AGQS).
3. 'ND' indicates the analyzed PFAS was not detected above the laboratory reporting limit.
4. PFAS data represents highest concentration detected at the Site.
5. Last update : 11/2/21