

STATUS REPORT ON THE OCCURRENCE OF PER- AND POLYFLUOROALKYL SUBSTANCE (PFAS) CONTAMINATION IN NEW HAMPSHIRE

This report has been developed to satisfy the requirements of the

Laws of New Hampshire

January Session of 2018, Chapter 306:2 (HB 1766)

Prepared by

New Hampshire Department of Environmental Services

Robert R. Scott, Commissioner

June 2022



PO Box 95, Concord, NH 03302-0095

www.des.nh.gov

Table of Contents

1. Introduction	3
2. Coakley Landfill Superfund Site	4
3. Former Pease Air Force Base Superfund Site.....	7
4. Statewide Public Water Supplies	11
5. Statewide PFAS Data	11
5.1 Solid Waste Facilities.....	11
5.2 Hazardous Waste Remediation Sites	11
5.3 Oil Remediation Sites	12
5.4 Groundwater Discharge Permit Sites (Wastewater Disposal to Groundwater)	12

APPENDICES

Appendix 1

House Bill 1766-FN- Final Version

TABLES

Table 1 – Public Water System PFAS Water Quality Summary

Table 2 – Solid Waste Facility PFAS Water Quality Summary

Table 3 – Hazardous Waste Remediation Sites PFAS Water Quality Summary

Table 4 – Oil Remediation Sites PFAS Water Quality Summary

Table 5 – Groundwater Discharge Permit Sites PFAS Water Quality Summary

LIST OF COMMON ACRONYMS

AGQS – Ambient Groundwater Quality Standard

EPA – United States Environmental Protection Agency

NHDES – New Hampshire Department of Environmental Services

PFAS – Per- and polyfluoroalkyl substances

PFOA – Perfluorooctanoic Acid

PFOS – Perfluorooctane Sulfonic Acid

PFHxS – Perfluorohexane Sulfonic Acid

PFNA – Perfluorononanoic Acid

PWS – Public Water System

1. Introduction

The New Hampshire Department of Environmental Services (NHDES) is engaged in an ongoing investigation into per- and polyfluoroalkyl substances (PFAS) in New Hampshire drinking water. New Hampshire and several other northeast states are dealing with several sites where there have been widespread PFAS impacts on drinking water supplies. In recognition of public concern regarding the issue of water quality in the Seacoast area and at areas of environmental interest across the state relative to PFAS, the Laws of New Hampshire, January Session of 2018 Chapter 306:2 (House Bill 1766) requires NHDES to report to the general court regarding bedrock testing and PFAS contamination in the Seacoast area and at other landfills and hazardous waste sites. This status report reflects an update to NHDES' December 2021 report and has been developed to satisfy the twice yearly reporting requirements established in Chapter 306:2 (House Bill 1766).

Per- and polyfluoroalkyl substances or PFAS are a family of over 5,000 man-made chemicals, some of which have been more widely used and studied than others¹. PFAS have been widely used since the 1940s in commercial, industrial, and household products and applications, including production of water-resistant materials, fire suppression foams, non-stick cookware, stain removers, etc. PFAS are used for their properties to resist heat, oil, grease, and water. Once released to the environment, PFAS are persistent, and some do not biodegrade or breakdown.

In 2019, NHDES adopted administrative rules that establish health-based Maximum Contaminant Levels (MCLs) and Ambient Groundwater Quality Standards (AGQS) for four per- and polyfluoroalkyl substances (PFAS) that include: 12 ppt for perfluorooctanoic acid (PFOA), 15 ppt for perfluorooctane sulfonic acid (PFOS), 18 ppt for perfluorohexane sulfonic acid (PFHxS), and 11 ppt for perfluorononanoic acid (PFNA). While enforcement of these standards was temporarily stayed by a court injunction, the MCLs and AGQS were established as a matter of law by House Bill 1264, which became effective July 23, 2020. MCLs are drinking water quality standards that non-transient public water systems (water systems serving the same 25 people more than 6 months per year) must comply with. An AGQS is the standard used to require site investigations and remedial action at and around contamination sites. AGQS are also used to identify where the provision of alternate drinking water is required when waste sites have contaminated private and/or public water supply wells. Please note that these rules do not require testing by owners of private water wells. NHDES does recommend for health reasons that private wells meet the AGQS.

This status report provides a brief summary of PFAS information available to date at the Coakley Landfill and former Pease Air Force Base superfund sites, both of which are located in the seacoast area of New Hampshire. This information includes a description of recent investigations at the Coakley site, and efforts to treat groundwater and drinking water at the Pease site. The report also presents PFAS data for public drinking water supplies, and groundwater data compiled from known PFAS sites statewide.

NHDES notes that its PFAS data are contained in several different databases, which impacts the ease with which PFAS information can be queried. Data provided in this status report generally is current for most NHDES programs through spring 2022, depending on the availability of program specific

¹ <https://www.fda.gov/food/chemicals/and-polyfluoroalkyl-substances-pfas>

information. Since new data are continuously provided to NHDES, readers may wish to access more up-to-date information using the following resources:

- Data viewer summarizing up-to-date PFOA and PFOS sampling results at <https://www4.des.state.nh.us/nh-pfas-investigation/> (under “Maps and Data”); and
- An online, searchable database referred to as “OneStop” comprised of environmental information and data compiled by select NHDES programs. OneStop does not provide access to all existing PFAS NHDES data, however, it is considered to be a valuable resource. The database can be found at <https://www4.des.state.nh.us/DESOnestop/BasicSearch.aspx>.

This status report is required to be updated every six months and provided to the legislature. NHDES anticipates updates to the report will be available June and December of each year.

2. Coakley Landfill Superfund Site

The Coakley Landfill Superfund Site (Coakley) is a closed 27-acre former municipal/industrial solid waste disposal facility located in North Hampton. The landfill operated from 1972 to 1982 and received incinerator ash from the Portsmouth Refuse-to-Energy Facility through 1985. The site was listed on the National Priorities List (Superfund) in 1983 and construction of selected remedies was completed in 1999. Sampling for the emerging contaminants 1,4-dioxane and PFAS in 2009 and 2016, respectively, confirmed their presence, and prompted extensive follow-on investigations. Currently, the Coakley Landfill Group (CLG), a consortium of the parties responsible for the contamination, is finalizing an investigation report that further develops the conceptual site model, and refines the source, fate, and transport of these emerging contaminants.

The following summary provides an update regarding ongoing activities in part related to the investigation of PFAS at Coakley generally through April 30, 2022. For additional site-specific information please visit NHDES’ OneStop database at: <https://www4.des.state.nh.us/DESOnestop/BasicSearch.aspx> or EPA’s website at: <https://cumulis.epa.gov/supercpad/cursites/csinfo.cfm?id=0101107>. The NHDES Site ID associated with Coakley is NHDES #198712001.

- The first entry in the table below is the only item dated outside of the reporting period, due to its late upload to the OneStop database and subsequent omission in the previous update. These meeting minutes summarize a discussion between the agencies and the CLG and their consultant with the primary meeting purpose being conveyance of agency expectations for a comprehensive draft final report on the Deep Bedrock Investigation.
- MW-25 is a new well that was installed in early 2021 and is located within the portion of the plume migrating south from the Site and within the Little River drainage basin. This well remained unfinished (i.e., without individual well completions within the open borehole) for the duration of the 2021 pump test. Consequently, on November 7, 2021, the CLG submitted a work plan for two well completions within the open borehole of MW-25. A number of line items in the current reporting period are related to the November 7 work plan and the agencies’ response to this work plan. Ultimately, a final approach was agreed upon and executed by the CLG for the completion of two wells within the open borehole of MW-25.

- The CLG submitted a Draft Deep Bedrock Investigation Final Report on December 22, 2021. On March 16, 2022, EPA issued a letter disapproving this report citing report deficiencies in completeness, technical accuracy, and responsiveness to previously conveyed comments on interim submittals and objectives of the investigation. The CLG submitted a request to extend the deadline for submission of a revised report on April 11, 2022. EPA approved a 45-day extension, along with additional clarifications, in a letter dated April 14, 2022. After further consideration of the agency comments on the Draft Report, the CLG decided to change consultants. Subsequent to that decision and the corresponding contracting issues, the CLG submitted another request to extend the deadline by an additional 90 days. EPA granted an additional 60-day extension. A revised report is now due by August 15, 2022.
- On January 10, 2022, Environmental Standards submitted a final report on the findings of a replicate sampling program designed to better understand the detection of perfluoro-octane-sulfonamide or PFOSA in recent sampling events. As background, spring 2020 private well sampling identified PFOSA at higher concentrations than fall 2019 results, which were analyzed by a different laboratory. Review and comparison of the PFOSA data from the two labs did not resolve the reporting discrepancy. Consequently, EPA requested that the CLG plan and implement a replicate sampling program to investigate and compare the analytical procedures and results of the two labs historically performing sample analysis. The CLG conducted a replicate sampling event during the spring 2021 groundwater monitoring round and had a representative set of samples analyzed by two different laboratories to help explain the disparities in prior analytical results for PFOSA. The study concluded that the occurrence of PFOSA from the laboratory where it has been detected is most likely due to groundwater matrix interferences. This finding was supported by laboratory data that did not show a corresponding increase in PFOSA concentrations in samples that had been spiked with a known amount of PFOSA (stated more simply, it appears that PFOSA was not actually present in the original water sample). As a result, the agencies have approved the CLG to utilize the laboratory having no PFOSA matrix interferences for future analytical needs. PFOSA is a PFAS compound for which there are currently no federal or state standards.
- The CLG submitted laboratory data reports for spring and fall Site-wide sampling events during this reporting period. Laboratory data from the fall sampling round identified two private wells that exceeded drinking water quality standards for two Site-related contaminants. Following these exceedances, the CLG collected confirmation samples from both private wells to determine only one confirmed exceedance. NHDES, under the authority of the Groundwater Management Permit for the Site, responded to the CLG in a March 3, 2022, letter requesting that the Group provide bottled water to both impacted private residences and develop a plan to provide potable drinking water to the property with a confirmed exceedance. In addition, the CLG was directed to develop a contingency plan to provide potable drinking water to the property that was not confirmed to have a drinking water quality exceedance should future water quality testing confirm a site-related contaminant above its respective drinking water standard.
- The Site Groundwater Management Permit (GMP) expired in 2018. Reissuing the GMP was postponed until completion of the Deep Bedrock Investigation, as this investigation was

intended to refine the conceptual site model that may affect multiple elements of the permit. Upon the agencies receiving and reviewing the *Draft Deep Bedrock Investigation Final Report*, NHDES issued comprehensive comments on the CLG's renewal application in a March 18, 2022, letter. Primary comments relate to the need for additional monitoring wells to verify compliance at the Groundwater Management Zone boundary to the west and south of the Site. The CLG will be submitting a work plan to install a new well couplet (overburden and bedrock groundwater monitoring wells) to the south and will be sampling existing temporary wells to the west during the spring 2022 Site-wide sampling to begin addressing these concerns.

Documents added to NHDES website between November 1, 2021 and April 30, 2022:

Date	Documents
August 11, 2021	This entry is the only exception to date range, due to its omission in the previous update. Meeting Minutes – Deep Bedrock Investigation Update and Agencies Expectations for Final Report https://www4.des.state.nh.us/IISProxy/IISProxy.dll?ContentId=4962053
November 7, 2021	CLG submittal: Deep Bedrock Interval Packer Sampling Results and Well Construction Recommendations: MW-25 www4.des.state.nh.us/IISProxy/IISProxy.dll?ContentId=4987827
December 6, 2021	EPA letter to CLG: Agency comments on the November 7, 2021, <i>Deep Bedrock Interval Packer Sampling Results and Well Construction Recommendations: MW-25</i> https://www4.des.state.nh.us/IISProxy/IISProxy.dll?ContentId=4971457
December 22, 2021	CLG submittal: of Draft Deep Bedrock Investigation Final Report https://www4.des.state.nh.us/IISProxy/IISProxy.dll?ContentId=4969036
January 6, 2022	CLG submittal: Spring 2021 Draft Summary Report https://www4.des.state.nh.us/IISProxy/IISProxy.dll?ContentId=4969032
January 6, 2022	CLG submittal: Revised 2020 Annual Summary Report (revision based on September 30, 2021 EPA letter) http://www4.des.state.nh.us/IISProxy/IISProxy.dll?ContentId=4970187 http://www4.des.state.nh.us/IISProxy/IISProxy.dll?ContentId=4970190
January 6, 2022	CLG submittal: Response to Agency comments on the November 7, 2021, <i>Deep Bedrock Interval Packer Sampling Results and Well Construction Recommendations: MW-25</i> https://www4.des.state.nh.us/IISProxy/IISProxy.dll?ContentId=4977973
January 10, 2022	Environmental Standards submittal: Summary of the PFOSA Sample Analysis Comparison https://www4.des.state.nh.us/IISProxy/IISProxy.dll?ContentId=4968659
January 27, 2022	EPA letter to CLG: Conditional approval of the January 6 revision of the Deep Bedrock Well Interval Packer Sampling Results and Well Construction Recommendations MW-25 https://www4.des.state.nh.us/IISProxy/IISProxy.dll?ContentId=4980000
March 3, 2022	NHDES letter to CLG: Response to fall 2021 private well sampling results (Groundwater Management Permit-related correspondence) https://www4.des.state.nh.us/IISProxy/IISProxy.dll?ContentId=4976120
March 10, 2022	CLG submittal: Fall 2021 Sampling Analytical Laboratory Reports https://www4.des.state.nh.us/IISProxy/IISProxy.dll?ContentId=4977974
March 16, 2022	EPA letter to CLG: Comments on the December 22, 2021, Draft Deep Bedrock Investigation Final Report https://www4.des.state.nh.us/IISProxy/IISProxy.dll?ContentId=4981830
March 17, 2022	NHDES letters to the private property owners regarding Fall 2021 sampling results https://www4.des.state.nh.us/IISProxy/IISProxy.dll?ContentId=4980742 https://www4.des.state.nh.us/IISProxy/IISProxy.dll?ContentId=4981097

Date	Documents
March 18, 2022	NHDES letter to CLG: Comments on Groundwater Management Permit renewal application https://www4.des.state.nh.us/IISProxy/IISProxy.dll?ContentId=4980967
April 11, 2022	CLG letter to EPA: Deadline extension request for revision to the Draft Deep Bedrock Investigation Final Report https://www4.des.state.nh.us/IISProxy/IISProxy.dll?ContentId=4986062
April 14, 2022	EPA letter to CLG: Response to CLG request for deadline extension on Draft Deep Bedrock Investigation Final Report https://www4.des.state.nh.us/IISProxy/IISProxy.dll?ContentId=4986063

3. Former Pease Air Force Base Superfund Site

The following provides an update regarding ongoing activities specific to the investigation and remediation of PFAS at the former Pease Air Force Base Superfund Site (Pease). NHDES notes that the Air Force maintains the official Administrative Record for Pease. Reports summarizing investigations and other site-specific documents are public record on the U.S. Air Force Civil Engineering Center (AFCEC) Administrative Record website <https://ar.afcec-cloud.af.mil/Search.aspx> . Once there, select *BRAC>Pease AFB>OU-9 PFC Operable Unit* then click “Search” to view the document listing.

- Pease Tradeport Municipal Water Supply.** The Haven well, the most productive of the three municipal supply wells on the Tradeport, was taken off-line immediately upon the discovery of PFAS in samples collected in April 2014 (including PFOS and PFOA at concentrations above the then applicable EPA Provisional Health Advisory levels). The other two Tradeport municipal supply wells (Smith and Harrison wells) did not have PFAS impacts above actionable concentrations and, therefore, remained on-line. The City of Portsmouth, under an agreement with the Air Force, installed a preliminary filtration system at its existing Grafton Road Treatment Plant for the Smith and Harrison wells in September 2016 using granular activated carbon (GAC). Regular monitoring for the presence of PFAS has been continuously conducted on the four municipal water supply wells that actively draw groundwater from the Pease aquifer (Smith well, Harrison well, and two off-base wells, Portsmouth #1 well and Collins well) and also on a network of sentry monitoring wells distributed throughout the southern portion of the Pease aquifer. The City of Portsmouth completed construction of a full-scale treatment plant using state-of-the-art ion-exchange resin in conjunction with GAC at their Grafton Road site in spring 2021 that allows for operation and treatment of the Smith, Harrison and Haven wells. Since bringing the Haven well back online in summer 2021, monitoring results of the Haven well and surrounding monitoring wells show marked decreases in PFAS concentrations from 2014 levels, demonstrating positive impacts of the aquifer restoration efforts described below. The City of Portsmouth posts the water supply well monitoring results and other pertinent information on their website.

NHDES notes the following links for additional updates regarding Pease Tradeport information:

[PEASE TRADEPORT WATER SUPPLY UPDATE](http://files.cityofportsmouth.com/files/water/PeaseWtrSupplyUpdate9_23_2021.pdf)

http://files.cityofportsmouth.com/files/water/PeaseWtrSupplyUpdate9_23_2021.pdf

[PEASE COMPREHENSIVE PFC SAMPLING DATA](http://files.cityofportsmouth.com/files/ww/PeasePFAS08.2020.pdf)

<http://files.cityofportsmouth.com/files/ww/PeasePFAS08.2020.pdf>

PEASE TRADEPORT WATER SYSTEM OVERVIEW

<http://files.cityofportsmouth.com/publicworks/PeaseWaterSystemOperationsUpdate033115.pdf>

- **Off-Site Private Wells.** In June 2014, the Air Force began an inventory and sampling program for private off-site supply wells within 1-mile of Pease in the towns of Newington, Greenland, and Portsmouth. To date, 45 residential drinking water wells have been sampled, five of which were documented to have PFOS/PFOA at concentrations near or above the original 2016 AGQS. All five were initially supplied with bottled water; four were provided with point-of-entry treatment (POET) systems, one was taken out of use. Of the four wells provided with POET systems, a permanent solution was agreed upon between the Air Force and three property owners to connect to Portsmouth's municipal supply system that already services parts of Newington. Two of those wells were successfully connected to the municipal system in December 2019; the Air Force is still seeking resolution with the third owner. The owner of the fourth well opted to take over operation and maintenance of their POET system from the Air Force rather than connect to the municipal supply.

In October 2019, NHDES sent letters to six additional private supply well owners to notify them of the development of the new AGQS for four PFAS because at least one PFAS concentration was detected in a past water quality sample above one or more of the new more stringent PFAS standards. The letters were intended to ensure the residents were aware of the new standards and to provide them with updated information and resources relative to PFAS. One of those six wells is on the Great Bay National Wildlife Refuge; U.S. Fish and Wildlife Service subsequently confirmed that it is not used for potable purposes.

Following reestablishment of the AGQS, as signed into law in July 2020, NHDES requested Air Force compliance with our standards and response actions including providing bottled water and permanent mitigation for affected private well owners. In correspondence dated September 2, 2020, the Air Force responded to NHDES that it would not take corrective action on private well issues unless detected concentrations exceed the EPA's Lifetime Health Advisory levels (70 ppt for PFOS/PFOA). Subsequent entreaties from New Hampshire's Congressional representatives and from Governor Sununu for the Air Force to take actions based on AGQS violations were met with the same response.

As a result, NHDES coordinated bottled water delivery to four of the residences (the fifth installed their own filtration system). NHDES subsequently contracted permanent mitigation actions at two of the properties: connection to the municipal supply at one and installation of a point-of-entry treatment system at another. A third owner declined NHDES' offer to connect them to the municipal supply. NHDES is evaluating the need for mitigation at the fourth of these impacted wells pending follow-on water quality monitoring results in 2021. In April 2022, the Air Force, following revised DoD policy, began actions to provide alternate water to these residences.

Since 2014, long-term monitoring has occurred on a regular basis for all residential wells where the owners have elected to participate. The long-term monitoring plan is continually evaluated and modified, as appropriate, based on the results. All sampling results are provided to each individual well owner.

- **Base-wide Hydrogeological Investigation.** Concurrent with initial response actions and completion of a CERCLA Preliminary Assessment for PFAS to identify areas where fluorinated Aqueous Film-Forming Foam (AFFF) was released, the source of the widespread PFAS at Pease, the Air Force conducted a base-wide PFAS site investigation (SI) to better understand the nature and extent of PFAS in soil, overburden, and bedrock groundwater. The SI was completed in 2016. This information was used to develop a conceptual site model of PFAS contamination and to develop a groundwater remediation plan called the Airfield Interim Mitigation System (AIMS).

A supplemental PFAS investigation, designated as Expanded Site Inspection (ESI), was conducted in 2018 and 2019 to further refine the relationship between overburden and bedrock groundwater and surface waters, both base-wide and with particular focus in Newington, north of Site 8. The ESI also included PFAS characterization and an exposure assessment of other media (soil, sediment, surface water, and shellfish). Results of the ESI were shared with the public at the 2019 Pease Restoration Advisory Board (RAB) meetings. Key conclusions of the ESI include: additional investigation and risk assessment is warranted and will occur as part of the next CERCLA phase, a Remedial Investigation (RI); and though PFAS were detected in shellfish collected from various locations, the detected concentrations did not exceed the Screening Levels (SLs) established for three PFAS by EPA. Because of the detection, NHDES' Environmental Health Program conducted a site-specific evaluation of PFAS in shellfish and concluded that a shellfish consumption advisory for PFAS was not warranted. The Final ESI report was published in March 2020 and is posted on the AFCEC Administrative Record website.

The Air Force has begun the Pease PFAS RI. A comprehensive outreach effort to property owners in the vicinity of Pease was conducted in fall 2020 to gather additional information about the presence of surface waters, springs, seeps, and non-potable wells on off-base properties as well as agricultural practices in the community to better inform the development of the Human Health Risk Assessment and Ecological Risk Assessment being conducted as part of the RI. Several technical sessions were held in early 2021 to seek input from Pease stakeholders including concerned community members as well as the City of Portsmouth and Pease Development Authority. This information was considered during the development of the RI Work Plan. The first phase of field work to refine the nature and extent of PFAS contamination was conducted in 2021, evaluation of these results is on-going, and a scope of work is being developed for the second phase of the investigation to be completed this year. The draft RI report is expected to be submitted for NHDES and EPA review and comment in early 2023.

- **Airfield Interim Mitigation System (AIMS).** The AIMS objectives include: intercepting PFAS-impacted groundwater upgradient of the Haven Well through a network of groundwater extraction wells; treatment of the intercepted water in a centrally-located treatment plant using best available technology; reinjection of the treated groundwater back into the Pease aquifer to restore the aquifer, supporting the City of Portsmouth's reactivation of the Haven Well and providing hydraulic protection of the southern Pease aquifer supply wells. Installation of the AIMS extraction and infiltration wells was completed in 2018. Construction of the AIMS treatment plant was completed, and the Air Force started operation in April 2019. Since startup, the AIMS has treated approximately 500 million gallons of groundwater.

- **Former Fire Training Area No. 2 (Site 8).** Concurrent with the base-wide PFAS Site Investigation, a separate investigation was conducted at the former fire training area where AFFF was known to have been used by the Air Force beginning in the early 1970s up through the late 1980s. Extensive investigations in the 1990s were conducted to address petroleum and solvent contamination. A remedy including a hydraulic containment system had been operated since 1995 and was demonstrated to have mitigated off-site migration of those contaminants. Based on the Site 8 PFAS investigation, a design was developed to augment the hydraulic containment system to better mitigate PFAS migration. That system and its associated state-of-the-art PFAS treatment plant began operating in spring 2018. System design and operations are regularly evaluated to optimize performance. Due to the unexpected presence of elevated iron concentrations in several of the Site 8 IMS extraction wells, the Air Force augmented the Site 8 IMS with an iron mitigation treatment phase. Operation, optimization, and performance monitoring of the Site 8 IMS is on-going. Since operation began, the Site 8 IMS has treated nearly 60 million gallons of groundwater.
- **Community Involvement.** Since discovery of PFAS in the municipal supply wells in May 2014, the community has been actively engaged and has participated in numerous public meetings hosted by NHDES and New Hampshire Department of Health and Human Services (NHDHHS). In addition, the following community groups have been developed for Pease PFAS-related issues:

 - Restoration Advisory Board (RAB). In 2015, NHDES requested the Air Force re-establish Pease’s RAB, a stakeholder group that meets quarterly to discuss ongoing environmental restoration of Pease. The RAB provides community members an open forum to talk with the Air Force and regulatory agencies about environmental restoration activities. The Pease RAB consists of local volunteer community members (including the NH Air National Guard) and appointed members representing the Air Force, regulatory agencies, the Pease Development Authority, and the City of Portsmouth. RAB information can be accessed on the Air Force Civil Engineering Center website: <https://www.afcec.af.mil/Home/BRAC/Pease.aspx>.
 - Community Assistance Panel (CAP): The initial forum that was created for community input on PFAS-related health concerns was the Community Advisory Board. To build on the community involvement started with the Board, the Agency for Toxic Substances and Disease Registry (ATSDR) formed the Pease CAP as a way for the community to participate directly in ATSDR’s health activities. CAP information can be accessed on the ATSDR website for Pease: <https://www.atsdr.cdc.gov/pfas/Pease-CAP.html>.

Information on the Pease Study, the first in the nation health study to better understand the effects of PFAS exposure, can be accessed on the ATSDR website for Pease: <https://www.atsdr.cdc.gov/sites/pease/index.html>.

ATSDR’s Health Consultation on PFAS in the Pease Tradeport Public Water System can be accessed on the ATSDR website for Pease: https://www.atsdr.cdc.gov/HAC/pha/pease/Pease_Air_Force_Base_HC-508.pdf.

ATSDR's Health Consultation on PFAS in the Private Residential Drinking Water Wells was finalized in February 2022 and can be accessed on the ATSDR website:

<https://www.atsdr.cdc.gov/HAC/pha/pease/PeaseAFB-HC-508.pdf>.

4. Statewide Public Water Supplies

NHDES began a statewide initiative to test drinking water from all community water supplies for PFAS in 2016. Of the 1,880 sources of drinking water that supply public water systems in New Hampshire, as of May 2022, approximately 79% (1,487 sources) have been sampled for PFAS with approximately 29% of wells having detections of PFOA, PFOS, PFHxS, and PFNA. Information included on the attached Table 1 summarizes sampling results for PFOA, PFOS, PFHxS, and PFNA. NHDES notes that exceedances of the current MCLs for the four PFAS compounds occurred at 103 water supply wells, which has required or may require that the owners of these wells install treatment or take the wells out of service.

Table 1 presents only one sample result for each source, representing the most recent concentration of PFOA, PFOS, PFHxS, and PFNA detected. Given the fact that treatment systems for PFAS removal have been and are in-process of being installed at some PFAS-impacted water systems, some of the sampling results shown in Table 1 reflect low or no presence of PFAS due to operation of these systems.

Treatment system installation or water system interconnections have occurred at approximately 43 public water systems to address PFAS contamination. The approximate population served by a public water system (community, institutional or commercial) that has either interconnected with another water system or installed treatment due to PFAS at the time of this summary is 83,000.

5. Statewide PFAS Data

The following summarizes PFAS information that NHDES has compiled to date from various sources at existing solid waste facilities, hazardous waste remediation sites, oil remediation sites, and groundwater discharge sites. Please refer to the additional resources referenced in Section 1 above for up-to-date and/or additional site-specific information.

5.1 Solid Waste Facilities

There are roughly 200 unlined/lined solid waste disposal facilities or synthetic lined wastewater treatment lagoons in New Hampshire for which the owner/operator is responsible for monitoring water quality. These sites have either a groundwater release detection permit (GDP) or groundwater management permit (GMP) that have been issued by NHDES, in accordance with applicable administrative rules. These permits prescribe programs for periodic groundwater quality monitoring and reporting, provide for groundwater remediation either through active measures or natural attenuation, specify performance standards for remedies, and describe procedures for performing site investigations and implementing remedial action plans.

NHDES has required groundwater sampling for PFAS at all of these sites. As of March 2022, 88% have sampled, and of those sites sampled, approximately 85% have PFAS detections, and 72% have exceedances of the AGQS for PFOA, PFOS, PFHxS, and/or PFNA. Refer to Table 2 for a summary of maximum PFOA, PFOS, PFHxS, and PFNA concentrations at each of the sites where data has been compiled by NHDES.

5.2 Hazardous Waste Remediation Sites

Hazardous waste remediation sites include all sites where a hazardous substance or waste has been released, and which often have a long-term remediation and management component prescribed and regulated through a NHDES-issued groundwater management permit or remedial action plan. There are 684 waste sites, including State-listed hazardous waste, Comprehensive Environmental Response, Compensation, and Liability Act (CERCLA), and Brownfield sites, that have an open status and are currently regulated by NHDES, in accordance with its administrative rules.

As outlined in a letter to responsible parties, site owners, and/or permittees dated May 18, 2017, and clarified in a follow-up letter dated October 19, 2017, NHDES is requiring waste sites that meet certain criteria to complete an initial screening for the presence of PFAS per the provisions of the NH Code of Administrative Rules, Chapters Env-Or 600 and Env-Or 700, as applicable. As of March 2022, 37% have sampled and of those sites sampled, approximately 94% have detected PFAS and 76% have exceedances of the AGQS for PFOA, PFOS, PFHxS, and/or PFNA. Refer to Table 3 for a summary of maximum PFOA, PFOS, PFHxS, and PFNA concentrations at each of the sites where data has been compiled by NHDES.

5.3 Oil Remediation Sites

Oil remediation sites include all sites where long-term remediation and management of petroleum contamination occurs primarily through a NHDES-issued GMP or remedial action plan. There are roughly 1,500 active petroleum sites, including, but not limited to, leaking underground/above ground storage tank sites, motor vehicle salvage yards, and spills that have an open status and are currently regulated by NHDES in accordance with the administrative rules.

NHDES undertook an initiative in 2018 requesting a small initial subset of these petroleum sites to voluntarily complete an initial screening for the presence of PFAS. As of March 2022, less than 1% of all petroleum sites have sampled and reported data to NHDES for PFAS. Of the sites sampled, several have exceedances of the AGQS for PFOA, PFOS, PFHxS, and/or PFNA. NHDES notes however, that in all cases to date, it has been concluded that the source and release mechanism(s) have not been attributable to the petroleum discharge. PFAS exceedances in groundwater were observed in the general vicinity of areas where fire suppression foam was used, and motor oil additives or other fluids were stored or discharged at motor vehicle salvage yards or unpermitted solid waste facilities. Refer to Table 4 for a summary of maximum PFOA, PFOS, PFHxS, and PFNA concentrations at each of the sites where data has been compiled by NHDES.

5.4 Groundwater Discharge Permit Sites (Wastewater Disposal to Groundwater)

NHDES regulates 87 facilities that dispose of wastewater to the ground through such practices as discharges to unlined lagoons, rapid infiltration basins, spray irrigation systems, very large leach fields, and seepage lagoons. These sites are managed under a Groundwater Discharge Permit (GDP), which allows the discharge in accordance with administrative rules that protect against impact to other properties and drinking water supply wells. NHDES has required sampling for PFAS at all of these sites. To date, 97% have sampled and of those sites sampled, approximately 85% have detected PFAS and 43% have exceedances of the AGQS for PFOA, PFOS, PFHxS, and PFNA. Refer to Table 5 for a summary of maximum PFOA, PFOS, PFHxS, and PFNA concentrations at each of the sites where data has been compiled by NHDES.

APPENDICES

Appendix 1

House Bill 1766-FN- Final Version

CHAPTER 306
HB 1766-FN - FINAL VERSION

04/26/2018 1630s
23May2018... 1983-CofC

2018 SESSION

18-2503
08/04

HOUSE BILL ***1766-FN***

AN ACT requiring the department of environmental services to report to the general court regarding bedrock testing and perfluorochemical contamination in the Seacoast area and at other landfills and hazardous waste sites.

SPONSORS: Rep. Messmer, Rock. 24; Rep. Cushing, Rock. 21; Rep. Bean, Rock. 21; Rep. Edgar, Rock. 21; Rep. T. Le, Rock. 31; Rep. P. Gordon, Rock. 29; Sen. Fuller Clark, Dist 21

COMMITTEE: Environment and Agriculture

AMENDED ANALYSIS

This bill requires the department of environmental services to report to the general court regarding perfluorinated chemical contamination at the Seacoast and at landfills and other hazardous waste sites.

Explanation: Matter added to current law appears in ***bold italics***.
Matter removed from current law appears ~~[in brackets and struck through.]~~
Matter which is either (a) all new or (b) repealed and reenacted appears in regular type.

CHAPTER 306
HB 1766-FN - FINAL VERSION

04/26/2018 1630s
23May2018... 1983-CofC

18-2503
08/04

STATE OF NEW HAMPSHIRE

In the Year of Our Lord Two Thousand Eighteen

AN ACT requiring the department of environmental services to report to the general court regarding bedrock testing and perfluorochemical contamination in the Seacoast area and at other landfills and hazardous waste sites.

Be it Enacted by the Senate and House of Representatives in General Court convened:

1 306:1 Findings. The general court acknowledges the public concern regarding the
2 issue of water quality in the Seacoast area and at areas of environmental interest all
3 over the state. The general court further finds that in view of bedrock testing due to
4 begin in the Seacoast area during the summer of 2018, and in view of the impending first
5 ever study of per and polyfluoroalkyl (PFAS) exposure, the general court shall be
6 informed, on a regular basis, of contaminant monitoring and contaminant migration,
7 and advised regarding new research on contaminant exposure and any developments in
8 remediation technology.

9 306:2 Department of Environmental Services; Reports Required.

10 I. The department of environmental services shall submit an initial report to the
11 general court by December 1, 2018, and shall submit interim reports every 6 months
12 thereafter, on the results of monitoring, testing, and any other analysis or data relative
13 to perfluorooctanesulfonic acid (PFOS) and perfluorooctanoic acid (PFOA) levels at
14 statewide sites that it has identified as sources of those contaminants. The reports shall
15 include preliminary results from bedrock testing conducted at the Coakley Landfill site
16 beginning in the summer of 2018. The department shall submit interim reports on the
17 bedrock testing by July 1, 2019 and December 1, 2019, and a final report within 6 months
18 of when such testing is completed. Other Seacoast area sites shall include, but not be
19 limited to, the Pease International Tradeport and its vicinity, the Hampton Landfill, the
20 Coakley Landfill, the Rye Breakfast Hill Landfill, the Rye Grove Landfill, the Garland
21 Well and nearby well sites, the former Cibor Airport, the Hampton Airport, and other
22 municipal and commercial operations within the Seacoast area deemed relevant by the
23 department. The department shall also include in such reports the PFOS and PFOA
24 levels at any landfill, hazardous waste, and other sites statewide where it currently
25 requires testing.

26 II. Copies of the reports required in paragraph I shall be submitted to:

27 (a) The president of the senate.

CHAPTER 306
HB 1766-FN - FINAL VERSION
- Page 2 -

1 (b) The speaker of the house of representatives.

2 (c) The chairman of the senate energy and natural resources committee, or
3 the successor committee with jurisdiction over energy and natural resource issues.

4 (d) The chairman of the environment and agriculture committee, or the
5 successor committee with jurisdiction over energy and natural resource issues.

6 (e) The joint legislative fiscal committee of the general court.

7 **306:3 Senate and House of Representatives Committees; Duties.** The senate energy
8 and natural resources committee and the house environment and agriculture committee,
9 or their successor committees as specified in section 2, paragraph II of this act, shall
10 collect and evaluate the reports required in section 2 of this act along with any other
11 reports, data, and information the committees deem relevant. The committees shall
12 solicit information from commissions and informed citizens in southeastern New
13 Hampshire and shall solicit information from the United States Environmental
14 Protection Agency regarding the reports required in section 2.

15 **306:4 Effective Date.** This act shall take effect July 1, 2018.

Approved: June 25, 2018
Effective Date: July 01, 2018

TABLES



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE #	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
0015010-001	ACWORTH PRIMARY SCH	ACWORTH	7/20/2020	ND	ND	ND	ND
0023010-001	PIPER MEADOWS PRIVATE COMMUNITY	ALBANY	3/29/2021	ND	ND	ND	ND
0022010-501	WILDWOOD DEV	ALBANY	3/10/2020	ND	ND	ND	ND
0032010-501	LEDGES AT NEWFOUND LAKE	ALEXANDRIA	11/5/2019	ND	ND	ND	ND
0043040-505	CATAMOUNT HILL	ALLENSTOWN	3/25/2020	ND	ND	ND	ND
0043020-511	OLDE TOWNE	ALLENSTOWN	9/23/2020	ND	ND	ND	ND
0055020-001	ALSTEAD PRIMARY SCH	ALSTEAD	7/20/2020	ND	ND	ND	ND
0055010-501	ALSTEAD VILAS SCH	ALSTEAD	7/20/2020	ND	ND	ND	ND
0059010-001	MOLE HILL THEATRE/LEAF CHARTER	ALSTEAD	12/21/2020	ND	ND	ND	ND
0055030-001	ORCHARD SCHOOL	ALSTEAD	12/4/2019	ND	ND	ND	ND
0052010-001	PAPERMILL VILLAGE	ALSTEAD	4/21/2021	ND	ND	ND	ND
0052010-503	PAPERMILL VILLAGE	ALSTEAD	7/13/2021	ND	ND	ND	ND
0053010-504	WELL HILL	ALSTEAD	1/20/2021	ND	ND	ND	ND
0061010-502	ALTON WATER WORKS	ALTON	3/10/2021	ND	ND	ND	ND
0061010-503	ALTON WATER WORKS	ALTON	7/21/2021	ND	3.78	ND	3.85
0062010-501	EAGLES REST MHP	ALTON	1/4/2021	ND	ND	ND	ND
0062050-501	LAKESIDE AT WINNIPESAUKEE	ALTON	11/5/2019	ND	ND	ND	ND
0063020-501	MERRYMEETING MHP	ALTON	3/10/2021	ND	ND	ND	ND
0065020-501	PROSPECT MOUNTAIN HIGH SCH	ALTON	12/10/2020	ND	ND	ND	ND
0075060-501	AMHERST MEDICAL CENTER	AMHERST	1/4/2021	ND	ND	ND	ND
0075070-001	CHRISTS CHURCH OF AMHERST	AMHERST	1/25/2021	ND	ND	ND	ND
0076130-501	COLONIAL PARK	AMHERST	9/24/2021	6.18	ND	ND	4.76
0072090-501	CONNOR COURT	AMHERST	4/12/2021	7.57	ND	ND	ND
0072080-001	GOWING WOODS	AMHERST	7/20/2021	4.18	ND	ND	ND
0076070-001	MC SQUARE	AMHERST	4/29/2021	4.54	ND	ND	ND
0076070-501	MC SQUARE	AMHERST	8/25/2021	7.5	ND	ND	ND
0078090-501	MEETING PLACE	AMHERST	7/21/2021	2.2	2.51	ND	5.58
0073030-000	RIDGEWOOD ESTATES	AMHERST	11/5/2019	ND	ND	ND	ND
0076040-002	SALZBURG SQUARE AMHERST	AMHERST	1/19/2022	13.6	3.81	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE #	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
0072070-501	SOUHEGAN WOODS	AMHERST	10/6/2021	6.96	ND	ND	ND
0081010-002	ANDOVER VILLAGE DIST	ANDOVER	2/20/2020	ND	ND	ND	ND
0086030-001	BELLETETES	ANDOVER	3/9/2021	ND	ND	ND	ND
0091010-501	ANTRIM SEWER AND WATER DEPT	ANTRIM	2/11/2020	ND	ND	ND	ND
0095010-001	OVERSEAS UNITED EDUC FNDTN	ANTRIM	6/22/2021	ND	ND	ND	ND
0092010-001	STEELE POND DEV	ANTRIM	8/5/2016	ND	ND	ND	ND
0101010-504	ASHLAND WATER DEPT	ASHLAND	7/22/2021	ND	ND	ND	ND
0101010-505	ASHLAND WATER DEPT	ASHLAND	7/22/2021	ND	ND	ND	ND
0106010-502	ROCHESTER SHOE TREE	ASHLAND	9/24/2020	ND	ND	ND	ND
0102010-500	ROPEWALK SERVICES	ASHLAND	3/6/2020	ND	ND	ND	ND
0102020-000	VILLAGE AT RIVERBEND	ASHLAND	2/12/2020	ND	ND	ND	ND
0115010-502	ATKINSON ACADEMY SCH	ATKINSON	8/22/2021	10.5	9.76	ND	2.57
0112100-502	ATKINSON WOODS	ATKINSON	7/7/2021	2.42	ND	ND	ND
0112060-501	COMMONS OF ATKINSON	ATKINSON	7/13/2021	7.11	4.68	ND	2.43
0112090-501	DEARBORN RIDGE	ATKINSON	5/17/2021	ND	ND	ND	ND
0116020-501	GEX	ATKINSON	8/16/2021	ND	ND	ND	ND
0115060-001	LEARNING PATH CHILD CARE CTR	ATKINSON	5/14/2021	6.12	ND	ND	ND
0116040-501	PALMER GAS	ATKINSON	2/21/2022	7.06	3.49	ND	ND
0116010-501	PEU/PIIONEER COMMERCE PARK	ATKINSON	7/20/2021	2.96	ND	ND	ND
0112080-001	WALNUT RIDGE/BRYANT WDS	ATKINSON	6/17/2019	5.9	1.6	2.1	ND
0112080-003	WALNUT RIDGE/BRYANT WDS	ATKINSON	6/17/2019	4.8	1.4	1.5	0.26
0112080-004	WALNUT RIDGE/BRYANT WDS	ATKINSON	6/17/2019	16	3.9	3.5	0.74
0112080-009	WALNUT RIDGE/BRYANT WDS	ATKINSON	6/17/2019	2.6	1.1	0.88	ND
0112080-011	WALNUT RIDGE/BRYANT WDS	ATKINSON	6/17/2019	2.1	0.89	0.7	ND
0112080-012	WALNUT RIDGE/BRYANT WDS	ATKINSON	6/17/2019	2.7	ND	0.8	ND
0112080-021	WALNUT RIDGE/BRYANT WDS	ATKINSON	6/17/2019	1.8	1.8	1.8	ND
0112080-013	WALNUT RIDGE/BRYANT WOODS	ATKINSON	5/26/2016	ND	ND	ND	ND
0112070-501	WATER WHEEL ESTATES	ATKINSON	2/4/2020	ND	ND	ND	ND
0112030-501	WRIGHT FARM CONDOS	ATKINSON	7/13/2021	4.9	ND	ND	2.65



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE #	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
0135020-001	AUBURN CHILDRENS HOUSE	AUBURN	6/24/2020	ND	ND	ND	ND
0135010-502	AUBURN VILLAGE SCH	AUBURN	1/14/2021	ND	ND	ND	ND
0135030-501	ITS A CHILDS WORLD	AUBURN	8/13/2020	ND	ND	ND	ND
0146040-501	BARNSTEAD BUSINESS PARK	BARNSTEAD	2/21/2021	ND	ND	ND	ND
0145010-502	BARNSTEAD ELEMENTARY SCH	BARNSTEAD	11/14/2019	ND	ND	ND	ND
0142010-019	PEU LOCKE LAKE	BARNSTEAD	1/4/2022	ND	ND	ND	ND
0142010-510	PEU/LOCKE LAKE	BARNSTEAD	2/11/2020	ND	ND	ND	ND
0142010-517	PEU/LOCKE LAKE	BARNSTEAD	2/11/2020	ND	ND	ND	ND
0156030-501	ASSOCIATED BUYERS	BARRINGTON	6/21/2021	ND	ND	ND	ND
0152030-001	BARRINGTON HILLS APTS/LOWER	BARRINGTON	11/19/2019	ND	ND	ND	ND
0152050-001	BARRINGTON HILLS APTS/UPPER	BARRINGTON	11/19/2019	ND	ND	ND	ND
0155080-500	BARRINGTON MIDDLE SCH	BARRINGTON	2/16/2021	ND	ND	ND	ND
0153050-506	BARRINGTON MOBILE HOME ESTATES	BARRINGTON	8/11/2021	4.27	ND	ND	ND
0153030-502	BARRINGTON OAKS	BARRINGTON	3/25/2021	ND	ND	ND	ND
0153030-503	BARRINGTON OAKS	BARRINGTON	3/25/2021	ND	ND	ND	ND
0155100-001	BARRINGTON VLG ENRICHMENT CTR	BARRINGTON	8/4/2021	ND	ND	ND	ND
0155050-501	BARRINGTON ELEMENTARY SCHOOL	BARRINGTON	9/21/2021	ND	2.78	ND	6.16
0155020-501	EARLY CHILDHOOD LEARNING CTR	BARRINGTON	11/18/2019	ND	ND	ND	ND
0152010-001	ELLISON FARM APARTMENTS	BARRINGTON	8/17/2021	ND	ND	ND	ND
0153060-503	EMERALD ACRES	BARRINGTON	1/22/2021	ND	ND	ND	ND
0156020-501	FOCUS HOLDINGS	BARRINGTON	3/31/2022	19.6	12.5	ND	2.7
0155070-501	FRISBIE HEALTH SERVICES	BARRINGTON	11/21/2020	ND	ND	ND	ND
0153020-501	HALCYON HILL	BARRINGTON	8/2/2021	5.49	8.39	ND	ND
0153040-501	LEE OAK COOPERATIVE	BARRINGTON	4/22/2021	3.94	ND	ND	ND
0156060-001	MIDPOINT PROPERTIES	BARRINGTON	4/1/2021	ND	ND	ND	ND
0152020-501	OLD STAGE COACH ARMS	BARRINGTON	4/14/2021	5.28	3.46	ND	ND
0152060-003	OYSTER RIVER APTS EAST/WEST	BARRINGTON	1/14/2020	ND	ND	ND	ND
0152090-501	PEPPERIDGE WOODS	BARRINGTON	11/13/2019	ND	ND	ND	ND
0151010-503	SWAINS LAKE VILLAGE WATER	BARRINGTON	3/3/2020	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE #	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
0156070-001	TURBOCAM B2	BARRINGTON	3/18/2020	ND	ND	ND	ND
0156040-004	TURBOCAM/PHASE I	BARRINGTON	3/18/2020	ND	ND	ND	ND
0156040-005	TURBOCAM/PHASE I	BARRINGTON	3/18/2020	ND	ND	ND	ND
0162250-504	BARTLETT PLACE	BARTLETT	3/9/2020	ND	ND	ND	ND
0161010-003	BARTLETT VILLAGE PCT	BARTLETT	9/22/2021	ND	ND	ND	ND
0168460-001	BEAR PEAK AT ATTITASH	BARTLETT	2/11/2020	ND	ND	ND	ND
0162340-001	BEAR VILLAGE SOUTH	BARTLETT	3/12/2020	ND	ND	ND	ND
0162430-501	BEARFOOT CREEK	BARTLETT	3/4/2020	ND	ND	ND	ND
0162180-001	BLUEBERRY VILLAGE CONDOS	BARTLETT	10/23/2019	ND	ND	ND	ND
0162160-001	COW HILL WELLHOUSE	BARTLETT	11/9/2016	ND	ND	ND	ND
0162160-503	COW HILL WELLHOUSE	BARTLETT	8/18/2021	ND	2.05	ND	ND
0162190-502	CRAWFORD HILLS	BARTLETT	2/11/2020	ND	ND	ND	ND
0162330-501	CRAWFORD POND	BARTLETT	2/11/2020	ND	ND	ND	ND
0162400-501	EAGLE RIDGE RESORT	BARTLETT	3/9/2020	ND	ND	ND	ND
0162350-000	GOODRICH PROPERTY	BARTLETT	10/23/2019	ND	ND	ND	ND
0162070-000	LINDERHOF PROP OWNR ASSN	BARTLETT	3/12/2020	ND	ND	ND	ND
0161020-001	LOWER BARTLETT WATER PCT	BARTLETT	7/8/2021	ND	ND	ND	ND
0161020-003	LOWER BARTLETT WATER PCT	BARTLETT	7/8/2021	ND	ND	ND	ND
0162210-502	MOUNTAINSIDE ON ATTITASH	BARTLETT	3/10/2020	ND	ND	ND	ND
0167010-501	MT ATTITASH SKI AREA/LODGE	BARTLETT	3/12/2020	ND	ND	ND	ND
0162270-505	NORDIC VILLAGE	BARTLETT	12/4/2020	ND	ND	ND	ND
0162050-502	NORTH LEDGE	BARTLETT	2/11/2020	ND	ND	ND	ND
0162170-511	RIVER RUN CONDOS	BARTLETT	9/22/2021	2.78	3.94	ND	ND
0162100-002	RIVERSBEND	BARTLETT	3/12/2020	ND	ND	ND	ND
0162140-502	RIVERSIDE COBB FARM	BARTLETT	3/12/2020	ND	ND	ND	ND
0162410-508	STILLINGS GRANT	BARTLETT	2/11/2020	ND	ND	ND	ND
0162390-501	SUGARWOOD ON THE SACO	BARTLETT	5/28/2021	4.2	7.51	ND	ND
0162200-503	TOP NOTCH CONDOS	BARTLETT	3/12/2020	ND	ND	ND	ND
0162260-001	VILLAGGIO BIANCO	BARTLETT	3/9/2020	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE #	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA	Max PFOS	Max PFNA	Max PFHxS
				Detected (ng/L) MCL/AGQS = 12	Detected (ng/L) MCL/AGQS = 15	Detected (ng/L) MCL/AGQS = 11	Detected (ng/L) MCL/AGQS = 18
0162310-502	WHISPERING BROOK	BARTLETT	3/9/2020	ND	ND	ND	ND
0171010-503	BATH VILLAGE WATER WORKS	BATH	12/4/2019	ND	ND	ND	ND
0196020-501	101 PLAZA	BEDFORD	4/19/2022	13.5	ND	ND	ND
0196330-501	124 BEDFORD CENTER RD	BEDFORD	2/10/2022	6.14	15.8	ND	ND
0196210-501	288 ROUTE 101	BEDFORD	2/3/2020	ND	ND	ND	ND
0196280-501	292 ROUTE 101	BEDFORD	8/5/2021	2.04	ND	ND	ND
0195100-501	BEDFORD VILLAGE MORNING SCHOOLE	BEDFORD	3/9/2021	ND	ND	ND	ND
0195090-001	BETHANY COVENANT CHURCH	BEDFORD	8/25/2021	6.05	ND	ND	ND
0192070-321	CABOT PRESERVE	BEDFORD	3/6/2020	14.7	2.72	ND	ND
0197020-001	CAMP FOSTER	BEDFORD	5/9/2017	ND	ND	3	ND
0197030-001	CAMP KETTLEFORD	BEDFORD	5/9/2017	ND	ND	ND	ND
0192060-501	ENGLISH WOODS	BEDFORD	1/21/2021	2.29	ND	ND	ND
0196270-501	EVERSOURCE ENERGY BEDFORD AWC	BEDFORD	9/21/2020	ND	ND	ND	ND
0196320-501	FAMILY MEDICAL CENTER	BEDFORD	3/2/2022	18.2	5.94	ND	4.17
0196310-001	FRENCH ATWOOD MARKETPLACE	BEDFORD	9/24/2021	2.66	ND	ND	ND
0195020-501	KELLOGG CHRISTIAN SCHOOL	BEDFORD	10/29/2019	40.2	2.63	2.31	ND
0195010-002	MONTESSOR SCH OF BEDFORD	BEDFORD	3/17/2021	ND	ND	ND	ND
0198010-001	OLDE ROAD II	BEDFORD	11/30/2018	93	2.6	1.3	0.8
0196170-001	PINE TREE PLACE CONDOS	BEDFORD	9/17/2021	7.94	ND	ND	ND
0202010-005	ABENAKI WATER /LAKELAND	BELMONT	11/5/2019	ND	ND	ND	ND
0202010-501	ABENAKI WATER /LAKELAND	BELMONT	5/21/2021	ND	ND	ND	ND
0202010-504	ABENAKI WATER /LAKELAND	BELMONT	1/18/2021	ND	ND	ND	ND
0202030-501	ABENAKI WATER/TIOGA	BELMONT	5/12/2021	ND	ND	ND	ND
0206040-501	AFL TELECOMMUNICATIONS LLC	BELMONT	11/21/2019	6.46	4.22	ND	ND
0206020-501	BELMONT BUSINESS PARK	BELMONT	11/15/2019	ND	ND	ND	ND
0209040-501	BELMONT MEDICAL CENTER	BELMONT	7/20/2021	ND	ND	ND	ND
0201010-501	BELMONT WATER DEPT	BELMONT	10/30/2019	ND	ND	ND	ND
0201010-502	BELMONT WATER DEPT	BELMONT	10/30/2019	ND	ND	ND	ND
0201010-503	BELMONT WATER DEPT	BELMONT	7/13/2021	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE #	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
0203010-001	CATES MOBILE HOME PARK	BELMONT	2/11/2020	ND	ND	ND	ND
0206050-501	EASTGATE PARK	BELMONT	3/17/2021	ND	ND	ND	ND
0203070-502	GRANITE STATE CAMPGROUND	BELMONT	1/28/2021	3.19	4.76	ND	ND
0203020-501	LADD HILL MHP	BELMONT	7/30/2021	ND	ND	ND	ND
0205010-501	LAKES REGION DAYCARE	BELMONT	7/20/2021	8.25	3.57	ND	ND
0203090-505	LAKES REGION MHP COOP II	BELMONT	9/23/2021	ND	ND	ND	ND
0203080-000	MALLARDS LANDING	BELMONT	11/6/2019	ND	ND	ND	ND
0203030-001	NORTHBROOK MHP	BELMONT	7/26/2021	9.81	9.99	ND	2.74
0203030-501	NORTHBROOK MHP	BELMONT	7/26/2021	9.06	5.88	ND	8.49
0203040-000	PINE GARDENS MHP	BELMONT	3/3/2020	ND	ND	ND	ND
0203060-504	SOLAR VILLAGE	BELMONT	2/11/2021	ND	ND	ND	ND
0202060-501	SUN LAKE VILLAGE	BELMONT	11/6/2019	ND	ND	ND	ND
0202020-500	SUNRAY SHORES WATER DIST	BELMONT	12/6/2019	ND	ND	ND	ND
0202040-501	WESTVIEW MEADOWS	BELMONT	6/29/2021	ND	ND	ND	ND
0211010-502	BENNINGTON WATER DEPT	BENNINGTON	2/21/2020	ND	ND	ND	ND
0212030-000	BIRCHES OF BENNINGTON	BENNINGTON	1/5/2021	ND	ND	ND	ND
0212020-501	MOUNTAINSIDE AT CROTCHED MTN	BENNINGTON	4/21/2021	ND	ND	ND	ND
0212020-502	MOUNTAINSIDE AT CROTCHED MTN	BENNINGTON	7/16/2021	ND	ND	ND	ND
0212010-501	SOUTH FACE CONDOS	BENNINGTON	1/5/2021	ND	ND	ND	ND
0224010-004	GLENCLIFF HOME FOR THE ELDERLY	BENTON	6/4/2020	ND	ND	ND	ND
0224010-504	GLENCLIFF HOME FOR THE ELDERLY	BENTON	1/17/2020	ND	ND	ND	ND
0231010-004	BERLIN WATER WORKS	BERLIN	10/10/2019	ND	ND	ND	ND
0231010-008	BERLIN WATER WORKS	BERLIN	11/6/2019	ND	ND	ND	ND
0231010-009	BERLIN WATER WORKS	BERLIN	10/10/2019	ND	ND	ND	ND
0241010-003	BETHLEHEM VILLAGE DIST	BETHLEHEM	8/10/2021	ND	ND	ND	ND
0245010-502	PROFILE HIGH SCH	BETHLEHEM	12/29/2020	ND	ND	ND	ND
0251010-002	PENACOOK BOSCAWEN WATER PCT	BOSCAWEN	12/29/2020	ND	ND	ND	ND
0251010-003	PENACOOK BOSCAWEN WATER PCT	BOSCAWEN	12/29/2020	ND	ND	ND	ND
0251010-004	PENACOOK BOSCAWEN WATER PCT	BOSCAWEN	12/29/2020	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE #	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
0266220-001	501 SOUTH STREET	BOW	1/11/2021	ND	ND	ND	ND
0262020-501	ABENAKI WATER/WHITE ROCK	BOW	9/26/2021	ND	ND	ND	ND
0262030-502	BELA BROOK WATER	BOW	11/6/2019	ND	ND	ND	ND
0266020-001	BOVIE SCREEN PRINTING	BOW	7/23/2021	ND	ND	ND	ND
0265020-502	BOW ELEMENTARY SCHOOL	BOW	9/21/2021	ND	ND	ND	ND
0265030-502	BOW HIGH SCHOOL	BOW	9/21/2021	ND	ND	ND	ND
0265010-502	BOW MEMORIAL SCHOOL	BOW	9/21/2021	5.67	ND	ND	ND
0269010-501	BOW MUNICIPAL BUILDING	BOW	10/6/2021	ND	ND	ND	ND
0261010-511	BOW MUNICIPAL WATER SYSTEM	BOW	10/6/2021	4.66	4.69	ND	ND
0266250-501	BOW SAFETY BLDG	BOW	10/6/2021	ND	ND	ND	ND
0266110-501	BOW TECHNOLOGIES	BOW	9/13/2021	2.56	2.24	ND	ND
0265050-511	BOW YOUTH CENTER	BOW	1/10/2022	ND	ND	ND	ND
0266150-502	CONCORD GROUP	BOW	12/11/2020	ND	ND	ND	ND
0262040-502	COTTAGES AT WINDCHIMES	BOW	4/6/2021	ND	ND	ND	ND
0262010-501	EVERGREEN DRIVE WATER	BOW	1/4/2021	ND	ND	ND	ND
0266050-002	GRAPPONE FORD COMPLEX	BOW	5/21/2021	7.06	11.6	ND	4.41
0266240-001	GRAPPONE HONDA	BOW	5/21/2021	4.82	6.66	ND	2.58
0266200-500	GRAPPONE TOYOTA	BOW	5/21/2021	5.36	ND	ND	4.77
0266010-000	GSP/MERRIMACK STATION	BOW	7/8/2021	7.09	8.52	ND	2.03
0265040-001	JOYFUL NOISE	BOW	2/3/2021	ND	ND	ND	ND
0265040-501	JOYFUL NOISE	BOW	2/3/2021	ND	ND	ND	ND
0265060-501	MEETING HOUSE MONTESSORI	BOW	11/13/2019	ND	ND	ND	ND
0266140-501	NH AUTO DEALERS ASSN	BOW	11/13/2019	ND	ND	ND	ND
0262060-501	PEU/STONE SLED FARM	BOW	3/4/2020	ND	ND	ND	ND
0262060-502	PEU/STONE SLED FARM	BOW	3/4/2020	ND	ND	ND	ND
0262050-501	PEU/WHITE ROCK SENIOR LIVING	BOW	7/8/2021	3.1	ND	ND	ND
0266090-001	PITCO FRIALATOR	BOW	5/13/2021	17.1	17.9	ND	13.1
0266090-501	PITCO FRIALATOR	BOW	2/9/2022	14.4	10	ND	14.9
0266130-002	RUGGLES III OFFICE BLDG	BOW	11/5/2019	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE #	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
0275090-501	CHILDRENS CTR FOR CREATVE LRNG	BRADFORD	6/29/2021	ND	ND	ND	ND
0272010-001	FISHERFIELD TOWNHOUSES	BRADFORD	10/21/2019	ND	ND	ND	ND
0275070-001	KEARSARGE REG ELEM SCH/BRADFRD	BRADFORD	12/23/2020	ND	ND	ND	ND
0275080-501	NFI NORTH TRNS HSING	BRADFORD	7/14/2021	ND	ND	ND	ND
0285040-501	A PLACE TO GROW	BRENTWOOD	9/17/2020	ND	ND	ND	ND
0282010-002	MILL POND CROSSING	BRENTWOOD	6/3/2020	ND	ND	ND	ND
0286020-601	OWENS CORNING	BRENTWOOD	6/25/2021	ND	ND	ND	ND
0284010-502	ROCKINGHAM COUNTY COMPLEX	BRENTWOOD	9/14/2021	2.92	6.31	ND	9.18
0284010-503	ROCKINGHAM COUNTY COMPLEX	BRENTWOOD	5/21/2021	ND	3.39	7.86	ND
0286060-500	ROCKINGHAM COUNTY COURTHOUSE	BRENTWOOD	8/16/2021	3.33	ND	ND	ND
0285010-502	SWASEY CENTRAL SCH	BRENTWOOD	6/25/2021	2.11	ND	ND	ND
0295010-001	BRIDGEWATER/HEBRON VIL SCH	BRIDGEWATER	3/16/2021	ND	ND	ND	ND
0293010-002	NEWFOUND ACRES MHP	BRIDGEWATER	2/12/2020	ND	ND	ND	ND
0298040-001	NEWFOUND GROCERY	BRIDGEWATER	7/22/2016	ND	ND	ND	ND
0297020-512	WHIP O WHILL CONDOS	BRIDGEWATER	4/8/2021	ND	ND	ND	ND
0292010-000	WHITTEMORE SHORES	BRIDGEWATER	11/6/2019	ND	ND	ND	ND
0301010-501	BRISTOL WATER WORKS	BRISTOL	4/2/2021	ND	ND	ND	ND
0301010-502	BRISTOL WATER WORKS	BRISTOL	4/2/2021	ND	ND	ND	ND
0301010-503	BRISTOL WATER WORKS	BRISTOL	4/2/2021	ND	ND	ND	ND
0305010-501	NEWFOUND REGIONAL HS	BRISTOL	1/8/2021	ND	ND	ND	ND
0305020-001	PB AND JS FAMILY CHILDCARE	BRISTOL	9/17/2021	ND	ND	ND	ND
0325050-501	CAPT SAMUEL DOUGLASS ACADEMY	BROOKLINE	12/22/2020	ND	ND	ND	ND
0326020-501	DECCO	BROOKLINE	10/28/2019	ND	ND	ND	ND
0325010-001	RICHARD MAGHAKIAN MEMORIAL SCH	BROOKLINE	12/21/2020	ND	ND	ND	ND
0325060-001	STONE LEDGE PLAZA	BROOKLINE	7/20/2021	ND	ND	ND	ND
0342060-002	BECKET HOUSE AT CAMPTON	CAMPTON	11/5/2019	ND	ND	ND	ND
0342010-512	BEEBE RIVER	CAMPTON	1/27/2021	ND	ND	ND	ND
0341010-508	CAMPTON VILLAGE PCT	CAMPTON	4/2/2021	ND	ND	ND	ND
0341010-509	CAMPTON VILLAGE PCT	CAMPTON	4/2/2021	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE #	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
0343010-000	CHESLEYS MHP	CAMPTON	5/19/2021	ND	ND	ND	ND
0342100-000	COACHMAN CONDOS	CAMPTON	1/20/2021	ND	ND	ND	ND
0342050-000	DEER RUN	CAMPTON	2/18/2020	ND	ND	ND	ND
0342090-001	RED SLEIGH CONDOS	CAMPTON	12/8/2020	ND	ND	ND	ND
0343020-502	SIX FLAGS MHP	CAMPTON	2/3/2021	ND	ND	ND	ND
0342020-001	TRIPPLEWOOD RESORT CONDOS	CAMPTON	4/2/2021	ND	ND	ND	ND
0346030-501	USFS WMNF ADMIN CMLPX	CAMPTON	9/13/2021	1.8	1.8	1.8	1.8
0342080-000	VALLEY VIEW CONDOS	CAMPTON	1/8/2020	ND	ND	ND	ND
0341030-502	WATERVILLE ESTATES VLG DIST	CAMPTON	3/12/2021	ND	ND	ND	ND
0356020-001	BARKER STEEL	CANAAN	3/11/2020	ND	ND	ND	ND
0351010-501	CANAAN WATER DEPT	CANAAN	3/11/2021	ND	ND	ND	ND
0354010-503	CARDIGAN MOUNTAIN SCH	CANAAN	1/10/2020	ND	ND	ND	ND
0353010-001	COUNTRY VILLAGE MHP	CANAAN	2/3/2021	ND	ND	ND	ND
0353010-002	COUNTRY VILLAGE MHP	CANAAN	2/3/2021	0.5	ND	ND	ND
0355060-001	INDIAN RIVER SCH	CANAAN	1/4/2022	8.17	9.38	ND	ND
0355070-001	MACOMA COMM HEALTH CARE	CANAAN	1/28/2021	ND	ND	ND	ND
0353020-001	MASCOMA VALLEY COOP	CANAAN	11/5/2019	ND	ND	ND	ND
0355030-001	MASCOMA VALLEY REG HIGH SCH	CANAAN	11/21/2016	12	15	ND	ND
0366040-001	BIRCHWOOD PLAZA	CANDIA	1/25/2021	ND	ND	ND	ND
0362020-502	CANDIA CROSSING	CANDIA	4/6/2022	ND	ND	ND	ND
0363010-503	COUNTRY LANE MANOR	CANDIA	9/7/2021	3.16	ND	ND	ND
0365010-503	HENRY W MOORE SCH	CANDIA	4/7/2021	ND	ND	ND	ND
0362010-501	HILLCREST MANOR APTS	CANDIA	1/5/2021	ND	ND	ND	ND
0365020-501	M AND C CHILDRENS LEARNING PL	CANDIA	5/24/2021	ND	ND	ND	ND
0365020-502	M AND C CHILDRENS LEARNING PL	CANDIA	2/15/2022	9.68	ND	ND	ND
0365040-001	REMLINGTON EDUC CENTER	CANDIA	9/24/2021	4.32	5.9	ND	ND
0375010-002	CANTERBURY ELEMENTARY SCH	CANTERBURY	1/20/2021	ND	ND	ND	ND
0374010-102	CANTERBURY SPRUCES HOUSING	CANTERBURY	1/20/2021	ND	ND	ND	ND
0381010-514	CARROLL WATER WORKS	CARROLL	10/24/2019	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE #	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
0382010-001	ROSEBROOK WATER	CARROLL	6/16/2021	ND	ND	ND	ND
0382010-002	ROSEBROOK WATER	CARROLL	6/16/2021	ND	ND	ND	ND
0398030-001	CENTER HARBOR INN	CENTER HARBOR	12/8/2016	4.6	ND	ND	ND
0396020-501	SENTERS MARKET CONDOS	CENTER HARBOR	4/1/2022	12.9	ND	ND	ND
0411010-004	CHARLESTOWN WATER WORKS	CHARLESTOWN	1/4/2021	ND	ND	ND	ND
0411010-005	CHARLESTOWN WATER WORKS	CHARLESTOWN	1/4/2021	ND	ND	ND	ND
0411010-502	CHARLESTOWN WATER WORKS	CHARLESTOWN	7/21/2021	2.54	ND	ND	ND
0413020-504	CONNECTICUT RIVER MHP	CHARLESTOWN	7/15/2020	ND	ND	ND	ND
0419010-501	LIFE FLLWSHP FOURSQRE CHURCH	CHARLESTOWN	1/20/2021	ND	ND	ND	ND
0412010-000	MEADOWVIEW APTS	CHARLESTOWN	8/4/2020	ND	ND	ND	ND
0411020-511	NORTH CHARLESTOWN WATER DEPT	CHARLESTOWN	1/4/2021	ND	ND	ND	ND
0411020-512	NORTH CHARLESTOWN WATER DEPT	CHARLESTOWN	1/4/2021	ND	ND	ND	ND
0413030-501	WINDY ACRES	CHARLESTOWN	8/4/2020	ND	ND	ND	ND
0435060-501	CHESTER ACADEMY	CHESTER	7/15/2021	2.2	ND	ND	6.4
0432030-502	CHESTER BROOK	CHESTER	9/13/2021	2.9	ND	ND	ND
0435080-501	CHESTERBROOK SCH OF NTRL LRNG	CHESTER	3/17/2021	ND	ND	ND	ND
0432020-502	OAK HILL	CHESTER	3/8/2021	ND	ND	ND	ND
0432040-501	PEU/SHAKER HEIGHTS	CHESTER	2/12/2020	ND	ND	ND	ND
0435070-001	PLAY LAUGH N GROW	CHESTER	10/3/2019	ND	ND	ND	ND
0438010-001	SHAKER HEIGHTS PROF PLAZA	CHESTER	5/25/2016	ND	ND	ND	ND
0432010-501	VILLAGES AT CHESTER CONDOS	CHESTER	10/22/2019	ND	ND	ND	ND
0437020-503	WASON POND COMMUNITY CENTER	CHESTER	2/10/2020	ND	ND	ND	ND
0445010-004	CHESTERFIELD CENTRAL SCH	CHESTERFIELD	12/18/2021	ND	ND	ND	ND
0449040-001	FEDEX FACILITY	CHESTERFIELD	12/29/2020	ND	ND	ND	ND
0446030-501	NORTHEAST HOME LOAN	CHESTERFIELD	12/29/2020	ND	ND	ND	ND
0446020-502	UNITED NATURAL FOODS	CHESTERFIELD	10/18/2021	ND	ND	ND	ND
0456010-502	CAMPING WORLD OF NEW HAMPSHIRE	CHICHESTER	9/27/2021	ND	ND	ND	ND
0455010-501	CHICHESTER CENTRAL SCH	CHICHESTER	12/7/2020	ND	ND	ND	ND
0453020-001	ROBINSONS MHP/UPPER	CHICHESTER	2/3/2021	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE #	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
0461010-002	CLAREMONT WATER DEPT	CLAREMONT	2/4/2020	ND	ND	ND	ND
0481010-503	COLEBROOK WATER WORKS	COLEBROOK	9/30/2021	ND	ND	ND	ND
0481010-504	COLEBROOK WATER WORKS	COLEBROOK	9/30/2021	ND	ND	ND	ND
0486010-501	KHEOPS INTERNATIONAL	COLEBROOK	3/22/2022	ND	ND	ND	ND
0493020-002	MOUNTAIN VIEW PARK ESTATES	COLUMBIA	8/30/1931	ND	ND	ND	ND
0501010-002	CONCORD WATER DEPT	CONCORD	4/16/2020	ND	ND	ND	ND
0501010-504	CONCORD WATER DEPT	CONCORD	4/16/2020	ND	ND	ND	ND
0501010-505	CONCORD WATER DEPT	CONCORD	8/12/2020	2.69	ND	ND	ND
0501010-506	CONCORD WATER DEPT	CONCORD	4/16/2020	ND	ND	ND	ND
0501010-507	CONCORD WATER DEPT	CONCORD	4/16/2020	ND	ND	ND	ND
0505010-002	SHAKER RD SCH	CONCORD	2/11/2021	ND	ND	ND	ND
0512190-001	BROOK VIEW VILLAGE	CONWAY	3/3/2021	2.83	2.24	3.38	ND
0512030-500	CATHEDRAL LEDGE	CONWAY	4/6/2021	ND	ND	ND	ND
0512200-503	CEDAR CREEK	CONWAY	3/10/2020	ND	ND	ND	ND
0515010-001	CONWAY COMMUNITY BLDG	CONWAY	9/20/2016	ND	ND	ND	ND
0516030-001	CONWAY MUNICIPAL CENTER	CONWAY	12/4/2020	ND	ND	ND	ND
0519020-002	CONWAY TOWN HALL	CONWAY	12/3/2020	ND	ND	ND	ND
0511010-501	CONWAY VILLAGE FIRE DIST	CONWAY	8/4/2020	ND	ND	ND	ND
0511010-502	CONWAY VILLAGE FIRE DIST	CONWAY	8/4/2020	ND	ND	ND	ND
0512260-502	DAVIS HILL	CONWAY	12/4/2020	ND	ND	ND	ND
0512150-501	DEERBROOK CONDOS	CONWAY	5/28/2021	6.05	3.42	ND	ND
0512050-000	ECHO LAKE WOODS	CONWAY	3/10/2020	ND	ND	ND	ND
0512060-501	FOREST EDGE	CONWAY	12/3/2020	ND	ND	ND	ND
0512070-001	FOREST PARK VILLAGE	CONWAY	3/12/2020	ND	ND	ND	ND
0512270-501	HALE ESTATES	CONWAY	10/24/2019	ND	ND	ND	ND
0515040-501	LITTLE HANDS BIG DREAMS	CONWAY	1/29/2021	ND	ND	ND	ND
0516040-001	LUPINE	CONWAY	10/23/2019	ND	ND	ND	ND
0512230-502	MELODY PINES CONDOS	CONWAY	3/17/2020	ND	ND	ND	ND
0513100-501	MOUNTAIN VALE VILLAGE MHP	CONWAY	5/24/2021	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE #	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
0512210-501	NEAR LEDGE	CONWAY	3/12/2020	ND	ND	ND	ND
0515020-001	NEW PINE TREE SCH	CONWAY	1/26/2021	ND	ND	ND	ND
0511030-503	NORTH CONWAY WATER PCT	CONWAY	3/18/2021	ND	ND	ND	ND
0511030-508	NORTH CONWAY WATER PCT	CONWAY	3/18/2021	ND	ND	ND	ND
0511030-509	NORTH CONWAY WATER PCT	CONWAY	3/18/2021	ND	ND	ND	ND
0511030-510	NORTH CONWAY WATER PCT	CONWAY	3/18/2021	ND	ND	ND	ND
0512110-502	NORTH PINES	CONWAY	9/27/2021	ND	ND	ND	ND
0516020-501	NORTHERN HUMAN SVCS	CONWAY	12/22/2020	ND	ND	ND	ND
0512170-501	OAKWOOD HEIGHTS	CONWAY	12/2/2020	ND	ND	ND	ND
0512080-501	REBECCA LANE WATER SYS	CONWAY	3/17/2020	ND	ND	ND	ND
0512240-506	ROCKHOUSE MOUNTAIN	CONWAY	3/18/2021	ND	ND	ND	ND
0512240-508	ROCKHOUSE MOUNTAIN	CONWAY	3/18/2021	ND	ND	ND	ND
0512180-503	SACO PINES	CONWAY	4/11/2022	ND	ND	ND	ND
0512120-501	SACO RIVER FOREST	CONWAY	3/3/2021	ND	ND	ND	ND
0512250-501	SACO WOODS CONDOS	CONWAY	3/12/2020	ND	ND	ND	ND
0512140-002	SOUTH PINES	CONWAY	3/17/2020	ND	ND	ND	ND
0512130-501	WOODLAND GROVE	CONWAY	3/10/2020	ND	ND	ND	ND
0525010-502	CORNISH ELEM SCH	CORNISH	10/7/2021	ND	ND	ND	ND
0545010-001	CROYDON VILLAGE SCH	CROYDON	12/18/2020	ND	ND	ND	ND
0578060-001	DANBURY COUNTRY STORE	DANBURY	12/8/2016	ND	ND	ND	ND
0575010-001	DANBURY ELEMENTARY SCH	DANBURY	12/30/2020	ND	ND	ND	ND
0582010-501	COLBY POND	DANVILLE	3/9/2021	ND	ND	ND	ND
0583030-506	COTTON FARMS MHP	DANVILLE	9/13/2021	3.17	ND	ND	ND
0583030-510	COTTON FARMS MHP	DANVILLE	2/15/2022	5.79	6.48	ND	2.24
0585010-502	DANVILLE ELEMENTARY	DANVILLE	7/6/2021	2.94	ND	ND	ND
0583020-005	IRON WHEEL MHP	DANVILLE	1/12/2022	15.9	11.4	ND	5.64
0583020-006	IRON WHEEL MHP	DANVILLE	1/12/2022	9.6	11.6	ND	7.54
0583020-501	IRON WHEEL MHP	DANVILLE	7/13/2021	2.97	ND	ND	ND
0583050-505	ROCK RIMMON COOPERATIVE	DANVILLE	4/14/2021	2.54	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE #	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA	Max PFOS	Max PFNA	Max PFHxS
				Detected (ng/L) MCL/AGQS = 12	Detected (ng/L) MCL/AGQS = 15	Detected (ng/L) MCL/AGQS = 11	Detected (ng/L) MCL/AGQS = 18
0583010-502	SPRUCE VALLEY MHP	DANVILLE	9/30/2021	2.72	2.18	ND	ND
0594010-003	CORNERSTONE PLACE	DEERFIELD	7/28/2021	3.16	2.41	ND	ND
0595020-501	DEERFIELD COMMUNITY SCH	DEERFIELD	12/5/2019	ND	ND	ND	ND
0595010-501	GEORGE B WHITE BLDG	DEERFIELD	8/11/2021	4.7	4.24	ND	ND
0594020-501	INN AT DEERFIELD	DEERFIELD	1/4/2021	ND	ND	ND	ND
0595040-001	LONGVIEW SCH	DEERFIELD	11/21/2019	ND	ND	ND	ND
0594030-001	SHERBURN WOODS	DEERFIELD	12/5/2020	0.7	ND	ND	ND
0596030-502	VAN BERKUM NURSERY	DEERFIELD	2/28/2022	4.8	2.77	ND	ND
0607030-503	HIS MANSION DIN HALL	DEERING	1/21/2021	ND	ND	ND	ND
0609010-501	HIS MANSION NEW BEGINNING	DEERING	1/21/2021	ND	ND	ND	ND
0603020-001	JOHNSON CITY MHP	DEERING	1/29/2020	ND	ND	ND	ND
0603010-502	LONGWOODS MHP	DEERING	7/16/2021	ND	ND	ND	ND
0605010-501	ROBIN HILL FARM/BLUE HOUSE	DEERING	9/8/2021	ND	ND	ND	ND
0613010-001	ANNIE OAKLEY	DERRY	9/25/2021	7.39	3.02	ND	ND
0612220-501	AUTUMN WOODS	DERRY	7/20/2021	4.25	ND	ND	ND
0612040-501	BARKLAND ACRES	DERRY	9/14/2021	13.4	7.26	ND	2.6
0616040-511	BROOKSTONE PARK/EAST	DERRY	3/15/2022	4.4	ND	ND	ND
0613060-513	CENTENNIAL ESTATES	DERRY	4/5/2022	14.4	ND	ND	ND
0618150-501	COWBELL CORNERS	DERRY	9/13/2021	3.98	ND	ND	ND
0612150-504	DREW WOODS	DERRY	7/15/2021	4.91	ND	ND	ND
0615060-501	E DERRY MEMORIAL ELEM SCH	DERRY	8/26/2021	3.28	8.41	ND	22.8
0612070-502	GLEN RIDGE DEV	DERRY	7/15/2021	5.21	ND	ND	ND
0612140-004	HI AND LO ESTATES	DERRY	7/7/2021	27.2	4.89	2.41	2.45
0612170-502	MAPLE HAVEN	DERRY	10/2/2019	1.9	ND	ND	ND
0612050-000	MORNINGSIDE DRIVE	DERRY	3/11/2022	16.5	4.25	ND	6.99
0612210-503	OLD COACH VILLAGE	DERRY	8/25/2020	6.81	5.45	ND	ND
0612110-501	PEU/FARMSTEAD ACRES	DERRY	10/2/2019	ND	ND	ND	ND
0612230-501	RAND SHEPARD HILL	DERRY	7/20/2021	6.94	2.09	ND	ND
0613030-501	RUNNING BROOK	DERRY	5/1/2021	6.86	2.16	3.77	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE #	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
0612240-501	WILLOW BEND	DERRY	12/26/2020	ND	ND	ND	ND
0612160-001	WOODLAND AT DERRY	DERRY	7/27/2016	ND	ND	ND	ND
0651010-003	DOVER WATER DEPT	DOVER	2/24/2022	2	ND	ND	ND
0651010-502	DOVER WATER DEPT	DOVER	2/24/2022	ND	ND	ND	ND
0651010-505	DOVER WATER DEPT	DOVER	2/24/2022	1.96	ND	ND	ND
0651010-515	DOVER WATER DEPT	DOVER	2/24/2022	ND	ND	ND	ND
0651010-517	DOVER WATER DEPT	DOVER	3/31/2022	6.13	2.71	ND	4.17
0651010-007	DOVER WATER DEPT - WELL NOT IN USE	DOVER	7/5/2018	106	173	50.7	ND
0651010-005	DOVER WATER DEPT - WELL NOT IN USE	DOVER	10/13/2016	82	160	35	6.2
0655030-501	MISS PATTYS CHILDCARE	DOVER	6/28/2021	ND	ND	ND	ND
0664010-502	DUBLIN CHRISTIAN ACADEMY	DUBLIN	12/1/2020	ND	ND	ND	ND
0664010-503	DUBLIN CHRISTIAN ACADEMY	DUBLIN	12/1/2020	ND	ND	ND	ND
0665010-501	DUBLIN CONSOLIDATED SCH	DUBLIN	10/25/2021	4.44	2.5	ND	ND
0664020-501	DUBLIN SCHOOL	DUBLIN	10/10/2019	2.19	ND	ND	ND
0666030-501	DUBLIN VILLAGE PARK	DUBLIN	7/20/2021	4.11	5.54	ND	ND
0665050-501	MOUNTAIN SHADOWS SCH	DUBLIN	9/23/2021	ND	ND	ND	ND
0665030-501	PHOENIX HOUSE DUBLIN CENTER	DUBLIN	8/19/2021	ND	ND	ND	ND
0666010-501	YANKEE PUBLISHING	DUBLIN	3/23/2022	ND	2.01	ND	ND
0685010-502	DUNBARTON ELEMENTARY SCH	DUNBARTON	12/27/2020	ND	ND	ND	ND
0694010-501	BROOKDALE SPRUCE WOOD	DURHAM	7/6/2021	2.42	ND	ND	ND
0692010-501	JOHNSON CREEK	DURHAM	11/25/2019	ND	ND	ND	ND
0692020-501	STAGECOACH FARMS	DURHAM	4/15/2021	ND	ND	ND	ND
0691010-002	UNH/DURHAM WATER SYS	DURHAM	5/25/2021	ND	ND	ND	ND
0691010-003	UNH/DURHAM WATER SYS	DURHAM	3/8/2021	ND	ND	ND	ND
0691010-005	UNH/DURHAM WATER SYS	DURHAM	3/8/2021	ND	ND	ND	ND
0691010-501	UNH/DURHAM WATER SYS	DURHAM	5/22/2020	2.02	ND	ND	ND
0691010-502	UNH/DURHAM WATER SYS	DURHAM	3/16/2021	1.95	ND	ND	ND
0702010-003	BARTON MHP	EAST KINGSTON	6/2/2021	ND	ND	ND	ND
0702020-003	BRANDYWINE	EAST KINGSTON	10/22/2019	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE #	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
0702020-501	BRANDYWINE	EAST KINGSTON	4/14/2021	ND	ND	ND	ND
0702040-504	COUNTRY HILLS OF EAST KINGSTON	EAST KINGSTON	2/21/2020	ND	ND	ND	ND
0705020-502	E KINGSTON ELEMENTARY SCH	EAST KINGSTON	5/18/2021	ND	ND	ND	ND
0705020-503	E KINGSTON ELEMENTARY SCH	EAST KINGSTON	1/24/2022	ND	ND	ND	ND
0702030-502	MAPLEVALE AND CRICKET HILL	EAST KINGSTON	7/14/2021	5.52	ND	ND	ND
0708040-501	POWWOW JUNCTION	EAST KINGSTON	9/14/2021	ND	ND	ND	ND
0732040-503	18 HUGHES LN	EFFINGHAM	2/10/2021	ND	ND	ND	ND
0735030-001	EFFINGHAM ELEMENTARY SCH	EFFINGHAM	12/14/2020	ND	ND	ND	ND
0732020-502	GREEN MOUNTAIN TREATMENT CTR	EFFINGHAM	2/4/2021	ND	ND	ND	ND
0732030-000	LOST VALLEY	EFFINGHAM	3/17/2020	ND	ND	ND	ND
0753020-502	DANIELS ACRES	ENFIELD	12/3/2019	ND	ND	ND	ND
0751010-002	ENFIELD WATER DEPT	ENFIELD	9/15/2020	ND	ND	ND	ND
0751010-003	ENFIELD WATER DEPT	ENFIELD	9/15/2020	ND	ND	ND	ND
0751010-005	ENFIELD WATER DEPT	ENFIELD	9/15/2020	ND	ND	ND	ND
0751010-504	ENFIELD WATER DEPT	ENFIELD	9/15/2020	ND	ND	ND	ND
0752020-001	LAKEVIEW CONDOS	ENFIELD	1/5/2021	ND	ND	ND	ND
0752020-002	LAKEVIEW CONDOS	ENFIELD	11/6/2019	ND	ND	ND	ND
0753030-501	LOWER SHAKER VILLAGE	ENFIELD	3/11/2020	ND	ND	ND	ND
0753010-001	WILSONS MHP	ENFIELD	3/27/2021	ND	ND	ND	ND
0761010-507	EPPING WATER AND SEWER DEPT	EPPING	1/21/2020	ND	ND	ND	ND
0761010-514	EPPING WATER AND SEWER DEPT	EPPING	1/21/2020	ND	ND	ND	ND
0763010-501	EVANS TRAILER PARK	EPPING	10/1/2019	ND	ND	ND	ND
0762050-502	GOVERNORS GREEN	EPPING	4/1/2020	ND	ND	ND	ND
0762040-501	MELLING GLEN	EPPING	4/1/2020	ND	ND	ND	ND
0762070-502	PLUMER COURT	EPPING	1/5/2021	ND	ND	ND	ND
0762080-501	VILLAGES ON THE LAMPREY	EPPING	4/14/2021	6.08	2.7	2.84	ND
0762120-502	WOODLANDS	EPPING	2/12/2020	ND	ND	ND	ND
0773020-002	COLBY BROOK ESTATES	EPSOM	8/3/2021	7.45	4.06	ND	ND
0773020-504	COLBY BROOK ESTATES	EPSOM	7/7/2021	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE #	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
0774010-001	EPSOM HEALTHCARE CTR	EPSOM	2/5/2021	ND	ND	ND	ND
0775020-511	EPSOM MED CTR	EPSOM	12/5/2020	ND	ND	ND	ND
0771010-501	EPSOM VILLAGE DIST	EPSOM	8/13/2021	6.22	2.07	ND	6.5
0771010-502	EPSOM VILLAGE DIST	EPSOM	8/13/2021	7.75	ND	nd	3.37
0771020-500	KINGS GRANT	EPSOM	6/1/2021	ND	ND	ND	ND
0773010-504	KINGS TOWNE MHP	EPSOM	11/16/2020	ND	ND	ND	ND
0775040-501	LEARNING TREE/46GAUTHIER	EPSOM	2/22/2022	ND	ND	ND	ND
0775030-501	LEARNING TREE/9GAUTHIER	EPSOM	2/22/2022	ND	ND	ND	ND
0774030-002	MEADOW BROOK	EPSOM	1/27/2021	ND	ND	ND	ND
0773030-504	SHELTERING PINES MHP	EPSOM	7/7/2021	2.85	ND	ND	ND
0781010-501	ERROL WATER WORKS	ERROL	3/9/2021	ND	ND	ND	ND
0803040-501	BEECH HILL PARK	EXETER	7/14/2021	3.86	6.24	ND	ND
0805010-501	BUILDING BLOCK COMMONS	EXETER	6/17/2021	2.12	ND	ND	ND
0805040-501	EXETER HIGH SCH	EXETER	3/17/2021	ND	ND	ND	ND
0802020-001	EXETER HIGHLANDS	EXETER	8/13/2021	ND	ND	ND	ND
0804020-001	EXETER HOSPITAL	EXETER	8/3/2016	4	8	24	3
0804010-001	EXETER HOSPITAL/SLEEP MED - WELL NOT IN USE	EXETER	8/3/2016	7	15	34	19
0803020-502	EXETER RIVER MOBILE HOME PARK	EXETER	7/14/2021	2.48	3.1	ND	ND
0805030-501	EXETER UNITED METHODIST CHURCH	EXETER	10/23/2019	ND	ND	ND	ND
0801010-002	EXETER WATER DEPT	EXETER	8/5/2020	2.35	1.13	ND	ND
0801010-003	EXETER WATER DEPT	EXETER	8/5/2020	5.13	4.37	2.01	ND
0801010-004	EXETER WATER DEPT	EXETER	8/5/2020	2.6	ND	ND	ND
0801010-507	EXETER WATER DEPT	EXETER	8/5/2020	ND	ND	ND	ND
0803050-501	ICEY HILL COOPERATIVE	EXETER	7/14/2021	3.44	3.23	ND	ND
0803030-501	LANDING AT EXETER RIVER	EXETER	7/14/2021	2.91	ND	ND	ND
0802030-000	LOUISBURG CIRCLE	EXETER	7/7/2021	4.8	2.25	ND	ND
0802040-501	PEU/FOREST RIDGE	EXETER	2/12/2020	ND	ND	ND	ND
0802010-001	PICKPOCKET WOODS	EXETER	9/7/2021	3.8	2.3	1.7	0.79
0811010-504	FARMINGTON WATER DEPT	FARMINGTON	3/5/2020	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE #	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
0811010-506	FARMINGTON WATER DEPT	FARMINGTON	3/5/2020	ND	ND	ND	ND
0823010-001	20 JAFFREY RD	FITZWILLIAM	7/20/2021	6.13	7.07	ND	ND
0821010-511	FITZWILLIAM VILLAGE/LAUGHNER	FITZWILLIAM	2/19/2021	ND	ND	ND	ND
0821010-512	FITZWILLIAM VILLAGE/LAUGHNER	FITZWILLIAM	2/18/2021	ND	ND	ND	ND
0821010-501	FITZWILLIAM VILLAGE/PRIGGE	FITZWILLIAM	7/20/2021	ND	ND	ND	ND
0825010-501	GEORGE S EMERSON ELEM SCH	FITZWILLIAM	9/9/2021	6.85	7.96	ND	ND
0827070-001	MEADOWOOD ASSEMBLY HALL	FITZWILLIAM	7/5/2016	ND	15	7	ND
0832010-501	CROTCHED MOUNTAIN MNTNC	FRANCESTOWN	10/30/2019	ND	ND	ND	ND
0835010-501	FRANCESTOWN ELEMENTARY SCH	FRANCESTOWN	10/30/2019	ND	ND	ND	ND
0831010-505	FRANCESTOWN VILLAGE WATER	FRANCESTOWN	3/3/2020	ND	ND	ND	ND
0841010-501	FRANCONIA VILLAGE WATER	FRANCONIA	3/3/2020	ND	ND	ND	ND
0841020-004	MITTERSILL WATER DEPT	FRANCONIA	3/3/2020	ND	ND	ND	ND
0841020-005	MITTERSILL WATER DEPT	FRANCONIA	3/3/2020	ND	ND	ND	ND
0851010-001	FRANKLIN WATER WORKS	FRANKLIN	6/7/2021	ND	ND	ND	ND
0851010-002	FRANKLIN WATER WORKS	FRANKLIN	6/7/2021	ND	ND	ND	ND
0851010-003	FRANKLIN WATER WORKS	FRANKLIN	6/7/2021	ND	ND	ND	ND
0851010-004	FRANKLIN WATER WORKS	FRANKLIN	6/7/2021	ND	ND	ND	ND
0862030-503	FREEDOM VILLAGE CONDOS	FREEDOM	3/16/2020	ND	ND	ND	ND
0861010-501	FREEDOM VILLAGE WATER PRECINCT	FREEDOM	3/10/2020	ND	ND	ND	ND
0862010-501	LOV WATER	FREEDOM	3/16/2020	ND	ND	ND	ND
0862020-501	PINE LANDING CONDOS	FREEDOM	9/14/2021	4.02	ND	ND	ND
0875040-001	BARNYARD BUDDIES	FREMONT	12/18/2020	ND	ND	ND	ND
0872020-501	BLACKROCKS VILLAGE	FREMONT	3/9/2021	ND	ND	ND	ND
0874020-501	COLONIAL POPLIN NURSING HOME	FREMONT	9/29/2021	10.8	11.7	ND	2.95
0876030-001	COOPERS CORNER/EAST	FREMONT	2/20/2020	ND	ND	ND	ND
0875030-501	COUNTRY CLUB FOR KIDS	FREMONT	7/27/2021	3.72	2.4	ND	ND
0875010-503	ELLIS SCHOOL - AFTER TREATMENT WAS INSTALLED	FREMONT	3/1/2022	ND	ND	ND	ND
0875010-502	ELLIS SCHOOL - BEFORE TREATMENT WAS INSTALLED	FREMONT	10/1/2019	15.5	15.8	15.8	34.9
0878020-001	FREMONT PIZZERIA RESTAURANT	FREMONT	2/9/2018	12	28	5	0.5



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE #	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
0872010-501	GOVERNORS FOREST	FREMONT	12/21/2020	ND	ND	ND	ND
0881010-503	ABENAKI WATER/GILFORD VILLAGE	GILFORD	1/18/2021	ND	ND	ND	ND
0888390-001	AIRPORT COUNTRY STORE	GILFORD	12/8/2016	ND	ND	ND	ND
0882100-511	BELKNAP HEIGHTS WATER	GILFORD	1/20/2021	ND	ND	ND	ND
0882050-001	BRAKE HILL ACRES	GILFORD	3/2/2020	ND	ND	ND	ND
0882050-002	BRAKE HILL ACRES	GILFORD	3/2/2020	ND	ND	ND	ND
0882220-101	BRETTON WOODS DEV	GILFORD	1/20/2021	ND	ND	ND	ND
0882130-503	BROADVIEW CONDOS	GILFORD	10/1/2019	ND	ND	ND	ND
0882180-502	BROOKSIDE CROSSING	GILFORD	12/5/2019	ND	ND	ND	ND
0882010-001	CHALET VILLAGE	GILFORD	10/11/2019	ND	ND	ND	ND
0882080-001	CHERRY VALLEY CONDOS	GILFORD	10/11/2019	ND	ND	ND	ND
0882170-001	COUNTRY VILLAGE WAY	GILFORD	12/5/2020	ND	ND	ND	ND
0882190-502	DOCKHAM SHORES ESTATES	GILFORD	3/2/2020	ND	ND	ND	ND
0883060-501	EDGE OF WOODS	GILFORD	10/22/2019	ND	ND	ND	ND
0885010-001	GILFORD ELEMENTARY SCH	GILFORD	12/29/2020	ND	ND	ND	ND
0882020-501	GILFORD FOREST ESTATES	GILFORD	2/12/2021	ND	ND	ND	ND
0882210-502	GILFORD MEADOWS	GILFORD	11/11/2019	ND	ND	ND	ND
0885020-003	GILFORD MIDDLE AND HIGH SCH	GILFORD	1/27/2021	ND	ND	ND	ND
0886150-501	GILFORD MUNICIPAL BLDG COMPLEX	GILFORD	3/24/2022	6.02	41.5	3.44	17.6
0885050-501	GILFORD PROFESSIONAL PARK	GILFORD	1/27/2021	ND	ND	ND	ND
0881010-003	GILFORD VILLAGE WATER DIST	GILFORD	11/16/2016	ND	ND	ND	ND
0881010-004	GILFORD VILLAGE WATER DIST	GILFORD	11/16/2016	ND	ND	ND	ND
0881010-005	GILFORD VILLAGE WATER DIST	GILFORD	11/16/2016	ND	ND	ND	ND
0881020-010	GUNSTOCK ACRES VILL DIST	GILFORD	7/22/2021	ND	ND	ND	ND
0881020-505	GUNSTOCK ACRES VILL DIST	GILFORD	7/22/2021	ND	ND	ND	ND
0887050-001	GUNSTOCK AREA	GILFORD	10/26/2021	ND	ND	ND	ND
0887050-002	GUNSTOCK AREA	GILFORD	10/26/2021	ND	ND	ND	ND
0882090-001	GUNSTOCK GLEN WATER	GILFORD	3/2/2020	ND	ND	ND	ND
0882410-501	HAMPSHIRE VILLAGE	GILFORD	1/20/2021	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE #	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
0882150-502	LAKE SHORE PARK	GILFORD	1/18/2021	ND	ND	ND	ND
0882040-002	LIBERTY HIGHLANDS WATER	GILFORD	1/20/2021	ND	ND	ND	ND
0883040-503	LRMHV	GILFORD	1/27/2021	ND	ND	ND	ND
0882140-003	MARINA BAY CONDOS I AND II	GILFORD	1/8/2021	ND	ND	ND	ND
0887150-001	MEADOWBROOK/CONFERENCE CENTER	GILFORD	12/8/2016	ND	ND	ND	ND
0883030-505	MOUNTAIN VIEW HOUSING	GILFORD	11/5/2019	ND	ND	ND	ND
0886190-501	NHDOS MARINE PATROL	GILFORD	3/17/2021	ND	ND	ND	ND
0883010-501	OLD LAKE SHORE	GILFORD	12/11/2020	ND	ND	ND	ND
0882160-500	SAMOSET AT WINNI	GILFORD	1/20/2021	ND	ND	ND	ND
0882420-501	STONEWALL VILLAGE	GILFORD	3/25/2021	ND	ND	ND	ND
0886040-001	UNDER HIS WING PRESCHOOL	GILFORD	1/27/2021	ND	ND	ND	ND
0886120-002	VILLAGE WEST I	GILFORD	3/25/2021	ND	ND	ND	ND
0886170-501	VILLAGE WEST II	GILFORD	11/15/2019	ND	ND	ND	ND
0882060-502	WINNSTOCK CONDOS	GILFORD	1/25/2021	ND	ND	ND	ND
0895010-502	GILMANTON ELEMENTARY SCH	GILMANTON	7/22/2021	3.13	ND	ND	ND
0905010-001	GILSUM ELEMENTARY SCH	GILSUM	12/29/2020	ND	ND	ND	ND
0906010-501	WS BADGER CO	GILSUM	4/19/2022	ND	ND	ND	ND
0912040-501	BRIAR COURT ESTATES	GOFFSTOWN	8/19/2021	ND	ND	ND	ND
0915010-504	GAGE FARM SCHOOLHOUSE	GOFFSTOWN	4/7/2022	ND	ND	ND	ND
0911010-004	GOFFSTOWN VILLAGE PCT	GOFFSTOWN	3/3/2020	ND	ND	ND	ND
0911010-501	GOFFSTOWN VILLAGE PCT	GOFFSTOWN	3/3/2020	ND	ND	ND	ND
0911010-502	GOFFSTOWN VILLAGE PCT	GOFFSTOWN	3/3/2020	ND	ND	ND	ND
0915020-501	LEARN AS WE PLAY CHLD CARE CTR	GOFFSTOWN	10/23/2019	ND	ND	ND	ND
0912050-502	MT LAUREL ESTATES	GOFFSTOWN	8/17/2021	11.1	ND	ND	ND
0912020-502	ORCHARD HIGHLANDS	GOFFSTOWN	10/23/2019	ND	ND	ND	ND
0926010-502	ANDRO RANGER STATION	GORHAM	7/21/2021	1.8	1.8	1.8	1.8
0921020-501	GORHAM HILL SPRING	GORHAM	1/24/2020	ND	ND	ND	ND
0921010-005	GORHAM WATER AND SEWER DEPT	GORHAM	1/24/2020	ND	ND	ND	ND
0921010-501	GORHAM WATER AND SEWER DEPT	GORHAM	1/24/2020	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE #	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
0956040-001	GRANTHAM GREENWAY	GRANTHAM	11/5/2019	ND	ND	ND	ND
0955010-001	GRANTHAM VILLAGE SCH	GRANTHAM	12/31/2020	ND	ND	ND	ND
0952020-001	GRAY LEDGES	GRANTHAM	4/8/2021	ND	ND	ND	ND
0951010-506	VILLAGE DIST OF EASTMAN	GRANTHAM	1/22/2020	ND	ND	ND	ND
0972010-010	CROTCHED MOUNTAIN REHAB CENTER	GREENFIELD	4/2/2021	ND	ND	ND	ND
0972010-011	CROTCHED MOUNTAIN REHAB CENTER	GREENFIELD	4/2/2021	ND	ND	ND	ND
0972010-512	CROTCHED MOUNTAIN REHAB CENTER	GREENFIELD	4/2/2021	ND	ND	ND	ND
0972010-517	CROTCHED MOUNTAIN REHAB CENTER	GREENFIELD	9/15/2021	ND	ND	ND	4.37
0974010-502	GREENFIELD COMMONS	GREENFIELD	4/22/2021	ND	ND	ND	ND
0975020-501	GREENFIELD ELEMENTARY SCH	GREENFIELD	12/4/2020	ND	ND	ND	ND
0987050-001	BREAKFAST HILL GOLF CLUB	GREENLAND	6/17/2021	15	2.68	ND	ND
0993030-501	FROST TRAILER PARK	GREENVILLE	2/18/2021	ND	ND	ND	ND
0991010-001	GREENVILLE WATER DEPT	GREENVILLE	2/1/2020	ND	ND	ND	ND
1021010-501	HALES LOCATION	HALES LOCATION	5/28/2021	2.43	ND	ND	ND
1035020-501	AGES AND STAGES HAMPSTEAD	HAMPSTEAD	7/22/2021	5.25	2.66	ND	2.09
1032070-001	COACH RUN CONDOS	HAMPSTEAD	9/17/2021	3.55	9.43	ND	13.1
1032090-501	GLENWOOD NORTH	HAMPSTEAD	12/3/2020	ND	ND	ND	ND
1035050-001	HAMPSTEAD ACADEMY	HAMPSTEAD	5/12/2021	3.81	2.88	ND	ND
1031010-007	HAMPSTEAD AREA WATER	HAMPSTEAD	7/19/2021	ND	ND	ND	ND
1031010-013	HAMPSTEAD AREA WATER	HAMPSTEAD	3/9/2021	ND	ND	ND	ND
1031010-020	HAMPSTEAD AREA WATER	HAMPSTEAD	7/19/2021	2.82	ND	ND	ND
1031010-502	HAMPSTEAD AREA WATER	HAMPSTEAD	7/19/2021	6.63	3.26	ND	ND
1031010-504	HAMPSTEAD AREA WATER	HAMPSTEAD	1/4/2022	ND	3.34	ND	ND
1031010-510	HAMPSTEAD AREA WATER	HAMPSTEAD	3/9/2021	ND	ND	ND	ND
1031010-512	HAMPSTEAD AREA WATER	HAMPSTEAD	7/19/2021	6.22	3.71	ND	ND
1031010-515	HAMPSTEAD AREA WATER	HAMPSTEAD	7/19/2021	4.31	ND	ND	ND
1031010-522	HAMPSTEAD AREA WATER	HAMPSTEAD	7/19/2021	4.59	2.69	ND	ND
1031010-523	HAMPSTEAD AREA WATER	HAMPSTEAD	7/19/2021	8.45	2.24	ND	2.47
1031010-524	HAMPSTEAD AREA WATER	HAMPSTEAD	11/11/2019	3.3	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE #	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA	Max PFOS	Max PFNA	Max PFHxS
				Detected (ng/L) MCL/AGQS = 12	Detected (ng/L) MCL/AGQS = 15	Detected (ng/L) MCL/AGQS = 11	Detected (ng/L) MCL/AGQS = 18
1031010-525	HAMPSTEAD AREA WATER	HAMPSTEAD	7/19/2021	2.18	ND	ND	ND
1031010-526	HAMPSTEAD AREA WATER	HAMPSTEAD	7/19/2021	5.5	ND	ND	ND
1031010-527	HAMPSTEAD AREA WATER	HAMPSTEAD	11/11/2019	ND	ND	ND	ND
1031010-528	HAMPSTEAD AREA WATER	HAMPSTEAD	3/9/2021	ND	ND	ND	ND
1031010-529	HAMPSTEAD AREA WATER	HAMPSTEAD	7/19/2021	5.75	2.19	ND	ND
1031010-530	HAMPSTEAD AREA WATER	HAMPSTEAD	7/19/2021	ND	ND	ND	ND
1034010-501	HAMPSTEAD HOSPITAL	HAMPSTEAD	9/17/2021	2.21	ND	ND	3.05
1035040-501	HAMPSTEAD MIDDLE SCH - PFAS TREATMENT INSTALLED	HAMPSTEAD	1/19/2022	ND	ND	ND	ND
1036010-501	HAMPSTEAD SHOPPERS VILLAGE	HAMPSTEAD	9/23/2021	6.07	10.2	ND	ND
1035110-601	HAZEL DRIVE KIDS	HAMPSTEAD	9/24/2021	ND	ND	ND	ND
1036080-001	RAM PRINTING	HAMPSTEAD	1/14/2021	2.15	2.62	ND	ND
1036040-001	STAGE ROAD JUNCTION	HAMPSTEAD	3/17/2021	ND	ND	ND	ND
1036090-002	THUNDERLINE Z	HAMPSTEAD	10/15/2021	3.98	4.18	ND	ND
1051010-504	AQUARION WATER/NH	HAMPTON	4/14/2021	3.71	2.28	ND	ND
1051010-508	AQUARION WATER/NH	HAMPTON	7/13/2020	2.48	ND	ND	ND
1051010-511	AQUARION WATER/NH	HAMPTON	11/20/2020	ND	ND	ND	ND
1051010-521	AQUARION WATER/NH	HAMPTON	1/11/2021	2.34	ND	ND	ND
1051010-529	AQUARION WATER/NH	HAMPTON	1/11/2021	3.08	3.22	ND	ND
1051010-531	AQUARION WATER/NH	HAMPTON	7/13/2020	2.24	ND	ND	ND
1051010-536	AQUARION WATER/NH	HAMPTON	4/4/2022	2.85	2.2	ND	ND
1053010-002	FOUR SEASONS MOBILE HOME PARK	HAMPTON	1/15/2020	ND	ND	ND	ND
1053020-504	HEMLOCK HAVEN	HAMPTON	1/15/2020	ND	ND	ND	ND
1053030-502	TAYLOR RIVER ESTATES	HAMPTON	7/6/2021	4.54	5.09	ND	ND
1048120-002	153 LAFAYETTE RD WATER SYSTEM	HAMPTON FALLS	3/22/2018	23	22	8	2
1046050-502	CRN REALTY	HAMPTON FALLS	11/25/2019	ND	ND	ND	ND
1045040-501	HERONFIELD ACADEMY	HAMPTON FALLS	11/18/2019	ND	ND	ND	ND
1045010-001	LINCOLN AKERMAN SCH	HAMPTON FALLS	3/17/2021	2.13	2.24	ND	ND
1045010-501	LINCOLN AKERMAN SCH	HAMPTON FALLS	9/27/2021	ND	ND	ND	ND
1042010-501	MEADOWS AT GRAPEVINE RUN	HAMPTON FALLS	1/13/2021	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE #	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
1061010-501	HANCOCK WATER WORKS	HANCOCK	2/11/2020	ND	ND	ND	ND
1075010-001	HAMPSHIRE COOP NURSERY SCH	HANOVER	12/18/2020	ND	ND	ND	ND
1071010-511	HANOVER WATER DEPT	HANOVER	1/8/2020	ND	ND	ND	ND
1075020-501	MONTESORI CHILDRENS SCH	HANOVER	3/17/2020	ND	ND	ND	ND
1085020-502	CHESHIRE MILLS BOARDING HOUSE	HARRISVILLE	7/27/2021	3.65	6.1	ND	ND
1086010-502	HISTORIC HARRISVILLE	HARRISVILLE	9/27/2021	5.79	18.6	ND	ND
1085010-001	WELLS MEMORIAL SCH	HARRISVILLE	3/12/2021	ND	ND	ND	ND
1097020-002	CNSP DRY RIVER CAMPGROUND	HARTS LOCATION	9/19/2016	ND	ND	ND	ND
1105020-001	BECKET HOUSE AT HALL FARM	HAVERHILL	9/8/2021	ND	ND	ND	ND
1102020-001	FRENCH POND ESTATES	HAVERHILL	2/25/2020	ND	ND	ND	ND
1101050-001	MOUNTAIN LAKES WATER DEPT	HAVERHILL	9/14/2021	ND	ND	ND	ND
1101050-004	MOUNTAIN LAKES WATER DEPT	HAVERHILL	9/14/2021	ND	ND	ND	ND
1101020-501	NO HAVERHILL WATER AND LIGHT	HAVERHILL	2/25/2020	ND	ND	ND	ND
1105010-511	OLIVERIAN EAST CAMPUS	HAVERHILL	9/8/2021	ND	ND	ND	ND
1107030-001	OLIVERIAN SCH	HAVERHILL	9/8/2021	ND	ND	ND	ND
1101010-501	PRECINCT OF HAVERHILL CORNER	HAVERHILL	11/26/2019	ND	ND	ND	ND
1101040-002	WOODSVILLE WATER AND LIGHT	HAVERHILL	2/25/2020	ND	ND	ND	ND
1113010-503	HILLSIDE INN CONDOS	HEBRON	2/12/2020	ND	ND	ND	ND
1113010-504	HILLSIDE INN CONDOS	HEBRON	2/12/2020	ND	ND	ND	ND
1112010-002	STONEGATE ACRES	HEBRON	2/26/2021	ND	ND	ND	ND
1121010-004	COGSWELL SPRINGS WATER WORKS	HENNIKER	3/18/2021	ND	ND	ND	ND
1121010-005	COGSWELL SPRINGS WATER WORKS	HENNIKER	3/18/2021	ND	ND	ND	ND
1126030-001	HHP	HENNIKER	8/13/2021	ND	ND	ND	ND
1127030-503	PATS PEAK	HENNIKER	3/9/2021	ND	ND	ND	ND
1123020-503	WOOD HILL VILLAGE	HENNIKER	2/3/2021	ND	ND	ND	ND
1123020-504	WOOD HILL VILLAGE	HENNIKER	2/3/2021	ND	ND	ND	ND
1131010-001	HILL WATER WORKS	HILL	9/15/2016	ND	ND	ND	ND
1131010-002	HILL WATER WORKS	HILL	1/27/2021	ND	ND	ND	ND
1141020-001	EMERALD LAKE	HILLSBOROUGH	3/27/2020	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE #	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
1141020-506	EMERALD LAKE	HILLSBOROUGH	3/27/2020	ND	ND	ND	ND
1141020-512	EMERALD LAKE	HILLSBOROUGH	3/27/2020	ND	ND	ND	ND
1145020-001	HILLSBORO BAPTIST CH	HILLSBOROUGH	3/15/2021	ND	ND	ND	ND
1141010-002	HILLSBOROUGH WATER WORKS	HILLSBOROUGH	1/14/2020	ND	ND	ND	ND
1145010-501	ROSEWALD FARM	HILLSBOROUGH	10/22/2019	ND	ND	ND	ND
1156010-001	GEORGES FIELD WATER SYSTEM	HINSDALE	3/9/2020	ND	ND	ND	ND
1151020-501	HINSDALE WATER DEPT/DOWNTOWN	HINSDALE	2/18/2021	ND	ND	ND	ND
1151010-503	NORTH HINSDALE WATER DEPT	HINSDALE	2/18/2021	ND	ND	ND	ND
1151010-506	NORTH HINSDALE WATER DEPT	HINSDALE	2/19/2021	ND	ND	ND	ND
1162010-500	HIGHLAND COLONY	HOLDERNESS	1/8/2020	ND	ND	ND	ND
1165020-501	HOLDERNESS CENTRAL SCH	HOLDERNESS	2/11/2020	ND	ND	ND	ND
1167190-001	SLNSC BLUE HERON SCH	HOLDERNESS	2/11/2020	ND	ND	ND	ND
1163010-001	TOWN LINE VILLAGE	HOLDERNESS	12/8/2020	ND	ND	ND	ND
1163010-503	TOWN LINE VILLAGE	HOLDERNESS	12/8/2020	ND	ND	ND	ND
1165010-501	WHITE MTN MONT SCH	HOLDERNESS	1/20/2021	ND	ND	ND	ND
1176100-001	18 CLINTON DR BLDG	HOLLIS	5/19/2021	3.05	ND	ND	ND
1176020-501	26 CLINTON DRIVE BLDG	HOLLIS	1/22/2020	ND	ND	ND	ND
1176060-501	DIAMOND CASTING MACHINE	HOLLIS	4/6/2021	ND	ND	ND	ND
1176090-501	FARM DESIGN	HOLLIS	9/14/2021	3.15	ND	ND	ND
1175050-503	HOLLIS BROOKLINE HS	HOLLIS	5/18/2021	2.62	ND	ND	ND
1176030-001	HOLLIS LINE MACHINE	HOLLIS	11/18/2019	ND	ND	ND	ND
1175060-001	HOLLIS MONT SCH	HOLLIS	9/22/2021	6.57	5.19	ND	ND
1175030-501	HOLLIS SCH DIST	HOLLIS	11/18/2019	ND	ND	ND	ND
1176010-502	HOLLIS VILLAGE MARKET PLACE	HOLLIS	7/21/2021	2.82	ND	ND	ND
1173010-501	PITARYS MOBILE HOME PARK/EAST	HOLLIS	2/16/2022	12.5	7.35	ND	2.32
1173020-503	PITARYS MOBILE HOME PARK/WEST	HOLLIS	2/16/2022	12.2	3.34	ND	ND
1176080-501	PURITAN PRESS	HOLLIS	8/16/2021	8.36	3.26	ND	ND
1172020-503	RUNNELLS LANDING	HOLLIS	8/16/2021	4.42	ND	ND	ND
1172030-501	SILVER LAKE ESTATES	HOLLIS	11/18/2019	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE #	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
1176070-001	ULTRASOURCE	HOLLIS	2/25/2020	ND	ND	ND	ND
1186010-002	198 LONDONDERRY TURNPIKE	HOOKSETT	9/27/2021	2.65	ND	ND	ND
1181020-503	HOOKSETT VILLAGE WATER PCT	HOOKSETT	1/6/2020	ND	ND	ND	ND
1181020-504	HOOKSETT VILLAGE WATER PCT	HOOKSETT	1/6/2020	ND	ND	ND	ND
1181020-506	HOOKSETT VILLAGE WATER PCT	HOOKSETT	1/6/2020	ND	ND	ND	ND
1181020-507	HOOKSETT VILLAGE WATER PCT	HOOKSETT	1/6/2020	ND	ND	ND	ND
1189030-501	NHDOT BURUAU TURNPIKE	HOOKSETT	4/2/2021	ND	ND	ND	ND
1185010-501	PLACES YOU'LL GROW	HOOKSETT	9/21/2021	5.35	ND	ND	ND
1195040-001	BEECH HILL SCH	HOPKINTON	2/11/2021	ND	ND	ND	ND
1191010-501	CONTOOCOOK VILLAGE PCT	HOPKINTON	2/24/2020	ND	ND	ND	ND
1193030-000	DEER MEADOWS	HOPKINTON	1/29/2020	ND	ND	ND	ND
1192010-001	E PENACOOK RD WATER SYS	HOPKINTON	4/23/2018	19.8	13.4	ND	ND
1193020-503	ELM BROOK VILLAGE	HOPKINTON	4/11/2022	ND	ND	ND	ND
1191020-001	HOPKINTON VILLAGE PCT	HOPKINTON	2/19/2017	ND	ND	ND	ND
1191020-002	HOPKINTON VILLAGE PCT	HOPKINTON	2/19/2017	1	ND	1.8	ND
1191020-003	HOPKINTON VILLAGE PCT	HOPKINTON	3/10/2021	ND	ND	ND	ND
1191020-502	HOPKINTON VILLAGE PCT	HOPKINTON	3/10/2021	ND	ND	ND	ND
1196030-001	MCLANE NORTHEAST	HOPKINTON	2/3/2021	ND	ND	ND	ND
1193010-501	MEADOWS THE	HOPKINTON	1/29/2020	ND	ND	ND	ND
1196050-502	YANKEE BOOK PEDDLER	HOPKINTON	2/3/2021	ND	ND	ND	ND
1205070-501	EARLY START LEARNING ACAD	HUDSON	9/9/2021	ND	ND	ND	ND
1202010-503	FRANCOEUR APT/HUDSON MOTOR INN	HUDSON	8/3/2021	2.95	ND	ND	ND
1203010-522	HUDSON MOBILE HOME ESTS	HUDSON	7/12/2021	4.92	ND	ND	ND
1201010-008	HUDSON WATER DEPT	HUDSON	12/11/2020	23.1	ND	2.98	ND
1201010-501	HUDSON WATER DEPT	HUDSON	4/4/2022	7.8	ND	ND	ND
1201010-502	HUDSON WATER DEPT	HUDSON	6/1/2021	13.6	ND	ND	ND
1205060-001	KIDDIE KONNECTION	HUDSON	3/9/2021	15.4	14.4	ND	2.69
1212080-512	BLACK MOUNTAIN MEADOW CONDOS	JACKSON	3/9/2020	ND	ND	ND	ND
1218010-001	DANA PLACE	JACKSON	9/22/2021	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE #	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
1212130-501	EAGLE BROOK	JACKSON	2/11/2020	ND	ND	ND	ND
1212110-502	EAGLE MOUNTAIN HOUSE	JACKSON	4/11/2022	5.53	21	ND	8.01
1212060-002	ELLIS RIVER VILLAGE	JACKSON	8/23/2016	ND	ND	ND	ND
1212090-501	HIGH PASTURES AT BLACK MTN	JACKSON	3/12/2020	ND	ND	ND	ND
1211010-501	JACKSON WATER PCT	JACKSON	2/11/2020	ND	ND	ND	ND
1212050-511	MT JEFFERSON/WASHINGTON CONDOS	JACKSON	2/11/2020	ND	ND	ND	ND
1212140-001	TYROL WELL A	JACKSON	3/18/2020	ND	ND	ND	ND
1212030-501	WILDCAT TOWNHOUSE RESORT	JACKSON	9/22/2021	ND	ND	ND	ND
1221010-502	JAFFREY WATER WORKS	JAFFREY	12/1/2020	ND	ND	ND	ND
1221010-505	JAFFREY WATER WORKS	JAFFREY	8/9/2021	2.93	13.9	ND	4.13
1221010-506	JAFFREY WATER WORKS	JAFFREY	12/1/2020	ND	ND	ND	ND
1221010-511	JAFFREY WATER WORKS	JAFFREY	2/9/2022	2.69	2.39	ND	10.7
1241010-005	KEENE WATER DEPT	KEENE	1/29/2020	ND	ND	ND	ND
1241010-006	KEENE WATER DEPT	KEENE	1/29/2020	ND	ND	ND	ND
1241010-501	KEENE WATER DEPT	KEENE	1/29/2020	ND	ND	ND	ND
1241010-502	KEENE WATER DEPT	KEENE	1/29/2020	ND	ND	ND	ND
1241010-503	KEENE WATER DEPT	KEENE	1/29/2020	ND	ND	ND	ND
1241010-504	KEENE WATER DEPT	KEENE	1/21/2021	ND	ND	ND	ND
1245010-001	MONADNOCK WALDORF SCH	KEENE	12/10/2020	ND	ND	ND	ND
1255010-502	KENSINGTON ELEMENTARY SCH	KENSINGTON	11/27/2020	ND	ND	ND	ND
1256010-003	UNITIL ENERGY SYS	KENSINGTON	4/14/2020	15.7	16.2	3.16	2.66
1256010-503	UNITIL ENERGY SYS	KENSINGTON	4/14/2020	9.25	7.18	ND	ND
1276020-501	266 ROUTE 125	KINGSTON	10/16/2019	ND	ND	ND	ND
1272080-501	ALL AMERICAN AL	KINGSTON	1/13/2021	ND	ND	ND	ND
1272020-501	ANNS LANDING	KINGSTON	10/25/2019	ND	ND	ND	ND
1278060-501	CARRIAGE TOWN PLAZA	KINGSTON	8/13/2021	5.28	ND	ND	13.8
1272050-501	COOPERS GROVE	KINGSTON	3/8/2021	ND	ND	ND	ND
1277090-001	COUNTRY SHORE CAMPGROUND	KINGSTON	7/1/2019	20.8	ND	ND	ND
1277090-002	COUNTRY SHORE CAMPGROUND	KINGSTON	8/27/2019	22	2.39	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE #	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
1275010-501	DANIEL J BAKIE SCH	KINGSTON	9/28/2021	ND	ND	ND	ND
1272070-502	KINGS LANDING	KINGSTON	3/9/2021	ND	ND	ND	ND
1279010-511	KINGSTON CHILDREN CENTER	KINGSTON	12/18/2020	ND	ND	ND	ND
1272010-501	KINGSTON PINES ELDERLY HOUSING	KINGSTON	10/1/2019	ND	ND	ND	ND
1279040-001	KINGSTON TOWN HALL	KINGSTON	1/4/2017	ND	ND	ND	ND
1272030-501	LAMPLIGHTER ESTATES	KINGSTON	3/9/2021	ND	ND	ND	ND
1272040-500	ROWELL ESTATES	KINGSTON	4/14/2021	2.91	ND	ND	ND
1275060-501	SANBORN REGIONAL HIGH SCH	KINGSTON	9/16/2021	4.1	ND	ND	ND
1272060-501	VILLAGE AT GRAN FIELDS	KINGSTON	5/17/2021	ND	ND	ND	ND
1285010-502	LACONIA CHRISTIAN SCH	LACONIA	9/13/2021	3.47	ND	ND	ND
1281010-001	LACONIA WATER WORKS	LACONIA	3/9/2021	ND	ND	ND	ND
1282010-501	MOUNTAIN VIEW APTS	LACONIA	4/6/2021	ND	ND	ND	ND
1282030-001	PENDLETON COVE	LACONIA	3/2/2020	ND	ND	ND	ND
1289010-002	PRESCOTT FARM ENVIRON ED CTR	LACONIA	3/5/2020	ND	ND	ND	ND
1282020-001	WENTWORTH COVE ESTATES	LACONIA	3/2/2020	ND	ND	ND	ND
1282050-500	WINDEMERE RIDGE	LACONIA	9/13/2021	ND	ND	ND	ND
1296010-001	EASTER SEALS YOUTH RES	LANCASTER	3/9/2021	ND	ND	ND	ND
1291010-002	LANCASTER WATER DEPT	LANCASTER	3/31/2021	ND	ND	ND	ND
1305020-501	LANDAFF BLUE SCH	LANDAFF	12/29/2021	ND	ND	ND	ND
1315010-002	FALL MOUNTAIN REGIONAL HS	LANGDON	7/15/2020	ND	ND	ND	ND
1315020-002	SARAH PORTER SCH	LANGDON	7/15/2020	ND	ND	ND	ND
1323040-002	CURRIERS MHP	LEBANON	11/5/2019	ND	ND	ND	ND
1321010-002	LEBANON WATER DEPT	LEBANON	1/22/2020	ND	ND	ND	ND
1323020-001	MASCOMA MEADOWS	LEBANON	11/5/2019	ND	ND	ND	ND
1323050-001	OLYMPIC MOBILE HOME VILL/LOWER	LEBANON	11/5/2019	ND	ND	ND	ND
1323030-002	OLYMPIC MOBILE HOME VILL/UPPER	LEBANON	11/5/2019	ND	ND	ND	ND
1336030-001	BENUCK AND RAINEY	LEE	11/21/2020	ND	ND	ND	ND
1332040-001	CEDAR WOOD ESTATES	LEE	2/19/2021	ND	ND	ND	ND
1332020-502	DARBY FIELD COMMONS	LEE	4/22/2021	4.25	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE #	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
1333030-501	EVERGREEN TERRACE	LEE	3/15/2021	ND	ND	ND	ND
1332030-501	GREYSTONE COMMONS	LEE	3/25/2020	ND	ND	ND	ND
1335030-002	GROWING PLACES	LEE	2/3/2021	ND	ND	ND	ND
1333010-501	HILL ACRES TRAILER PARK	LEE	4/1/2021	ND	ND	ND	ND
1334010-501	KIRKWOOD CORNERS SENIOR LIVING	LEE	11/25/2019	ND	ND	ND	ND
1339010-501	LEE CONGREGATIONAL CH	LEE	2/3/2021	ND	ND	ND	ND
1336020-001	LEE MARKETPLACE	LEE	9/30/2021	ND	ND	ND	ND
1336020-002	LEE MARKETPLACE	LEE	9/30/2021	ND	ND	ND	ND
1336020-003	LEE MARKETPLACE	LEE	9/30/2021	ND	ND	ND	ND
1335020-001	LIVE AND LEARN DAY CARE	LEE	8/31/2021	6.06	9.16	ND	ND
1335010-501	MAST WAY ELEMENTARY SCH	LEE	11/25/2019	ND	ND	ND	ND
1332010-001	OYSTER RIVER CONDOS	LEE	1/27/2021	ND	ND	ND	ND
1333060-501	PACKERS FALLS VILLAGE	LEE	4/21/2021	ND	ND	ND	ND
1332050-501	PEU/THURSTON WOODS	LEE	2/12/2020	ND	ND	ND	ND
1333020-000	PINE KNOLL VILLAGE	LEE	4/29/2021	5.49	ND	ND	ND
1339030-001	WENTWORTH DOUGLASS MED OFFICE	LEE	8/26/2021	12.4	ND	ND	ND
1339030-501	WENTWORTH DOUGLASS MED OFFICE	LEE	2/17/2022	ND	ND	ND	ND
1345010-503	LEMPSTER COMMUNITY SCH	LEMPSTER	7/14/2021	10.2	ND	ND	ND
1351010-004	LINCOLN WATER WORKS	LINCOLN	2/4/2020	ND	ND	ND	ND
1351010-005	LINCOLN WATER WORKS	LINCOLN	2/4/2020	ND	ND	ND	ND
1351010-506	LINCOLN WATER WORKS	LINCOLN	2/4/2020	ND	ND	ND	ND
1361010-502	LISBON WATER DEPT	LISBON	2/4/2020	ND	ND	ND	ND
1361010-503	LISBON WATER DEPT	LISBON	2/4/2020	ND	ND	ND	ND
1378010-001	CROFTERS PUB - WELL NOT IN USE	LITCHFIELD	5/6/2016	110	ND	ND	ND
1372020-001	LITCHFIELD APARTMENTS - WELL NOT IN USE	LITCHFIELD	3/13/2016	87	ND	ND	ND
1378030-001	LITCHFIELD PLAZA - WELL NOT IN USE	LITCHFIELD	4/15/2016	92	ND	ND	ND
1376010-001	LITCHFIELD TECHNOLOGY PARK - WELL NOT IN USE	LITCHFIELD	3/9/2016	34	ND	ND	ND
1378070-001	LOBSTER BOAT PLZ	LITCHFIELD	8/25/2021	ND	ND	ND	ND
1377020-001	MELS FUNWAY PARK - WELL NOT IN USE	LITCHFIELD	3/9/2016	57	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE #	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA	Max PFOS	Max PFNA	Max PFHxS
				Detected (ng/L) MCL/AGQS = 12	Detected (ng/L) MCL/AGQS = 15	Detected (ng/L) MCL/AGQS = 11	Detected (ng/L) MCL/AGQS = 18
1378060-001	NATICOOK GRILL - WELL NOT IN USE	LITCHFIELD	4/21/2016	61	ND	ND	ND
1378050-001	ROMANOS PIZZA - WELL NOT IN USE	LITCHFIELD	4/26/2016	23	ND	ND	ND
1379010-502	TABERNACLE CHRISTIION CH	LITCHFIELD	4/29/2021	ND	ND	ND	ND
1381010-002	LITTLETON WATER AND LIGHT DEPT	LITTLETON	9/8/2020	ND	ND	ND	ND
1381010-501	LITTLETON WATER AND LIGHT DEPT	LITTLETON	8/19/2020	ND	ND	ND	ND
1386010-501	PEAK THREE	LITTLETON	4/2/2021	ND	ND	ND	ND
1395110-501	28 BUTTRICK RD PROPERTY	LONDONDERRY	3/5/2020	ND	ND	ND	ND
1395090-501	ARK LEARNG CENTER	LONDONDERRY	4/20/2021	2.32	ND	ND	ND
1395090-502	ARK LEARNG CENTER	LONDONDERRY	4/6/2022	5.68	2.78	ND	ND
1392320-001	BITIM APARTMENTS	LONDONDERRY	4/5/2022	5.86	ND	ND	ND
1392050-501	BOUMIL GROVE CONDOS	LONDONDERRY	12/21/2021	4.21	ND	ND	ND
1392180-502	CENTURY VILLAGE CONDOS	LONDONDERRY	4/7/2022	19.8	8.88	ND	2.02
1396060-501	HOLTON	LONDONDERRY	2/24/2022	11.4	2.21	ND	2.25
1392070-501	MIDRIDGE CONDOS	LONDONDERRY	2/7/2022	14	3.71	ND	2.98
1392010-500	OAKRIDGE CONDOS	LONDONDERRY	7/21/2021	6.4	3.22	ND	ND
1392030-512	OLDE COUNTRY VILLAGE	LONDONDERRY	4/20/2022	24	6.51	ND	3.2
1392290-501	PEU/HARVEST VILLAGE	LONDONDERRY	4/13/2022	ND	ND	ND	ND
1392310-501	PEU/MINISTERIAL/PARRISH HILLS	LONDONDERRY	7/8/2021	4.14	ND	ND	ND
1392040-501	PEU/PINEHAVEN WATER TRUST	LONDONDERRY	7/8/2021	5.56	2.5	ND	ND
1393060-502	PONDEROSA MHP	LONDONDERRY	9/6/2021	4.08	ND	ND	ND
1396110-501	REEDS FERRY SMALL BLDG	LONDONDERRY	7/23/2021	20.4	ND	ND	ND
1392200-001	ROLLING MEADOWS CONDOS I	LONDONDERRY	2/23/2022	27.6	9.74	ND	4.54
1392220-501	ROLLING MEADOWS CONDOS III	LONDONDERRY	2/23/2022	17.6	9.25	ND	5.63
1392230-001	ROLLING MEADOWS CONDOS IV	LONDONDERRY	2/23/2022	26.9	7.84	ND	2.82
1392300-501	SOUTHVIEW CONDOS	LONDONDERRY	4/21/2022	7.56	2.57	ND	ND
1392130-512	STONEHENGE APARTMENTS	LONDONDERRY	1/11/2021	24.4	ND	ND	ND
1696070-003	TOWNE SQUARE PROF CONDOS	LONDONDERRY	7/29/2021	7.92	ND	ND	ND
1395140-501	VICTORY BAPTIST SCH	LONDONDERRY	3/25/2022	2.21	ND	ND	ND
1393050-512	WAGON WHEEL	LONDONDERRY	2/28/2022	15.9	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE #	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
1402010-001	FLINTLOCK APTS	LOUDON	1/29/2020	ND	ND	ND	ND
1403030-001	FREEDOM HILL/PINE RIDGE	LOUDON	1/13/2021	ND	ND	ND	ND
1403010-501	KOS MANUFACTURED HOUSING CMNTY	LOUDON	1/8/2021	ND	ND	ND	ND
1405010-002	LOUDON ELEMENTARY SCH	LOUDON	11/14/2019	ND	ND	ND	ND
1407020-001	NH MOTOR SPEEDWAY	LOUDON	9/29/2020	ND	4.18	ND	ND
1407060-001	NH MOTOR SPEEDWAY/MAIN OFFICE	LOUDON	6/24/2020	ND	ND	ND	ND
1403040-001	PRESIDENTIAL PINES/LOWER	LOUDON	4/16/2021	3.11	4.4	ND	ND
1403020-501	PRESIDENTIAL PINES/UPPER	LOUDON	11/14/2019	ND	ND	ND	ND
1402020-501	VILLAGES AT LOUDON	LOUDON	1/20/2021	ND	ND	ND	ND
1402030-001	VOA/NNE SENIOR HOUSING	LOUDON	10/29/2019	ND	ND	ND	ND
1435030-501	CROSSROADS ACADEMY	LYME	3/1/2021	ND	ND	ND	ND
1435040-001	CROSSROADS ACADEMY/NORTH	LYME	3/17/2020	ND	ND	ND	ND
1435050-001	LYME NURSERY SCHL	LYME	3/1/2021	ND	2.3	ND	ND
1431010-001	LYME WATER	LYME	1/5/2021	ND	ND	ND	ND
1431010-003	LYME WATER	LYME	1/5/2021	ND	ND	ND	ND
1431010-004	LYME WATER	LYME	1/5/2021	ND	ND	ND	ND
1436020-501	PATHWAYS ORFORD ROAD RESIDENCE	LYME	10/22/2019	ND	ND	ND	ND
1432010-001	POND VIEW APTS	LYME	2/3/2021	ND	ND	ND	ND
1445010-001	LYNDEBOROUGH CENTRAL SCH	LYNDEBOROUGH	3/24/2022	6.44	7.58	ND	6.3
1456030-501	CARRIAGE HILL AL	MADBURY	2/3/2021	ND	ND	ND	ND
1458010-002	LITTLE TREE ED CTR	MADBURY	3/31/2021	ND	ND	ND	ND
1456020-501	MADBURY WOODS APARTMENTS	MADBURY	10/1/2019	ND	ND	ND	ND
1455010-501	MOHARIMET SCH	MADBURY	12/28/2020	ND	ND	ND	ND
1463010-001	BROOKWOOD PARK	MADISON	7/15/2021	2.08	ND	ND	ND
1466050-002	MACLEAN PRECISION MACHINE	MADISON	3/23/2022	7.3	28.5	2.51	68.6
1466050-601	MACLEAN PRECISION MACHINE	MADISON	3/15/2022	ND	ND	ND	ND
1465010-002	MADISON ELEMENTARY SCH	MADISON	1/27/2021	ND	ND	ND	ND
1466020-000	MADISON LUMBER MILL	MADISON	10/3/2019	ND	ND	ND	ND
1462040-501	SILVER LAKE LANDING SR HOUSING	MADISON	3/10/2020	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE #	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
1461010-011	VILLAGE DISTRICT OF EIDELWEISS	MADISON	2/23/2021	ND	ND	ND	ND
1461010-510	VILLAGE DISTRICT OF EIDELWEISS	MADISON	1/25/2021	ND	ND	ND	ND
1471010-001	MANCHESTER WATER WORKS	MANCHESTER	10/14/2021	5.17	ND	ND	ND
1471010-003	MANCHESTER WATER WORKS	MANCHESTER	1/12/2022	4.6	ND	ND	ND
1472030-501	ROCKWOOD TERRACE CONDOS	MANCHESTER	4/15/2021	10.9	2.28	ND	ND
1482010-501	MARLBOROUGH ESTATES	MARLBOROUGH	10/29/2019	ND	ND	ND	ND
1481010-001	MARLBOROUGH WATER WORKS	MARLBOROUGH	3/16/2021	ND	ND	ND	ND
1481010-504	MARLBOROUGH WATER WORKS	MARLBOROUGH	3/16/2021	ND	ND	ND	ND
1495010-001	JOHN D PERKINS SR ELEM SCH - NO TREATMENT INSTALLED	MARLOW	12/29/2020	3.03	84.4	24	ND
1495010-501	JOHN D PERKINS SR ELEM SCH - PFAS TREATMENT INSTALLED	MARLOW	3/3/2022	ND	ND	ND	ND
1515010-501	MASON PUBLIC SCH	MASON	12/30/2020	ND	ND	ND	ND
1522020-501	EAST BLUFF HIGHLAND CONDOS	MEREDITH	1/27/2021	ND	ND	ND	ND
1522030-001	EAST BLUFF VILLAGE CONDOS	MEREDITH	1/27/2021	ND	ND	ND	ND
1524010-000	FORESTVIEW MANOR	MEREDITH	2/10/2021	ND	ND	ND	ND
1522090-500	GROUSE POINT CLUB	MEREDITH	12/5/2020	ND	ND	ND	ND
1525020-502	INTER LAKES ELEMENTARY SCH	MEREDITH	2/19/2020	ND	ND	ND	ND
1525010-001	INTER LAKES HIGH SCH	MEREDITH	2/19/2020	ND	ND	ND	ND
1521010-003	MEREDITH WATER DEPT	MEREDITH	1/7/2020	ND	ND	ND	ND
1522010-502	PATRICIAN SHORES	MEREDITH	3/9/2020	ND	ND	ND	ND
1522070-500	PINE HILL COMMUNITY ASSN	MEREDITH	10/22/2019	ND	ND	ND	ND
1522040-002	SANDS OF BROOKHURST	MEREDITH	4/14/2021	3.63	2.62	ND	ND
1531010-003	MERRIMACK VILLAGE DIST	MERRIMACK	4/26/2021	20.5	2.08	ND	ND
1531010-005	MERRIMACK VILLAGE DIST	MERRIMACK	4/26/2021	42.2	ND	2.12	ND
1531010-007	MERRIMACK VILLAGE DIST	MERRIMACK	4/26/2021	29.5	3.28	ND	ND
1531010-008	MERRIMACK VILLAGE DIST	MERRIMACK	4/26/2021	13.2	ND	ND	ND
1531010-009	MERRIMACK VILLAGE DIST	MERRIMACK	4/26/2021	20.7	ND	ND	ND
1531010-011	MERRIMACK VILLAGE DIST	MERRIMACK	4/26/2021	86.6	4.38	2.65	ND
1531010-504	MERRIMACK VILLAGE DIST	MERRIMACK	7/15/2021	17.1	ND	ND	ND
1531010-505	MERRIMACK VILLAGE DIST	MERRIMACK	7/15/2021	13.4	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE #	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA	Max PFOS	Max PFNA	Max PFHxS
				Detected (ng/L) MCL/AGQS = 12	Detected (ng/L) MCL/AGQS = 15	Detected (ng/L) MCL/AGQS = 11	Detected (ng/L) MCL/AGQS = 18
1531010-508	MERRIMACK VILLAGE DIST	MERRIMACK	7/15/2021	26.2	2.74	ND	ND
1531010-509	MERRIMACK VILLAGE DIST	MERRIMACK	4/7/2022	ND	ND	ND	ND
1531010-510	MERRIMACK VILLAGE DIST	MERRIMACK	1/27/2022	ND	ND	ND	ND
1545010-501	MIDDLETON ELEM SCH	MIDDLETON	7/14/2021	ND	ND	ND	ND
1542030-500	PEU/SUNRISE ESTATES	MIDDLETON	2/11/2020	ND	ND	ND	ND
1553010-001	DEER ESTATES	MILAN	10/24/2019	ND	ND	ND	ND
1555010-002	MILAN VILLAGE SCH	MILAN	12/6/2021	1.7	1.7	1.7	1.7
1566040-501	115/119 EMERSON RD	MILFORD	11/20/2019	ND	ND	ND	ND
1562030-503	BADGER HILL	MILFORD	7/15/2021	2.13	ND	ND	ND
1563020-101	FAIRHAVEN MOBILE HOME PARK	MILFORD	7/12/2021	ND	ND	ND	ND
1562040-501	HERITAGE WAY	MILFORD	4/6/2020	ND	ND	ND	ND
1565010-501	LITTLE ARROWS CC SVS	MILFORD	3/11/2022	ND	ND	ND	16.4
1566020-502	MILFORD TECHNOLOGY CENTER	MILFORD	4/19/2022	ND	ND	ND	ND
1561010-504	MILFORD WATER UTILITIES DEPT	MILFORD	9/17/2021	2.93	ND	ND	ND
1561010-509	MILFORD WATER UTILITIES DEPT	MILFORD	9/17/2021	5.02	ND	ND	ND
1586040-001	INDEX PACKAGING	MILTON	7/23/2021	ND	ND	ND	ND
1585030-001	MILTON CHILDRENS CENTER	MILTON	11/7/2019	ND	ND	ND	ND
1581010-502	MILTON WATER DIST	MILTON	3/9/2021	ND	ND	ND	ND
1581010-504	MILTON WATER DIST	MILTON	3/9/2021	ND	ND	ND	ND
1583010-502	PINELAND PARK	MILTON	3/15/2020	ND	ND	ND	ND
1582010-501	SHORTRIDGE ACADEMY	MILTON	10/18/2019	ND	ND	ND	ND
1591010-511	MONROE WATER DEPT	MONROE	2/25/2020	ND	ND	ND	ND
1591010-512	MONROE WATER DEPT	MONROE	2/25/2020	ND	ND	ND	ND
1605010-501	MONT VERNON VILLAGE SCH	MONT VERNON	8/3/2021	7.54	ND	ND	ND
1603010-516	ROLLING ACRES MHP	MONT VERNON	7/20/2021	ND	ND	ND	ND
1615030-002	A CHILDS PLACE	MOULTONBOROUGH	2/11/2021	ND	ND	ND	ND
1612260-000	CROSSWINDS	MOULTONBOROUGH	7/1/2021	ND	ND	ND	ND
1616040-501	CRUCON CRUISE OUTLET	MOULTONBOROUGH	7/1/2021	ND	ND	ND	ND
1612030-501	FAR ECHO HARBOR	MOULTONBOROUGH	4/23/2021	3.18	6.29	5.8	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE #	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
1616010-000	HARBOR PINES ON LAKE SHORE DR	MOULTONBOROUGH	8/2/2021	4.3	ND	ND	ND
1618240-001	HARBOR SQUARE SHOPPING CENTER	MOULTONBOROUGH	3/17/2022	17.4	1.97	ND	ND
1612220-000	HARBOURSIDE ON WINNI	MOULTONBOROUGH	1/24/2022	ND	14.8	ND	17.3
1612170-000	JONATHANS LANDING CONDOS	MOULTONBOROUGH	7/2/2021	ND	ND	ND	ND
1612230-001	KILNWOOD ON KANASATKA	MOULTONBOROUGH	4/2/2021	ND	ND	ND	ND
1612200-000	LANDS END	MOULTONBOROUGH	3/9/2020	ND	ND	ND	ND
1615020-501	MOULTONBOROUGH ACADEMY	MOULTONBOROUGH	12/18/2020	ND	ND	ND	ND
1615010-503	MOULTONBOROUGH CENTRAL SCH	MOULTONBOROUGH	12/3/2019	ND	ND	ND	ND
1612010-501	PARADISE SHORES	MOULTONBOROUGH	3/16/2020	ND	ND	ND	ND
1612010-508	PARADISE SHORES	MOULTONBOROUGH	3/16/2020	ND	ND	ND	ND
1615050-001	RED HILL BUSINESS CENTER	MOULTONBOROUGH	10/10/2019	13.1	ND	ND	ND
1612270-501	STANYAN ROAD	MOULTONBOROUGH	10/15/2019	ND	ND	ND	ND
1612250-511	WENTWORTH ACRES	MOULTONBOROUGH	12/18/2020	ND	ND	ND	ND
1612040-500	WEST POINT	MOULTONBOROUGH	3/9/2020	ND	ND	ND	ND
1612080-501	WEST WYNDE VILLAGE	MOULTONBOROUGH	4/6/2021	ND	ND	ND	ND
1612210-501	WINDWARD HARBOR CONDOS	MOULTONBOROUGH	2/11/2020	ND	ND	ND	ND
1621010-001	PENNICHUCK WATER WORKS	NASHUA	4/4/2022	2.87	ND	ND	ND
1621010-508	PENNICHUCK WATER WORKS	NASHUA	9/21/2020	ND	ND	ND	ND
1622010-501	PWW/FARLEY RD ESTATES	NASHUA	10/4/2019	ND	ND	ND	ND
1625020-501	SECOND NATURE ACADEMY	NASHUA	9/13/2021	4.15	ND	ND	ND
1635010-501	NELSON ELEMENTARY SCH	NELSON	12/21/2020	ND	ND	ND	ND
1645030-501	CHESTNUT CHRISTIAN PRESCH	NEW BOSTON	3/31/2021	ND	ND	ND	ND
1645010-001	NEW BOSTON ELEMENTARY SCH	NEW BOSTON	11/29/2020	ND	ND	ND	ND
1645040-501	ROSE MEADOW ACRES	NEW BOSTON	8/24/2021	ND	ND	ND	ND
1645020-501	STRONG FOUNDATIONS	NEW BOSTON	9/22/2021	17.8	ND	ND	ND
1646020-001	USAF NH SATELLITE TRACKING STN	NEW BOSTON	4/15/2021	9.92	12.1	ND	4.65
1646020-002	USAF NH SATELLITE TRACKING STN	NEW BOSTON	4/26/2021	6.15	5.69	4.98	ND
1675020-001	7 DEPOT ROAD BEING COOL	NEW DURHAM	12/5/2020	ND	ND	ND	ND
1672020-505	COPPLE CROWN VILL DIST	NEW DURHAM	3/21/2022	ND	ND	ND	4.33



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE #	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
1672010-501	MANITOOS SHORES	NEW DURHAM	3/17/2021	ND	ND	ND	ND
1675010-501	NEW DURHAM ELEMENTARY SCH	NEW DURHAM	9/20/2021	2.93	ND	ND	ND
1692030-501	MANSFIELD WOODS	NEW HAMPTON	4/23/2021	ND	ND	ND	ND
1691010-002	NEW HAMPTON VILLAGE PCT	NEW HAMPTON	9/23/2021	ND	ND	ND	ND
1691010-003	NEW HAMPTON VILLAGE PCT	NEW HAMPTON	11/6/2019	ND	ND	ND	ND
1716060-001	APPLETON BUSINESS CENTER	NEW IPSWICH	2/12/2020	ND	ND	ND	ND
1712010-501	APPLETON GARDENS	NEW IPSWICH	2/18/2021	ND	ND	ND	ND
1715040-500	BOYNTON MIDDLE SCH	NEW IPSWICH	12/30/2020	ND	ND	ND	ND
1713010-504	FREEDOM POND	NEW IPSWICH	5/19/2021	2.92	5.2	ND	ND
1715060-501	HIGHBRIDGE HILL ELEM SCH	NEW IPSWICH	6/9/2021	8.29	10	2.45	ND
1715020-501	MASCENIC REGIONAL HIGH SCH	NEW IPSWICH	6/9/2021	12.5	6.63	2.2	ND
1716050-501	VANGUARD MANUFACTURING	NEW IPSWICH	2/19/2021	ND	ND	ND	ND
1716080-001	WARWICK MILLS	NEW IPSWICH	8/3/2021	3.27	ND	ND	ND
1712040-511	WILDER VILLAGE CLUSTER	NEW IPSWICH	12/4/2020	ND	ND	ND	ND
1721010-008	NEW LONDON SPRINGFIELD WATER	NEW LONDON	2/5/2020	ND	ND	ND	ND
1722010-501	SEASONS AT LAKE SUNAPEE	NEW LONDON	8/12/2021	ND	ND	ND	ND
1722020-502	SLOPE N SHORE CLUB	NEW LONDON	2/3/2021	ND	ND	ND	ND
1652020-506	CHALK POND WATER	NEWBURY	2/24/2020	ND	ND	ND	ND
1652050-001	NEWBURY ELDERLY HOUSING	NEWBURY	2/3/2021	0.4	ND	ND	ND
1656010-001	NEWBURY HARBOR PLAZA	NEWBURY	3/9/2021	ND	ND	ND	ND
1681010-501	NEWFIELDS VLG WATER AND SEWER	NEWFIELDS	7/22/2020	3.1	ND	2.98	ND
1732030-514	GREAT BAY WATER SYSTEM	NEWMARKET	2/16/2022	9.48	ND	ND	2.12
1732010-001	MOODY POINT	NEWMARKET	2/23/2021	ND	ND	ND	ND
1731010-506	NEWMARKET WATER WORKS	NEWMARKET	4/15/2020	ND	ND	ND	ND
1731010-507	NEWMARKET WATER WORKS	NEWMARKET	4/15/2020	ND	ND	ND	ND
1731010-508	NEWMARKET WATER WORKS	NEWMARKET	4/15/2020	ND	ND	ND	ND
1732020-511	WADE FARM CONDOS	NEWMARKET	7/6/2021	ND	ND	ND	ND
1742010-001	CARY AND ALLEN ST DEV	NEWPORT	3/24/2021	ND	ND	ND	ND
1749010-001	KIDS WORLD ACADEMY OF NH	NEWPORT	2/3/2021	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE #	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
1746020-001	LATVA MACHINE	NEWPORT	3/17/2021	ND	ND	ND	ND
1741010-502	NEWPORT WATER WORKS	NEWPORT	2/12/2020	ND	ND	ND	ND
1741010-503	NEWPORT WATER WORKS	NEWPORT	2/12/2020	ND	ND	ND	ND
1752020-501	MEADOWVIEW APARTMENTS	NEWTON	10/2/2019	ND	ND	ND	ND
1755050-004	NEWTON LEARNING CENTER	NEWTON	5/17/2021	6.83	ND	ND	ND
1756050-502	ONE PUZZLE LANE	NEWTON	2/15/2022	ND	ND	ND	ND
1752030-511	PACKER MEADOWS	NEWTON	10/1/2019	ND	ND	ND	ND
1755010-001	SANBORN MEM SCH/SEACOST LRNG	NEWTON	8/19/2021	ND	ND	ND	ND
1752070-501	SARGENT WOODS	NEWTON	3/9/2021	ND	ND	ND	ND
1756040-503	TEREX ENVIRONMENTAL EQUIPMENT	NEWTON	5/24/2021	ND	ND	ND	ND
1753010-502	WILLOW GROVE TRAILER PARK	NEWTON	3/10/2020	ND	ND	ND	ND
1777040-001	SAGAMORE GOLF CLUB/DWELLBUB 79	NORTH HAMPTON	8/25/2016	ND	ND	ND	ND
1777020-001	SAGAMORE/HAMPTON GOLF CLUB	NORTH HAMPTON	8/25/2016	ND	ND	ND	ND
1773020-001	SEACOAST CAMPING AND RV RESORT	NORTH HAMPTON	9/26/2016	1.9	ND	ND	ND
1773020-002	SEACOAST CAMPING AND RV RESORT	NORTH HAMPTON	9/26/2016	ND	ND	ND	ND
1773020-102	SEACOAST CAMPING AND RV RESORT	NORTH HAMPTON	9/26/2016	2.6	ND	ND	ND
1767020-001	CANTERBURY CROSSING	NORTHFIELD	1/20/2021	ND	ND	ND	ND
1762010-501	HIGHLANDS VILLAGE DIST	NORTHFIELD	2/3/2021	ND	ND	ND	ND
1763010-502	SODA BROOK	NORTHFIELD	3/17/2021	ND	ND	ND	ND
1764010-502	SPAULDING YOUTH CENTER - PFAS TREATMENT	NORTHFIELD	6/16/2021	ND	ND	ND	ND
1766030-001	YOUNG ENTERPRISES NH	NORTHFIELD	1/4/2021	ND	ND	ND	ND
1781010-502	GROVETON WATER SYS	NORTHUMBERLAND	10/21/2019	ND	ND	ND	ND
1781030-502	LOST NATION WATER	NORTHUMBERLAND	10/21/2019	ND	ND	ND	ND
1795020-001	COE BROWN NORTHWOOD ACADEMY	NORTHWOOD	3/25/2021	ND	ND	ND	ND
1795040-001	COE BROWN NORTHWOOD ACADEMY	NORTHWOOD	3/25/2021	ND	ND	ND	ND
1798060-502	COOPER HILL PIZZERIA	NORTHWOOD	4/22/2021	ND	ND	ND	ND
1796010-001	HANNAFORD NORTHWOOD 8160	NORTHWOOD	9/11/2020	ND	ND	ND	ND
1798030-502	JOHNSONS SEAFOOD AND STEAK	NORTHWOOD	4/13/2022	ND	ND	ND	ND
1793020-103	LOON ESTATES	NORTHWOOD	12/7/2020	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE #	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
1793030-501	NORTHWOOD MOUNTAIN VIEW MHP	NORTHWOOD	4/15/2021	2.12	6.76	6.8	ND
1792050-001	THE MEADOW AT NORTHWOOD	NORTHWOOD	1/27/2020	ND	ND	ND	ND
1793010-501	TOWER VIEW	NORTHWOOD	4/6/2020	ND	ND	ND	ND
1792040-001	VILLAGE AT MEAD FIELD	NORTHWOOD	11/17/2016	ND	ND	ND	ND
1792030-001	VLG OF NORTHWOOD RDG WTR DIST	NORTHWOOD	11/19/2019	ND	ND	ND	ND
1792030-002	VLG OF NORTHWOOD RDG WTR DIST	NORTHWOOD	11/19/2019	ND	ND	ND	ND
1805060-001	ALL ABOARD PRESCH AND CHLDCARE	NOTTINGHAM	8/7/2020	ND	ND	ND	ND
1802020-501	CAMELOT COURT	NOTTINGHAM	3/9/2021	ND	ND	ND	ND
1809020-002	NOTTINGHAM COMMUNITY CHURCH	NOTTINGHAM	5/6/2021	2.25	5.88	ND	ND
1805050-501	NOTTINGHAM COMMUNITY SCH	NOTTINGHAM	12/7/2020	ND	ND	ND	ND
1831010-505	ORFORD VILLAGE DIST	ORFORD	1/20/2021	ND	ND	ND	ND
1835010-002	RIVENDELL INTERSTATE SCH	ORFORD	3/3/2020	ND	ND	ND	ND
1842010-505	BLUFFS AT OSSIPEE LAKE	OSSIPEE	3/17/2020	ND	ND	ND	ND
1844010-501	CARROL COUNTY COMPLEX	OSSIPEE	7/6/2021	ND	ND	ND	ND
1844010-505	CARROL COUNTY COMPLEX	OSSIPEE	7/6/2021	ND	ND	ND	ND
1845020-001	CORNERSTONE CHRISTIAN ACADEMY	OSSIPEE	7/21/2020	ND	ND	ND	ND
1842060-501	DEER COVE WATER	OSSIPEE	3/12/2020	ND	ND	ND	ND
1846090-501	HANNAFORD OSSIPEE 8159	OSSIPEE	7/21/2020	ND	ND	ND	ND
1842030-503	INDIAN MOUND GOLF CLUB	OSSIPEE	4/20/2021	2.12	ND	ND	ND
1842020-505	INDIAN MOUND SHOPPING CTR	OSSIPEE	4/28/2021	ND	ND	ND	ND
1843010-000	OSSIPEE MTN ESTATES	OSSIPEE	2/10/2021	ND	ND	ND	ND
1841010-501	OSSIPEE WATER DEPT	OSSIPEE	11/18/2019	ND	ND	ND	ND
1842050-001	POLAND BROOK WOODS	OSSIPEE	6/7/2021	ND	ND	ND	ND
1843020-503	SANDY RIDGE ESTATES	OSSIPEE	2/10/2021	ND	ND	ND	ND
1856050-501	AMERICAN FOODS	PELHAM	1/6/2022	27.3	12.2	3.58	5.97
1852100-501	BOULDER HILLS	PELHAM	7/13/2021	ND	ND	ND	ND
1855080-001	COLONIAL WAY PLAZA	PELHAM	3/24/2021	ND	ND	ND	ND
1859040-001	CROSSROADS BAPTIST CHURCH	PELHAM	12/3/2020	ND	ND	ND	ND
1855070-001	DYNAMIC FOUNDATION FOR CHILDREN	PELHAM	11/24/2020	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE #	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
1852130-501	GARLAND WOODS	PELHAM	1/13/2021	ND	ND	ND	ND
1856040-501	HANNAFORD PELHAM 8015	PELHAM	8/11/2020	ND	ND	ND	ND
1852060-511	HIGHLANDS ESTATES	PELHAM	1/20/2022	9.15	ND	ND	ND
1855090-001	KINGS KIDS CHILD CARE CENTER	PELHAM	9/9/2021	2.94	6.72	ND	ND
1852140-502	LONG POND WOODS	PELHAM	5/18/2021	ND	ND	ND	ND
1852080-542	OLD LAWRENCE ROAD	PELHAM	4/12/2022	28.4	4.07	ND	6.41
1852110-501	PARADISE ESTATES CONDOS	PELHAM	5/18/2021	2.18	ND	ND	ND
1856070-502	PELHAM INDUSTRIAL PARK I	PELHAM	9/14/2021	ND	ND	ND	ND
1856070-503	PELHAM INDUSTRIAL PARK I	PELHAM	4/4/2022	ND	ND	ND	ND
1856010-502	PELHAM PLAZA	PELHAM	6/24/2021	3.02	ND	ND	ND
1855060-001	PERFECT PLACE	PELHAM	9/1/2021	11	7.66	ND	ND
1852020-501	PEU/GAGE HILL	PELHAM	2/17/2022	7.4	2.68	ND	ND
1852120-501	PEU/SKY VIEW ESTATES	PELHAM	2/4/2020	ND	ND	ND	ND
1851010-501	PEU/WILLIAMSBURG	PELHAM	7/7/2021	4.85	ND	ND	ND
1852040-002	PROLYN TOWNHOUSE APARTMENTS - NO TREATMENT	PELHAM	4/22/2021	23	9.81	6.74	2.6
1852040-505	PROLYN TOWNHOUSE APARTMENTS - PFAS TREATMENT	PELHAM	1/27/2022	ND	ND	ND	ND
1852090-501	SIMPSON MILL ROAD	PELHAM	11/27/2020	ND	ND	ND	ND
1862030-501	BOROUGH RD APARTMENTS	PEMBROKE	11/19/2019	ND	ND	ND	ND
1862010-001	MEETING HOUSE WATER	PEMBROKE	8/6/2021	ND	ND	ND	ND
1866030-501	NEW ENGLADN FLOWER FARM	PEMBROKE	6/2/2021	ND	ND	ND	ND
1861010-006	PEMBROKE WATER WORKS	PEMBROKE	8/19/2020	ND	ND	ND	ND
1861010-502	PEMBROKE WATER WORKS	PEMBROKE	8/19/2020	5.88	19.2	6.69	ND
1861010-503	PEMBROKE WATER WORKS	PEMBROKE	8/19/2020	ND	ND	ND	ND
1861010-504	PEMBROKE WATER WORKS	PEMBROKE	8/19/2020	ND	ND	ND	ND
1861010-507	PEMBROKE WATER WORKS	PEMBROKE	8/19/2020	ND	ND	ND	ND
1861010-509	PEMBROKE WATER WORKS	PEMBROKE	4/4/2022	3.23	8.99	ND	3.01
1875010-501	HAPPY VALLEY SCH	PETERBOROUGH	3/16/2021	ND	ND	ND	ND
1875030-511	MONADNOCK COMM EARLY LNGCTR	PETERBOROUGH	2/022/21	ND	ND	ND	ND
1879020-001	PETERBOROUGH PLAYERS THEATRE	PETERBOROUGH	4/14/2016	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE #	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
1871010-501	PETERBOROUGH WATER WORKS	PETERBOROUGH	10/3/2019	ND	ND	ND	ND
1871010-503	PETERBOROUGH WATER WORKS	PETERBOROUGH	10/3/2019	ND	ND	ND	ND
1871010-504	PETERBOROUGH WATER WORKS	PETERBOROUGH	10/3/2019	ND	ND	ND	ND
1875020-001	WELL SCHOOL	PETERBOROUGH	6/2/2021	ND	ND	ND	ND
1885010-503	PIERMONT VILLAGE SCH	PIERMONT	1/13/2021	ND	ND	ND	ND
1897020-501	AMC PINKHAM NOTCH CAMP	PINKHAMS GRANT	3/24/2020	ND	ND	ND	ND
1901010-506	PITTSBURG WATER DEPT	PITTSBURG	4/15/2021	ND	ND	ND	ND
1913010-001	GRIGGS MOBILE HOMES	PITTSFIELD	1/13/2021	ND	ND	ND	ND
1911010-501	PITTSFIELD AQUEDUCT	PITTSFIELD	1/14/2021	ND	ND	ND	ND
1916020-001	PODMORE MANUFACTURING	PITTSFIELD	4/6/2022	ND	ND	ND	ND
1921020-001	MERIDEN VILLAGE WATER DIST	PLAINFIELD	3/26/2020	ND	ND	ND	ND
1921020-002	MERIDEN VILLAGE WATER DIST	PLAINFIELD	3/26/2020	ND	ND	ND	ND
1921020-003	MERIDEN VILLAGE WATER DIST	PLAINFIELD	3/26/2020	ND	ND	ND	ND
1921010-506	PLAINFIELD VILLAGE WATER DIST	PLAINFIELD	3/2/2020	ND	ND	ND	ND
1921010-507	PLAINFIELD VILLAGE WATER DIST	PLAINFIELD	3/2/2020	ND	ND	ND	ND
1926010-501	TOWNLINE EQUIP	PLAINFIELD	2/5/2021	ND	ND	ND	ND
1936070-501	144 MAIN STREET	PLAISTOW	3/2/2020	ND	ND	ND	ND
1932130-503	26 CHANDLER AVE CONDOS	PLAISTOW	4/4/2022	11.6	2.32	ND	2.42
1936230-502	3 / 11 PLAISTOW RD PLAZA	PLAISTOW	3/15/2022	ND	ND	ND	ND
1936300-001	BARONS CONDOS	PLAISTOW	9/27/2021	13.4	17.4	ND	23.3
1932150-501	BLUEBERRY KNOLL ESTATES	PLAISTOW	3/9/2020	ND	ND	ND	ND
1938090-501	BRICKYARD PLAZA	PLAISTOW	9/29/2021	17	3.2	ND	4.04
1932110-001	BRYANT BROOK	PLAISTOW	10/9/2019	ND	ND	ND	ND
1932250-501	CHANDLER PLACE APTS	PLAISTOW	8/13/2021	4.82	2.1	ND	ND
1932190-502	CHANDLER TERRACE	PLAISTOW	4/4/2022	10.8	4.75	ND	ND
1932120-501	CROSS RIDGE ESTATES	PLAISTOW	7/19/2021	13	15.4	ND	ND
1936310-511	ETHAN ALLEN PLAZA	PLAISTOW	6/23/2021	10.9	6.62	ND	3.6
1936270-001	FIELDSTONE INDUSTRIAL PARK	PLAISTOW	2/17/2020	ND	ND	ND	ND
1936160-001	FITZGERALD SAFETY COMPLEX	PLAISTOW	8/4/2017	4	ND	16	73



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE #	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA	Max PFOS	Max PFNA	Max PFHxS
				Detected (ng/L) MCL/AGQS = 12	Detected (ng/L) MCL/AGQS = 15	Detected (ng/L) MCL/AGQS = 11	Detected (ng/L) MCL/AGQS = 18
1932040-501	FOREST GLEN CONDOS	PLAISTOW	7/14/2020	5.63	ND	2.34	ND
1932020-502	GOLDEN HILL	PLAISTOW	4/19/2022	16.1	18.7	ND	ND
1938190-511	GREAT ELM PLAZA	PLAISTOW	3/2/2020	ND	ND	ND	ND
1932090-501	GREENFIELD HILL ESTATES	PLAISTOW	7/7/2021	3.17	ND	ND	ND
1935070-001	LITTLE EXPLORERS	PLAISTOW	9/20/2021	3.41	ND	ND	ND
1932230-501	LITTLE RIVER VILLAGE	PLAISTOW	7/7/2021	ND	ND	ND	ND
1936150-503	MARKET BASKET	PLAISTOW	3/3/2022	2.56	ND	ND	ND
1932060-501	MOONGATE FARM	PLAISTOW	1/10/2022	8.8	5.81	ND	ND
1936100-501	PENTUCKET SHOPPING CENTER	PLAISTOW	12/9/2021	7.9	2.28	ND	2.39
1938240-002	PLAISTOW COMM YMCA	PLAISTOW	9/21/2021	3.39	ND	ND	ND
1936130-001	PLAISTOW COMMONS	PLAISTOW	6/22/2020	ND	ND	ND	ND
1938040-501	PLAISTOW REG HEALTHCARE	PLAISTOW	9/17/2021	3.99	2.74	ND	ND
1936040-002	PLAZA 125	PLAISTOW	9/20/2018	11.8	5.56	4.92	ND
1935010-003	POLLARD ELEMENTARY SCH	PLAISTOW	3/1/2022	12.8	6.22	ND	3.63
1932170-501	RAINBOW RIDGE	PLAISTOW	7/7/2021	ND	ND	ND	ND
1932140-001	RUTLEDGE PLACE	PLAISTOW	1/19/2022	12	8.95	ND	3.42
1936110-001	SCANDIA PLASTICS	PLAISTOW	9/8/2021	2.71	ND	ND	ND
1932220-501	SHADY LANE APARTMENTS	PLAISTOW	5/19/2021	6.71	4.58	ND	8.66
1936280-001	SPARTON BECKWOOD	PLAISTOW	8/16/2021	ND	ND	ND	ND
1932080-503	STONEBRIDGE VILLAGE	PLAISTOW	10/25/2019	ND	ND	ND	ND
1932100-502	STRAWBERRY HILL	PLAISTOW	4/20/2021	4.5	3.38	ND	ND
1932200-511	SWEET HILL ESTATES	PLAISTOW	4/19/2021	ND	ND	ND	ND
1932240-501	THE RESERVE AT SNOWS BROOK	PLAISTOW	7/7/2021	2.15	ND	ND	ND
1935020-001	TIMBERLANE MIDDLE SCH	PLAISTOW	10/3/2019	ND	ND	ND	ND
1935030-511	TIMBERLANE REGIONAL HS	PLAISTOW	10/3/2019	ND	ND	ND	ND
1932180-501	TUXBURY MEADOWS	PLAISTOW	8/24/2021	3.03	ND	ND	ND
1932050-008	TWIN RIDGE CONDOS	PLAISTOW	4/20/2021	6.57	3.67	ND	ND
1932050-512	TWIN RIDGE CONDOS	PLAISTOW	8/17/2021	3.11	ND	ND	ND
1932070-501	VALLEY FIELD APTS NORTHLAND	PLAISTOW	7/13/2021	3.35	2.9	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE #	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
1932210-500	WEST PINE CONDOS	PLAISTOW	7/21/2021	8.16	7.5	ND	ND
1932030-502	WEST VIEW PARK CONDOS	PLAISTOW	9/16/2021	11.5	ND	ND	2.74
1945010-001	MOUNTAIN VILLAGE SCH	PLYMOUTH	3/25/2021	ND	ND	ND	ND
1949030-001	PLYMOUTH COMMERCE PARK	PLYMOUTH	3/24/2021	ND	ND	ND	ND
1941010-501	PLYMOUTH VLG WATER AND SEWER	PLYMOUTH	1/15/2021	ND	ND	ND	ND
1941010-502	PLYMOUTH VLG WATER AND SEWER	PLYMOUTH	1/15/2021	ND	ND	ND	ND
1942020-001	TENNEY BROOK CONDOS	PLYMOUTH	8/19/2021	ND	ND	ND	ND
1942010-003	TENNEY BROOK II	PLYMOUTH	1/27/2021	ND	ND	ND	ND
1942010-501	TENNEY BROOK II	PLYMOUTH	1/27/2021	ND	ND	ND	ND
1943010-007	WHIP O WILL	PLYMOUTH	4/26/2021	ND	ND	ND	ND
1943010-106	WHIP O WILL	PLYMOUTH	4/26/2021	ND	ND	ND	ND
1943010-501	WHIP O WILL	PLYMOUTH	4/26/2021	ND	ND	ND	ND
1951020-510	PEASE TRADE PORT - PFAS TREATMENT INSTALLED	PORTSMOUTH	2/10/2022	ND	ND	ND	ND
1951010-502	PEASE TRADE PORT - WELL NOT IN USE	PORTSMOUTH	5/14/2014	320	2400	830	14
1951010-501	PORTSMOUTH WATER WORKS	PORTSMOUTH	3/1/2022	ND	ND	ND	ND
1951010-503	PORTSMOUTH WATER WORKS	PORTSMOUTH	3/1/2022	7	5.59	ND	9.05
1951010-504	PORTSMOUTH WATER WORKS	PORTSMOUTH	3/1/2022	ND	ND	ND	ND
1951010-506	PORTSMOUTH WATER WORKS	PORTSMOUTH	3/1/2022	5.74	ND	ND	ND
1951010-507	PORTSMOUTH WATER WORKS	PORTSMOUTH	3/1/2022	2.82	ND	ND	ND
1951010-508	PORTSMOUTH WATER WORKS	PORTSMOUTH	3/1/2022	ND	ND	ND	ND
1951010-516	PORTSMOUTH WATER WORKS	PORTSMOUTH	3/1/2022	4.15	2.96	ND	ND
1972080-501	BLACKSTONE RESERVE	RAYMOND	3/17/2021	ND	ND	ND	ND
1972040-502	BRANCH RIVER APARTMENTS	RAYMOND	4/22/2021	5.35	3.77	5.75	ND
1973050-502	HILL TOP	RAYMOND	7/19/2021	4.43	2.25	ND	5.19
1973060-503	LEISURE VILLAGE	RAYMOND	11/21/2019	ND	ND	ND	ND
1972050-501	PAWTUCKAWAY FARMS	RAYMOND	12/18/2020	ND	ND	ND	ND
1972070-501	PEU/CLEARWATER ESTATES	RAYMOND	2/12/2020	ND	ND	ND	ND
1972010-505	PEU/LIBERTY TREE ACRES	RAYMOND	10/22/2019	1.88	ND	ND	ND
1975010-001	RAYMOND HIGH SCH	RAYMOND	11/10/2016	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE #	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
1971010-504	RAYMOND WATER DEPT	RAYMOND	10/24/2019	ND	ND	ND	ND
1971010-505	RAYMOND WATER DEPT	RAYMOND	10/24/2019	ND	ND	ND	ND
1971010-506	RAYMOND WATER DEPT	RAYMOND	10/24/2019	ND	ND	ND	ND
1972020-501	RIVERVIEW MANOR CONDOS	RAYMOND	4/14/2021	ND	2.17	2.17	ND
1972060-500	WESTGATE ESTATES	RAYMOND	10/30/2019	ND	ND	ND	ND
1985010-002	ST BENEDICT CENTER MONASTERY	RICHMOND	4/6/2020	ND	ND	ND	ND
1992050-001	CARRIAGE APTS	RINDGE	10/11/2019	ND	ND	ND	ND
1996010-501	CHESHIRE MARKET PLACE	RINDGE	9/29/2021	ND	2.25	ND	ND
1992020-106	DUNBAR PROPERTIES	RINDGE	12/5/2020	ND	ND	ND	ND
1994010-502	FRANKLIN PIERCE UNIVERSITY	RINDGE	3/17/2021	ND	ND	ND	ND
1995030-501	HAMPSHIRE COUNTRY SCH	RINDGE	6/26/2021	ND	ND	ND	ND
1992040-502	HAMPSHIRE COURT WATER	RINDGE	9/15/2021	ND	ND	ND	ND
1996040-504	HANNAFORD RINDGE 8180	RINDGE	10/13/2021	20.4	27.4	77.5	2.44
1995050-501	HERITAGE CHRISTIAN SCH	RINDGE	3/12/2021	ND	ND	ND	ND
1993010-511	MONADNOCK TENANTS	RINDGE	1/6/2020	ND	ND	ND	ND
1992070-501	PAYSON VILLAGE	RINDGE	2/18/2021	ND	ND	ND	ND
1996060-001	PHASE 10	RINDGE	7/7/2021	3.28	ND	ND	ND
1995010-001	RINDGE MEMORIAL SCH	RINDGE	7/7/2021	2.15	ND	ND	ND
1996020-001	WAL MART STORE 2057	RINDGE	9/8/2021	2.01	ND	ND	ND
2003020-506	ACORN TERRACE	ROCHESTER	7/8/2021	ND	ND	ND	ND
2003020-508	ACORN TERRACE	ROCHESTER	7/8/2021	ND	ND	ND	ND
2006020-501	CORNERSTONE VNA ROCHESTER	ROCHESTER	1/4/2022	ND	ND	ND	ND
2001020-001	COUNTRY RIDGE MHP	ROCHESTER	7/9/2021	ND	ND	ND	ND
2002030-504	DUSTIN HOMESTEAD	ROCHESTER	8/31/2021	7.64	5.96	ND	ND
2002050-500	GRANDVIEW ESTATES	ROCHESTER	12/23/2020	ND	ND	ND	ND
2004010-503	INN AT SECRETARIAT	ROCHESTER	7/1/2021	4.86	ND	ND	ND
2002040-501	MEADOWBROOK VILLAGE	ROCHESTER	7/12/2021	ND	ND	ND	ND
2003030-511	PARADISE ESTATES	ROCHESTER	1/11/2022	13.5	6.02	ND	2.8
2002020-501	PROFILE APARTMENTS	ROCHESTER	7/21/2021	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE #	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
2001010-001	ROCHESTER WATER DEPT	ROCHESTER	8/14/2020	ND	ND	ND	ND
2001010-002	ROCHESTER WATER DEPT	ROCHESTER	8/25/2021	ND	ND	ND	ND
2001010-503	ROCHESTER WATER DEPT	ROCHESTER	8/25/2021	3.71	3.27	ND	ND
2003040-000	STONY BROOK	ROCHESTER	2/3/2020	ND	ND	ND	ND
2003090-001	WESTWIND ESTATES II	ROCHESTER	2/20/2020	ND	ND	ND	ND
2011010-509	ROLLINSFORD WATER SEWER DIST	ROLLINSFORD	2/10/2022	9.1	3.36	ND	ND
2011010-514	ROLLINSFORD WATER SEWER DIST	ROLLINSFORD	6/30/2020	ND	ND	ND	ND
2032010-002	HAWTHORNE VILLAGE	RUMNEY	2/12/2020	ND	ND	ND	ND
2035010-501	RUSSELL ELEMENTARY SCH	RUMNEY	2/12/2020	ND	ND	ND	ND
2036010-001	STONEWALL CABLE	RUMNEY	2/12/2020	ND	ND	ND	ND
2041010-006	RYE WATER DIST	RYE	4/5/2022	2.23	ND	ND	ND
2041010-008	RYE WATER DIST	RYE	4/5/2022	4.8	ND	ND	2.26
2041010-501	RYE WATER DIST	RYE	4/5/2022	8.49	6.21	ND	ND
2053020-501	ACKERMAN RETIREMENT PARK	SALEM	9/27/2021	8.01	8.82	ND	5.72
2052070-501	AUTUMN WOODS	SALEM	7/7/2021	ND	ND	ND	ND
2056010-501	KLEIN MARINE SYSTEMS	SALEM	7/23/2021	3.43	7.57	ND	ND
2052030-503	LANCASTER FARMS	SALEM	7/7/2021	2.92	ND	ND	ND
2055020-501	MERRIMACK VALLEY MONTESSOR SCH	SALEM	9/8/2021	4.4	2.82	ND	2.07
2052060-001	MILLVILLE CIRCLE/NORTH	SALEM	1/24/2020	ND	ND	ND	ND
2052010-002	MILLVILLE CIRCLE/SOUTH	SALEM	7/16/2021	4.91	ND	ND	2.38
2055010-502	NORTH SALEM ELEMENTARY SCH	SALEM	3/24/2022	13.9	5.71	10.2	2.73
2056040-001	NORTH SALEM VILLAGE	SALEM	3/23/2020	ND	ND	ND	ND
2051010-009	SALEM WATER DEPT	SALEM	5/17/2021	7.43	2.16	ND	ND
2051010-510	SALEM WATER DEPT	SALEM	4/13/2020	3.47	ND	ND	ND
2057060-001	SCOTTISH HIGHLAND GOLF COURSE	SALEM	6/14/2016	ND	ND	ND	ND
2053030-001	SHADOW LAKE MOBILE HOME PARK	SALEM	9/25/2021	5.24	ND	ND	ND
2065010-001	SALISBURY ELEMENTARY SCH	SALISBURY	12/30/2020	ND	ND	ND	ND
2075030-501	SAINT BANI MIDDLE BLDG	SANBORNTON	9/30/2021	5.64	2.43	ND	ND
2075010-501	SAINT BANI UPPER BLDG	SANBORNTON	3/12/2021	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE #	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
2075020-002	SANBORNTON CENTRAL SCH	SANBORNTON	12/29/2020	ND	ND	ND	ND
2075070-001	SAPLINGS PRESCHOOL	SANBORNTON	12/5/2020	ND	ND	ND	ND
2078010-503	STEELE HILL RESORT	SANBORNTON	9/15/2021	2.77	2.14	ND	ND
2078010-505	STEELE HILL RESORT	SANBORNTON	9/15/2021	2.73	ND	ND	ND
2082060-501	CORNERSTONE ESTATES	SANDOWN	3/9/2021	ND	ND	ND	ND
2082020-001	FAIRFIELD	SANDOWN	7/19/2021	ND	ND	ND	ND
2082020-502	FAIRFIELD	SANDOWN	7/19/2021	ND	ND	ND	ND
2082080-501	LITTLE MILL WOODS	SANDOWN	3/8/2021	ND	ND	ND	ND
2082070-500	MILL PINE VILLAGE	SANDOWN	10/30/2019	ND	ND	ND	ND
2082010-503	PEU/BEAVER HOLLOW	SANDOWN	7/6/2021	5.71	ND	ND	ND
2082040-502	PINE ACRES CONDOS	SANDOWN	8/9/2021	9.85	6.6	ND	4.11
2085020-501	PLAYMATES LEARNING CENTER	SANDOWN	6/23/2021	5.15	ND	ND	ND
2082030-001	REEDS CROSSING	SANDOWN	3/13/2021	ND	ND	ND	ND
2085040-001	SANDOWN NORTH ELEMENTARY SCH	SANDOWN	10/31/2019	ND	ND	ND	ND
2082050-501	STONEFORD	SANDOWN	7/14/2021	2.6	ND	ND	ND
2082110-501	TOWNHOUSES AT WELLS VILLAGE	SANDOWN	7/19/2021	ND	ND	ND	ND
2082090-501	WATERFORD VILLAGE ESTATES	SANDOWN	3/9/2021	ND	ND	ND	ND
2095020-501	SANDWICH CENTRAL SCH	SANDWICH	6/16/2021	ND	ND	ND	ND
2095030-001	SANDWICH CHILDRENS CTR	SANDWICH	9/15/2021	ND	ND	ND	ND
2111010-501	SEABROOK WATER DEPT	SEABROOK	7/23/2021	8.32	3.81	ND	ND
2111010-503	SEABROOK WATER DEPT	SEABROOK	7/23/2021	4	ND	ND	ND
2111010-512	SEABROOK WATER DEPT	SEABROOK	7/12/2021	3.98	ND	ND	ND
2111010-514	SEABROOK WATER DEPT	SEABROOK	2/23/2021	ND	ND	ND	ND
2111010-516	SEABROOK WATER DEPT	SEABROOK	7/13/2021	ND	ND	ND	ND
2151010-005	SOMERSWORTH WATER WORKS	SOMERSWORTH	3/24/2020	ND	ND	ND	ND
2151010-506	SOMERSWORTH WATER WORKS	SOMERSWORTH	3/24/2020	ND	ND	ND	ND
2165020-501	BARNARD SCH	SOUTH HAMPTON	12/18/2020	ND	ND	ND	ND
2185010-002	STARK VILLAGE SCH	STARK	5/10/2021	ND	ND	ND	ND
2192020-001	NORTHERN VIEW APTS	STEWARTSTOWN	4/6/2021	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE #	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
2195020-001	STEWARTSTOWN COMM SCH	STEWARTSTOWN	6/28/2021	ND	ND	ND	ND
2206010-502	CARLISLE WIDE PLANK FLOORS	STODDARD	3/31/2021	ND	ND	ND	ND
2205010-503	JAMES FAULKNER MEM SCH	STODDARD	4/18/2022	ND	ND	ND	ND
2212010-501	BOW LAKE ESTATES	STRAFFORD	3/9/2021	ND	ND	ND	ND
2221010-502	NORTH STRATFORD WATER DEPT	STRAFFORD	6/28/2021	ND	ND	ND	ND
2221010-503	NORTH STRATFORD WATER DEPT	STRAFFORD	6/28/2021	ND	ND	ND	ND
2215010-502	STRAFFORD SCH	STRAFFORD	8/23/2021	ND	ND	ND	ND
2215040-501	WHITEHOUSE EARLY LRNG CTR	STRAFFORD	4/15/2021	ND	ND	ND	ND
2223020-001	NORTH STRATFORD MHP	STRATFORD	3/9/2021	ND	ND	ND	ND
2223010-001	PLEASANT VALLEY PARK ESTATES	STRATFORD	8/30/2021	ND	ND	ND	ND
2236190-501	149/151 PORTSMOUTH AVE	STRATHAM	3/1/2022	ND	ND	ND	ND
2232150-512	ABERDEEN/WEST	STRATHAM	11/18/2019	ND	ND	ND	ND
2235010-001	ACORN SCH	STRATHAM	4/15/2021	ND	ND	ND	ND
2232060-001	BALMORAL CONDOS	STRATHAM	8/16/2021	ND	ND	ND	ND
2236040-001	BELL AND FLYNN	STRATHAM	8/25/2021	ND	ND	ND	3.27
2236150-501	BMW OF STRATHAM	STRATHAM	3/8/2022	8.12	2.3	ND	ND
2232160-502	BURNHAVEN	STRATHAM	7/20/2021	ND	ND	ND	ND
2232200-501	CHISHOLM FARM	STRATHAM	1/3/2022	12.8	3.29	ND	2.11
2235060-501	CORNERSTONE SCHOOL	STRATHAM	5/25/2021	4.74	3.13	ND	ND
2232010-504	GLENDARRY CONDOS	STRATHAM	7/13/2021	11.3	6.53	ND	3.04
2232140-501	JEWETT HILL	STRATHAM	7/14/2021	4.72	3.92	ND	ND
2236010-001	KINGS HIGHWAY PLAZA	STRATHAM	8/12/2021	7.29	2.99	ND	ND
2236170-001	LINDT AND SPRUNGLI USA/BLDG D	STRATHAM	8/19/2020	2.46	ND	ND	ND
2236180-502	LINDT AND SPRUNGLI USA/BLDG E	STRATHAM	3/16/2020	ND	ND	ND	ND
2236120-001	MILLBROOK OFFICE PARK	STRATHAM	5/18/2021	2.83	ND	ND	ND
2232070-511	MONTROSE CONDOS	STRATHAM	4/20/2021	3.45	ND	ND	ND
2232130-502	MUIRFIELD CLUSTER	STRATHAM	1/27/2021	ND	ND	ND	ND
2236070-002	NP STRATHAM	STRATHAM	7/20/2021	ND	21	ND	ND
2236070-501	NP STRATHAM	STRATHAM	7/20/2021	3.11	2.49	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE #	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
2232040-000	PENINSULA AT WINDING BROOK	STRATHAM	3/3/2020	ND	ND	ND	ND
2232080-502	PHEASANT RUN CONDOS	STRATHAM	12/11/2020	ND	ND	ND	ND
2236100-001	PIPERS LANDING	STRATHAM	1/14/2022	68.5	52.4	ND	90.6
2236090-002	RCN CONDOS	STRATHAM	9/27/2021	22.4	7.4	ND	ND
2236090-502	RCN CONDOS	STRATHAM	3/10/2022	20	8.03	ND	ND
2232210-501	ROLLINS HILL	STRATHAM	1/13/2021	ND	ND	ND	ND
2232030-501	SALT RIVER CONDOS	STRATHAM	10/18/2021	8.12	4.59	ND	2.22
2236130-504	STRATHAM CENTRAL CONDOS	STRATHAM	1/3/2022	ND	ND	ND	ND
2239010-501	STRATHAM COMMUNITY CHURCH	STRATHAM	6/17/2021	3.39	ND	ND	ND
2236140-501	STRATHAM CROSSING 7621	STRATHAM	10/18/2021	30.2	ND	ND	ND
2236140-504	STRATHAM CROSSING 7621	STRATHAM	4/12/2022	24.3	ND	ND	ND
2232050-501	STRATHAM GREEN CONDOS - PFAS TREATMENT	STRATHAM	1/14/2022	ND	ND	ND	ND
2235050-501	STRATHAM MEMORIAL SCH	STRATHAM	9/23/2021	13.8	5.27	ND	ND
2236050-001	STRATHAM PLAZA	STRATHAM	9/20/2021	12.5	5.38	ND	ND
2238060-503	STRATHAM PLZ/MARKET BASKET	STRATHAM	3/23/2022	32.9	15.6	4.04	ND
2232090-000	STRATHAM WOODS	STRATHAM	12/23/2020	ND	ND	ND	ND
2232020-502	THORNHILL CONDOS	STRATHAM	4/6/2020	ND	ND	ND	ND
2232110-501	TURNBERRY	STRATHAM	1/8/2021	ND	ND	ND	ND
2232190-001	VINEYARDS	STRATHAM	3/25/2021	ND	ND	ND	ND
2271020-502	GEORGES MILLS WATER WORKS	SUNAPEE	2/13/2020	ND	ND	ND	ND
2272020-502	MEADOW BROOK AT SUNAPEE	SUNAPEE	3/25/2020	ND	ND	ND	ND
2275020-001	MOUNT ROYAL ACADEMY	SUNAPEE	12/30/2020	ND	ND	ND	ND
2271010-002	SUNAPEE WATER WORKS	SUNAPEE	2/13/2020	ND	ND	ND	ND
2285010-501	SURRY VILLAGE CHARTER SCH	SURRY	12/21/2020	ND	ND	ND	ND
2281010-001	SURRY VILLAGE WATER	SURRY	6/10/2020	ND	ND	ND	ND
2295010-502	KEARSARGE REGIONAL HIGH SCH	SUTTON	12/22/2020	ND	ND	ND	ND
2295030-502	KEARSARGE REGIONAL MIDDLE SCH	SUTTON	1/11/2022	6.36	ND	ND	ND
2295030-511	KEARSARGE REGIONAL MIDDLE SCH	SUTTON	3/4/2020	150	ND	ND	6.34
2296010-002	LABSPHERE	SUTTON	10/27/2021	3.92	4.5	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE #	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
2295020-501	SUTTON CENTRAL SCH	SUTTON	12/22/2020	ND	ND	ND	ND
2302010-001	ASHUELOT RIVER APTS	SWANZEY	10/30/2019	ND	ND	ND	ND
2302040-505	EASTFIELD CROSSING	SWANZEY	11/5/2019	ND	ND	ND	ND
2302050-500	FOREST VIEW ESTATES	SWANZEY	10/30/2019	ND	ND	ND	ND
2305050-501	MONADNOCK REGIONAL HIGH SCH	SWANZEY	11/12/2019	ND	ND	ND	ND
2303010-010	PINE GROVE MOBILE HOME PARK	SWANZEY	8/19/2021	ND	ND	ND	ND
2303010-508	PINE GROVE MOBILE HOME PARK	SWANZEY	8/19/2021	2.09	ND	ND	ND
2306060-501	TOYOTA OF KEENE	SWANZEY	7/13/2020	ND	ND	ND	ND
2303020-500	VIEW POINT COOP	SWANZEY	10/30/2019	ND	ND	ND	ND
2301020-501	WEST SWANZEY WATER	SWANZEY	7/15/2020	ND	ND	ND	ND
2312070-501	CHOCORUA MEADOWS	TAMWORTH	10/23/2019	ND	ND	ND	ND
2312060-001	CHOCORUA WOODS	TAMWORTH	2/11/2020	ND	ND	ND	ND
2315030-501	COMMUNITY SCH	TAMWORTH	1/8/2021	ND	ND	ND	ND
2312090-501	HIGHLAND PLACE	TAMWORTH	7/20/2021	ND	ND	ND	ND
2315010-501	KENNETH A BRETT SCH	TAMWORTH	3/15/2021	ND	ND	ND	ND
2312020-501	MOUNTAIN VIEW ESTATES	TAMWORTH	4/6/2021	ND	ND	ND	ND
2318090-503	NORTHWAY APTS/DAYS INN	TAMWORTH	3/16/2020	ND	ND	ND	ND
2312050-503	REMICK ACRES	TAMWORTH	1/27/2021	ND	ND	ND	ND
2313010-000	TAMWORTH MOBILE HOME PARK	TAMWORTH	10/23/2019	ND	ND	ND	ND
2313020-000	TAMWORTH PINES	TAMWORTH	8/12/2021	2.96	ND	ND	ND
2315020-001	TAMWORTH PRESCHOOL	TAMWORTH	12/29/2020	ND	ND	ND	ND
2311010-005	TAMWORTH WATER WORKS	TAMWORTH	3/10/2020	ND	ND	ND	ND
2312030-501	WHITE LAKE ESTATES	TAMWORTH	3/10/2020	ND	ND	ND	ND
2342010-512	175 ESTATES	THORNTON	2/18/2020	ND	ND	ND	ND
2342090-001	BIRCH BEND	THORNTON	1/8/2020	ND	ND	ND	ND
2342100-001	CONE RIDGE APTS	THORNTON	1/20/2021	ND	ND	ND	ND
2342110-505	MILL BROOKE VILLAGE	THORNTON	3/9/2021	ND	ND	ND	ND
2342030-001	MOUNTAIN RIVER CONDOS	THORNTON	4/2/2021	ND	ND	ND	ND
2342040-000	MOUNTAIN RIVER CONDOS EAST	THORNTON	4/2/2021	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE #	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
2342020-502	NORTHPOINTE WATER	THORNTON	4/22/2021	5.41	ND	ND	ND
2348110-500	OWLS NEST GC AND CONDOS	THORNTON	1/20/2021	ND	ND	ND	ND
2342080-000	STAR RIDGE	THORNTON	2/3/2021	ND	ND	ND	ND
2345010-002	THORNTON CENTRAL SCH	THORNTON	2/12/2020	ND	ND	ND	ND
2342070-002	WATERVILLE ACRES CONDOS	THORNTON	2/11/2020	ND	ND	ND	ND
2342060-002	WHITE MOUNTAIN RESORT/GATEWAY	THORNTON	2/18/2020	ND	ND	ND	ND
2356010-001	3M TILTON	TILTON	9/7/2021	ND	ND	ND	ND
2356100-001	AUTOSERV OF TILTON	TILTON	11/6/2019	ND	ND	ND	ND
2356080-001	BJS WHOLESALE CLUB 309	TILTON	3/31/2021	ND	ND	ND	ND
2353040-502	COUNTRY MEADOWS	TILTON	2/26/2021	ND	ND	ND	ND
2356110-001	EVERSOURCE ENERGY TILTON AWC	TILTON	4/8/2021	ND	ND	ND	ND
2351020-501	LOCHMERE VILLAGE DIST	TILTON	3/21/2022	ND	7.63	ND	24.9
2352020-001	PEU/NORTHERN SHORES	TILTON	1/19/2021	ND	ND	ND	ND
2353010-501	RODGERS DEV	TILTON	11/6/2019	ND	ND	ND	ND
2356060-501	TANGER OUTLET CENTER	TILTON	11/6/2019	ND	ND	ND	ND
2351010-503	TILTON NORTHFIELD WATER DIST	TILTON	6/7/2021	ND	ND	ND	ND
2351010-504	TILTON NORTHFIELD WATER DIST	TILTON	6/7/2021	ND	ND	ND	ND
2356020-001	TOWN LINE PLAZA	TILTON	6/18/2021	2.09	3.05	ND	2.89
2353020-501	WINDY HILL/NORTH	TILTON	4/2/2021	ND	ND	ND	ND
2353090-002	WINDY HILL/SOUTH	TILTON	4/2/2021	ND	ND	ND	ND
2352010-002	WINNISQUAM RESORT CONDOS	TILTON	2/3/2021	ND	ND	ND	ND
2352040-501	WINNISQUAM VILLAGE CONDOS	TILTON	5/1/2021	ND	ND	ND	ND
2361010-503	TROY WATER WORKS	TROY	3/16/2021	ND	ND	ND	ND
2361010-504	TROY WATER WORKS	TROY	3/16/2021	ND	ND	ND	ND
2361010-505	TROY WATER WORKS	TROY	3/16/2021	ND	ND	ND	ND
2361010-512	TROY WATER WORKS	TROY	3/16/2021	ND	ND	ND	ND
2372020-002	HIDDEN VALLEY/MASON	TUFTONBORO	3/12/2020	ND	ND	ND	ND
2372020-006	HIDDEN VALLEY/MASON	TUFTONBORO	3/12/2020	ND	ND	ND	ND
2373010-000	NORTH COUNTRY VILLAGE	TUFTONBORO	1/13/2021	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE #	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
2376010-003	PAK 2000 OFFICE	TUFTONBORO	8/29/2016	ND	ND	ND	ND
2375010-502	TUFTONBORO CENTRAL SCH	TUFTONBORO	6/29/2021	ND	ND	ND	ND
2372050-501	WINMIR CONDOS	TUFTONBORO	6/23/2021	ND	ND	ND	ND
2384010-003	SULLIVAN COUNTY COMPLEX	UNITY	2/18/2021	ND	ND	ND	ND
2384010-507	SULLIVAN COUNTY COMPLEX	UNITY	2/18/2021	ND	ND	ND	ND
2384010-514	SULLIVAN COUNTY COMPLEX	UNITY	2/22/2021	ND	ND	ND	ND
2385010-511	UNITY ELEMENTARY SCH	UNITY	3/12/2021	ND	ND	ND	ND
2392010-501	BEVERLY HILLS WATER	WAKEFIELD	4/14/2021	ND	ND	ND	ND
2395020-001	LEARNING WITH LOVE	WAKEFIELD	10/3/2019	ND	ND	ND	ND
2392030-500	MICHAWANIC VILLAGE CONDOS	WAKEFIELD	3/12/2020	ND	ND	ND	ND
2395030-501	PINE RIVER POND CNTRY DAYCARE	WAKEFIELD	8/10/2021	ND	ND	ND	ND
2391010-502	SANBORNVILLE WATER DEPT	WAKEFIELD	9/8/2021	ND	2	ND	ND
2391010-503	SANBORNVILLE WATER DEPT	WAKEFIELD	2/26/2021	ND	ND	ND	ND
2392020-001	WAKEFIELD ACRES	WAKEFIELD	2/10/2021	ND	ND	ND	ND
2406010-101	BENSON WOODWORKING	WALPOLE	3/12/2021	ND	ND	ND	ND
2405010-501	DREWSVILLE CARRIAGE HOUSE	WALPOLE	1/20/2021	ND	ND	ND	ND
2401030-501	N WALPOLE VILLAGE DIST/HIGH	WALPOLE	9/30/2021	ND	ND	ND	ND
2401020-507	N WALPOLE VILLAGE DISTRICT/LOW	WALPOLE	9/30/2021	ND	ND	ND	ND
2401020-508	N WALPOLE VILLAGE DISTRICT/LOW	WALPOLE	9/29/2021	ND	ND	ND	ND
2401010-001	WALPOLE WATER DEPT	WALPOLE	7/14/2020	ND	ND	ND	ND
2401010-502	WALPOLE WATER DEPT	WALPOLE	7/14/2020	ND	ND	ND	ND
2415010-501	MAGDALEN COLLEGE	WARNER	11/25/2020	ND	ND	ND	ND
2413010-503	PLEASANT LAKE MHP	WARNER	12/14/2021	ND	ND	ND	ND
2411010-503	WARNER VILLAGE WATER DIST	WARNER	4/28/2021	ND	ND	ND	ND
2411010-504	WARNER VILLAGE WATER DIST	WARNER	4/28/2021	ND	ND	ND	ND
2421010-002	GLENCLIFF IMPROVEMENT	WARREN	9/13/2021	ND	ND	ND	ND
2422010-502	SOUTH MAIN STREET WATER DIST	WARREN	9/14/2021	ND	ND	ND	ND
2435020-001	WASHINGTON ELEMENTARY SCH	WASHINGTON	1/25/2021	ND	ND	ND	ND
2441010-502	WATERVILLE VALLEY WATER DIST	WATERVILLE VALLEY	3/3/2020	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE #	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
2441010-503	WATERVILLE VALLEY WATER DIST	WATERVILLE VALLEY	3/3/2020	ND	ND	ND	ND
2441010-504	WATERVILLE VALLEY WATER DIST	WATERVILLE VALLEY	3/3/2020	ND	ND	ND	ND
2455060-501	CENTER WOOD ELEM SCH	WEARE	4/7/2021	ND	ND	ND	ND
2452040-501	COLLINS LANDING	WEARE	1/25/2021	ND	ND	ND	ND
2458030-002	COUNTRY THREE CORNERS	WEARE	8/9/2018	ND	ND	ND	ND
2456010-003	GRANITE STATE TELEPHONE	WEARE	8/5/2016	ND	ND	ND	ND
2455040-003	JOHN STARK REG HIGH SCH	WEARE	4/7/2021	3.7	1	ND	ND
2453020-000	KUNCANOWET HILLS MHP	WEARE	9/2/2021	ND	ND	ND	ND
2458070-501	LANCTOTS CENTER	WEARE	1/23/2020	ND	ND	ND	ND
2452010-501	PEU/DANIELS LAKE	WEARE	7/8/2021	ND	ND	ND	ND
2452030-514	SOUTH WEARE WATER	WEARE	11/5/2019	ND	ND	ND	ND
2452030-515	SOUTH WEARE WATER	WEARE	11/20/2019	ND	ND	ND	ND
2453010-005	SUGAR HILL MANOR MHP	WEARE	12/18/2020	ND	ND	ND	ND
2459010-001	TOWN OFFICES	WEARE	8/5/2021	ND	2.12	ND	ND
2458060-001	WEARE CENTER PLAZA	WEARE	12/13/2021	ND	ND	ND	ND
2455080-001	WEARE MIDDLE SCH	WEARE	11/6/2019	ND	ND	ND	ND
2455020-001	WEARE MIDDLE SCHOOL	WEARE	11/3/2016	ND	ND	ND	ND
2462040-003	PILLSBURY LAKE/FRANKLIN PIERCE	WEBSTER	4/28/2021	ND	ND	ND	ND
2462040-500	PILLSBURY LAKE/FRANKLIN PIERCE	WEBSTER	4/28/2021	ND	ND	ND	ND
2462050-502	PILLSBURY LAKE/PENINSULA	WEBSTER	4/28/2021	ND	ND	ND	ND
2465010-001	WEBSTER ELEMENTARY SCH	WEBSTER	12/30/2020	ND	ND	ND	ND
2475010-001	WENTWORTH ELEMENTARY SCH	WENTWORTH	2/12/2020	ND	ND	ND	ND
2494010-006	CHESHIRE COUNTY COMPLEX	WESTMORELAND	10/8/2019	ND	ND	ND	ND
2494010-007	CHESHIRE COUNTY COMPLEX	WESTMORELAND	10/8/2019	ND	ND	ND	ND
2495030-001	WESTMORELAND ELEMENTARY SCH	WESTMORELAND	12/21/2020	ND	ND	ND	ND
2505010-002	WHITE MTN REG HS	WHITEFIELD	3/31/2021	ND	ND	ND	ND
2501010-001	WHITEFIELD WATER	WHITEFIELD	4/28/2021	ND	ND	ND	ND
2501010-008	WHITEFIELD WATER	WHITEFIELD	4/28/2021	ND	ND	ND	ND
2501010-009	WHITEFIELD WATER	WHITEFIELD	4/28/2021	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE #	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
2501010-010	WHITEFIELD WATER	WHITEFIELD	4/28/2021	ND	ND	ND	ND
2501010-012	WHITEFIELD WATER	WHITEFIELD	4/28/2021	ND	ND	ND	ND
2501010-514	WHITEFIELD WATER	WHITEFIELD	4/28/2021	ND	ND	ND	ND
2512010-001	POUND ROAD WATER WORKS	WILMOT	4/8/2021	ND	ND	ND	ND
2525010-512	HIGH MOWING SCH	WILTON	7/15/2021	4.02	ND	ND	ND
2526040-501	KIMBALL PHYSICS	WILTON	2/12/2020	ND	ND	ND	ND
2525030-501	PINE HILL WALDORF CHLD VILLAGE	WILTON	10/22/2019	ND	ND	ND	ND
2525020-502	PINE HILL WALDORF SCH	WILTON	10/22/2019	ND	ND	ND	ND
2521010-505	WILTON WATER WORKS	WILTON	9/16/2020	ND	ND	ND	ND
2521010-506	WILTON WATER WORKS	WILTON	12/22/2020	ND	ND	ND	ND
2533020-000	GREEN VALLEY MOBILE HOME PARK	WINCHESTER	7/13/2021	ND	ND	ND	ND
2533010-501	SOUTH PARRISH	WINCHESTER	7/13/2020	ND	ND	ND	ND
2531010-501	WINCHESTER WATER DEPT	WINCHESTER	1/14/2021	ND	ND	ND	ND
2531010-502	WINCHESTER WATER DEPT	WINCHESTER	1/14/2021	ND	ND	ND	ND
2531010-503	WINCHESTER WATER DEPT	WINCHESTER	1/15/2021	ND	ND	ND	ND
2546240-501	183 ROCKINGHAM ROAD	WINDHAM	8/11/2021	3.33	ND	ND	ND
2546020-001	AP DAILEY	WINDHAM	8/11/2021	6.51	2.73	ND	ND
2546020-501	AP DAILEY	WINDHAM	3/8/2022	ND	ND	ND	ND
2542190-503	CAMELOT III	WINDHAM	8/11/2021	6.93	ND	ND	ND
2546170-001	CAPITAL TRANSPORTATION	WINDHAM	6/16/2021	8.68	ND	ND	ND
2546080-501	CASTLE COMMONS	WINDHAM	8/12/2021	4.93	5.07	ND	4.54
2546150-001	COBBETTS PROF PARK	WINDHAM	8/25/2021	2.68	ND	ND	ND
2546090-001	COMMONS AT WINDHAM 1/WEST BLDG	WINDHAM	7/20/2017	7	6	10	ND
2546160-501	COMMONS AT WINDHAM 2/EAST BLDG	WINDHAM	3/11/2022	8.6	8.05	ND	2.47
2546200-501	CYR LUMBER	WINDHAM	9/7/2021	4.8	7.28	ND	ND
2548150-001	DUNKIN DONUTS /PC 346676 UNTREATED	WINDHAM	7/20/2017	27	100	159	ND
2546220-501	FIVE INDUSTRIAL DR	WINDHAM	8/9/2021	6.06	ND	ND	6.59
2546250-502	GATEWAY PARK	WINDHAM	4/22/2021	2.57	ND	ND	ND
2545020-501	GOLDEN BROOK SCH	WINDHAM	1/4/2021	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE #	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
2542160-502	HADLEIGH WOODS	WINDHAM	8/2/2021	9.27	ND	ND	ND
2548170-001	HOWIE GLYNN AND SONS CONV STRE	WINDHAM	7/31/2017	6	27	40	ND
2546260-501	INDIAN ROCK OFFICE PARK II	WINDHAM	10/7/2021	6.18	2.53	ND	ND
2546180-001	KAHUNA	WINDHAM	2/4/2020	ND	ND	ND	ND
2545080-501	KIDDIE ACADEMYU	WINDHAM	9/9/2021	8.45	ND	ND	ND
2542130-001	MCAULEY COMMONS	WINDHAM	1/27/2021	ND	ND	ND	ND
2546230-501	MEDICUS OFFICES	WINDHAM	1/13/2022	9.75	4.04	ND	4.04
2549050-001	NESMITH LIBRARY	WINDHAM	4/9/2018	6.4	ND	0.99	ND
2542140-501	PEU/CASTLE REACH	WINDHAM	7/6/2021	9.96	ND	ND	ND
2542150-502	PEU/FLETCHER CORNER ESTATES	WINDHAM	2/4/2020	ND	ND	ND	ND
2542010-501	PEU/GOLDEN BROOK	WINDHAM	7/7/2021	2.4	ND	ND	ND
2542060-503	PEU/HARDWOOD HTS BIRCH HILL	WINDHAM	7/6/2021	8.44	4.9	ND	ND
2542170-500	PEU/LAMPLIGHTER VILLAGE	WINDHAM	7/6/2021	3.9	ND	ND	ND
2542180-501	PEU/SPRUCE POND ESTS	WINDHAM	7/6/2021	6.67	ND	ND	ND
2542030-003	PEU/W AND E	WINDHAM	7/6/2021	6.59	2.36	ND	2.55
2542030-504	PEU/W AND E	WINDHAM	4/5/2022	7.92	3.34	ND	2.72
2549020-001	SENIOR CITIZENS CENTER	WINDHAM	5/2/2018	6.8	31	10	1.8
2546190-502	SHAWS SUPERMARKET 686	WINDHAM	4/11/2022	8.03	4.34	ND	ND
2549010-001	TOWN HALL/PLANNING/DEV/TV STAT	WINDHAM	6/7/2017	8	16	8	ND
2542070-501	VILLAGES OF WINDHAM	WINDHAM	7/19/2021	5.82	2.08	ND	ND
2544010-501	WARDE REHABILITATION/NURSING	WINDHAM	1/22/2022	7.13	5.37	ND	2.45
2545110-501	WEE CARE LEARNING CTR	WINDHAM	8/9/2021	10.6	2.53	ND	5.82
2546070-501	WINDHAM ACADEMY	WINDHAM	9/2/2021	7.3	7.15	ND	15.5
2545010-501	WINDHAM CENTER SCH - PFAS TREATMENT INSTALLED	WINDHAM	2/23/2022	ND	ND	ND	ND
2545010-502	WINDHAM CENTER SCH - PFAS TREATMENT INSTALLED	WINDHAM	9/22/2021	ND	ND	ND	ND
2545090-001	WINDHAM COOPTVE KINDERGARTEN	WINDHAM	11/5/2019	ND	ND	ND	ND
2545040-501	WINDHAM CROSSING LEARNING CTR	WINDHAM	7/20/2021	3.95	2.05	ND	ND
2545100-501	WINDHAM HIGH SCH	WINDHAM	9/29/2021	5.98	ND	ND	ND
2545030-501	WINDHAM MIDDLE SCH	WINDHAM	9/22/2021	ND	ND	ND	ND



Table 1 - Public Water System
PFAS Water Quality Summary

WATER SOURCE #	WATER SYSTEM NAME	TOWN	DATE SAMPLED	Max PFOA Detected (ng/L) MCL/AGQS = 12	Max PFOS Detected (ng/L) MCL/AGQS = 15	Max PFNA Detected (ng/L) MCL/AGQS = 11	Max PFHxS Detected (ng/L) MCL/AGQS = 18
2546030-502	WINDHAM PLAZA	WINDHAM	3/10/2021	ND	ND	ND	ND
2544020-501	WINDHAM TERRACE	WINDHAM	7/12/2021	8.81	9.54	ND	4.37
2548180-001	WINDHAM TOWNE SHOPPES	WINDHAM	8/24/2017	10.9	7.79	ND	ND
2546110-001	WINDHAM VILLAGE GREEN	WINDHAM	8/9/2021	3.36	3.22	ND	ND
2547060-501	WINDHAM WOODS SCH	WINDHAM	9/21/2021	ND	2.3	ND	ND
2542200-501	WOOD MEADOW ESTATES	WINDHAM	1/20/2021	ND	ND	ND	ND
2542080-500	WYNRIDGE CONDOS	WINDHAM	9/16/2021	4.21	ND	ND	ND
2557060-501	WEDIKO KITCHEN	WINDSOR	2/3/2021	ND	ND	ND	ND
2552010-501	WEDIKO SCHOOL	WINDSOR	7/12/2021	4.69	7.16	ND	ND
2552010-502	WEDIKO SCHOOL	WINDSOR	2/3/2021	ND	ND	ND	ND
2552010-513	WEDIKO SCHOOL	WINDSOR	2/3/2021	ND	ND	ND	ND
2563010-000	BIRCH OF WOLFBORO COOP	WOLFEBORO	5/28/2021	2.07	ND	ND	ND
2562030-001	POINT BREEZE CONDOS	WOLFEBORO	1/13/2021	ND	ND	ND	ND
2562050-502	SHERWOOD FOREST	WOLFEBORO	1/8/2020	ND	ND	ND	ND
2562010-001	WENTWORTH ESTATES	WOLFEBORO	7/12/2021	ND	ND	ND	3.76
2561010-002	WOLFEBORO WATER AND SEWER	WOLFEBORO	8/19/2020	ND	ND	ND	ND
2572010-501	JACK O LANTERN CONDOS	WOODSTOCK	2/3/2020	ND	ND	ND	ND
2571020-502	WOODSTOCK WATER DEPT	WOODSTOCK	11/14/2019	ND	ND	ND	ND
2571020-503	WOODSTOCK WATER DEPT	WOODSTOCK	11/14/2019	ND	ND	ND	ND

NOTES:

1. Concentrations shown are in parts per trillion (ppt) or nanograms per liter (ng/L).
2. Cells that are shaded gray indicate an exceedance of the current Maximum Contaminant Level (MCL) and the Ambient Groundwater Quality Standards (AGQS) included in Env-Or 600 Contaminated Site Management.
3. NH's four regulated PFAS compounds include: perfluorooctanoic acid (PFOA), perfluorooctane sulfonic acid (PFOS), perfluorohexane sulfonic acid (PFHxS), and perfluorononanoic acid (PFNA).
4. 'ND' indicates the analyzed PFAS was not detected above the laboratory reporting limit.
5. Data represents the most recent PFAS sampling result at the water system and may reflect post-PFAS treatment system results.



Table 2 - Solid Waste Facility
PFAS Water Quality Summary

NHDES Site #	Site Name	Project Type	Town	Max PFOA Detected (ng/L) AGQS = 12	Max PFOS Detected (ng/L) AGQS = 15	Max PFNA Detected (ng/L) AGQS = 11	Max PFHxS Detected (ng/L) AGQS = 18
198400001	ACWORTH TOWN LANDFILL	LAND/UNLN	ACWORTH	93	11.2	ND	15.7
198802002	KANCAMAGUS LANDFILL	LAND/UNLN	ALBANY	ND	ND	ND	ND
198705017	INDECK ALEXANDRIA ENERGY CTR	LWW/LAG	ALEXANDRIA	ND	ND	ND	ND
199012032	TOWN OF ALLENSTOWN	LAND/UNLN	ALLENSTOWN	34	219	2.2	146
198400006	ALTON TOWN LANDFILL	LAND/UNLN	ALTON	63	15	ND	13
198704029	SOUHEGAN REG LANDFILL	LAND/UNLN	AMHERST	20	3.58	0.44	6.12
198704047	ANDOVER TOWN LANDFILL	LAND/UNLN	ANDOVER	9.54	ND	ND	ND
198904068	WASTEWATER TRT FACILITY	LWW/LAG	ANTRIM	17.6	7.26	ND	13.8
198705020	ASHLAND MUNICIPAL LANDFILL	LAND/UNLN	ASHLAND	ND	ND	ND	ND
198400026	GODIN SITE	LAND/UNLN	ATKINSON	11	20.8	ND	ND
199002015	AUBURN TOWN LANDFILL	LAND/UNLN	AUBURN	97	78	3.2	31.5
198806003	BARRINGTON LANDFILL	LAND/UNLN	BARRINGTON	11.4	3.52	ND	2.45
198704028	BARTLETT LANDFILL	LAND/UNLN	BARTLETT	ND	ND	ND	ND
198704084	BEDFORD LANDFILL	LAND/UNLN	BEDFORD	57.9	54.9	ND	78.4
198704071	HURRICANE ROAD STUMP DUMP	LAND/UNLN	BELMONT	ND	ND	ND	ND
198704042	BENNINGTON TRI-TOWN LANDFILL	LAND/UNLN	BENNINGTON	11	ND	ND	ND
198400054	BERLIN TOWN LANDFILL I	LAND/UNLN	BERLIN	129	90.9	ND	12.6
198400055	CATES HILL LANDFILL	LAND/UNLN	BERLIN	ND	ND	ND	ND
198704035	DUMMER YARD LANDFILL - JAMES RIVER	LAND/UNLN	BERLIN	424	740	13.2	21.6
198400057	BETHLEHEM TOWN LANDFILL (OLD)	LAND/UNLN	BETHLEHEM	75	99.6	8.4	24.1
198704033	NORTH COUNTRY ENVIRONMENTAL SERVICES LF	LAND/LN	BETHLEHEM	64	12.6	8.72	13.8
198400060	WASTE WATER TREATMENT PLANT	LWW/LAG	BETHLEHEM	ND	ND	ND	ND
199101052	CALIFORNIA FIELDS	LAND/UNLN	BOSCAWEN	17	10	ND	6
198901021	CORN HILL ROAD LANDFILL	LAND/UNLN	BOSCAWEN	189	59.6	4.87	108
198400064	BOW TOWN LANDFILL	LAND/UNLN	BOW	3.7	3.6	ND	ND
198400065	MERRIMACK STATION AND ASH LANDFILL	LAND/LN	BOW	ND	ND	ND	ND
198400069	FMR NAUGHTON LANDFILL & AUTOCRAFT SITE	LAND/UNLN	BRADFORD	57	59	2.7	36.3
199101059	BRIDGEWATER DUMP/INCINERATOR	LAND/UNLN	BRIDGEWATER	7.81	ND	ND	4.6
198704078	NEW HAMPTON LANDFILL	LAND/UNLN	BRISTOL	ND	ND	ND	ND
198400082	CANDIA TOWN LANDFILL	LAND/UNLN	CANDIA	78.5	56.6	1.99	7.3



Table 2 - Solid Waste Facility
PFAS Water Quality Summary

NHDES Site #	Site Name	Project Type	Town	Max PFOA Detected (ng/L) AGQS = 12	Max PFOS Detected (ng/L) AGQS = 15	Max PFNA Detected (ng/L) AGQS = 11	Max PFHxS Detected (ng/L) AGQS = 18
198400084	CANTERBURY TOWN LANDFILL	LAND/UNLN	CANTERBURY	196	1337	4	791
198705080	CARROLL TOWN LANDFILL	LAND/UNLN	CARROLL	89.3	ND	ND	28
198809009	CENTER HARBOR LANDFILL	LAND/UNLN	CENTER HARBOR	11.4	20.8	ND	ND
198400087	CHARLESTOWN LANDFILL/TRANSFER STATION	LAND/UNLN	CHARLESTOWN	63.9	28.3	ND	5.06
198704036	CHESTER MUNICIPAL LF	LAND/UNLN	CHESTER	28.3	9.12	0	4.74
198706002	CLAREMONT LANDFILL	LAND/UNLN	CLAREMONT	729	477	44	54.9
198400096	COLEBROOK MUNICIPAL LANDFILL	LAND/UNLN	COLEBROOK	229	22.9	12.7	59.8
201202055	TILLOTSON RUBBER LIQUID WASTE DISP AREA	LAND/UNLN	COLEBROOK	196	8.13	ND	5.82
198401001	CONCORD CITY LANDFILL/TRANSFER STATION	LAND/UNLN	CONCORD	16.2	19.8	ND	5.34
198406038	OLD SUNCOOK ROAD LANDFILL (1)	LAND/UNLN	CONCORD	186	22.9	ND	29.1
198401017	CONWAY LANDFILL/SEPTAGE LAGOONS	LAND/UNLN	CONWAY	82.3	5.05	ND	14.9
198908068	LOWER MT WASHINGTON VALLEY LANDFILL	LAND/LN	CONWAY	40.6	4.31	5.47	8.18
199103019	CROYDON LANDFILL	LAND/UNLN	CROYDON	11	13	ND	3.2
198810003	OLD LANDFILL/X-FER STATION	LAND/UNLN	DALTON	58.9	9	828	ND
198401031	DEERFIELD LANDFILL	LAND/UNLN	DEERFIELD	14.4	4.47	ND	ND
198706001	DERRY MUNICIPAL LANDFILL	LAND/UNLN	DERRY	20.1	13.4	ND	5.6
198401060	DUBLIN SANITARY LANDFILL	LAND/UNLN	DUBLIN	26.4	81	0.91	1.87
199006011	DURHAM LANDFILL	LAND/UNLN	DURHAM	28	41	0.66	26
198805021	EFFINGHAM TOWN LANDFILL	LAND/UNLN	EFFINGHAM	35.7	388	5.89	92.2
198401071	BULKY WASTE LANDFILL & OLD DUMP SITE	LAND/UNLN	EPPING	505	174	25.4	519
198406000	ERROL LANDFILL	LAND/UNLN	ERROL	20.6	6.61	ND	ND
198401081	CROSS ROAD LANDFILL/STUMP DUMP (TOWN)	LAND/UNLN	EXETER	7.53	7.04	ND	ND
198401085	FARMINGTON MUNICIPAL LANDFILL	LAND/UNLN	FARMINGTON	407	312	ND	98.4
198401092	CONCORD REG COOP RESIDUE LANDFILL	LAND/LN	FRANKLIN	ND	ND	ND	ND
198401090	OLD FRANKLIN LANDFILL	LAND/UNLN	FRANKLIN	33.9	34	ND	5.9
199101056	FREEDOM LANDFILL	LAND/UNLN	FREEDOM	24.9	54.1	ND	ND
198906002	GILMANTON LANDFILL	LAND/UNLN	GILMANTON	387	227	9.74	58.1
198402003	GILSUM LANDFILL/SEPTAGE PIT	LAND/UNLN	GILSUM	287	1150	14.4	9.73
198402005	GOFFSTOWN MUNICIPAL LANDFILL	LAND/UNLN	GOFFSTOWN	12.4	10.9	ND	1.6
198705009	GOSHEN SANITARY LANDFILL/TRANSFER STA	LAND/UNLN	GOSHEN	317	1400	5.7	29



Table 2 - Solid Waste Facility
PFAS Water Quality Summary

NHDES Site #	Site Name	Project Type	Town	Max PFOA Detected (ng/L) AGQS = 12	Max PFOS Detected (ng/L) AGQS = 15	Max PFNA Detected (ng/L) AGQS = 11	Max PFHxS Detected (ng/L) AGQS = 18
199102037	GRAFTON OLD LANDFILL	LAND/UNLN	GRAFTON	42.1	382	ND	77.1
199103005	GRANTHAM LANDFILL	LAND/UNLN	GRANTHAM	17.2	9.15	ND	ND
198708004	CROTCHED MOUNTAIN FOUNDATION	LAND/UNLN	GREENFIELD	ND	ND	ND	ND
199102032	GROTON TOWN DUMP	LAND/UNLN	GROTON	8.15	17.6	0.52	0.58
198402023	HAMPTON MUNICIPAL LANDFILL	LAND/UNLN	HAMPTON	77.5	95.6	6	8.71
198705010	HANCOCK TOWN LANDFILL	LAND/UNLN	HANCOCK	140	1330	15	261
198708010	HARRISVILLE TOWN LANDFILL	LAND/UNLN	HARRISVILLE	97.1	93.5	2	11.3
198402028	HENNIKER TOWN LANDFILL/TRANSFER STATION	LAND/UNLN	HENNIKER	ND	55.4	ND	ND
198704088	HILLSBORO TOWN LANDFILL/X-FER STATION	LAND/UNLN	HILLSBOROUGH	430	370	110	12
198704004	HILLSBORO WWTF	LWW/LAG	HILLSBOROUGH	1.7	ND	ND	ND
198402033	HINSDALE MUNICIPAL LANDFILL	LAND/UNLN	HINSDALE	826	1550	380	33
198402035	HINSDALE PRODUCTS LANDFILL	LAND/UNLN	HINSDALE	18.6	3.61	ND	ND
199009014	HOLDERNESS LANDFILL	LAND/UNLN	HOLDERNESS	89.5	107	712	16
198402043	HOOKSETT TRANSFER/HIGHWAY	LAND/UNLN	HOOKSETT	62.2	11.3	ND	28.7
199105019	HOPKINTON WASTEWATER TREATMENT FACILITY	LWW/LAG	HOPKINTON	5.92	ND	ND	7
198705021	HOPKINTON/WEBSTER LANDFILL	LAND/UNLN	HOPKINTON	19.3	ND	ND	9.88
199204002	BENSON PARK (FORMER BENSONS ANIMAL PARK)	LAND/UNLN	HUDSON	29.2	16.6	ND	ND
198402057	HUDSON TOWN LANDFILL	LAND/UNLN	HUDSON	186	33.5	2.61	11.1
198712013	JACKSON OLD LANDFILL	LAND/UNLN	JACKSON	7.66	9.5	ND	ND
198402073	JAFFREY LANDFILL & WWTF / ULWW LAGOONS	LAND/UNLN	JAFFREY	ND	ND	ND	ND
198402076	JEFFERSON TOWN LANDFILL	LAND/UNLN	JEFFERSON	0.91	2.8	ND	0.66
199009001	KEENE MUNICIPAL LANDFILL	LAND/UNLN	KEENE	263	355	9.9	57.9
198402082	KEENE OLD CITY LANDFILL	LAND/UNLN	KEENE	22	93	ND	211
198705089	KINGSTON TOWN LANDFILL	LAND/UNLN	KINGSTON	4.99	ND	ND	ND
198709021	LACONIA DISPOSAL GARDENS	LAND/UNLN	LACONIA	ND	ND	ND	ND
198705056	LANCASTER DISPOSAL FACILITY	LAND/UNLN	LANCASTER	20.8	48.1	ND	5.11
198710039	LEBANON LANDFILL	LAND/LN	LEBANON	88.8	15.1	ND	28.5
198403011	LEMPSTER TOWN LANDFILL	LAND/UNLN	LEMPSTER	ND	ND	ND	ND
198704025	LISBON TOWN LANDFILL AND LAGOONS	LAND/UNLN	LISBON	110	18.1	ND	28
198704045	LITTLETON TOWN LANDFILL	LAND/UNLN	LITTLETON	575	70.2	52.4	40



Table 2 - Solid Waste Facility
PFAS Water Quality Summary

NHDES Site #	Site Name	Project Type	Town	Max PFOA Detected (ng/L) AGQS = 12	Max PFOS Detected (ng/L) AGQS = 15	Max PFNA Detected (ng/L) AGQS = 11	Max PFHxS Detected (ng/L) AGQS = 18
199001001	NORTON CO LANDFILL	LAND/UNLN	LITTLETON	11	ND	ND	ND
198804014	SPARTAN CONSOLIDATED	LAND/UNLN	LONDONDERRY	210	200	6.8	29
198801025	LOUDON LANDFILL/X-FER STATION	LAND/UNLN	LOUDON	1160	63.3	55.7	49.9
198403039	MADISON LANDFILL	LAND/UNLN	MADISON	2.8	ND	ND	ND
198403055	MANCHESTER MUNICIPAL LANDFILL	LAND/UNLN	MANCHESTER	532	172	11.8	35.7
198403071	MARLBOROUGH MUNICIPAL LANDFILL	LAND/UNLN	MARLBOROUGH	48.6	62	ND	16.9
199103022	MARLOW MUNICIPAL LANDFILL	LAND/UNLN	MARLOW	139	1600	4.7	7.6
198403073	MEREDITH MUNICIPAL LANDFILL	LAND/UNLN	MEREDITH	91.1	24	ND	12
198403083	MERRIMACK TOWN LANDFILL	LAND/UNLN	MERRIMACK	2450	1680	30	285
198508002	HITCHINER MANUFACTURING LANDFILL	LAND/LN	MILFORD	4.8	ND	NA	NA
198708009	MILFORD SLUDGE DISPOSAL LAND (WWTF)	LAND/LN	MILFORD	197	84.1	7.6	57.9
198908012	MILFORD TRANSFER STATION	LAND/UNLN	MILFORD	47.8	34.4	2	27.7
198403093	MILTON TOWN LANDFILL	LAND/UNLN	MILTON	10.9	25	0	0
198403092	TOWN W W T P	LWW/LAG	MILTON	ND	ND	ND	ND
198705087	FORMER MOULTONBOROUGH TOWN LANDFILL	LAND/UNLN	MOULTONBOROUGH	555	601	19.4	342
198904055	BLUE LINE EXPRESS (WEBSTER SQUARE)	LAND/UNLN	NASHUA	78.4	32.5	ND	24.1
198403099	FOUR HILLS LANDFILL NASHUA RECYCL CTR	LAND/UNLN	NASHUA	246	116	8.38	108
200203021	LINCOLN PARK/COLISEUM AVE. (FMR ADS 207)	LAND/UNLN	NASHUA	90.4	21.8	5.61	7.02
200009057	NASHUA RIVERSIDE LANDFILL	LAND/UNLN	NASHUA	29.6	92.8	ND	5.61
200202018	ROUSSEL PARK	LAND/UNLN	NASHUA	253	2.18	4.28	11.4
198705083	SHADY LANE LANDFILL (FORMER ADS 309)	LAND/UNLN	NASHUA	59.3	47.7	ND	9.73
198404014	NEW BOSTON TRANSFER STATION	LAND/UNLN	NEW BOSTON	15.4	4.21	1.55	2.46
198811009	NEW DURHAM HIGHWAY DEPT	LAND/UNLN	NEW DURHAM	ND	ND	ND	ND
198404017	NEW IPSWICH TOWN LANDFILL	LAND/UNLN	NEW IPSWICH	1100	430	200	156
198404020	NEW LONDON OLD TOWN LANDFILL	LAND/UNLN	NEW LONDON	39.5	42.3	2.7	1
198710013	NEW LONDON STUMP DUMP	LAND/UNLN	NEW LONDON	8.73	13.7	ND	ND
198806028	NEWBURY DEMO DEBRIS LANDFILL	LAND/UNLN	NEWBURY	48	240	2.04	150
198704049	NEWMARKET LANDFILL	LAND/UNLN	NEWMARKET	12	12	ND	4
198705052	NEWPORT MUNICIPAL LANDFILL	LAND/UNLN	NEWPORT	35.7	20	ND	4.81
198908037	NEWPORT WWTF	LWW/LAG	NEWPORT	ND	ND	ND	ND



Table 2 - Solid Waste Facility
PFAS Water Quality Summary

NHDES Site #	Site Name	Project Type	Town	Max PFOA Detected (ng/L) AGQS = 12	Max PFOS Detected (ng/L) AGQS = 15	Max PFNA Detected (ng/L) AGQS = 11	Max PFHxS Detected (ng/L) AGQS = 18
198404027	NH/VT SOLID WASTE PROJECT	LAND/LN	NEWPORT	ND	ND	ND	ND
199101029	NEWTON MUNICIPAL LANDFILL	LAND/UNLN	NEWTON	101	111	2.32	13.2
198704070	NORTHFIELD HIGHWAY GARAGE	LAND/UNLN	NORTHFIELD	25	610	5.9	330
198404034	PIKE INDUSTRIES INC 700	LAND/UNLN	NORTHFIELD	4	ND	ND	ND
198801023	GROVETON LANDFILL	LAND/UNLN	NORTHUMBERLAND	107	232	4.46	300
199001014	NOTTINGHAM MUNICIPAL SOLID WASTE FAC	LAND/UNLN	NOTTINGHAM	2360	239	354	87.6
198809004	ORFORD LANDFILL	LAND/UNLN	ORFORD	61.3	8.05	ND	9.25
198404045	OSSIPEE LANDFILL/INCINERATOR	LAND/UNLN	OSSIPEE	29.1	31	10.7	23
198404052	ROKETENETZ LANDFILL	LAND/UNLN	PELHAM	900	3100	170	92
198404049	PEMBROKE LANDFILL	LAND/UNLN	PEMBROKE	15.3	19.5	ND	4.65
198905054	EMS PARCEL B SITE (OLD TOWN DUMP)	LAND/UNLN	PETERBOROUGH	ND	ND	NA	NA
198404057	PETERBOROUGH TOWN LANDFILL	LAND/UNLN	PETERBOROUGH	39	87	4.1	9.7
198903064	PIERMONT TOWN LANDFILL	LAND/UNLN	PIERMONT	11	20	ND	63.2
199004019	PITTSBURG TRANSFER STATION LF	LAND/UNLN	PITTSBURG	ND	ND	ND	ND
198901008	SW INCIN & TRSFR STA (BCEP)	LAND/UNLN	PITTSFIELD	26	27.6	ND	3.42
199105022	MERIDEN WASTEWATER TREATMENT FACILITY	LWW/LAG	PLAINFIELD	9.53	6.9	ND	ND
198404075	PLAISTOW MUNICIPAL LANDFILL	LAND/UNLN	PLAISTOW	47.9	170	5	13
198404078	PLYMOUTH INCINERATOR/ASH LF	LAND/UNLN	PLYMOUTH	17.6	29.5	3.08	4.6
198404087	JONES AVE LANDFILL & ASH CONTAINMENT	LAND/UNLN	PORTSMOUTH	33	21.8	ND	18
198404088	PSNH SCHILLER STATION	LAND/UNLN	PORTSMOUTH	ND	7.51	ND	ND
198808007	RANDOLPH LANDFILL OLD	LAND/UNLN	RANDOLPH	16.4	11	ND	2
198404092	RAYMOND LANDFILL	LAND/UNLN	RAYMOND	230	2000	7.1	150
198705045	ROCHESTER LANDFILL	LAND/UNLN	ROCHESTER	1100	311	24.9	148
198706010	TLR-I AND III (PHASES I-IV)	LAND/LN	ROCHESTER	460	70	16	20
198706006	TLR-II	LAND/LN	ROCHESTER	41	6.8	7.4	4.1
198808005	RUMNEY LANDFILL	LAND/UNLN	RUMNEY	43.5	54.1	ND	7.48
198704080	RYE GROVE ROAD LANDFILL	LAND/UNLN	RYE	82.3	110	ND	28.1
198705029	RYE MUNICIPAL LANDFILL	LAND/UNLN	RYE	90.1	36	ND	18
198405024	LL & S LANDFILL	LAND/UNLN	SALEM	850	1100	55	230
198405030	SHANNON RD LANDFILL	LAND/UNLN	SALEM	458	631	ND	50.3



Table 2 - Solid Waste Facility
PFAS Water Quality Summary

NHDES Site #	Site Name	Project Type	Town	Max PFOA Detected (ng/L) AGQS = 12	Max PFOS Detected (ng/L) AGQS = 15	Max PFNA Detected (ng/L) AGQS = 11	Max PFHxS Detected (ng/L) AGQS = 18
198405034	SALISBURY TOWN LANDFILL	LAND/UNLN	SALISBURY	22.1	ND	ND	ND
198405036	SANBORNTON TOWN LANDFILL	LAND/UNLN	SANBORNTON	12.4	ND	ND	4.49
198405037	SANDWICH LANDFILL	LAND/UNLN	SANDWICH	4.98	7.67	ND	ND
198910015	SHELBURNE LANDFILL	LAND/UNLN	SHELBURNE	15.4	21.4	ND	2.44
198405054	LAMPREY REGIONAL COOP/SLUDGE ASH LF	LAND/LN	SOMERSWORTH	16	19.8	ND	10
198405050	SPRINGFIELD POWER FMR HEMPHILL POWER	LWW/LAG	SPRINGFIELD	10.3	7.05	ND	ND
198705031	JAMES RIVER BARK PILE	LAND/UNLN	STARK	7.1	ND	ND	ND
198500040	STARK MUNICIPAL LANDFILL	LAND/UNLN	STARK	ND	ND	ND	ND
198500020	STRAFFORD LANDFILL	LAND/UNLN	STRAFFORD	48.4	150	ND	11
199102024	STRATFORD MUNICIPAL LANDFILL	LAND/UNLN	STRATFORD	ND	ND	ND	ND
198909004	STRATHAM LANDFILL	LAND/UNLN	STRATHAM	124	37.2	ND	80.7
198706016	MT CARBERRY LANDFILL	LAND/LN	SUCCESS	240	50.3	14.5	88.4
199103006	SUNAPEE LANDFILL	LAND/UNLN	SUNAPEE	406	271	110	19.5
199105015	W SWANZEY VILLAGE AREA WWTF	LWW/LAG	SWANZEY	3.71	ND	ND	ND
198704017	TAMWORTH TOWN LANDFILL	LAND/UNLN	TAMWORTH	337	127	95.4	12.1
199101060	THORNTON LANDFILL	LAND/UNLN	THORNTON	13.9	ND	ND	ND
198405081	TOWN OF TROY LANDFILL	LAND/UNLN	TROY	62.9	57.9	65	18
198405083	TUFTONBORO TOWN LANDFILL	LAND/UNLN	TUFTONBORO	173	7	5.24	45.8
198809016	UNITY MUNICIPAL LANDFILL	LAND/UNLN	UNITY	3700	92	410	40
198704018	WAKEFIELD TOWN LANDFILL	LAND/UNLN	WAKEFIELD	623	148	130	66.1
198705026	WALPOLE LANDFILL	LAND/UNLN	WALPOLE	54.1	200	ND	15.1
199102030	WARREN DUMP #1	LAND/UNLN	WARREN	ND	ND	ND	ND
198806031	WASHINGTON LANDFILL	LAND/UNLN	WASHINGTON	14	27.7	ND	ND
198704005	WEARE LF/SEPTAGE LAG/TOWN GARAGE	LAND/UNLN	WEARE	7.41	8.19	ND	ND
199102031	WENTWORTH LANDFILL	LAND/UNLN	WENTWORTH	63.6	2.51	ND	25.6
199105008	CHESHIRE COUNTY HOME WWTF & JAIL	LWW/LAG	WESTMORELAND	ND	ND	ND	ND
198806027	WESTMORELAND LANDFILL	LAND/UNLN	WESTMORELAND	82.3	145	2.68	10.9
198801018	DG WHITEFIELD LLC (FMR POWER & LIGHT CO)	LWW/LAG	WHITEFIELD	ND	ND	ND	ND
200111035	MOUNTAIN VIEW GRAND RESORT & SPA	LAND/UNLN	WHITEFIELD	74.4	47.8	ND	8.58
198406001	SEWAGE TREATMENT FAC	LWW/LAG	WHITEFIELD	ND	ND	ND	ND



Table 2 - Solid Waste Facility
PFAS Water Quality Summary

NHDES Site #	Site Name	Project Type	Town	Max PFOA Detected (ng/L) AGQS = 12	Max PFOS Detected (ng/L) AGQS = 15	Max PFNA Detected (ng/L) AGQS = 11	Max PFHxS Detected (ng/L) AGQS = 18
199102009	WHITEFIELD LANDFILL	LAND/UNLN	WHITEFIELD	23.1	8.54	ND	2.71
198704087	WILTON SANITARY LANDFILL	LAND/UNLN	WILTON	20.7	12.3	ND	ND
198704085	WINCHESTER TOWN LANDFILL	LAND/UNLN	WINCHESTER	ND	ND	ND	ND
198801019	WINDHAM TOWN LANDFILL	LAND/UNLN	WINDHAM	20.4	10.5	ND	12.2
199101048	WOLFEBORO ABANDONED DUMP	LAND/UNLN	WOLFEBORO	13	13	ND	8.4
198406014	WOLFEBORO ASH LANDFILL	LAND/UNLN	WOLFEBORO	254	121	7.6	107

NOTES:

1. Concentrations shown are in parts per trillion (ppt) or nanograms per liter (ng/L).
2. Cells that are shaded gray indicate an exceedance of the current Ambient Groundwater Quality Standards (AGQS) included in Env-Or 600 Contaminated Site Management.
3. NH's four regulated PFAS compounds include: perfluorooctanoic acid (PFOA), perfluorooctane sulfonic acid (PFOS), perfluorohexane sulfonic acid (PFHxS), and perfluorononanoic acid (PFNA).
4. 'ND' indicates the analyzed PFAS was not detected above the laboratory reporting limit.
5. 'NA' indicates that the specified PFAS was not analyzed at the site.
6. Data represents highest concentration detected at the Site.



Table 3 - Hazardous Waste Remediation Sites
PFAS Water Quality Summary

NHDES Site #	Site Name	Project Type	Town	Max PFOA Detected (ng/L) AGQS = 12	Max PFOS Detected (ng/L) AGQS = 15	Max PFNA Detected (ng/L) AGQS = 11	Max PFHxS Detected (ng/L) AGQS = 18
201701004	CENTRAL PORTION OF HOWE DRIVE AREA	SITEEVALHW	AMHERST	965	29.8	ND	ND
201605022	FORMER TCI FACILITY	HAZWASTE	AMHERST	18000	120	13	43
201701005	SOUTHERN PORTION OF CALDWELL DRIVE AREA	SITEEVALHW	AMHERST	1090	13	ND	ND
202004027	NORTH HOLLIS ROAD/SOUTH MERRIMACK ROAD	SITEEVALHW	AMHERST/HOLLIS	99	85	ND	5.3
200009045	L W PACKARD & CO INC	SITEEVALHW	ASHLAND	44.4	12.4	ND	ND
198703020	ATKINSON FIRE DEPT	SITEEVALHW	ATKINSON	225	5.59	ND	215
200210001	EMERY DRIVE SITE	HAZWASTE	ATKINSON	10.7	11.2	1.82	2.81
199707009	28 COMMERCIAL COURT (FMR 8 PRISCILLA LN)	HAZWASTE	AUBURN	3	2.38	ND	ND
199809034	88 PRISCILLA LANE PROPERTY	SITEEVALHW	AUBURN	24	100	2.7	33
199608027	FORMER INSURANCE SALVAGE AUCTION	HAZWASTE	AUBURN	3	ND	ND	ND
198406023	TIBBETTS ROAD DRUM SITE	CERCLA	BARRINGTON	2.46	2.71	0.385	0.576
200602025	NASHUA ROAD PROPERTY	HAZWASTE	BEDFORD	23.7	8.75	ND	ND
202004008	SO. NH FE TURNPIKE EXPANSION PROJECT	SITEEVALHW	BEDFORD	303	6.52	2.8	5.02
199709046	CHLOR ALKALI FACILITY (CROWN VANTAGE)	CERCLA	BERLIN	201	70.1	ND	8.99
202001022	FMR ISAACSON STRUCTURAL STEEL-MAP 105-14	SITEEVALHW	BERLIN	307	698	ND	6.17
201703005	FORMER SINCLAIR HOTEL PROPERTY	HAZWASTE	BETHLEHEM	ND	ND	ND	ND
198400061	ALLIED LEATHER CORP./QUEEN ST. LANDFILL	HAZWASTE	BOSCAWEN	ND	ND	ND	ND
198708008	FORMER GRAPHIC PACKAGING	HAZWASTE	BOW	8.84	9.52	1.08	3.78
200610095	OMNI TECHNOLOGIES CORPORATION	HAZWASTE	BRENTWOOD	ND	ND	ND	ND
198906062	ROCKINGHAM COUNTY COMPLEX	HAZWASTE	BRENTWOOD	3800	46000	4500	15000
198706012	FREUDENBERG NOK	HAZWASTE	BRISTOL	3360	534	85.4	75.2
199902022	FMR BEEBE RIVER MILL LAGOON	HAZWASTE	CAMPTON	ND	ND	ND	ND
200911039	101 MULBERRY STREET PROPERTY	HAZWASTE	CLAREMONT	7.46	9.38	4.56	2.83
198400091	BARNEY BASS COMPANY	HAZWASTE	CLAREMONT	1.4	1.3	ND	ND
199807063	FORMER POWERAY INFRARED CORP.	HAZWASTE	CLAREMONT	2.43	ND	ND	ND
199601023	FORMER SYNERGY GAS (ALLSTAR GAS)	HAZWASTE	CLAREMONT	19	62	ND	98
201805030	NORTH ST AND WASHINGTON ST AREA	SITEEVALHW	CLAREMONT	19	62	ND	98
199206033	OLD JOY MANUFACTURING FOUNDRY	SITEEVALHW	CLAREMONT	3.21	2.16	ND	ND
200308070	T BIRD MINI MART	HAZWASTE	CLAREMONT	6	4	1	0.9
198401012	BEEDE ELECTRICAL INSTRUMENTS	HAZWASTE	CONCORD	1.93	3.39	ND	ND
200011034	CONCORD CLEANERS	HAZWASTE	CONCORD	67.9	177	21.2	13.1



Table 3 - Hazardous Waste Remediation Sites
PFAS Water Quality Summary

NHDES Site #	Site Name	Project Type	Town	Max PFOA Detected (ng/L) AGQS = 12	Max PFOS Detected (ng/L) AGQS = 15	Max PFNA Detected (ng/L) AGQS = 11	Max PFHxS Detected (ng/L) AGQS = 18
198904063	CONCORD COAL GAS SITE	HAZWASTE	CONCORD	14.6	144	ND	5.92
199811043	DOT GULLY HILL STORAGE SHED	HAZWASTE	CONCORD	21	87.9	ND	92.5
198711003	ELECTROPAC WORLDWIDE (FMR VISHAY SPRAGUE)	HAZWASTE	CONCORD	12.8	158	ND	16.2
199212014	EXIT 13 COAL TAR POND	HAZWASTE	CONCORD	21.8	3.6	ND	2.88
198605043	FORMER ALLIED LEATHER TANNERY	HAZWASTE	CONCORD	18	57	0.9	8.9
201710012	RICHARD FLYNN FIRE ACADEMY	HAZWASTE	CONCORD	2200	35000	25000	5100
198708002	KEARSARGE METALLURGICAL CORP	CERCLA	CONWAY	25.3	4.37	3.72	2.9
199110087	WHITE MOUNTAIN LAUNDRY & DRY CLEANERS	HAZWASTE	CONWAY	6.11	ND	ND	ND
201802004	24 SCOBIE POND ROAD PROPERTY	SITEEVALHW	DERRY	59	24	2	38
201511011	FORMER NH MARBLE & FIBERGLASS	HAZWASTE	DERRY	111	776	5.86	56.9
198401037	HADCO PRINTED CIRCUIT	HAZWASTE	DERRY	170	850	7	150
202005042	ROYAL T CARWASH	HAZWASTE	DERRY	266	103	69	9.73
200410018	16 INDUSTRIAL PARK DRIVE LLC	HAZWASTE	DOVER	7.56	29.5	ND	ND
200701053	COCHECO PARK	HAZWASTE	DOVER	12.5	74.5	ND	ND
198401047	DOVER GAS WORKS	HAZWASTE	DOVER	100	22	35	10
198803019	DOVER LANDFILL SUPERFUND SITE	CERCLA	DOVER	1100	890	430	1500
199202044	DOVER PUBLIC WORKS GARAGE	HAZWASTE	DOVER	320	16	53	5
198705067	ELECTROCRAFT NEW HAMPSHIRE	HAZWASTE	DOVER	<2	<6	<2	<3
198401046	FMR ELLIOTT & WILLIAMS ROSES	HAZWASTE	DOVER	42.3	520	ND	10.5
198710022	FMR TEXTRON AUTOMOTIVE COMPANY PROPERTY	HAZWASTE	DOVER	13.5	5.76	ND	1.84
199011005	HEIDELBERG WEB SYSTEMS INC (FRMLY HARRIS	HAZWASTE	DOVER	9.7	5.9	2	3.1
199203042	MOORE BUSINESS EQUIPMENT (FORMER)	HAZWASTE	DOVER	8.3	6.77	ND	25.3
198907059	ONE WASHINGTON CENTER INC	HAZWASTE	DOVER	28.1	124	9.7	8.52
200707072	VARNEY'S CLEANERS	HAZWASTE	DOVER	9.33	17.9	ND	ND
199812012	BUXTON OIL CO INC	HAZWASTE	EPPING	12	28	0.51	2.1
198710024	KEEFE ENVIR.	CERCLA	EPPING	306	46	2.6	12.5
198908063	RESOURCES WASTE SERVICES LLC	HAZWASTE	EPPING	180	122	10.8	38
200502096	83-85 EPPING ROAD PROPERTY	HAZWASTE	EXETER	ND	ND	ND	ND
198605257	FMR. ALOSE SHOE CO., INC.	SITEEVALHW	EXETER	3.43	ND	ND	7.08
198705014	COLLINS & AIKMAN PLANT (FMR TEXTRON)	CERCLA	FARMINGTON	34.5	94	4.29	14.3
198401083	TEXTRON'S CARDINAL LANDFILL	HAZWASTE	FARMINGTON	6.42	5.44	ND	2.38



Table 3 - Hazardous Waste Remediation Sites
PFAS Water Quality Summary

NHDES Site #	Site Name	Project Type	Town	Max PFOA Detected (ng/L) AGQS = 12	Max PFOS Detected (ng/L) AGQS = 15	Max PFNA Detected (ng/L) AGQS = 11	Max PFHxS Detected (ng/L) AGQS = 18
198603048	UNION TELEPHONE COMPANY	HAZWASTE	FARMINGTON	5	11.6	ND	3
200009052	MEADOWOOD ASSEMBLY HALL	HAZWASTE	FITZWILLIAM	110	1600	59	370
198705001	ACME STAPLE COMPANY	HAZWASTE	FRANKLIN	ND	ND	ND	ND
201704004	FMR CIAO PASTA	SITEEVALHW	FRANKLIN	120	210	16	120
199306026	FRANKLIN FIRE STATION	HAZWASTE	FRANKLIN	890	10000	480	1500
198402001	GILFORD FIRE TRAINING SITE	HAZWASTE	GILFORD	6.01	85.1	ND	ND
201908051	GILFORD MUNICIPAL COMPLEX	SITEEVALHW	GILFORD	7	60	3	28
200411113	LOWER LIBERTY HILL ROAD SITE	HAZWASTE	GILFORD	ND	ND	ND	ND
198908003	NUTTER CONSTRUCTION	HAZWASTE	GILMANTON	4.51	ND	ND	ND
201705038	FLETCHER MOUNTAIN - 14 DEPOT ST	SITEEVALHW	GOFFSTOWN	130	680	15	160
200110023	FORMER GOFFSTOWN DPW GARAGE	HAZWASTE	GOFFSTOWN	8.6	2.5	1.8	1.5
200001038	JOHNSON AND JOHNSTON ASSOCIATES, INC.	HAZWASTE	HAMPSTEAD	11	45	ND	7
201811034	610 LAFAYETTE ROAD	HAZWASTE	HAMPTON	27	31	4.9	2.3
198804018	HAMPTON FOREIGN AUTO	HAZWASTE	HAMPTON	22	52	3	2.2
198904009	HAMPTON MAIN TOLL PLAZA	HAZWASTE	HAMPTON	12	2.64	0.8	1.4
198805025	HESS 29202-LUCIER HOLDINGS	HAZWASTE	HAMPTON	22.8	14.2	9.79	9.63
200007006	HANCOCK FORMER DUMP SITE	HAZWASTE	HANCOCK	5.07	140	39	25.7
199101025	COLD REGIONS RESEARCH & ENGINEERING LAB	HAZWASTE	HANOVER	8.2	5.9	1.8	10
198802009	HANOVER CONSUMERS COOP SOCIETY	HAZWASTE	HANOVER	127	49.1	60.7	10.3
199705006	HYPERTHERM INC	HAZWASTE	HANOVER	6	16	ND	ND
201111109	RENNIE FARM PROJECT	HAZWASTE	HANOVER	ND	ND	ND	ND
199104013	CONTINENTAL INDUSTRIES	HAZWASTE	HINSDALE	2.74	ND	ND	ND
199606069	MCGOLDRICK PAPER CO INC	SITEEVALHW	HINSDALE	23.6	280	13	1.54
199210027	AUTO WHOLESALE OF HOOKSETT/NAULT SUBARU	HAZWASTE	HOOKSETT	61.1	13.5	ND	8.3
198709008	GE AVIATION	HAZWASTE	HOOKSETT	11.3	8.88	ND	4.37
201801035	MARTIN'S FERRY	HAZWASTE	HOOKSETT	560	1	ND	81
198708005	MARKLIN CANDLE CO FMR AEROTRONIC FAC	HAZWASTE	HOPKINTON	221	1550	14.2	497
198402070	BURNS HILL RD SITE	HAZWASTE	HUDSON	ND	ND	ND	ND
198805019	COMPUTER OPTICS	HAZWASTE	HUDSON	41	54	ND	6
198806099	HUDSON LANDFILL (BURNS HILL RD)	HAZWASTE	HUDSON	63.7	28.5	0.665	4.16
199805041	MELBA BURTON PROPERTY	HAZWASTE	HUDSON	7.94	ND	ND	ND



Table 3 - Hazardous Waste Remediation Sites
PFAS Water Quality Summary

NHDES Site #	Site Name	Project Type	Town	Max PFOA Detected (ng/L) AGQS = 12	Max PFOS Detected (ng/L) AGQS = 15	Max PFNA Detected (ng/L) AGQS = 11	Max PFHxS Detected (ng/L) AGQS = 18
199908001	FMR BUSSIÈRE PROPERTY (ELITE LAUNDRY)	HAZWASTE	JAFFREY	16	110	1.6	13
199108021	HADLEY PROPERTIES	HAZWASTE	JAFFREY	ND	ND	ND	ND
200203055	JAFFREY WATER WORKS TURNPIKE RD. WELL	SITEEVALHW	JAFFREY	108	2060	6.76	386
198708007	WW CROSS TACK PILE	HAZWASTE	JAFFREY	9.4	21	ND	7.4
200609038	KEARSARGE REGIONAL MIDDLE SCHOOL	HAZWASTE	KEARSARGE	2390	13.9	88.5	3.19
201310007	32 WASHINGTON STREET SITE	HAZWASTE	KEENE	97.6	30.1	5.8	21.1
200108004	ACHILLE AGWAY	HAZWASTE	KEENE	8.5	2.6	1.1	2.6
200104006	AUBUCHON/MARTIAL ARTS CENTER	HAZWASTE	KEENE	27.5	13.6	ND	ND
198801029	CENTRAL SCREW/KEENE MILL	HAZWASTE	KEENE	ND	14.6	ND	18
200401019	COLONY MILL MARKETPLACE	HAZWASTE	KEENE	ND	ND	ND	ND
199411051	FAIRBANKS PLAZA	HAZWASTE	KEENE	21	36.8	ND	4.63
198402080	FINDINGS INC.	HAZWASTE	KEENE	7.75	3.03	ND	ND
198909019	FORMER ZINN'S BOWLING LANES	HAZWASTE	KEENE	7	ND	ND	6
199101014	MAIN STREET SUNOCO	HAZWASTE	KEENE	ND	ND	ND	0.37
199802052	PEOPLES LAUNDRY INC	HAZWASTE	KEENE	12	23	ND	4
199412009	PSNH 227 EMERALD ST	HAZWASTE	KEENE	10	5.9	0.91	2
199103010	RIVERSIDE PLAZA	HAZWASTE	KEENE	9.73	5.93	ND	3.47
198910006	TIMKEN SUPER PRECISION	HAZWASTE	KEENE	ND	6.13	ND	ND
199103103	KINGSTON FIRE DEPT	HAZWASTE	KINGSTON	400	326	130	41.6
199004006	OTTATI & GOSS/GREAT LAKES CONTAINER CORP	CERCLA	KINGSTON	3200	4750	28.8	65
199506014	BARON MACHINE COMPANY	HAZWASTE	LACONIA	2	ND	ND	ND
201207059	FMR ABC FABRICATORS, INC.	HAZWASTE	LACONIA	32.2	27.1	ND	ND
200404044	FORMER VERNITRON PROPERTY	HAZWASTE	LACONIA	5.86	7.6	ND	ND
198910016	FRED FULLER OIL CO INC (FMR ELECTRO-CIR)	HAZWASTE	LACONIA	150	180	2.2	470
199212023	LACONIA STATE SCHOOL	SITEEVALHW	LACONIA	3.5	2.5	ND	ND
199906039	LAKES REGION LINEN	HAZWASTE	LACONIA	37.6	160	5	5
199312038	MESSER STREET COAL TAR SITE	HAZWASTE	LACONIA	48	8.1	4300	4.4
199204007	BOND OPTICS	HAZWASTE	LEBANON	16.2	4.46	110	ND
201704036	KLEEN DRYCLEANERS RETAIL SITE	HAZWASTE	LEBANON	16.8	18.8	2.69	154
198801003	KLEEN LAUNDRY	HAZWASTE	LEBANON	16.8	18.8	2.69	154
198705054	TIMKEN AEROSPACE (FMR SPLIT BALLBEARING)	HAZWASTE	LEBANON	4.94	18.7	ND	ND



Table 3 - Hazardous Waste Remediation Sites
PFAS Water Quality Summary

NHDES Site #	Site Name	Project Type	Town	Max PFOA Detected (ng/L) AGQS = 12	Max PFOS Detected (ng/L) AGQS = 15	Max PFNA Detected (ng/L) AGQS = 11	Max PFHxS Detected (ng/L) AGQS = 18
199501031	BONNIE PLANTS (FOMERLY JOLLY FARMER)	SITEEVALHW	LEMPSTER	2.28	3.55	ND	ND
198902003	FMR FRAMATONE CONNECTORS USA(BURNDY LLC)	HAZWASTE	LINCOLN	196	296	49.6	37.8
201708017	APPLETREE MALL	HAZWASTE	LONDONDERRY	470	192	568	27
198803007	AUBURN ROAD LANDFILL	CERCLA	LONDONDERRY	201	38.9	6.16	14.4
200410259	COOKSON ELECTRONICS	HAZWASTE	LONDONDERRY	189	1310	14.9	1.26
198802020	FLIGHT ONE OWNERS ASSOC. SITE	HAZWASTE	LONDONDERRY	52.4	17.2	2.68	11.8
201501009	IMPACTED WATER SUPPLY WELLS	HAZWASTE	LONDONDERRY	29.9	44.2	2.94	3.02
200009020	MANCHESTER AIRPORT SOUTH REGIONAL	HAZWASTE	LONDONDERRY	290	100	36	280
198705068	PLAZA 28	HAZWASTE	LONDONDERRY	33	29.2	4.6	11.7
201803016	SANBORN ROAD AREA SITE	HAZWASTE	LONDONDERRY	117	377	ND	1540
199004008	TINKHAM'S GARAGE	CERCLA	LONDONDERRY	831	758	19	99.7
199104012	TOWN OF LONDONDERRY (FORMER LAMONT LABS)	HAZWASTE	LONDONDERRY	77.6	9.13	ND	6.13
198705022	NE METAL RECYCLING (FMR MADBURY METALS)	HAZWASTE	MADBURY	1700	1440	99.8	630
202103016	MADISON TOWN MUNICIPAL COMPLEX	SITEEVALHW	MADISON	26.3	2.49	429	14.2
199702009	122 MCGREGOR STREET	HAZWASTE	MANCHESTER	10.1	3.63	ND	8.34
198904041	ALLTEX UNIFORM RENTAL SERVICE INC	HAZWASTE	MANCHESTER	120	1800	29	98
200211048	CATHOLIC MEDICAL CENTER	HAZWASTE	MANCHESTER	117	9290	39	180
199111011	CMC HEALTH PAVILION	HAZWASTE	MANCHESTER	36.3	38.8	5.48	10.9
200305008	COMCAST OF NEW HAMPSHIRE	HAZWASTE	MANCHESTER	451	317	107	380
198612003	E & R LAUNDRY	HAZWASTE	MANCHESTER	110	100	18	24
199307019	JCM MANAGEMENT	HAZWASTE	MANCHESTER	500	674	15.9	89.9
199402007	MANCHESTER PLACE	HAZWASTE	MANCHESTER	34.4	25	8.09	8.16
199712026	MANCHESTER TRANSIT AUTHORITY	HAZWASTE	MANCHESTER	25.1	10.1	ND	8.1
198912008	MILL WEST FMR ELBES ASSOCIATES	HAZWASTE	MANCHESTER	15.2	39.3	ND	11.9
200205010	MORGAN SELF STORAGE SITE	HAZWASTE	MANCHESTER	44	31	2.9	14
199110029	PARK & ROYAL CLNRS (WEST SIDE SALVAGE)	HAZWASTE	MANCHESTER	15.8	82	3.31	2.26
199310024	RAY'S CHEVRON STATION	SITEEVALHW	MANCHESTER	28	10	ND	11
198403058	RR DONNELLEY CO FMRMOORE BUSINESS FORMS	HAZWASTE	MANCHESTER	129	35.1	7.07	11.8
200102004	SUNSHINE FABRICARE	HAZWASTE	MANCHESTER	33.5	ND	ND	6.95
198403040	UNIVERSITY CENTER AS (AMOSKEAG MACHINE)	HAZWASTE	MANCHESTER	27.4	18.9	ND	8.92
198605200	MEREDITH VILLAGE SAVINGS BANK FMR MOBIL	HAZWASTE	MEREDITH	3.43	NA	NA	7.08



Table 3 - Hazardous Waste Remediation Sites
PFAS Water Quality Summary

NHDES Site #	Site Name	Project Type	Town	Max PFOA Detected (ng/L) AGQS = 12	Max PFOS Detected (ng/L) AGQS = 15	Max PFNA Detected (ng/L) AGQS = 11	Max PFHxS Detected (ng/L) AGQS = 18
198901022	HARCROS CHEMICAL GROUP	HAZWASTE	MERRIMACK	120	12	2.1	4.4
198403080	LONGA DISPOSAL AREA	SITEEVALHW	MERRIMACK	130	8.7	0.8	7
199610014	MARJAN/CORBIN SITE	SITEEVALHW	MERRIMACK	61.5	18.5	ND	2.84
198611001	MERRIMACK WELL #6 & #7 VILLAGE H2O DIST	SITEEVALHW	MERRIMACK	99	85	ND	5.3
198406030	N.H. PLATING CO.	CERCLA	MERRIMACK	506	17	6.43	15
198711006	NASHUA CORP	HAZWASTE	MERRIMACK	120	2000	12	74
199712055	SAINT GOBAIN PERFORMANCE PLASTICS	HAZWASTE	MERRIMACK	69500	2560	2960	200
201610175	TROWBRIDGE DR AREA PFC DETECTS	SITEEVALHW	MERRIMACK	35	102	2.12	4
198506001	FLETCHERS PAINT/ELM STREET	CERCLA	MILFORD	7.27	14.7	ND	8.68
198506002	FLETCHERS PAINT/MILL STREET SITE	CERCLA	MILFORD	11	3.11	ND	1.15
198505002	OK TOOL CO (OU-1)	CERCLA	MILFORD	ND	ND	ND	ND
199109008	SPEAR NH (FORMERLY GAR-DOC)	HAZWASTE	MILFORD	18.2	60	2.23	NA
199202008	OLD MILTON DUMP	SITEEVALHW	MILTON	69.4	303	ND	17.3
199406081	25 PROGRESS AVE (FMR SPRAY TECH)	HAZWASTE	NASHUA	23.7	17.2	2.26	3.19
200807038	323 DANIEL WEBSTER HIGHWAY	HAZWASTE	NASHUA	242	405	18.5	68.6
198404001	ACT (FORMER SHELDAHL, FORMER IRI)	HAZWASTE	NASHUA	15	37	1.4	6.5
198603002	BRONZE CRAFT CORP	HAZWASTE	NASHUA	19	5	0.54	25
198605230	CLOCKTOWER PLACE	HAZWASTE	NASHUA	46	38	12	4
198910020	CLOCKTOWER PLACE/FMR SPRAGUE SITE	HAZWASTE	NASHUA	46	38	12	12
198708042	CORONIS CLEANERS INC	HAZWASTE	NASHUA	101	41	3	11
198106005	ELEXSYS INTERNATIONAL INC	HAZWASTE	NASHUA	46.4	60.7	13	4.43
199810022	ENERGY NORTH NATURAL GAS	HAZWASTE	NASHUA	15	9.5	0.56	5.3
198604324	FAB BRAZE CORP	HAZWASTE	NASHUA	39	5.33	ND	3.18
198404000	FIMBEL DOOR (GRANITE ST LEATHER)	SITEEVALHW	NASHUA	16.2	3.61	ND	ND
199612010	FORMER KOLLSMAN FACILITY	HAZWASTE	NASHUA	ND	ND	ND	ND
198406029	GILSON ROAD SITE	CERCLA	NASHUA	470	1190	11.1	7.43
198904062	GL & V PULP GROUP (FMR INGERSOLL-RAND)	HAZWASTE	NASHUA	20	59	0.68	4.3
198704027	HAMPSHIRE CHEMICAL CORP	HAZWASTE	NASHUA	28	26	NA	NA
199109039	NASHUA AIRPORT AUTHORITY	HAZWASTE	NASHUA	19	68	ND	54
199410039	NASHUA MOTOR EXPRESS INC	HAZWASTE	NASHUA	120	80	3.6	110
200409215	SCRAP METALS, INC.	HAZWASTE	NASHUA	370	560	77	66



Table 3 - Hazardous Waste Remediation Sites
PFAS Water Quality Summary

NHDES Site #	Site Name	Project Type	Town	Max PFOA Detected (ng/L) AGQS = 12	Max PFOS Detected (ng/L) AGQS = 15	Max PFNA Detected (ng/L) AGQS = 11	Max PFHxS Detected (ng/L) AGQS = 18
198710027	NEW BOSTON SPACE FORCE STATION	HAZWASTE	NEW BOSTON	150	520	17	110
199505034	NEWFIELDS LIGHT INDUSTRIAL PRK	HAZWASTE	NEWFIELDS	4.5	2.7	ND	ND
199001012	DEFENSE FUEL SUPPORT POINT	HAZWASTE	NEWINGTON	453	2380	133	313
198404025	FORMER PEASE AIR FORCE BASE	HAZWASTE	NEWINGTON	130000	490000	357	31000
198705051	SPRAGUE - RIVER ROAD TERMINAL	HAZWASTE	NEWINGTON	33	1.6	7.4	1.7
201708036	41 EXETER RD. SITE	HAZWASTE	NEWMARKET	82	55	2.3	330
198708011	FMR ESSEX MILLS	HAZWASTE	NEWMARKET	7.73	13.1	NA	NA
199805019	AMBARGIS PROPERTY	HAZWASTE	NEWPORT	2.36	2.92	ND	ND
200104007	STURM RUGER & CO INC (FMR DORR MILL)	HAZWASTE	NEWPORT	1960	16.5	553	2.44
201904026	227/227A ATLANTIC AVENUE AREA SITE	SITEEVALHW	NORTH HAMPTON	139	660	4.8	290
198712001	COAKLEY LANDFILL	CERCLA	NORTH HAMPTON	914	819	774	120
198906065	PROWASH CARWASH AND LUBE	HAZWASTE	NORTH HAMPTON	380	270	123	360
198607029	PS MARSTON ASSOC INC (ABENAQUI CARRIERS)	SITEEVALHW	NORTH HAMPTON	180	12	4.3	5
200006031	WYMAN-GORDON INV CASTINGS INC	HAZWASTE	NORTHFIELD	18.1	175	13.3	3.16
198404038	HARDING METALS	HAZWASTE	NORTHWOOD	334	1030	20.9	83.1
199309009	TOWN OF PEMBROKE WATER WORKS	SITEEVALHW	PEMBROKE	18.6	63.5	ND	12
198404058	BROWN'S SEPTAGE PITS	HAZWASTE	PETERBOROUGH	61	120	4.9	29
198404060	SOUTH MUNICIPAL WELL STUDY	CERCLA	PETERBOROUGH	4.29	8.33	NA	NA
201612039	FREESE PROPERTIES INC	SITEEVALHW	PITTSFIELD	24.6	5.22	ND	2.31
198404061	PITTSFIELD WEAVING (FRMLY CAMBION)	HAZWASTE	PITTSFIELD	16.2	202	ND	ND
199710020	PITTSFIELD PUBLIC WORKS DEPT	SITEEVALHW	PITTSFIELD	5.53	1.86	ND	0.7
198404068	BEEDE WASTE OIL CORP(AKA CASH OIL SALES)	CERCLA	PLAISTOW	410	1700	11	600
198404076	CHART INDUSTRIES	HAZWASTE	PLAISTOW	6.32	ND	ND	2.97
202004024	ELM/KINGSTON/HALE SPRING AREA SITE	SITEEVALHW	PLAISTOW	584	2450	2830	3230
198404067	STATE LINE PLAZA	HAZWASTE	PLAISTOW	61	35	12	6.3
201005026	150 MIRONA ROAD PROPERTY	SITEEVALHW	PORTSMOUTH	47.9	119	4.7	12.8
198404081	ALLTEX UNIFORM/COLONIAL SERVICES	HAZWASTE	PORTSMOUTH	260	1490	32.8	49.1
199801091	BENGAL CLEANERS FACILITY	HAZWASTE	PORTSMOUTH	7.9	2.59	10.2	3.91
201010003	FMR BOURNIVAL KIA SITE	HAZWASTE	PORTSMOUTH	17	25	3	4
199408047	FORMER COUNTRY MOTOR SALES	SITEEVALHW	PORTSMOUTH	20	280	4.4	140
201801004	HANSCOM'S TRUCK STOP, INC.	HAZWASTE	PORTSMOUTH	6	7.4	2	10



Table 3 - Hazardous Waste Remediation Sites
PFAS Water Quality Summary

NHDES Site #	Site Name	Project Type	Town	Max PFOA Detected (ng/L) AGQS = 12	Max PFOS Detected (ng/L) AGQS = 15	Max PFNA Detected (ng/L) AGQS = 11	Max PFHxS Detected (ng/L) AGQS = 18
198905023	PLAZA 800	HAZWASTE	PORTSMOUTH	100	340	13	6
199605033	PORTSMOUTH USED CAR CENTER	HAZWASTE	PORTSMOUTH	29.4	84	ND	10
200512019	WENTWORTH SCRAP METAL PROPERTY	HAZWASTE	PORTSMOUTH	34	81	3.9	23.1
201110061	FORMER REGIS TANNERY - LOT 120	HAZWASTE	RAYMOND	1230	2410	4.31	769
198705081	FORMER REGIS TANNERY (AKA REX LEATHER)	HAZWASTE	RAYMOND	1230	2410	5.5	769
198704094	MOTTOLO WASTE SITE	CERCLA	RAYMOND	484	187	12	118
199108024	DICK POULIN CHEVROLET OLDS	SITEEVALHW	ROCHESTER	131	671	11.5	20.6
200309133	FMR ADVANCED RECYCLING	HAZWASTE	ROCHESTER	63	22	2.3	21
198405009	LYDALL INC	HAZWASTE	ROCHESTER	21000	11000	770	2400
199705019	OFF PRICE OUTLET STORE	SITEEVALHW	ROCHESTER	131	662	11.5	20.6
199611022	PIERCE FORD	HAZWASTE	ROCHESTER	100	1100	2.9	67
202111021	ROCHESTER TOYOTA	SITEEVALHW	ROCHESTER	16	54	ND	2.1
199306038	SWD PROPERTY MANAGEMENT PARCEL	HAZWASTE	ROCHESTER	ND	ND	ND	ND
198909002	JANCO	HAZWASTE	ROLLINSFORD	30	32	1.8	1.2
200101009	FOYE'S CORNER MARKET & VACANT PARCEL	HAZWASTE	RYE	52.3	7.64	2.86	3.28
201812014	23 BUS ROAD SITE	HAZWASTE	SALEM	67.4	45	5.82	8.09
200108010	DAISY CLEANERS	HAZWASTE	SALEM	146	618	44.4	23.2
199704003	HONDA MOTORCAR	HAZWASTE	SALEM	21.8	28.7	1.4	4.8
198405027	KEEWAYDIN DRIVE	HAZWASTE	SALEM	62.6	13.2	3.06	13
199309056	KEY PACKAGING INDUSTRIES CORP	HAZWASTE	SALEM	50.3	18.6	10.4	9.46
198405033	OLD SALEM WASTEWATER FACILITY	HAZWASTE	SALEM	209	337	8.32	46.6
198405032	UNIVEX CORP.	HAZWASTE	SALEM	9.22	13.2	ND	2.59
199211045	139 FOLLY MILL RD	HAZWASTE	SEABROOK	3.22	3.11	ND	ND
198705069	DDR SEABROOK (FORMER VENTURE INDUSTRIES)	HAZWASTE	SEABROOK	4.6	2.3	1.1	ND
199202001	FOGG AUTO SALVAGE PROPERTY	HAZWASTE	SEABROOK	18.7	26	ND	ND
198405038	K J QUINN & CO INC	HAZWASTE	SEABROOK	19	10	ND	2.6
200411112	BRETON CLEANERS PROPERTY	HAZWASTE	SOMERSWORTH	52.9	17	8.26	13.7
199708013	GENERAL ELECTRIC	HAZWASTE	SOMERSWORTH	14	13	ND	3.9
198405055	SOMERSWORTH SANITARY LANDFILL	CERCLA	SOMERSWORTH	343	581	28.4	51
200210068	GH EVARTS & CO INC	HAZWASTE	SPRINGFIELD	1.2	5.9	ND	ND
198705075	ANTIQUÉ REPAIR COMPANY	HAZWASTE	STRATHAM	85	57	5.9	ND



Table 3 - Hazardous Waste Remediation Sites
PFAS Water Quality Summary

NHDES Site #	Site Name	Project Type	Town	Max PFOA Detected (ng/L) AGQS = 12	Max PFOS Detected (ng/L) AGQS = 15	Max PFNA Detected (ng/L) AGQS = 11	Max PFHxS Detected (ng/L) AGQS = 18
199707014	DEMOULAS / MARKET BASKET	SITEEVALHW	STRATHAM	340	590	76	6.4
199507007	STRATHAM FIRE DEPT	HAZWASTE	STRATHAM	320	3900	4.3	940
199106008	BIG APPLE CONVENIENCE STORE	HAZWASTE	TILTON	15	ND	ND	ND
198405082	TROY MILLS ROCKWOOD BROOK LANDFILL	CERCLA	TROY	2140	10.9	57.3	22.5
199607014	PAK 2000	HAZWASTE	TUFTONBORO	108	5540	54	1100
199806071	CENTRAL PLATING & CO.	HAZWASTE	WALPOLE	1070	7080	0.72	806
202107008	GRAND POWER SYSTEMS	HAZWASTE	WARNER	3.53	34.5	ND	ND
198704006	BROWN STREET FURNITURE	SITEEVALHW	WHITEFIELD	5.18	3.09	ND	ND
199103001	WS PACKAGING GROUP INC FMR LABEL ART	HAZWASTE	WILTON	2.7	2.4	ND	ND
198406006	A C LAWRENCE LEATHER	HAZWASTE	WINCHESTER	95.8	212	ND	17.6
201704035	CENTRAL METAL FINISHING	HAZWASTE	WINDHAM	89	730	16	8
200110005	WINDHAM MARINE SITE	HAZWASTE	WINDHAM	20.4	12.9	ND	5.89
201709003	WINDHAM SR. CENTER AREA	HAZWASTE	WINDHAM	120	2400	42	274
199704060	FORMER KIMBALLS LUMBER	HAZWASTE	WOLFEBORO	93	ND	4.2	ND
199408043	WOLFEBORO POWER EQUIPMENT INC.	SITEEVALHW	WOLFEBORO	6.56	20.6	ND	ND

NOTES:

1. Concentrations shown are in parts per trillion (ppt) or nanograms per liter (ng/L).
2. Cells that are shaded gray indicate an exceedance of the current Ambient Groundwater Quality Standards (AGQS) included in Env-Or 600 Contaminated Site Management.
3. NH's four regulated PFAS compounds include: perfluorooctanoic acid (PFOA), perfluorooctane sulfonic acid (PFOS), perfluorohexane sulfonic acid (PFHxS), and perfluorononanoic acid (PFNA).
4. 'ND' indicates the analyzed PFAS was not detected above the laboratory reporting limit.
5. 'NA' indicates that the specified PFAS was not analyzed at the site.
6. Data represents highest concentration detected at the Site.



Table 4 - Oil Remediation Sites
PFAS Water Quality Summary

NHDES Site #	Site Name	Project Type	Town	Max PFOA Detected (ng/L) AGQS = 12	Max PFOS Detected (ng/L) AGQS = 15	Max PFNA Detected (ng/L) AGQS = 11	Max PFHxS Detected (ng/L) AGQS = 18
199902045	PERFECT FIT INDUSTRIES FMRTTHOMAS HODGSON	OPUF	ALLENSTOWN	25	26	10	60
200009053	ESSLINGER OIL UNDERCOATING	MOST	ALSTEAD	ND	5.25	ND	ND
199409033	ALTON IRVING BULK TERMINAL	LAST	ALTON	31.5	240	5.51	129
199907011	IRVING OIL CORPORATION	SPILL/RLS	ALTON	953	92100	102	9070
201703001	JANVRIN PROPERTY	OPUF	BARTLETT	ND	ND	ND	ND
201507027	FARAN PROPERTY	OPUF	BRIDGEWATER	5.35	ND	ND	ND
199104009	FORMER JOHNSON & DIX BULK FUEL	LUST	CONCORD	41.9	12	ND	9.58
199004021	NH DOT HIGHWAY GARAGE 12	LUST	CONCORD	16.1	220	7.82	153
200109011	WEBER AUTO & TRUCK PARTS INC	LAST	DERRY	133	640	8	140
201701036	CULLEN RESIDENCE	OPUF	DOVER	39	16	3.7	6.2
200412055	TIM & JONIS TOWING/AUTO RECYCLING	ETHER	EPPING	8.2	3.1	ND	17
198605555	FMR. HUNT'S AUTO REPAIR	ETHER	FRANCONIA	136	741	27.1	121
201410048	SILVER RESIDENCE	OPUF	GILFORD	ND	ND	ND	ND
201507028	MARCIANO RESIDENCE	OPUF	HAMPSTEAD	6.03	ND	ND	2.04
200309090	KAPOTIS PROPERTY	LAST	HAVERHILL	ND	24	ND	ND
199209012	N HAVERHILL CONV INC FMR GARYS FUEL	MOST	HAVERHILL	376	ND	ND	745
198904023	EVERSOURCE ENERGY (FMR PSNH)	LUST	HILLSBOROUGH	434	235	161	7.88
199407009	FORMER AL LAMBERTS GARAGE	ETHER	HOOKSETT	213	3900	51.8	1100
199404022	UNITIL ENERGY SYSTEMS INC.	LUST	KENSINGTON	78.2	26.1	3.4	7.5
198402084	JOHNS TRUCK & AUTO	ETHER	KINGSTON	7.23	5.84	ND	3.98
199203034	MOBIL 13052	ETHER	LEE	28	38	ND	ND
200203024	TRI-STATE CAR CRUSHING (FRMR BROOKS PROP	ETHER	LEMPSTER	3	6	ND	ND
201612036	P & H TRANSPORTATION TANKER SPILL	SPILL/RLS	LONDONDERRY	278	22.6	15.9	21.3
200702049	MAJESTIC MOTORS	ETHER	MERRIMACK	650	34	10	42
198906013	HENRY HANGERS COMPANY	LUST	NASHUA	46	ND	ND	13
199502055	YEATON OIL CO INC	LAST	PLYMOUTH	0	0	0	0
199006049	FORMER PHILIP SINGER REVOCABLE TRUST	LUST	PORTSMOUTH	27	11	4.1	3.9
199607056	ROWELL AND WATSON CO INC	LAST	ROLLINSFORD	8.23	3.94	2.38	ND
199506011	FORMER MIDWAY EXCAVATORS INC	MOST	SOUTH HAMPTON	16	11.8	2.46	2.76



Table 4 - Oil Remediation Sites
PFAS Water Quality Summary

NHDES Site #	Site Name	Project Type	Town	Max PFOA Detected (ng/L) AGQS = 12	Max PFOS Detected (ng/L) AGQS = 15	Max PFNA Detected (ng/L) AGQS = 11	Max PFHxS Detected (ng/L) AGQS = 18
198903004	FORMER FLUFFYS CONVENIENCE STORE	LUST	TILTON	2.4	5.4	1.5	ND
199210004	WAKEFIELD GENERAL STORE INC	ETHER	WAKEFIELD	4.27	4.3	ND	ND
199312032	BROOKSIDE MINI MART	LUST	WILTON	7.36	13.2	ND	ND
200203023	BROOKS PROPERTY	ETHER	WINDSOR	9.2	36	1.5	20

NOTES:

1. Concentrations shown are in parts per trillion (ppt) or nanograms per liter (ng/L).
2. Cells that are shaded gray indicate an exceedance of the current Ambient Groundwater Quality Standards (AGQS) included in Env-Or 600 Contaminated Site Management.
3. NH's four regulated PFAS compounds include: perfluorooctanoic acid (PFOA), perfluorooctane sulfonic acid (PFOS), perfluorohexane sulfonic acid (PFHxS), and perfluorononanoic acid (PFNA).
4. 'ND' indicates the analyzed PFAS was not detected above the laboratory reporting limit.
5. 'NA' indicates that the specified PFAS was not analyzed at the site.
6. Data represents highest concentration detected at the Site.



Table 5 - Groundwater Discharge Permit Sites
PFAS Water Quality Summary

NHDES SITE #	SITE NAME	PROJECT TYPE	TOWN	Max PFOA Detected (ng/L) Std = 12	Max PFOS Detected (ng/L) Std = 15	Max PFNA Detected (ng/L) Std = 11	Max PFHxS Detected (ng/L) Std = 18
198400008	CEDAR COVE SEPTIC	SEPTIC	ALTON	55	ND	ND	ND
200506037	MEADOW BROOK CROSSING	SEPTIC	AMHERST	52	ND	ND	ND
199705002	ASHLAND WWTF UWW LAGOON	UWWLAG	ASHLAND	11	13.7	13.6	ND
200011029	ATKINSON COUNTRY CLUB	SPRAYIRR	ATKINSON	17.8	ND	ND	ND
200403086	BLUEBERRY STATION CAR WASH	SEPTIC	BARNSTEAD	5.13	9.82	ND	ND
199512013	GRAND SUMMIT AT ATTITASH	SEPTIC	BARTLETT	ND	5	ND	ND
198812003	STILLINGS GRANT	SEPTIC	BARTLETT	ND	ND	ND	ND
199009032	STORYLAND	SEPTIC	BARTLETT	5.48	3.71	ND	ND
199008008	WMNF HARTS LOCATION	RIB	BARTLETT	ND	ND	ND	ND
198400051	MONADNOCK PAPER MILL	UWW/LAG	BENNINGTON	8.7	6.7	ND	ND
19910510	GLENCLIFF HOME	SEPTIC	BENTON	5.24	36.8	4.49	ND
199105012	MERRIMACK COUNTY COMPLEX UWW LAGOON	UWW/LAG	BOSCAWEN	9.9	4.7	ND	ND
198906062	ROCKINGHAM COUNTY COMPLEX SPRAY IRRIG	SPRAYIRR	BRENTWOOD	11	ND	ND	ND
198711013	CANAAN WWTF	RIB	CANAAN	8.2	ND	ND	ND
198400085	BRETTON WOODS RIB	RIB	CARROL	16.9	12.2	ND	ND
198710018	MT WASHINGTON HOTEL RESORT	RIB	CARROL	9.14	4.6	ND	ND
199105007	CHARLESTOWN WWTF	UWW/LAG	CHARLESTOWN	22.7	93	14.4	ND
199105009	Colebrook WWTF	UWW/LAG	COLEBROOK	4.33	7.72	7	ND
198912004	CONWAY VILLAGE FIRE DISTRICT	UWW/LAG	CONWAY	16.2	10.9	5.1	ND
198907055	NORTH CONWAY RIB	RIB	CONWAY	27.4	292	6.71	178
198706001	DERRY UWW LAGOON	UWWLAG	DERRY	38.1	119	9.88	7.66
198401040	BALSAMS UWW LAGOON	UWW/LAG	DIXVILLE	8.76	ND	ND	ND
198401070	EPPING WWTF	UWW/LAG	EPPING	61.1	34.4	35.3	ND
198401079	EXETER WWTF UWW/LAG	UWWLAG	EXETER	75	54.4	8.1	18
200012033	FARMINGTON RIB SITE MW-14	RIB	FARMINGTON	19.9	5	ND	5.63
198803020	CROTCHED MOUNTAIN RESORT	SPRAYIRR	FRANCESTOWN	ND	ND	ND	ND
198908055	GORHAM PAPER MILL UWW LAGOONS	UWW/LAG	GORHAM	21.4	43	ND	5.13
198801026	EASTMAN	UWW/LAG	GRANTHAM	5	7	ND	ND
198708004	CROTCHED MTN REHAB - TRENCH SEPT PLUS DRIP	SEPTIC	GREENFIELD	3.38	ND	ND	ND
200403117	GROVETON WWTF	UWW/LAG	GROVETON	9.53	12	4.5	ND



Table 5 - Groundwater Discharge Permit Sites
PFAS Water Quality Summary

NHDES SITE #	SITE NAME	PROJECT TYPE	TOWN	Max PFOA Detected (ng/L) Std = 12	Max PFOS Detected (ng/L) Std = 15	Max PFNA Detected (ng/L) Std = 11	Max PFHxS Detected (ng/L) Std = 18
199807009	SARGENT CAMP NATURE CLASSROOM WW LAG	UWW/LAG	HANCOCK	9.38	6.4	6.14	ND
199008008	USDA-FS	SEPTAGE-LAG	HARTS LOCATION	ND	ND	ND	ND
198402027	BOUDREAU SEPTAGE LAGOON	SEPTAGE-LAG	HAVERHILL	98	14.7	7.9	14.9
199406035	BROX GRAVEL PIT	SPRAYIRR	HOOKSET	ND	ND	ND	ND
198705021	HOPKINTON/WEBSTER LANDFILL & LAGOONS	SEPTAGE-LAG	HOPKINTON	200	106	18.9	44
199505004	MCLANE NORTHEAST TRUCK WASH	SEPTIC	HOPKINTON	4	ND	ND	ND
198402073	TOWN OF JAFFREY UWW/LAG	UWW/LAG	JAFFREY	20.6	26.3	7.62	4.22
199103013	LANCASTER WWTF	UWW/LAG	LANCASTER	ND	ND	ND	ND
198705050	CARDIGAN MOUNTAIN	SEPTIC	LEBANON	9	ND	ND	13
198704055	LINCOLN WWTF UWW LAGOON	UWW/LAG	LINCOLN	8.2	29.3	ND	ND
199009018	SCHOFIELD SEPTAGE	SEPTAGE	LISBON	9.85	ND	ND	ND
198801025	LOUDON LANDFILL SEPTAGE LAGOON	SEPTAGE-LAG	LOUDON	282	46.3	8.39	25.5
198909017	NH MOTOR SPEEDWAY	SEPTIC	LOUDON	38.7	240	31.1	229
199403026	DARTMOUTH SKIWAY MW-1	UWWLAG	LYME	ND	ND	ND	ND
199907040	CAMP LAWRENCE	UWWLAG	MEREDITH	ND	ND	ND	ND
199907043	CAMP NOKOMIS	UWW/LAG	MEREDITH	ND	ND	ND	ND
199007020	BAY DISTRICT	UWW/LAG	MOULTONBOROUGH	5.21	ND	ND	ND
199810020	CAMP WINAUKEE	UWW/LAG	MOULTONBOROUGH	1.97	2.53	ND	ND
199103016	NEW HAMPTON WWTF MONITORING	UWWLAG	NEW HAMPTON	292	21.3	ND	14.7
199812019	WARWICK MILLS SEPTIC	SEPTIC	NEW IPSWICH	25	6	4	ND
198908064	BLODGETT LAING WWTF	RIB	NEWBURY	9.23	18.4	ND	ND
198704058	MT SUNNAPEE LAGOON PLUS SPRAY IRRIG	UWW/LAG-SPRAYIRR	NEWBURY	ND	ND	ND	ND
199806017	HIGHLANDS VIL DIST.	SEPTIC	NORTHFIELD	ND	ND	ND	ND
198909013	NORTHUMBERLA OVERLA FLOW	SEPTIC	NORTHUMBERLA	61.7	44.8	54.9	6.37
198404040	NORTHWOOD SEPTAGE FACILITY	SEPTAGE	NORTHWOOD	102	39.6	96.9	14.4
198404044	CARROL COUNTY COMPLEX OVERLA FLOW	SEPTIC	OSSIPEE	7.45	25.5	5.43	ND
198404046	OSSIPEE TOWN SEPTIC LEACHFIELDS	SEPTIC	OSSIPEE	14.3	ND	ND	4.58
199103017	PETERBOROUGH WWTF	UWW/LAG	PETERBOROUGH	ND	ND	ND	ND
198712011	PITTSBURG RIB SITE	RIB	PITTSBURG	49.5	ND	7.99	ND
198712010	PITTSBURG SEPTAGE LAGOON	SEPTAGE	PITTSBURG	51.1	10.9	ND	6.48



Table 5 - Groundwater Discharge Permit Sites
PFAS Water Quality Summary

NHDES SITE #	SITE NAME	PROJECT TYPE	TOWN	Max PFOA Detected (ng/L) Std = 12	Max PFOS Detected (ng/L) Std = 15	Max PFNA Detected (ng/L) Std = 11	Max PFHxS Detected (ng/L) Std = 18
198604204	PITTSBURG WWTF UWW LAGOON	UWW/LAG	PITTSBURG	59.2	ND	ND	4.77
199105022	MERIDAN WWTF RIB	RIB	PLAINFIELD	9.53	6.9	ND	ND
199606073	WALMART DISTRIB CENTER SEPTIC	SEPTIC	RAYMOND	4.72	5.7	ND	ND
199601006	CAMP TAKODAH YMCA	UWW/LAG	RICHMOND	29	23	ND	ND
199312051	FRANKLIN PIERCE	RIB	RINDGE	2.9	ND	ND	ND
198712014	JARVIS CUTTING TOOLS	SEPTIC	ROCHESTER	3.53	ND	ND	ND
198405011	ROCHESTER WWTF UWW LAGOON	UWW/LAG	ROCHESTER	197	23	18	11.3
201004021	EVOLVE HEALTH CARE	SEPTIC	RYE	ND	ND	ND	ND
199706032	97 SHOPPES - COMMERC SEPTIC SYSTEM	SEPTIC	SALEM	7.73	8.19	ND	ND
199007007	MT WASHINGTON OBSERVATORY	SEPTIC	SARGENTS PURCHASE	ND	ND	ND	ND
199907047	CAMP HALE UWW LAGOON	UWW/LAG	SAWICH	ND	8.13	ND	ND
199907046	MANCHESTER YMCA CAMP FOSS	UWW/LAG	STRAFFORD	5	ND	ND	ND
198910049	STRATFORD SEPTAGE FACILITY	SEPTAGE	STRATFORD	ND	ND	ND	ND
200304015	SEWALL FARM COO ASSSOC SEPTIC LEACHFIELD	SEPTIC	STRATHAM	ND	ND	ND	ND
200210028	TRICKET STRATHAM IRVING CAR WASH	SEPTIC	STRATHAM	6.6	3.93	ND	ND
198704011	SUTTON SEPTAGE FACILITY	SEPTAGE	SUTTON	445	94.1	21.1	62
199105014	TROY WASTEWATER TP	UWW/LAG	TROY	ND	ND	ND	ND
198907053	WAKEFIELD WWTF RIB PLUS SEPTIC	RIB - SEPTAGE	WAKEFIELD	7.31	ND	ND	ND
199009012	WATERVILLE VALLEY WWTF UWW LAGOON	UWW/LAG	WATERVILLE VALLEY	13	4	6	ND
199007031	WARDE HEALTH CTR SISTERS OF MERCY LEACHFIELD	SEPTIC	WINDHAM	15.5	11.3	ND	ND
200707014	WOLFEBORO RIB SITE	RIB	WOLFEBORO	6.19	8.37	4.49	9.49
198705015	WOLFEBORO SPRAY	SPRAYIRR	WOLFEBORO	7.23	11.8	ND	20.8

NOTES

1. Concentrations shown are in parts per trillion (ppt) or nanograms per liter (ng/L).
2. Cells that are shaded gray indicate an exceedance of the Ambient Groundwater Quality Standard (AGQS).
3. 'ND' indicates the analyzed PFAS was not detected above the laboratory reporting limit.
4. PFAS data represents highest concentration detected at the Site.
5. Last update : 05/03/2022